

Numbers may not add due to rounding.

Updated: 2008-03-14
 EB-2007-0905
 Exhibit E2
 Tab 1
 Schedule 1
 Table 1

Table 1
Production Forecast Trend - Nuclear (TWh)

Line No.	Prescribed Facility	2005 Actual	2006 Actual	2007 Actual	2008 Plan	2009 Plan
		(a)	(b)	(c)	(d)	(e)
1	Darlington NGS	27.6	27.0	27.2	28.6	26.6
2	Pickering A NGS	3.6	6.4	3.6	7.1	7.3
3	Pickering B NGS	13.9	13.5	13.4	15.7	16.0
4	Total	45.0	46.9	44.2	51.4	49.9
5	Unit Capacity Factor (%)	83.8	81.5	77.1	88.7	86.2
6	Planned Outage Days	345.8	323.5	331.2	254.1	343.4
7	FEPO Days	39.8	167.0	131.2	0.0	0.0
8	FLR (%)	5.4	6.4	11.7	5.1	4.2