Filed: 2008-06-20 EB-2007-0905 J6.1 Page 1 of 3

UNDERTAKING J6.1

<u>Undertaking</u>

5 To produce the business case summaries for the nuclear capital projects listed in Exhibit 6 D2, Tab 1, Schedule 2, Table 1, and the Nuclear OM&A Projects that have total costs 7 greater than \$10 M.

8 9

1

2 3

4

10 **Response**

11

Table 1 below provides a list of the nuclear capital projects greater than \$10M as listed
in Ex. D2-T1-S2, table 1, and the nuclear OM&A projects greater than \$10 M as listed at
Ex. F2-T3-S3 page 3. Approved business case summaries (BCSs) for the projects listed
in Table 1 are attached.

16

17 The projects in Table 1 are subdivided into four groups. Tab A lists the six large capital 18 projects that come into service during the test period for which Mr. Rupert requested additional information (Transcript Volume 6, June 2, 2008, page 93, lines 4-26). Tab B 19 20 lists the remainder of the capital projects greater than \$10M that come into service 21 during the test period. Tab C lists the capital projects greater than \$10M that are 22 expected to be in-service beyond the test period and therefore do not impact revenue 23 requirement. Tab D lists the OM&A projects that are over \$10M and that have 24 expenditures during the test period.

25

Please note the following exceptions and constraints with regard to the attached approved BCSs:

28 29

30

31

32 33

34

35

 To be consistent with the information provided in Undertaking J6.5, the list in Table 1 below includes a copy of the approved business case summary for Project 31718
 Darlington New Change Room Facility, which is now forecast to exceed \$10M.

- For Project 38296 Darlington Boiler Primary Side Cleaning, listed in Table 1 below, a BCS is not included. The planned test period expenditures for this OM&A project have not yet been released and a BCS for this work has yet to be completed.
- 36 37 38

39

40

41

42

43

44

 The attached BCSs contain redactions of commercially sensitive information. Specifically, project resource cost estimates (particularly costs for materials and external purchased contract services) and project contingencies are considered commercially sensitive. Their disclosure may unfavourably impact the vendor quotes OPG receives in the future. In addition, commercial information related to OPG non-energy customers and OPG margins on external business (e.g., Project 31555 – Darlington D2O Storage Facility) has also been selectively redacted due to its competitive commercial nature.

45 46

OPG is required to restrict access to certain nuclear facility information by
 Regulations under the Nuclear Safety Control Act. As a result of these

1	requirements, business case summaries for security projects are not attached.
2	The following information applies to approval of security projects:
3	
4	• For security-related and other regulatory projects, net present value or other
5	cost/benefit analyses are generally not performed in preparation of the
6	business case summary since the projects are required for continued station
7	operation. Instead, the objective is delivering the required regulatory results at
8	the lowest life cycle cost.
9	
10	 In order to ensure greatest value/lowest viable cost for security projects, OPG
11	therefore:
12	
13	works closely with CNSC staff (directly, or via participation in industry approximation) to all other integrations and the integration of approximation of a start
14 15	associations) to clearly understand the intent of specific regulations, and
15	constructively influence the resulting requirements to minimize cost of
16 17	implementation;
17	generates alternatives to meet the resulting regulatory requirements;
18	
20	seeks information as to how and at what cost other utilities have met these
20	requirements; and,
21	
23	competitively bids material and service contracts wherever possible.
23	
25	This approach was followed for the security projects listed in the attached Table
26	1.

Filed: 2008-06-20 EB-2007-0905 J6.1 Page 3 of 3

1

Table 1 – Projects > \$10 Million with Expenditures in the Test Period

2

ab A: Capit	al Projects Coming In-service Duri	ing the Test Period (Board Panel Identified Projects
25609 ¹	Nuclear Programs and Training	Security Fence Project
25905 ¹	Nuclear Programs and Training	Security Monitoring Room
28452	Darlington	Second Darlington Full Scope Simulator Project
33925 ²	Darlington	Used Fuel Dry Storage Facility Project
34000	Darlington	Auxiliary Heating System – Phase 1 & 2
46537	Pickering A	Calandria Vault Inspection
Tab B: Capit	al Projects Coming In-service Duri	ing the Test Period (Balance of Projects)
25901 ¹	Nuclear Programs and Training	Security Hardening Project
25902 ¹	Nuclear Programs and Training	Controlled Area Improvements
25908 ¹	Nuclear Programs and Training	Security Doors Upgrade
31718	Darlington	Construction Change Room
33293	Darlington	Main Control Room HVAC
33631	Darlington	Chiller Replacement to Reduce CFC Emissions
33815	Darlington	FH Computer Replacement
33977	Darlington	DCC Replacement
34008	Darlington	Feeder Replacement 'ALARA' Optimization
40543	Pickering B	CFC Chillers Replacement Project
49104	Pickering B	Auxiliary Power System for PB
49109	Pickering B	Standby Generator Governor Upgrades
62558 ¹	Nuclear Programs and Training	Security Optimization
62567	Engineering & Modifications	Additional Feeder Cut and Weld Tooling
79016	Darlington	Fire Protection Upgrade Program Phase 2
79147	Pickering B	Chemistry Standards (CH-002) at PB
79148	Darlington	Fire Protection Upgrade Program Phase 3
ab C: Capit	al Projects Coming In-service Bey	ond the Test Period
31555	Darlington	D20 Storage and Drum Handling Project
31717	Darlington	Maintenance Facility
33955	Darlington	SDS Aging Management
33973	Darlington	Standby Generator Controls Retrofit
49251	Pickering A	D ₂ 0 Storage and Drum Cleaning Facility
49266	Pickering A	Switchyard Relay Building Replacement
ab D: OM&	A Projects (Expenditures During T	est Period)
38296 ³	Darlington	Boiler Primary Side Cleaning
38457	Darlington	Environmentally Qualified Component Replacement
49201	Pickering A	Unit 4 Boiler Chemical Clean
49204	Pickering A	Unit 4 Boiler Flushing
49248	Pickering A	Units 1&4 -Replace Boiler Divider Plate Locking Tab
40641	Pickering B	P7 and P8 Tab and Divider Plate Repair
40645	Pickering B	Boiler Water Lancing
62553	Engineering & Modifications	Digital Control Computer Aging Management

Note 1: Business Case Summaries for Security projects have not been provided.

Note 2: Full Release BCS (December 2007) is provided – covering both capital expenditures, and those funded by ONFA funds. Partial Release BCS (July 06) is also included for additional background information.

Note 3: Test period work will be approved under a new project number. A BCS for the test period work is under development, but not yet completed.

BUSINESS CASE SUMMARY

Second Darlington Full Scope Simulator Project 16 - 28452 Capital 16 - 28453 Capital

Full Release Business Case Summary D-BCS-59000-10002-R000

Routing	Location	Action	Signature	Date
Alyssa Hall Assistant Technical Engineer/Officer 701-3561	P72-2	Prepare BCS	alysus Hall	13-Jul-20
Peter Moore Project Leader I 701-3567	P72-3	Review BCS	Pet Cin Care.	13.141.2007.
Tony Saliba Project Leader II 701-3047	P72-2	Review BCS	Those like	13 July 2007
Gary Kotwa Section Manager PMO 701-3755	P72-1	Review BCS	Chuy o hor	13 July 2007
Vince Tzambazis Project Manager - Design Projects 701-2520	P72-2	Review BCS	For	13 July 207
Dianne Gaine Manager - Design Projects 701-4181	P72-1	Review BCS	1. Jour	3 July 107
Sean Granville perations Manager, Darlington 3-7715	D01 - OSB2A	Review BCS	DSrl	2007/7/13
Greg Hall Manager, Simulators and CBT Technology 701-5811	P0603	Review BCS	gillant	16-Jul-07
Silviu Idita Manager, DNGS Authorization Training 701-3090	P06	Review BCS	SILVID A LOTTA Manager, Authorization Training	2007/07/12
Dwight Zerkee Manager, Nuclear Finance - Investment Management 702-5058	P8203	Review BCS		165007
Mark Arnone Director Projects and Modifications 701-6063	P72-1	Review BCS	Al-	16 July 2007
Ball Senior Financial Analyst 702-4084	P82-3B6	Return For Distribution		



BUSINESS CASE SUMMARY

Second Darlington Full Scope Simulator Project 16 - 28452 Capital 16 - 28453 Capital Full Release Business Case Summary D-BCS-59000-10002-R000

<u>Routing</u>	Location	Action	Signature	Date
Randy Leavitt Nuclear Finance 702-5085	P823	Review BCS	Flenint	July 17 2007
W. Robbins S.V. P. Darlington	D8-ES3	Submit BCS	#Aunoco-	JUly 18/07
J. Beech V.P. Nuclear Finance	H7-E19	Review BCS	12	July 18 2.2
T. Mitchell Chief Nuclear Officer	P82-6	Review BCS	Mutchen	
D. Power V.P. Corporate Investment Planning	H7-D06	Approve BCS	Deres .	20 July 2007 By 2007 Ory 22/0.
P. Charlebois EVP & Chief Operating Officer	H19-A21	Review BCS	5	Aug 22/07
J. Hankinson President & Chief Operating Officer	H19-A21	Approve BCS	Attan purson	Aug 23/0-7
		Choose One	t	
		Choose One		
		Choose One		
	₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩ ₩	Choose One		
		Choose One	• ····································	
		Choose One		
		Choose One	······································	
		Choose One		
R. Ball Senior Financial Analyst 702-4084	P82-3B6	Return For Distribution		,,

ONTA	RIO	PÛ	ER
			TION

Page: 3 of 29

BUSINESS CASE SUMMARY

Second Darlington Full Scope Simulator Project 16 - 28452 Capital 16 - 28453 Capital

Full Release Business Case Summary D-BCS-59000-10002-R000

1/ RECOMMENDATION:

We recommend approval of a Full Release of \$28.0 M Capital (including contingency) to complete the remaining phases of the Second Darlington Full Scope Simulator and the Darlington Learning Center Modifications Projects, with the objective of having a second full scope simulator available for training in Q3 2009. This includes U2 and U0 panels and the modification of the existing DLC to accommodate the simulator and supporting training facilities including upgrades/installation of HVAC, Fire Protection, electrical, LAN, telephone, PA, structural, training classrooms, conference/maintenance rooms, restroom facilities etc. The existing training simulator for Darlington Nuclear Generating Station cannot support Operations simulator needs. Simulator needs have increased beyond the hours available from a single simulator. There are 4 primary business objectives for this project:

- 1) The business objective is to address the high attrition rates for current DNGS certified staff. It is forecasted that 18 Authorized Nuclear Operators (ANOs) are eligible for retirement in the current business planning period and it is a requirement to assume 100% attrition as per the commitment to the CNSC (Attachment E: Correspondence from T. N. Mitchell, CNO, to G. R. Schwarz and T. E. Schaubel, CNSC. N-CORR-00531-03850.) Based on the staffing plans and current assumptions, without the second simulator, the sustainable ANO staffing levels of 56 required to run the business will not be accomplished within the current Business Planning Cycle.
- 2) The business objective is to support increased planned and minimum complements on each shift crew. DNGD has an more stringent licensing requirement to ensure only certified staff are on the MCR panel at all times, which means that the use of Supervised Control Panel Operators (uncertified staff) will no longer be allowed. Originally the license requirement was a minimum complement of 4 ANOs, and in 2005 the license minimum complement increased to 5 ANOs. By July 2009 the license minimum complement will increase to 6 ANOs. This factor will increase the demand on simulator hands-on hours. The REG-C N-CORR-00531-03217 compliance date is July 31, 2009. In order to ensure that there are 6 ANOs on duty at all times, 40 ANOs need to be assigned to the 5 operating crews and an additional 16 ANOs for other supporting roles is required to be self sustaining (See Attachment D).
- 3) The business objective is to ensure the safe and effective operation of the station to support not only the licensed positions on shift but also the supporting roles in areas of: outage planning, integrated planning, continuing and initial training, fix it now teams etc. To not staff and support these roles will result in a significant and adverse affect on the Stations Operating and Outage performance as well as challenge the safe operation of the station.
- 4) The business objective is to increase continuing training hands-on hours per year for certified staff to the recommended industry minimum standard and, thereby, meet CNSC expectations for authorized personnel training and eventually reach top industry standards. The CNSC references governing documents issued by INPO as their guideline to Improve performance at Canadian Nuclear Plants. The Academy Document produced by the National Academy for Nuclear Training (NANT) under the support of INPO, "Guidelines for Continuing Training and Recertification of Licensed Personnel, January 2007, ACAD 07-001", states that the <u>minimum</u> number of technical content contact hours per year is 160 (200 on average), which includes 60 hours of hands-on simulator training. OPG has committed to the CNSC to follow this requirement and meet 200 hours of simulator focused continuing training hours per year (Attachment F: Correspondence from G. Preston, Executive VP & CNO to G. Schwarz, Dr. Personal Qualification Assessment Division CNSC, N-CORR-00531-00948, Sept. 29, 2000). DNGS is currently at 200 hours for simulator focused continuing training per year for certified staff, with only 30-35 hours being simulator hands-on time. 60 hours of hands-on time is considered a minimum (ACAD Standard) and in fact the majority of other utilities are training on average approximately 95 hours per year (See graph C in the Background and Issues Section).

Training projections are outlined in a "Two Simulator Rationale" (Attachment G) document prepared by the Training Department that estimated Simulator loading based on approved 2005 - 2009 staffing plans and training program documentation as well as an estimated numbers of hours required to meet industry standards. The results were verified though an external third party review and the risks were assessed by performing a sensitivity analysis.



e objective will be achieved by the addition of a second full scope simulator and supporting facilities at the Darlington cearning Centre (DLC). Initial training programs will continue at the existing simulator located in the Pickering Learning Centre PLC) with all continuing/re-certification training performed at the DLC. This strategy will ensure that adequate time is available to handle the increased demands for training, delivery and testing.

Anticipated licensed staffing requirements to support the upcoming REG-C N-CORR-00531-03217 compliance date of July

OPG Confidential	Page:	4

Page: 4 of 29

BUSINESS CASE SUMMARY

009, has been considered and included in the Future Business Planning Cycle. Related OM&A costs to maintain the new mulator and DLC facilities are described in Appendix C under Financial Model Other Assumptions.

Currently Released	Capital	Davolonmontal	69	864	- 1		na sina una ana ana ana ana ana ana ana ana a		(* <u>(*)</u> <u>**</u> ********************************	933
Currently Released	OM&A	Developmental –	+		• - · - · .	•		•	····	
Requested Now	Capital		•	1.479	18.812	6.104	628			27,023
Requested Now	OM&A	Full	•	····				·		
Future Funding Reg'd	Capital	• 1								
Future Funding Req'd	OM&A	None -		······································			~~~~ ~	~~~		
Total Project Costs		······································	69	2,343	18.812	6.104	628			27.956
Other Costs		, 		· · · · · · · · · · · · · · · · · · ·			· ·····			£1,300
Ongoing Costs		· · · · · · · · · · · · · · · · · · ·					· · · · · · · · · · · · · · · · · · ·	+	·	
Grand Total			69	2.343	18.812	6.104	628	+		27,956

Submitted By:

(for)

mcc July 18/2007 Date: Wayne Robbins

Sr. Vice President Darlington Nuclear

Finance Approvat 2267 **BorrPower** Date: VP Corporate Investment Planning

Line Approval (Per OAR Element 1.1 Project in Budget):

M. Runded Jim Hankin CEO

Aug 23/07 Dates



BACKGROUND & ISSUES

The training of Authorized Staff including Shift Managers, Control Room Shift Supervisors and Unit Main Control Room Operators is a critical component of Plant Operations. The training and qualification of these staff is time and resource intensive. The standards and regulatory requirements surrounding this area are governed by the regulatory body governing the operation of the plant (CNSC) and best industry practices (INPO and WANO).

The training of the authorized staff can be broken down into three specific areas.

- Initial training (and testing) of personnel to be qualified for certified positions.
- Continuing training programs to maintain the skills and qualification to meet both DNGS and industry standards.
- Recertification testing of authorized staff. This facet of the program is to allow support continued licensing of the authorized individual by the CNSC.

In the late 1990s, an Integrated Improvement Plan (IIP) initiative was developed to consolidate and improve training at the site. Space for a future simulator was included in the construction of the DLC. A project that involved moving the existing Simulator from the PLC to the DLC was approved in 2003 and then subsequently cancelled in early 2004 by the Nuclear Executive Committee prior to the start of any field execution activities (ref. D-BCS-33813-10001). Although it had a number of benefits, this project did not address the cause of many of the training deficiencies – insufficient simulator time.

Later in 2004, a Darlington Authorization Training Focus Group was formed in response to a number of candidates withdrawing from the program (ref. SCR D-2004-05573). The purpose of the group was to evaluate training methods and to explore alternative strategies to achieve the Darlington staffing plan for Authorized Nuclear Operators (ANOs). A number of solutions were put forward (See A/R# 28055593) and have since been implemented to improve the program and increase the uccess of candidates. These included:

- improving the selection and preparation process for candidates Complete
- increasing the number of Authorized Training Supervisors (ATSs) Complete with rotations from the plant
- improving documentation Continuing requirement
- provision of desktop simulators for use by ATSs to reduce loading on the full scope simulator Complete
- split mode operation of the simulator to allow concurrent U0 and reactor unit training Complete
- development of schedules to allow simulator use from 6:00 a.m. to 12:00 a.m., 7 days a week Complete. In addition interim training classes are scheduled until 04:00, but are not expected to continue due to Society and PWU agreements.
- increasing class sizes to makeup for loss of candidates Complete

These initiatives, although expected to improve the short term success of training, have not been sufficient to maintain adequate staffing levels.

Since these initiatives have been implemented several issues have developed that are driving the amount of simulator handson time required to meet mandatory training and testing programs above the time available on the current Simulator located at the PLC. High attrition rates, and increases in shift minimum complement both contribute to the increase in simulator handson time.


The following charts model the projected staffing scenarios based on both 1 and 2 simulators. Based on the staffing plans and current assumptions, without the second simulator, the sustainable ANO staffing levels of 56 required to run the business will not be accomplished within the current Business Planning Cycle. With this, comes a significant risk for the next 7 to 8 years, as the staffing levels are extremely low. Note, staffing plans since 2005 are based on a 2rd simulator being in full operation by Q1 2009 based on approvals obtained from the NEC.



Page: 6 of 29

BUSINESS CASE SUMMARY

Graph A: One Simulator Only






Page: 7 of 29

BUSINESS CASE SUMMARY

Graph B: Darlington Second Simulator



Note: Both Graphs A and B above assume that all licensed staff will become recertified each year. Currently each certified ANO receives only 30-35 hours of hands-on time and OPG has committed to the CNSC to follow the requirement of the ACAD 07-001 document as per correspondence from G. Preston, Executive VP & CNO to G. Schwarz, Dr. Personal Qualification Assessment Division CNSC, N-CORR-00531-00948, Sept. 29, 2000 (Attachment F).

The chart in Attachment D (ANO Deployment based on Certified Staff Numbers) describes the risks due to attrition for licensed ANOs.

As stated, once the number of 44 certified ANOs is reached the business will not be able to recover from this without significant impacts to running the units. Prior to this point however, risks to the safe and effective operation of the station are also present as we deviate from the business plan number of 56 ANOs.

The delta between the projected CNSC commitment of ANO's on shift and the target number of ANO's defines the number of ANO positions in the Darlington organization to support the safe operation of the station and the continuation of the initial and continuing training programs. The roles of these positions are defined in the various governances related to Outage Planning and assessing. Integrated planning processes, Fix it now (FIN) team composition and Training programs development and execution. Significant adverse affects on station performance will result should these roles be omitted and the accountabilities not be carried out. The nature of the programs is such that an individual with the training knowledge and skills of an authorized version are required to make these processes effective.

- erson are required to make these processes effective. The accountabilities range between functional group but include:
 - Operations and License review and approval of scheduled and planned maintenance work programs, procedures, and work plans on Nuclear Units in accordance with department governance and procedures.
 - Operations and License review of the schedules coordinating work and outage activities.
 - Outage Management oversight.
 - License review of Reactor Alignment changes during outage and routine planned maintenance activities.



Page: 8 of 29

BUSINESS CASE SUMMARY


• CNSC mandated continuing training program execution. Development and delivery of training in both initial and continuing training programs.

Another issue contributing to the demand for a second simulator is that DNGS is currently only at 30-35 hours of continuing training simulator hands-on hours. OPG has committed to the CNSC to follow the requirement of the ACAD 07-001 document issued by INPO and deliver 200 hours of simulator focused continuing training, of which 60 hours is simulator hands-on hours.

As the experienced operators retire and are replaced by new less experienced license holders, simulator training will be a critical factor in preparing operators to effectively respond to unit transients and prevent them from escalating to more severe events. As operating experience decreases there is a risk of more events occurring due to operator errors. The average experience of Darlington's certified staff is expected to drop over the next couple years. Details can be seen in the chart below:

Table 1: Average Licensed Operator Experience							
2005	2006	2007	2010	2012			
7	7.7	6.3	6	5			

Industry experience has shown that qualified but inexperienced certified staff needs 80 hours of contact time to ensure they maintain the skills and knowledge to respond to transients and events and in fact the majority of other utilities are training on average approximately 95 hours per year.



Graph C: Simulator Hands-on Hours per Year per Operator


Currently, DNGS licensed staff are receiving 30-35 hours of simulator hands on hours. This does not meet our regulatory commitment, and there is an inherent risk to the safe operation of the plant.

A simulator hands-on demand analysis was performed to determine the total amount of hands-on hours required to maintain the certified staffing plan shown in Graph B above for safe operation.



Page: 9 of 29

BUSINESS CASE SUMMARY



Assumptions:

ONTARIOPOTER

GENERATION

- Available Simulator training / testing usage between 08:00 to 24:00 for 5 days a week without weekends and holidays
 results ~ 4,000 hours of simulator time a year.
 - o 365 days -104 days [weekends] 8 days [holidays] = 253 days -2% breakdown = 3967 hours @ 16 hrs/day.
 - This does not include the 30 days for annual maintenance outage, where 320 hours are lost from training and testing or the regular day to day maintenance where an additional 384 hours are lost over the year.
- For continuing training of currently certified ANOs, to calculate the amount of hands-on time, the number of projected ANOs is divided into groups of 3 and then multiplied by 60 hrs (as only 3 can be credited with actual "hands-on" time per training event).
 1/3 of the number of delivery hours is added due to efficiency of simulator usage (set-up time, turnaround, etc.). This has been scaled up/down as applicable in the table for years where the number on ANOs is greater or less than 60.
- All types of training (<u>initial and continuing</u>), all types of testing (<u>initial and recertification</u>) for all types of certified staff (<u>ANOs. U0CROs, CRSSs and SMs</u>) require a large amount of simulator time for both development and delivery (and a smaller component of simulator time for remedials).

As highlighted in the graph, only approximately 4000 simulator hours are available per year for training, testing, maintenance and miscellaneous activities and DNGS needs already far exceed this. Because of CNSC commitments for 2009, the amount of hours required to meet the current Business Planning Cycle for certified staff is more than double.

ctions have been taken to mitigate the hands-on time delta between supply vs. demand. For example, DNGS Operations ave tried to retain the current certified staff beyond early eligible retirement date, but this does not eliminate the long term attrition and in the future this option will not be viable due to reluctance from a bargaining position. As well, to accommodate for these extra hours currently in 2007, training is scheduled on midnight shifts and weekends. However, this poses a risk to the safe operation of the nuclear reactors in the future if OPG decides to continue with this option and not proceed with the second simulator. Based on the collective agreement, Letter Of Understanding (Attachment H: LOU - 119) for CRSS CRSOS,



Page: 10 of 29

BUSINESS CASE SUMMARY

ATS, UOTS and SSIT, if overtime cannot be filled on a voluntary basis, forced overtime will be limited to 3 non-consecutive weeks per employee (and is even more restrictive for ANOs, CROs, ANOITs and CROITs in the PWU).

PNGS B is currently not in the same position as DNGD and has not requested the need for a second simulator in the current Business Plan. The current CNO accepted business assumption is that there will not be a refurbishment at PNGS B. In addition, PNGS B currently has a younger demographic and do not require unit zero certifications.

OPEX and planning for a second simulator at Bruce B was investigated. Response to date with regards to Bruce B has been limited due to the sensitivity of information and they have not stated whether they are including the requirement for a second simulator in their current business plan. It was released however, that if the decision to refurbish Bruce B is made, a Full scope second simulator will be included in that Business Case.

Currently Bruce A, and two US three-unit stations, Palo Verde and Browns Ferry, have a second simulator. Oconnee's is pursuing a second simulator (approval pending).

Developmental Release of \$933k was obtained in September 2006. The project has completed Preliminary Design for DLC Modifications in May 2007. Completed Technical specification, Request for Proposal, Bid evaluation to Engineer, Procure and Construct a second full scope simulator, and awarded contract in June 2007 to complete Preliminary Engineering for Main Simulator by Oct 2007.





Page: 11 of 29

BUSINESS CASE SUMMARY

3/ ALTERNATIVES AND ECONOMIC ANALYSIS

5001s	No Project	Alt 1 (Red	commended)	All 2	All 3	Alt 4	Alt 5
		Full Cost	Incremental Cost	Detay 1 Year			PLC Option
Revenue	(360,337)	Ø	0	(11,858)	0	0	4,772
OM8A	(94,054)	(109,514)	(109,514)	(107,547)	0	0	(110,342)
Capital	0	(27,963)	(27,030)	(28,358)	0	0	(32,030)
Present Value (PV)	(91,027)	(45,078)	(45,300)	(48,529)	0	0	(46,655)
Net Present Value (NPV)	WA	44,949	45,727	42,498	0	0	44,372
IRR%	NA	16.0%	16.4%	17.5%	N/A	N/A	15.7%
Discounted Payback (Yrs)	NA	10.15	9394	10,85	NA	NA	10.32

Status Quo - Not Recommended

This is not an acceptable option and there are many unfavorable impacts. Operator simulator continuing training contact hours for simulator "hands-on" will drop further away from the ACAD minimum industry standard of 60 hours per year per operator. The industry median is estimated to be approximately 95 hours. DNGS is currently at 30-35 hours which is half of the minimum. The lack of an additional simulator will result in less than 30 hours and make this situation worse.

There is a risk to continued full operation of the plant if the required number of authorized staff is not maintained. A cascading negative affect on plant operation will occur when the training program no longer has authorized staff to support training and valuation of currently certified staff and new initial trainees. Once this level is reached, the business will not be able to recover without significant business impacts. (See Attachment D).

There is a risk of Outage delays because there will not be enough certified staff to be assigned to the outage program, a possibility of an increase in preventive and corrective maintenance backlogs due to the inability of Operations to staff the work control area, staffing to support IPG and FIN will not be maintained, the procedural backlog will increase and the quality will decrease, and the issuance will have to be by duty ANO's. More importantly, there is a potential impact to the safe operation of DNGS nuclear reactor due to reduction of experienced operators.

The Regulatory body may order DNGD to comply to what was committed, should training and operational programs be found less than acceptable when evaluated against industry standards. There is a potential failure to meet OPG production targets, and to meet OPG business objectives to advance DNGS Operations and training programs to top industry standards.

With not building the second simulator at DNGS, continued travel costs of \$125k/year and overtime costs of \$1.1M/year (For 1 extra ANO coverage: \$125k/h x 24 h/d x 365 d/year) would be incurred to increase shift complement which is currently only at 30 ANOs, to 45 ANO's (40 minimum complement and 5 ATS) starting in 2009 (See Graph A). This cost does not include ANOs in support of work control, outage, FIN etc.

Considering all the risks to OPG stated above, status quo option is not recommended.

Alternative 1 - Second Darlington Full Scope Simulator - Recommended

Provision of a Second Full Scope Simulator at the DLC will meet the four key business objectives for this project. It will address the staffing plan targets and ensure that sufficient certified staff are available (and maintained) to safely operate all Darlington units, meet OPG production targets, as well as provide necessary certified staff in support of other operational programs (e.g., training, outages, integrated operational planning, work control area, fix-it-now (FIN) teams, ...etc). It will also provide the means to develop and deliver "hands-on" training to meet industry standards and thus further OPG's objective to be a leader in the industry. The DLC structure currently has space provisions to house the new Simulator. Internal capital modifications will be required to create the new simulator training facility. This includes upgrades/installation of HVAC, Fire "rotection, electrical, LAN, telephone, PA, structural, training classrooms, conference/maintenance rooms, etc."

Alternative 2 - Delay Project - Not Recommended

The decision to install a second simulator could be delayed until early 2009 when a final decision will be made whether to support station refurbishment to extent DNGD's service life beyond the current assumed date of 2018.

ONTARIOPO" ER	OPG Confidential	Page: 12 of 29
GENERATION	BUSINESS CASE SUMM	ARY


The advantage of delaying the project will be that the capital costs could be rolled into the cost of station refurbishment. However it should be noted that the costs of a second simulator will still need to be paid and the future costs may well be higher due to inflation. In addition the risk of delaying the decision for a second simulator will push back the time period for building the simulator. As time advances the obsolescence of hardware to support construction of the simulator will become more of an issue.

In short, delaying the decision to build a second simulator will result in the same adverse and unacceptable consequences as acceptance of the status quo. The delay of the decision will also further delay the eventual in service date for training purposes until Q1 2011 at the earliest. The primary drivers for an additional simulator are of concern today and will continue to drive the need for a second simulator into the foreseeable future. In addition there is a potential increased risk to procurement of the correct materials and components to construct the simulator due to aging and obsolescence.

Alternative 3 - Second Darlington Simulator - Unit 0 only - Not Recommended

The alternative of constructing the Unit 0 Simulator for Darlington was assessed as a reduced scope option. This may partially offset new U0 certification requirements, however the U0 simulator cannot be split in whole from the Unit training as the team has to practice and be tested together, similar to the station MCR environment. This option will also not address the larger area of need; reactor unit staff planning and training preparation/delivery issues. Improvements in the area of staffing rotational positions, increasing training development time and "hands-on" training time cannot occur with one simulator plus a new U0 simulator only.

Graph E below shows the remaining simulator usage hours still required for ANOs, CRSSs and SMs; where U0 CRO initial and continuing training has been extracted due to building a U0-ONLY simulator. While total overall usage did decline for the ANO/CRSS/SM when compared to Graph D, this new graph shows that the remaining simulator hours are equal to 2 simulators @ 16 hours/day for 5 days a week. To achieve this alternative a Full Scope U0-ONLY simulator (hardware and oftware) would still have to be built and commissioned. Even then, U0 would not be getting any overall control room practice in initial training and as discussed, the ANO/CRSS/SM needs would not be met.





Page: 13 of 29

BUSINESS CASE SUMMARY

Again, this option would not allow us to even start to address increasing regulatory and industry standards, expectations and requirements, or the requirement to increase "hands-on" time and other activities necessary to reach top industry standards. In fact, compensatory actions such as the recall of certified staff from current support programs would significantly and adversely impact areas essential to plant operation and is neither sufficient nor sustainable. On these bases, this alternative is not recommended.

Alternative 4 – Increase training hour to 24/7 - Not Recommended

By increasing training to 24/7, it slightly improves the simulator demand situation; however this option would require negotiation with both labour unions. A one time agreement with Society was already exhausted and would be very difficult to obtain again. Based on LOU – 119 for CRSS CRSOS, ATS, UOTS and SSIT, forced overtime is limited to 3 non-consecutive weeks per employee if voluntary overtime is not an option. Training during these off hours has also already been identified as a contributing factor to current failures as it leads to a lack in management oversight during training and leads to insufficient use of ATS resources.

Even if an agreement with labour unions is obtained, this option is insufficient to makeup for the shortfall in simulator hours (See Graph D, starting in 2008). Training 24 hours 7 days a week, and taking into consideration a 2% breakdown rate, a total of 8585 simulator hands-on hours are available. Again, this option would not allow us to even start to address increasing regulatory and industry standards, expectations and requirements, or the requirement to increase "hands-on" time and other activities necessary to reach top industry standards.

On these bases, this alternative is not recommended, however, may be required in the interim until such time as an additional Full scope simulator becomes available.

Alternative 5 – Second Darlington Full Scope Simulator at PLC - Not Recommended

The alternative of constructing the second full scope simulator at the PLC was assessed; however it is not considered a viable option. It may create continuity from a maintainability perspective and will eliminate the need for additional maintenance staff. However, placing the second simulator at the PLC would require an extension to the PLC. This requirement will cause the in service date of the second simulator to be delayed by 1 year due to design/permit/build durations. Modifying the DLC to accommodate the simulator allows a capital savings and an in service date which is acceptable to the stakeholders.

There would also continue to be a burden of \$125k/year in travel costs for trainees to travel to Pickering for training. Constructing the simulator at the DLC reduces this cost, eliminates possible driving safety issues, and allows more effective training due to proximity to the station. This alternative is therefore not recommended.

ONTARIO	POWER
	GENERATION

BUSINESS CASE SUMMARY

/ THE PROPOSAL

Engineering, Procurement, Installation, and Commissioning of a second simulator in the existing footprint of the DLC facility. The DLC structure currently has space provisions to house the new Simulator. Internal capital modifications will be required to create the new simulator training facility. This includes upgrades/installation of HVAC, Fire Protection, electrical, LAN, telephone, PA, structural, training classrooms, conference/maintenance rooms, etc.

A fixed price bid has been agreed to for the purchase of the new simulator and the preliminary engineering portion of the contract is in progress under the current release. Once additional funding is approved via this release, the remainder of the PO will be enacted to ensure delivery in Q2 2009.

Preliminary Engineering has been completed for the DLC modification portion of the project.

This full release will fund the following key deliverables:

- Full Scope Simulator Project # 16-28452
 - Conforming fixed priced contract with Engineer, Procure, Construct (EPC) vendor
 - Work plans, and project schedule
 - Quality and control manuals, quality, safety, and environmental plan
 - Design plan, and engineering documentation
 - Inspection and testing plan, Factory Acceptance Testing, Site Acceptance Testing, and documentation
 - Training plan
 - Delivery of main simulator components and spare parts
 - Commissioning, turnover including AFS
 - Simulator fidelity assurance enhancements post AFS including technical support, material, and minor refinements. The accountability of the Fidelity assurance work will be transferred from P&M to Simulator and e-learning Technology Department upon completion of AFS in July 2009. P&M will update Project Closeout and Lessons Learned reports if required upon completion of fidelity assurance work.
- DLC Modifications Project # 16-28543
 - Contract for detailed engineering
 - Contract for construction of modifications
 - Work plans, assessments, and project schedule
 - Design Plan and NEF ECC documentation including new drawings
 - · Quality and control manuals, quality, safety, and environmental plan
 - Design plan, and engineering documentation
 - Inspection and Testing Plan
 - Detailed commissioning specification
 - Commissioning report and plan
- AFS and lessons learned for both Projects # 16-28452/28453
- Project close out and PIR for both Projects # 16-28452/28453







1	OPG Confidential	Page:	15 o ₹ 29	
1			a de la constante de la consta	-

BUSINESS CASE SUMMARY

5/ QUALITATIVE FACTORS

ONTARIOPOW

Constructing the Second Full Scope Simulator for Darlington has additional benefits that will specifically have an impact on:

Training Quality

Having a second full scope simulator provides greater flexibility for training and testing schedules including remedial training and testing for failed test results (that will not have to take away from other mandated training and testing programs, as currently occurs). It provides opportunity for greater Line Management involvement and ownership of training as the new facility will be located on site, and provides on-site opportunities for support of Provincial Emergency Exercises. In the future, when the initial training requirements will slightly decrease, it provides opportunity for training programs that are currently not running, to be incorporated to increase our chances in reaching top industry standards.

Employee Engagement

Having the opportunity to train additional licensed staff allows for employee movement throughout the organization and provides different career paths for employees. As well, it benefits the organization as it distributes operational and focused knowledge which supports other job positions at OPG. In addition, it will help with the quality of life for the instructors and trainees by reducing the weekend and early morning (12:00 to 4:00 am) training time and reduces the amount of traveling time during work hours.



Safety Events

Having the opportunity to increase the amount of hands-on time above the minimum will give the licensed staff confidence while working at the panel and this in turn will reduce the risk of operator error.

Driving from site to site contributes to an increased risk to personnel. By having a second simulator at Darlington, this risk will be eliminated and will reduce the exposure to OPG.



OPG Conf	na
ONTANOP GUNER	GENERATION



16 of 29

۲

<u>6/ RISKS</u>

Description of Risk	Description of Consequence	Risk Before Mitigation	Mitigaating Activity	Riak After Mitigation
Exceeding release limit	Cost overrun	Medium	A fixed price bid has been received for the purchase of the new simulator. Preliminary Engineering is complete for the DLC Mods and an estimate of remaining engineering costs has been obtained from the Design Agent. A third party estimate has been obtained for the DLC capital modifications. This estimate was based on the previous simulator move project and the known differences have been accounted for in the BCS estimate. A specific contingency of the project (16-28453) for execution coordination between several contractors to ensure compliance to schedule and ensure compliance to schedule and the release limit.	٢٥
Architectural/engineering agency utilized for the detailed design of the DLC for the move project unavailable to perform the work for this project.	This release assumes that much of the previous design, still owned by the AE firm can be re-used for this project. If not, both cost and schedule will increase.	Medium	Existing documentation is available and will be utilized to the greatest extent possible to reduce design costs. Schedule float associated with the DLC modification portion of the project will be used to accommodate their resourcing if required.	Fow

IOPOWER Generation	
ON MAL	

OPG Confidential	

17 of 29

Page:

BUSINESS CASE SUMMARY

Scope for the DLC Mods may be increased by the Design Agency	Schedule and cost overrun	Wedium	Design information developed during the Simulator Move Project will be utilized to ensure the scope is well defined taking into consideration identified preliminary design changes	Low
Schedule for completing the milestones may be delayed due to long lead material delivery	ŕ	Medium	Long lead materials have been identified in fixed price EPC for the Main Simulator. The schedule will be frozen upon award of contract	Low
Schedule may be delayed due to coordination among several contractors.	Cost overruns due to stand down time or delays. Delays to schedule.	Medium	Implement a phased execution for DLC Mods to lineup with the installation and commissioning of the simulator with OPG oversight and contract management	Low
Resources				
Lack of experienced Design support for this phase of the	Delay in completion of this phase	Medium	The design work will be completed by Design Agencies. Regular interface	Low

IN TAY IOPOW	FION OPG Confidential BUSINESS	S CASE SUMMARY	Page: 18 of 29 ARY
project Lack of experienced Project Engineering/Management support	Delay in completion of this phase	Medium	meetings will be held with the Design Agencies to ensure threats to schedule are mitigated and design requirements for both projects are met. Project Leader II has been hired and group is staffing MP2/3/4 positions. Expected to be complete by end of June 2007.
Technical Based on Previous simulator Based on Previous simulator acquisition projects, the Second DNGS Simulator will have fidelity challenges which will impair its functions. 1. Station Changes made during the simulator project phases will be missing. 2. Fidelity of some Instruments will be inconsistent with the station.	 Simulator training and Testing of Operations Staff at the DLC will not be possible on station changes because of the project design data freeze date (i.e controller replacements, device replacements, and Station Computer changes). Differences in fidelity of some instruments between the simulator and the reference unit at the station may result in Auditor findings (i.e WANO AFIs). Experience from the Second Bruce A Simulator project was that some panel instrumentation as finally installed differed from the station equivalent which impaired panel fidelity. 	Wedium	 Lessons Learned from experience on past simulator acquisition projects will be incorporated into the Second DNGS Simulator project's plan as follows. An allowance of the base cost to mitigate these technical risks. Project execution will be in phases to expedite the Ready for Training schedule: 1) a) Initial training and testing of Operations Staff on station changes can be performed on the DNGS Simulator at the PLC. b) Project resources are assigned to Simulator Vendor purchanse orders will be staged to allow for: 2) Simulator Vendor purchanse orders will be staged to allow for: b) Manufacture through Initial Installation at the DLC



Page:	
OPG Confidential	
	į

19 of 29

BUSINESS CASE SUMMARY



d) Required instruments will be re- engineered and supplied to ensure fidelity with the station	Increased costs to meet requirements Medium Start project to demonstrate that OPG is Low moving to correct the deficiency of training and bring the training program up to industry standards.		Potential harm to OPG emplyoees and Medium Implement control under OPG Health and Contractors. Safety Plans. Pre and Post Job Briefs will be performed to inform workers of all hazards. Limited and controlled access to DLC working area will be inforced and only qualified personnel will have access
	Regulatory CNSC may request an evaluation of our training program and enact a tighter timeline for in service to meet Industry Standards	Environmental No significant risk for this release.	Health & Shety There are health and safety risks to regular OPG employees and contractors during the construction phase. (Air quality, noise, electrical, craning, working at heights, etc)





20 of 29

Page:

BUSINESS CASE SUMMARY

A DECISION MADE INTO DECISION IN THE AND NEAD TO DECISION	LOW	Kisk Magnitude is too large to be managed	Low	
to extend DNGS service life to		at the Project level Pending Coornorate		
2044				
		nacisiai.		
		2		
		_	_	-

BUSINESS CASE SUMMARY

7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Final AFS Date:		PIR Responsibility (Sponsor Title)
Comprehensive	Jul 2009	Jun 2011	Manager Operations

Comments:

Parameter Current Baseline		Targeted Result	How will it be measured?	Who will measure it? (person / group)	
Simulator Training hours	30-35 hrs/year/per	>60 hrs/year/per	Training stats	Training	
Meet minimum complement on each shift crew	6 ANO's per crew	8 ANO's per crew, and 15 ANO's for supporting roles	Operations shift schedules	Operations	
Reduction in \$125k/yr + \$1.1M/yr OM&A travel time to PLC and Overtime costs to maintain shift complement		\$0/yr	Cost reports	Operations	
Simulator Availability for Training	N/A – new simulator	Exceeds 98% [standard for all simulators]	Statistics on forced outages during Simulator Training for 6 months after AFS Completion 16-28452	Simulator & eLearning Technology Dept	
	Simulator Training hours Meet minimum complement on each shift crew Reduction in OM&A travel time to PLC and Overtime costs to maintain shift complement Simulator Availability for	ParameterCurrent BaselineSimulator Training hours30-35 hrs/year/perMeet minimum complement on each shift crew6 ANO's per crewReduction in OM&A travel time to PLC and Overtime costs to maintain shift complement\$125k/yr + \$1.1M/yrSimulator Availability forN/A – new simulator	ParameterCurrent BaselineTargeted ResultSimulator Training hours30-35 hrs/year/per>60 hrs/year/perMeet minimum complement on each shift crew6 ANO's per crew of ANO's per crew, and 15 ANO's for supporting rolesReduction in OM&A travel time to PLC and Overtime costs to maintain shift complement\$125k/yr + \$1.1M/yr of \$0/yrSimulator Availability forN/A – new simulator Keeduction and the simulator	ParameterCurrent BaselineTargeted Resultmeasured?Simulator Training hours30-35 hrs/year/per>60 hrs/year/perTraining statsMeet minimum complement on each shift crew6 ANO's per crew of and 15 ANO's for supporting roles0 perations shift schedulesReduction in OM&A travel time to PLC and Overtime costs to maintain shift complement\$125k/yr + \$1.1M/yr solvr\$0/yrCost reportsSimulator Availability for TrainingN/A - new simulator simulatorExceeds 98% [standard for all simulators]Statistics on forced outages during Simulator Training for 6 months after AFS	

OPG Confidential

Page: 22 of 29

BUSINESS CASE SUMMARY

Glossary (acronyms, codes, technical terms)

- ANO Authorized Nuclear Operator ATS – Authorized Training Supervisor CRSS – Control Room Shift Supervisor
- CRSSIT Control Room Shift Supervisor In Training
- EPC Engineer, Procure, Construct
- FIN Fix It Now

Appendix "A"

- INPO Institute of Nuclear Power Operations
- IPG Integrated Planning Group
- MCR Main Control Room (Station)
- NANT National Academy for Nuclear Training
- NPT Nuclear Programs and Training







Page: 23 of 29

BUSINESS CASE SUMMARY

Appendix "B"

Project Funding History

Choose Project 28452		All	Existing a	nd Planr Cum	ted Relea Iulative Vi	ses (incl alues	continger	icy)			
Release Type	Month	Year	2006	2007	2008	2009	2010	2011	2012	Later	Total
Developmental	Sep	2,006	69	864						····(<u></u>	933
Full	Aug	2,007		641	11,676	2.347	628		•• • • • • • • • • • • • •		15,292
					: + - · · · · · · · ·	,,.					0
· · · · · · · · · ·					Ì.,						0
					, ; ,						0
					•						0
											0
				, . , .	 						0
· · · · · · · · · · · · · · · · · · ·			· · · · · · · · · · · · · · · · · · ·								· · ·
LTD Spent	Jun	2,007		339			· · · · · · · · ·		· · · · · · · · · · · · · · · · · · ·		339

Month &	Year	2006	2007	2008	alues 2009	2010	2011	2012	Later Total
Sep	2,006	0	0	0	n den som en state for det state for en som en s N		9 9 9 7 9 9 0 0 0 1 1 0 1 0 1 0 1 0 1 0 1 0 1 0	54.67971471144 	0
Aug	2,007		838	7,136	3,757			•••••	11,73
									0
						1			0
				,					0
									0
			·····	I					0
	;						Ī		0
	Sep	Sep 2,006	Sep 2,006 0	Sep 2,006 0 0	Sep 2,006 0 0 0	Sep 2,006 0 0 0	Sep 2,006 0 0 0	Sep 2,006 0 0 0	Sep 2,006 0 0 0

Comments:

OPG Confidential

Financial Model – Assumptions

Page: 24 of 29

Appendix "C"

í.

ž.

BUSINESS CASE SUMMARY

Project Cost Assumptions:

- Based on agreed upon fixed price contract for EPC (Main Simulator).
- Based on Altus Helyar estimate for Simulator Move Project with considerations to known preliminary engineering changes (DLC Mods).
- Interest of 5.9% with allocated yearly cashflows up to 2009.
- Identified specific contingencies to manage risks
- 15% general contingency for accuracy of estimates
- Allowance for overtime and travel costs for Factory Acceptance Tests (FATs) and Site Acceptance Tests (SATs) to
 meet schedule and the phased approach implementation.
- AFS for Project 16-28453 in Q2 2009.
- AFS for Project 16-28452 in Q3 2009 and 100 % declaration report of equipment in service in Q3 2009
- Transfer of \$100K for materials, 150K for FTE coverage, and \$750K for Contract work to NPT in Q3 2009 to complete post AFS fidelity assurance work in 2009 and up to Q2 2010 based on OPEX. This work will be part of Project closeout activities without interest.
- Project closeout (ECC) in Q4 2009.
- Final Project closeout in Q4 2010.

Financial Assumptions:

- Escalation 1.5%
- Discount Factor 0.07
- Outage Overheads (k\$/PO day) \$300

Project / Station End of Life Assumptions:

Currently end of life for DNGS is 2020, however a decision will be made in 2009 whether to support station refurbishment to extend DNGS service life to 2044. Based on CNO expectations, OPG is to plan DNGS investments assuming a life extension (End of Project Life 2044).

Energy Price / Production Assumptions:

- Unit MW Output 878 MW
- Unit Energy Cost \$49.50 per MW

Operating Cost Assumptions:

___N/A

Other Assumptions:

Additional ongoing Nuclear Programs and Training OM&A resources are required to operate and maintain a second simulator site and associated facilities. The incremental ongoing costs are based on 2010 and 1.5 % escalation onwards

The incremental OM&A resource increase for Simulator & e-Learning Technology Department required to maintain the Second Darlington Simulator includes two FTEs in 2008 and three FTEs afterwards[two extra M&P engineers and one extra PWU control technician] plus \$100k per annum for material/spares/consumables. These ongoing costs are included in the 2008-2012 issue paper # 44 pending business plan and are estimated to be:

2008: \$269,000 2009: \$518,000 2010: \$537,000 2011: \$550,000 2012: \$560,000 on-going





OPG Confidential

Page: 25 of 29

BUSINESS CASE SUMMARY

The incremental OM&A resource increase for Authorized Training to increase the amount of ATS Simulator Instructors to support the staffing for the current Business Plan includes five FTEs. These ongoing costs are included in the 2008-2012 issue paper # 44 pending business plan and are estimated to be:

2009: \$1,125,000 2010: \$1,177,000 2011: \$1,194,000 2012: \$1,212,000 on-going

The incremental OM&A resource increase for Nuclear East Facilities to maintain the DLC facilities includes 2 FTEs (one janitor and one control tech), and \$300k for spare parts and supplies to support the additional facility. These ongoing costs are included in the 2008-2012 issue paper # 44 pending business plan and are estimated to be:

2009: \$600,000 2010: \$627,000 2011: \$636,000 2012: \$646,000 on-going

All the incremental OM&A costs presented are included in the 2008-2012 issue paper # 44-pending business plan and have been used to calculate the Net Present Value of the project.



ł,



Page: 26 of 29

BUSINESS CASE SUMMARY

Darlington Second Simulator 16 - 28452 Capital

Full Release Business Case Summary D-BCS-59000-10002-R000 <u>Attachment "A</u>" <u>Project Cost Summary</u>

\$000's Capital	LTD Prior Yr 2006	2007	This Release 2008	This Release 2009	This Release 2010	2011	2012	Later	Total
Project Management (OPG)	6	237	336	275	16	andrean a 5 1/2.		4	870
Engineering & Drafting (OPG)	41	165	744	302	130			• •	1,382
Material									
Installation - PWU, BTU									
Contract - Design									
Contract - Installation		and Said and Said	A REAL PROPERTY OF A REAL PROPER	100 W 11-82				-	
Contract - Other								-	
· · · · · · · · · · · · · · · · · · ·							1.1		-
Interest (Capital Project Only)									
Project Costs (excl contingency)	-		Concernment of						
General Contingency						1		12000/0002/02	Sector Lands
Specific Contingency	1 10								
Project Costs (Incl contingency)	47	1,505	11,676	2,347	628		nores para any	an an tao an an	16,204
2007-2011 Business Plan	250	1,350	11,050	2,253	alando nadit -	8-1623A-1623E-1 1	and de la de la La de la d	1211124333). H	14,903
Variance to Business Plan	(203)	65	(897)	(212)	546				(701)
Committed Cost				. 24 4 4 4 4 4 4 5 4 5 4 5 4 5 4 4 5 4 5	0011 <u>0 070000 1</u>	and a state of the second s	1.417 <u>92/11/1</u> 2		(1910) (1499) / /
Inventory Write Off Required					·· ···				· · · · · ·
Spare Parts / Inventory	÷,,				· ··		_··· ،	·	<u></u>
Total Release (excl contingency)	47	1,415	10,153	2,041	546	38.638.245	ana ang ang		
Total Release (incl contingency)	47	1,505	11,676	and a second second second				*	14,202
and analog tools and shine	e – v střest, k stř -	574 - 19 - 19 .4.	\$1,010	2,347	628				16,204
Ongoing OM&A (non-project)			269	1,643	1,714	1.744	1.772	73,485	80,627
Removal Costs (incl in above)		dinerie in							

Design Complete		Up to - 15%	Quality of E	Estimate	Release + 1	5% to - 10%
3 rd Party Estimate	No	OPEX used	Yes	Lessons Lea	arned	Yes
Reviewed by Sponsor	Yes	Budgetary Quote(s)	Yes	Phase 1 Act	ual Used	Yes
Similar Projects	Yes	Contracts in place	Yes	Competitive		Yes

 Variance to Business Plan

 The estimated variance(s) to the 2007-2011 Business Plan will be addressed through the portfolio management process.

 A PCRAF will be approved by Sep 2007.

Reviewed By:

í.

111 ince Tzambazis

Juny 17,2007

Approved By:

Dianne Gaine

Eng & Mods Manager (Strat IV)

Date:

417167.

roject Manager

Date:



aly17/07

BUSINESS CASE SUMMARY

DLC Modifications 16 28453 Capital

Full Release Business Case Summary D-BCS-59000-10002-R000 Attachment "A" **Project Cost Summary**

5000's	LTD Prior Yr		This Release	This Release					
Capital	2006	2007	2009	2009	2010	2011	2012	Later	Total
Project Management (OPG)	22	191	286	103	a second a second a second	ar an the state of the			601
Engineering & Dralling (OPG)		64	114	71		····			249
iterial									
nstallation - PWU, BTU									
Contract - Design									
Contract - Installation									
Contract - Other									-
	-	2							
nterest (Capital Project Only)									
Project Costs (exc) contingency).	1								
General Contingency									
recific Contingency									
oject Costa (Incl contingency)	22	838	7,136	3,757					11,752
2007-2011 Business Plan	250	849	5,006						6,105
/ariance to Business Plan	(228)	(120)	764	3,267					3,682
Committed Cost							1		-
nventory Write Of Required							· · · · · · · · · · · · ·		*
Spare Parts / Inventory									•
Total Release (excl contingency)	22	729	5,770	3,267		8 ⁷ -			9,787
Total Release (Incl contingency)	22	838	7,138	3,757					11,752
	100000000						and the second	Nobereteren Newsteret	
Ongoing OM&A (non-project)				600	627	636	646	26,856	29,375
Removal Costs (incl in above)			an the state		100 M	1002002 1002002			

Design Complete	Up to - 40%		Quality of Estimate		Release + 15% to - 10%	
3 rd Party Estimate	Yes	OPEX used	N/A	Lessons Lea	irned	Yes
F 'ewed by Sponsor Yes		Budgetary Quote(s)	No	Phase 1 Act	ual Used	Yes
Similar Projects	Yes	Contracts in place	Yes	Competitive	Bid	Yes

Variance to Business Plan The estimated variance(s) to the 2007-2011 Business Plan will be addressed through the portfolio management process. A PCRAF will be approved by Sep 2007.

eviewed By:

354

Approved By: July 17, 2007

Vince Tzambazis Project Manager /

Dianne Gaine Eng & Mods Manager (Strat IV)

Dieu

ONTARIOPOWER GENERATION	
ULIULIMIUIY	

l

BUSINESS CASE SUMMARY

Second Darlington Full Scope Simulator Project 16 - 28452 Capital 16 - 28453 Capital

Full Release Business Case Summary D-BCS-59000-10002-R000

			ariance A	1000000000	
	LTD Jun 2007	Last BCS	This BCS	Variance	Comments
Project Management (OPG)	210	1,000	1,471	471	
Engineering & Drafting (OPG)	100	731	1.631	900	······································
laterial			1,001	300	
Installation - PWU, BTU	,				
Contract - Design	14 - C				
Contract - Installation	H				
Contract - Other					
Interest (Capital Project Only)					······································
Project Costs (excl contingency)					
General Contingency	1				an a shekarin <u>an an a</u>
Specific Contingency					· · · · · · · · · · · · · · · · · · ·
Project Costs (Incl contingency) Committed Cost	558	23,893	27,206	3,313 0	
Inventory Write Off Required		······································		0	
Spare Parts / Inventory		-y		0	· · · · · · · · · · · · · · · · · · ·
Total Release (incl contingency)	558	23,893	27,206	3,313	-
Total Release (excl contingency)	558	20,784	23,240	2,456	
	19.577777777545777777	r XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX	109,514		an a
Ongoing OM&A (non-project) Removal Costs (incl in above)	a la chuir a chuir	しちい いんが そんね	VICE BE AND DESCRIPTION	109,514	

Comments:

BUSINESS CASE SUMMARY

Attachment "C"

Key Milestones

Completion Date		Date	Description					
Day	Day Mth Yr		1					
15	June	2007	Purchase Order Issued - Preliminary Design 16-28452					
04	Sept	2007	Full Release BCS Approved 16-28452/28453					
02	Oct	2007	Design Agency Contract for Detailed Engineering Awarded 16-28453					
11	Oct	2007	Purchase Order Issued - EPC 16-28452					
21	Jan	2008	Contractor - Start Pre-fabrication of Panels 16-28452					
09	April	2008	Contractor - Final Design Complete 16-28452					
23	May	2008	Contractor - Final Design Complete 16-28453					
23	May	2008	Award Installation Contract 16-28453					
09	June	2008	Start Installation 16-28453					
29	Sept	2008	Contractor - Start Installation of Panels 16-28452					
08	May	2009	AFS Complete 16-28453					
15	July	2009	AFS Complete 16-28452 (Ready for Training)					
31	Dec	2010	Project Closeout Complete 16-28452/28453					

A Project Execution Plan (PEP) will be approved by Aug 2007

Comments:



		0	PG Confidential PUSINESS CASE SUM	Page 1 of
Darlington Used Fuel Dry Storag Area (FFAA) East) Business Cas Final Release Business Case Sum	se Summary	for Final R	lelease of Funds 16-33925 (Facility Auxiliary
Routing	Location	Action	Signature	Date
G. Gordon Acting Section Manager, Design Projects – 703-3558	BW7-02	Review BCS	In Make	Dec 12/0,
G. Kotwa Section Manager, PMO 703-3528	BW7-02	Review BCS	Autom	Dec12467
P. Floyd Manager, Design Projects – Darlington 703-3563	BW7-02	Review BCS	the Month	Dec 12/07
J. Pinnegar Manager, Fuel Handling – Darlington 703-7493	D08 OSB- 2	Review BCS	Mange	- Dec 19/0
D. Zerkee Manager Investment Management 702-5058	P82-3	Review BCS	Palana frederikten by phone.	Dec Z 1 200
M. Arnone Director, Projects and Mods 710-6063	P72-2	Review BCS		
J. Lehman Director Station Enging – Darl. (Acting) 703-7584 S. Parks (J. Jacka P	D08 ES2	Review BCS	John Span	Dec 20/27
S. Parks (Junita P R. Leavitt Director, Investment Management 702-5085	P823-315	Review BCS	Planing.	Der 21/07







			DPG Confidential BUSINESS CASE SUMM	Page 1 of
Darlington Used Fuel Dry Stor Area (FFAA) East) Business (Final Release Business Case Su			Station Modifications (Fuel]	and the second s
Routing	Location	Action	Signature	Date
G. Gordon Acting Section Manager, Design Projects - 703-3558	BW7-02	Review BCS	In Mate	Dec. 12/0
G. Kotwa Section Manager, PMO 703-3528	BW7-02	Review BCS	Augen	Dec 124/07
P. Floyd Manager, Design Projects – Darlington 703-3563	BW7-02	Review BCS	the St Flogh	Dec 12/07
J. Pinnegar Manager, Fuel Handling – Darlington 703-7493	D08 OSB- 2	Review BCS	Mineyo	Dec 12/07
D. Zerkee Aanager Investment Management 02-5058	P82-3	Review BCS	Arallon fr. Duzertalan.	Dec 20, 200 g
 Arnone Director, Projects and Mods 10-6063 	P72-2	Review ' BCS	The	19 Dec 2007
Lehman Frector Station Enging - Darl. Acting) 703-7584	D08 ES2	Review BCS		
Leavitt irector, Investment Management 2-5085	P823-315	Review BCS	- Lawritz	Dec 20, 2007-
Gordon Hing Section Manager. Design ojects – 793-3558	i	Approve BCS		









Document Number: 00044-BCS-00120.3- 00003	Revision. R0	Page: 1 of 8
Darlington Used Fi In-Station Modificat (FFAA) East) Bus Re	tions (Fuel Facilit	v Auxiliary Area

1. <u>RECOMMENDATION:</u>

Approval is requested for a final release of \$11.9M for installation of equipment and modifications to the Darlington Fuel Facility Auxiliary Area (FFAA) East, in order to complete the Darlington Used Fuel Dry Storage (UFDS) Project. This release includes the installation of equipment and modifications to the Darlington FFAA East (also described as water pools, or irradiated fuel bays).

Project funding of \$93.8M has been previously approved for the detail design, regulatory approvals, installation of equipment and modifications to the FFAA West, and the acquisition of long-lead material items required for Fuel Facility Auxiliary Area - East; as well as the regulatory approvals, detail design and construction of the Darlington UFDS Facility. The total project cost estimate is \$105.7M, which is \$2.5M less than the original estimate provided to the Ontario Power Generation (OPG) Board of Directors in 2004 at the time of the first release of funds requiring their approval.

This project is categorized as a Sustaining investment, required for the continued operation of the station past 2009. Funding is included in the approved business plan consistent with this proposal. Project cash flows are provided in Appendix B.

2. <u>SIGNATURES</u>

Submitted by:

Nash Date

K. Nash Senior Vice-President, Nuclear Waste Management

Recommended by:

Sel 12-18 07 Appellatte 2007-12-21 Date Date

W. Robbins Senior Vice-President, Darlington

Recommended by:

- and

Mutchell 18 Arios

T. Mitchell Chief Nuclear Officer

Financial Approval by:

Recommended by:

Date

P. Charlebois **Executive Vice-President** & Chief Operating Officer

Line Approval per OAR Element 1.1

huls dur Feb 2/08 Date

D Hanbidge Senior Vice-President & Chief Financial Officer

MARKANIN FILT. 4/03

/I/Hankinson President & Chief Executive Officer







Document Number: 00044-BCS-00120.3- 00003	Revision: Rů	Page: 2 of 8
	uel Dry Storage F Itions (Fuel Facilit siness Case Summ elease of Funds	y Auxiliary Area

3. <u>BACKGROUND & ISSUES</u>

Used nuclear fuel arising from Darlington Nuclear Station is currently stored in the east and west irradiated fuel bays (water pools) located inside the station. The west water pool will become full in 2009 and the east in 2010. The purpose of the Darlington UFDS Project is to provide additional used fuel interim storage capacity to allow continued operation of the station. The project consists of modifications to the station water pools to allow Dry Storage Containers (DSC's) to be loaded, design and construction of a UFDS Facility and upgrades to site roads to allow the DSC's to be transferred to the UFDS Facility.

The original schedule established in 2001 for initial used fuel transfers to dry storage was October 2007. This allowed for a one-year contingency in project schedule, plus a one-year buffer capacity in Darlington water pools. Both OPG and Bruce Power operate with a minimum of one-year water pool buffer capacity to accommodate unforeseen operating and production problems in water pools, the UFDS Facility and at the Dry Storage Container (DSC) manufacturing plant. The first used fuel transfers to dry storage are now expected to occur at Darlington by January 2008.

The release history/plans for this project are summarized below:

1) Work under previous Releases	
Jan 2001	 developmental release of \$2.4 M approved by VP, Nuclear Waste Management Division to submit a Comprehensive Environmental Assessment (EA) Study to the Canadian Nuclear Safety Commission (CNSC). EA approval was granted in November 2003 for a Used Fuel Dry Storage (UFDS) Facility and up to 3 storage buildings (total capacity for 1,500 DCS's). This should provide used fuel storage capacity for a 40 year operating life for the four Darlington units.
Nov 2002	 developmental release of \$5.4 M approved by VP, Nuclear Waste Management Division (bringing the total release to \$7.8 M) for (a) preliminary engineering of a UFDS Facility and In-Station Modifications, and (b) to prepare and submit an application for a Construction License to the CNSC. Construction license was granted in August 2004.
Jun 2004	 partial release of \$12.2 M approved by OPG Board of Directors (bringing the total release to \$20.0 M) to complete the detailed design and specifications of the in- station modifications, together with the CNSC approval. This work has been completed.
Mar 2005	 partial release of \$52.5 M approved by OPG Board of Directors (bringing the total release to \$72.5 M) for detailed design and construction of the UFDS Facility, including the processing building, one storage building for 500 DSC's in a new security protected zone, and road upgrades at the Darlington site. This work has been completed.







Document Number: 90044-BCS-09129.3- 00003	Revision: R0	Page: 3 of 8
Darlington Used F In-Station Modificat (FFAA) East) Bus Re	tions (Fuel Facili	ty Auxiliary Area

Jun 2006	 partial release of \$21.3 M approved by OPG Board of Directors (bringing the total release to \$93.8 M) for installation of equipment and modifications to the Fuel Facility Auxiliary Area (FFAA) West and the acquisition of long-lead time items for the FFAA East. The FFAA West is targeted for service by Dec. 2007, 4 months ahead of schedule.
	2) Work to be done under this Release
Nov 2007	 final release of \$11.9 M for installation of equipment and modifications to the Fuel Facility Auxiliary Area (FFAA) – East with a projected completion date of Dec. 2008. Total project releases will be \$105.7 M.

Project cost estimates are included in Appendix C.

4. <u>ALTERNATIVES</u>

Dry storage is the preferred method of providing additional interim storage capacity for used nuclear fuel. The rationale for this alternative was established in earlier project releases (see notes 1 & 2). Dry storage is used at the Pickering Waste Management Facility and at the Western Waste Management Facility (located at the Bruce Nuclear Site). The same Dry Storage Container design is also being used at all these facilities.

5. THE PROPOSAL

This final phase of the overall project includes the installation of equipment and modifications to the FFAA East by December 2008. The project milestones include:


- Dec 2007 Final contractual arrangements in place
- Apr 2008 Concrete demolition complete
- May 2008 Complete installation of impact pads (2)
- Dec 2008 FFAA East available for service (AFS)
- Oct 2009 Project Closeout



Business Case Summary (BCS), Darlington Used Fuel Dry Storage (DUFDS) Project - Release #3 - Detailed Engineering of In-Station Modifications, June 2004

BCS, DUFDS Project - Release #4 - Detailed Design & Const'n of Dry Storage Facility. March 24, 2005





6. QUALITATIVE FACTORS

The use of DSC's is consistent with the long-term management recommendations for used nuclear fuel submitted by the Nuclear Waste Management Organization to the Federal government.

The completion of the Darlington UFDS Project will allow the Darlington Nuclear Generating Station to continue to operate beyond 2009.

A Sustainable Energy Development Impact Assessment was conducted for the Western Used Fuel Dry Storage Facility in 2000. For a similar installation, the assessment concluded that the approach of using DSC's has the least impact on the environment when compared to the assessed alternatives.

7. RISKS

The current estimate is based on detailed design work conducted by an experienced Canadian nuclear engineering company, with a competitively-bid construction contract. The modifications to the west pool are anticipated to be completed by December 2007, and the lessons learned are being applied to finalize the funding/scheduling requirements for the east pool.

The risks built into the contingency funds are presented in Appendix A.

8. POST IMPLEMENTATION REVIEW (PIR) PLAN

A Comprehensive Post Implementation Review (PIR) will be carried out for the overall project (\$105.7 M) within one year of the in-service dates of both Fuel Facility Auxiliary Areas (by Dec. 2009), consistent with the corporate PIR Procedure. It will be conducted by an Independent Team with the Team Leader appointed by the Project Approval Authority. The Comprehensive PIR will be an independent and systematic performance evaluation of the project for these objectives:

- assess the realization of the project benefits consisting of: (a)
 - the detailed design and specification of the in-station modifications; and (1)
 - the installation of equipment and modifications to the FFAA. (2)
- review project plan, implementation and operational performance; (b)
- review BCS major assumptions, economic and financial evaluation looking back (C) from results, for future decisions;
- (d)review project risk management; and
- Identify over-all lessons learned, in addition to those documented by the project (e)team, for future improvement.









Document Number:
00044-BCS-00120.3-
00003Revision:
R0Page:
5 of 8Dartington Used Fuel Dry Storage Facility Project:
In-Station Modifications (Fuel Facility Auxiliary Area
(FFAA) East) Business Case Summary for Final
Release of Funds

APPENDIX A: Risk Summary - 2008 to 2009

			Γ		Co	ntinge	ncy
Roferance		Probability	Impact	Mitigation Measures	Exposure (\$k)	Risk Factor	Total (\$k)
1	Cost - Material costs escalate in 2008.	н	M	Advance purchase and fabrication where possible.			
2	Schedule - Regular or emergent fuel handling/station work requires the project to vacate the work area. Potential schedule delays of up to 6 days per month.	М	М	Signed coordination agreement between the station and the project.			
	Cost - Costs higher due to design errors, plant configuration issues. Design contract extension amount higher than estimated.	H	м	Contract change process and process for field changes and instaliation package release. Definition of design scope of work			
	Schedule/Cost - Closeout activities longer in duration due to contractual terms and conditions.	н		Project closeout process in place. Start closeout early.			
	Cost - Concrete has radioactive contamination, causing higher waste costs. Risk of "clean" disposal site shutdown increases cost.	н		Lessons learned from FFAA - West waste handling (>\$800k cost) used to lower costs for FFAA - East. Contingency plan for waste site.			
	Resourcing - Future contractor labour shortage occurs, resulting in inability of contractor to maintain schedule and guality.	M	M	Contract award to secure resources.			
7 1				SUB-TOTAL			
1 1	Unforeseen miscellaneous items (unknown unknowns)		(Communication and project meetings.			
				TOTAL		•	

Note:

The risk summary applies to the balance of work required to complete the in-station modifications for FFAA – East.





Document Number: 00044-BCS-00120.3- 06003	Revision: R0	Page: 6 of 8
Darlington Used Fi In-Station Modificat (FFAA) East) Bus Re	tions (Fuel Facilit	v Auxiliary Area

www.www.ut.andex.org

For Internal Project Cost Control







Document Number: 00044-8CS-00120.3- 00003	Revision: R0	Page: 7 of 8
Darlington Used F In-Station Modifica (FFAA) East) Bus R	tions (Fuel Facili	ty Auxiliary Area

APPENDIX B: PROJECT CASH FLOWS & BUSINESS PLAN

The project cash flows and approved business plan funding are provided in the table below. The additional funding required to implement the In-Station Modifications can be accommodated within OPG Nuclear's approved business plan envelope.

		1			
	2001 - 6	2007	2008	2009	Totals
Current Estimate (\$M)	15.4	16.6	14.0	1.8	47.8
Current Estimate w/o Contingency (\$M)					
Business Plan (\$M)	15.4	11.2	16.1	Ö.9	43.6
Variance to Business Plan (including contingency) (\$M)		5.4	(2.1)	0.9	4.2
Variance to Business Plan (excluding contingency) (\$M)	-			······································	

Table 2: In-Station Modifications (Capital)

Table 3: Dry Storage Facility (Nuclear Waste Provisions)

		Year				
	2001 - 6	2007	2008	2009	Totals	
Current Estimate (\$M)	35.3	20.5	0.5	~	56 3	
Business Plan (\$M)	35.3	25.2	0	-	60 5	
Variance (\$M)	-	(4.7)	0.5	-	(4.2)	



 Document Number:
 Revision:
 Page:

 00044-BCS-00120.3 R0
 8 of 8

 00003
 R0
 8 of 8

 Darlington Used Fuel Dry Storage Facility Project:
 In-Station Modifications (Fuel Facility Auxiliary Area (FFAA) East) Business Case Summary for Final Release of Funds

APPENDIX C: PROJECT COST ESTIMATES

Darlington Used Fuel Dry Storage Project - Cost Estimates (\$k)

		Y/I			•	
(\$k)		2006	<u>2007</u>	2008	2009	<u>Totals</u>
1	Design-Owners Agent	Manager				
2	Design Agency					
3	Other contracts				1	
4	OPG Project Management					
5	OPG CMO / FE / Support					
6	Construction Labour and Fabrication				-	
7	Waste Handling					
8	Long Lead (LL) Materials					
9	Advance EFFAA LL Materials	-				
10	Advance EFFAA construction					
11	General Material	-		are sume the	41411	
12	Travel and Board	-	and a shirt	an aller and	lala and	
13	Letter of Credit	-				
14	Specific Contingency			and the lot of the second	13111	
15	Interest	-				
	Subtotal					
16	Contingency	-				
	In-Station Totals	15,400	16.620	13,980	1.790	47.790
	Dry Storage Facility	32.668	25.232	0	0	57.900
	Project Totals	48,068	41,852	13,980	1.790	105,690

Approved by:

Greg Gordon, Acting Section Manager Design Projects, Darlington

4-DEC 2007

Date

33925



ONTARIOPOWER	Document Number:	Revision:	Page:	DUFD.
	00044-BC5-00120.3-00002	R00	1 of 9	Partial
GENERATION	BUSINE	SS CASE SUMM	ARY	Releas

DARLINGTON USED FUEL DRY STORAGE PROJECT – RELEASE #5 – IN-STATION MODIFICATIONS – FUEL FACILITY AUXILIARY AREA (FFAA) - WEST

1. RECOMMENDATION:

Approval is requested for a partial release of \$21.3M, for the installation of equipment and modifications to the Fuel Facility Auxiliary Area (FFAA) – West at the Darlington plant, and the acquisition of long-lead material items required for FFAA – East. Subject to approval of this current release, and including previous funding approval of \$72.5M, the total releases to date for the Darlington Used Fuel Dry Storage Project would be \$93.8M. The total project cost is currently estimated at \$108.2M.

The <u>In-Station Modification</u> work initiated to date includes the detail design and CNSC approvals work associated with the fuel facility auxiliary areas. The current cost estimate for the In-Station Modifications is \$50.3M, funded from the capital program. The expected inservice date for the FFAA – West has been revised to April 2008. A final funding release for the FFAA - East is planned for September 2007. The current estimate for the final release is \$14.4M. The expected in-service date for the FFAA – East has been revised to April 2009.

The <u>Dry Storage Facility</u> work initiated to date includes the regulatory approvals, detail design and construction of the facility. A total of \$57.9M has been released for this work, funded from Nuclear Waste Provisions. The expected in-service date for the Dry Storage Facility is 2007.

This project is categorized as a *Sustaining* investment, required for the continued operation of the Darlington plant. The project is listed in the approved business plan for 2006. The project cash flows are provided in Appendix 1.







TITLE: Darlington Used Fuel Dry Storage Project -Release #5 - In-Station Modifications -Fuel Facility Auxiliary Area (FFAA) - West

Page: 2 of 9

2. SIGNATURES

Submitted by:

Ken Nash Date Vice-President. Nuclear Waste Management Division

Recommended by:

Jure_14,2004

Gregory Smith Senior Vice-President, Darlington

Financial Approval by:

Donn Hanbidge Date

SVP & Chief Financial Officer

3. BACKGROUND AND ISSUES

Recommended by:

- Jam 19/01 Pierre Charlebois Date Chief Nuclear Officer

Line Approval per O.A.R. Element 1.1:

President and CEO

Used nuclear fuel arising from Darlington Nuclear Station is currently stored in east and west water pools (also referred to as irradiated fuel bays) located inside the station. The west water pool is projected to become full in February 2009, and the east water pool in 2010. The purpose of the Darlington Used Fuel Dry Storage Project is to provide additional used fuel interim storage to allow continued operation of the station.

The total project consists of modifications to the station water pools to allow DSC's to be loaded, design and construction of a DSF, and upgrades to site roads to allow the DSC's to be transferred to the DSF. The DSF approved for construction by CNSC comprises a processing building where the DSC's are welded, x-rayed and prepared for storage, and up to three storage buildings with a total capacity of 1,500 DSC's. This capacity, together with existing water pool storage, is sufficient to accommodate used fuel from a 40-year operating life for all four Darlington reactors. It is projected that the second and third storage buildings will be needed by 2015 and 2023, respectively and at a cost in the order of \$10M to \$15M per building.



The original target in-service date of 2007 allowed for a one-year contingency in project schedule, plus a one-year buffer capacity in the Darlington water pools. Both OPG and Bruce Power operate with a minimum of one year water pool buffer capacity to accommodate unforeseen operating and production problems in water pools, the dry storage facility (DSF), and



 Darlington Used Fuel Dry Storage Project Document Number:
 Page:

 Release #5 - In-Station Modifications 00044-BCS-00120.3-00002
 3 of 9

 Fuel Facility Auxiliary Area (FFAA) - West
 00044-BCS-00120.3-00002
 3 of 9

at the dry storage container (DSC) manufacturing plant. It is currently projected that the first fuel will be moved from the west bay in April 2008, ten months ahead of its projected fill date.

Dry storage at Pickering Waste Management Facility (PWMF) became operational in 1995, and at the Western Waste Management Facility (WWMF) (located at the Bruce Nuclear Site) in 2002. All fuel bundles are stored in standard DSC's. Each DSC holds 384 fuel bundles and weighs 70 tonnes. It is planned to use the same dry storage container design at Darlington and to use similar processing equipment in the DSF. A total of 550 DSC's are currently in storage. Operational experience has been excellent.

The release history/plans for the different phases of this project follow:

	I) Work in Progress/Completed to Date
Jan 2001	A development release of \$2.4M was approved under the authority of the Vice President, Nuclear Waste Management Division to submit a Comprehensive Environmental Assessment (EA) Study to the Canadian Nuclear Safety Commission (CNSC). EA approval was granted in November 2003 for the Dry Storage Facility and up to three storage buildings.
Nov 2002	A development release of \$5.4M was approved under the authority of the Vice President, Nuclear Waste Management Division (bringing the total release to \$7.8M) for preliminary engineering for the Dry Storage Facility and In-Station Modifications, and to prepare and submit an application to the CNSC for a Construction Licence. The construction licence was granted in August 2004.
Jun 2004	A partial release of \$12.2M was approved under the authority of the OPG Board of Directors (bringing the total release to \$20.0M) for the completion of detail design and specifications of the in-station modifications, together with CNSC approval. This work has been completed.
Mar 2005	A partial release of \$52.5M was approved under the authority of the OPG Board of Directors (bringing the total release to \$72.5M) for the detail design and construction of the Dry Storage Facility. The work scope includes the processing building, one storage building for 500 DSC's in a new security protected zone, and upgrade of the roadways at the Darlington site. The work is targeted for completion by the end of 2007.

II) Work to be Done Under this Release				
Mar 2006	A partial release of \$21.3M is the subject of this business case (bringing the total release to \$93.8M), and comprises the installation of equipment and modifications to the Fuel Facility Auxiliary Area (FFAA) – West, and the acquisition of long-lead material items required for FFAA – East. The FFAA – West is now targeted for service by April 2008.			





	III) Future Work
Sep 2007	A final project release of \$14.4M (bringing the total release to \$108.2M) will be sought to complete the installation of equipment and modifications to the FFAA – East. The FFAA – East is now targeted for service in April 2009.

Page:

4 of 9

4. ALTERNATIVES

The previous releases for this project established the scope and direction for interim dry storage at Darlington.^{1, 2, 3, 4} Dry storage is the preferred method of providing additional capacity. The total project cost is estimated at \$108.2M, with an in-service date of April 2009. The completion of the Darlington Used Fuel Dry Storage Project will allow the Darlington Nuclear Generating Station to continue to operate beyond 2009.

5. THE PROPOSAL

This current phase of the overall dry storage project will allow for the installation of equipment and modifications to the Fuel Facility Auxiliary Area (FFAA) – West, and the acquisition of long-lead material items required for FFAA – East. The cost estimate for this phase is based on a competitively-bid construction contract. The overall project estimates are summarized in Appendix 2.

This phase of work is expected to start in July 2006, with the following milestones:

- Jul 2006 All long-lead material item purchase orders placed for both fuel bays; and award major construction contract
- Sep 2006 Start of services relocation work to FFAA-West
- Nov 2006 Start of major construction/construction zone set-up
- Mar 2008 Complete FFA-West installation
- Apr 2008 FFAA West available for service complete.

- ² Business Case Summary, DUFDS Project Development Release for EA Approval, Construction License & Preliminary Engineering, November 26, 2002
- ³ Business Case Summary, Darlington Used Fuel Dry Storage Project Release #3 Detailed Engineering of In-Station Modifications, June 2004
- ⁴ Business Case Summary, Darlington Used Fuel Dry Storage Project Release #4 Detailed Design & Construction of Dry Storage Facility, March 24, 2005





¹ Business Case Summary, Darlington Used Fuel Dry Storage Project – Development Release for Environmental Assessment Submission, January 9, 2001



TITLE: Darlington Used Fuel Dry Storage Project -Release #5 – In-Station Modifications – Fuel Facility Auxiliary Area (FFAA) - West

6. QUALITATIVE FACTORS

The use of DSC's is consistent with the long-term management recommendations submitted by the Nuclear Waste Management Organization to the federal government.

A Sustainable Energy Development Impact Assessment was conducted for the Westem Used Fuel Dry Storage in 2000. For a similar installation, the assessment concluded that the approach of using DSC's has the least impact on the environment when compared to the assessed alternatives.

7. RISKS

7.1 Current Release Risks

Modification of Water Pools

The current estimate is based on detailed design work conducted by an experienced Canadian nuclear engineering company, with a competitively-bid construction contract. Because of a substantive number of outstanding design considerations and logistical complexities, the equipment and modification work will be conducted in two phases. The lessons learned from the west pool can be used to finalize the design and funding requirements for the east pool. An overall contingency factor of **The** has been applied to this phase of the project cost estimate. A risk matrix summary is included in Appendix 3.

7.2 Other Risks

Construction of the Dry Storage Facility

A turnkey design-build contract has been awarded, and is progressing on schedule and within budget. A 95% design stage has been achieved and several risks eliminated. There is a high level of confidence that the facility will be completed within the approved funding of \$52.5M (as approved by Release #4) for this part of the project. The Dry Storage Facility is expected to be available for service in accordance with the original schedule of 2007. As of April 2006, \$15.8M has been spent on the Dry Storage Facility.

Facility Location

The location of the Dry Storage Facility was previously assessed for potential conflict with new-build nuclear units on the Darlington site. It has been confirmed that it should be possible to locate up to four units on the site without encroaching on the DSF. The location of future dry storage buildings will be dependent on any plans for additional new-build nuclear units.







TITLE: Darlington Used Fuel Dry Storage Project -Release #5 - In-Station Modifications -Fuel Facility Auxiliary Area (FFAA) - West

8. POST IMPLEMENTATION REVIEW PLAN

- A Comprehensive Post Implementation Review (PIR) will be carried out within one year of the . project in service of both Fuel Facility Auxiliary Areas (by April 2010), consistent with the corporate PIR Procedure. It will be conducted by an Independent Team with the Team Leader appointed by the Project Approval Authority.
- The Comprehensive PIR will be an independent and systematic performance evaluation of ٠ the project for these objectives:
 - Assess the realization of the project benefits consisting of:
 - i. The detailed design and specification of the in-station modifications, and
 - ii. The installation of equipment and modifications to the Fuel Facility Auxiliary Areas,
 - \geq Review project plan, implementation and operational performance.
 - Review BCS major assumptions, economic and financial evaluation looking back from \succ results, for future decisions.
 - ⋟ Review project risk management.
 - \geq Identify over-all lessons learned, in addition to those documented by the project team, for future improvement.





TITLE Conditionation (1) of the All States	The second s	
TITLE: Darlington Used Fuel Dry Storage Project -	Document Number:	Page:
	00044-BCS-00120.3-00002	
Fuel Facility Auxiliary Area (FFAA) - West		1010

Appendix 1 - Project Cash Flows & Business Plan

The project cash flows and approved business plan funding are provided in the table below. The additional funding required to implement the In-Station Modifications can be accommodated within OPG Nuclear's approved business plan envelope.

Year 🗲	2001 – 5	2006	2007	2008	2009	Total
Current Total Estimate (\$M)	9.5	8.1	18.3	13.4	1.0	50.3
Current Estimate w/o Contingency (\$M)						
Business Plan (\$M)	9.5	19.1	12.0	1.2	-	41.8
Variance (\$M)						

Dry Storage Facility (Nuclear Waste Provisions)

Year →	2001 – 5	2006	2007	2008	2009	Totai
Current Estimate (\$M)	12.4	20.3	25.2	-	-	57.9
Business Plan (\$M)	12.4	21.5	25.2	-	-	59.1
Variance (\$M)	-	(1.2)	-	-	-	(1.2)

ITLE: Darlington Used Fuel Dry Storage P Release #5 – In-Station Modification Fuel Facility Auxiliary Area (FFAA) -	ns –				Number: 120.3-00002	Pag 8 of	
Daulianster Hand Front	Append						
Darlington Used Fuel		i <u>ge Pro</u> /E	oject -	<u>- Cost E</u>	stimates		
	(\$ k) 20		2006	<u>2007</u>	2008	<u>2009</u>	Total
1. IN-STATION MODIFICATIONS							•••
Owner's Agent							
Design Agency							
Licencing Support			-				
Other Contracts	-						
OPG Project Management/Support				Color-	-	6 m (1997 -	
OPG DSF/Calandría Road Support							
Construction Labour							
Material							· ·
Outstanding Claims/Contract Scope							
Interest							
Contingency				·····			
Sub-total	9,54	19 8	,140	18,263			35,952
Final Release - East Fuel Bay					13,368	983	14,351
IN-STATION MODIFICATIONS ESTIM	ATE 9,54	19 8	, 140	18,263	13 ,368	98 3	50,3 03

in-Station Modifications Estimate

Approved by:

Bay Balachovek, Project Manager, Design Projects

Date:

May 30, 2006

2. DRY STORAGE FACILITY

12,376 20,262 25,232

28,402

43,495

21,925

• **57,8**70

108,173

983

-

13,**368**

3. PROJECT TOTALS



TITLE: Darlington Used Fuel Dry Storage Project -Release #5 - In-Station Modifications -Fuel Facility Auxiliary Area (FFAA) - West

		1	1		Co	ntinge	ency
Duformente		Probability	tmbact	Mitigation Measures	Exposure (\$k)	Probability	Total (x\$)
1	Schedule - West fuel bay fills faster than predicted. Reduced storage buffer could Impact unit operation, with potential deretings.	м	H	Manage the buffer by maintaining preferential fuel deliveries to the FFAA-East. Reconfiguration of the fuel bays will also increase buffer.			
2	Schedule - Regular or emergent fuel handling/station work requires the project to vacate the work area. Potential schedule delays of up to 3 days per month.	м	М	Sign coordination agreement between the station and the project.			
3	Schedule - Late delivery for long lead material items, resulting in delay for FFAA-West completion.	м	М	Purchase Orders for long lead Items to ba issued Immediately following project release.			
4	Cost - Installation costs higher than estimated due to sole source or schedule compression.	н	M	Contract requests fixed price, and negotiation with 2 lead bidders.	2	·	
5	Cost - Project costs increase due to field changes, and late design package approval. Field changes could cause up to 2 days per week schedule loss/cost increases.	н	М	Walkdown of design to identify field changes. Implement an efficient field change approval process.			
6	Cost - Concrete has radioactive contamination, ceusing a major delay for handling radioactive waste, and higher waste costs.	L	М	Identify contamination ahead of construction, together with contingency process for handling radioactive waste.			
7	Resourcing - Future contractor labour shortage occurs, resulting in inability of contractor to maintain schedule and quality.	м	м	Contract award to secure resources.			J
				SUB-TOTAL ►			
8	Unforeseen miscellaneous items (unknown unknowns).	м		Communication and project meetings.	964	1	964
	······································	****		TOTAL >			

Appendix 3 - Risk Summary





OPG Confidential

1 of 11

Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

Auxiliary Heating System Project 16 - 34000

Developmental Release Business Case Summary D-BCS-73110-10001-R000

<u>Routing</u>	Location	<u>Action</u>	Signature	Date
derek fung Project Engineer, Design Projects, DND 703-3535	BW7-02	Prepare BCS	Jan of a	4 23 Feb 2006
Nahil Rahman Section Manager, Design Projects, DND 703-3527	BW7-02	Review BCS	J.A.	23 FEB 2006
John Taras Section Manager, PMO, DND 703-3528	BW7-02	Review BCS	Pfor J Tavas	24 feb 2006
Robert Black Manager, Design Projects, DND 703-3520	BW7-02	Review BCS	ABled	27 FEBÓL
Bill Qualtrough Manager,Performance Engineering, DND 703-7484	D08-ES2	Review BCS	andto	MANEWISLOB
Ron Ball Senior Financial Advisor 702-4084	P82-3B6	Review BCS	Pr	20 Mon ols
rk Arnone ector, Projects & Modifications	P72 E4.4	Submit BCS	Rhe	21 Mare 2006
Gord Brown Controller, Engineering & Modifications 702-5059	P82 F3-A6	Approve BCS	ALS -	20 Mar 06
Stu Seedhouse Director,Station Englneering, DND 703-7464	D08-ES3	Approve BCS	Sseal	2 3 Man Zaxi
Ball Senior Financial Analyst 702-4084	P82-3B6	Return For Distribution		

Last printed 2/23/06 9:00 AM

ONTARIOPOWER

GENERATION

FIN-TMP-PA-005 (Supersedes N – 10207 BCS)

OPG Confidential

2 of 11

Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

Auxiliary Heating System Project 16 - 34000

Developmental Release Business Case Summary D-BCS-73110-10001-R000

1/ RECOMMENDATION:

ITARIO**pu**i

We recommend a release of \$2.2M (including contingency) of developmental funding to complete the 'Definition Phase' of the Auxiliary Heating System (AHS) Project with the intention of placing a new system in service by the Fall of 2008.

The business objective of this project is to provide a reliable back-up supply of heating steam to prevent major equipment damage and thereby support the safe return of Darlington units to service following a four unit shutdown during the winter months. This will be achieved by replacing the existing Construction Boilerhouse with a facility that can, in the event of a four unit shutdown, maintain the temperature inside the Powerhouse and TRF/HWMB above 10°C to prevent impairment of both safety and non-safety related systems due to heavy water freezing (heavy water freezes at +4.8°C).

The existing Construction Boilerhouse (CBH) cannot continue to provide this capability because:

it does not have sufficient installed capacity

GENERATION

- · the building and oil feeder piping are not fully compliant
- it was never designed as a permanent system and is costly to maintain.
- · it does not meet reliability requirements from both a nuclear safety and conventional risk assessment

Refurbishment of the CBH is not recommended because:

- it would cost at least as much as replacement with greater cost and schedule risks.
- it would result in the unavailability of a back-up system for up to two heating seasons.

is project is consistent with the approved 2006-2010 Business Plan with \$2M budgeted for 2006.

A Project Execution Plan (PEP) will be prepared as a deliverable of this release and submitted for approval by 30 Nov 06.

\$000's Capital		Including Contingency	Excluding Contingency			Excluding Contingency
Released to Date:	Developmental	0		Feb.06	Spent Life to Date:	0
Requested Now:	Developmental	2,200		2006-2010	Apprid Business Plan (Tot Proj):	
Cumulative Release:	Total to Date	2,200		2006-2010	Business Plan Variance:	
Total Project Estimate:	+60% to -25%	23,505		2006	Budget (Current Year)	
Current Year Estimate:	2006	2,200		2006	Budget Variance (Current Yr)	
Type of investment:	Sustaining	N/A		Cumulative Rel	ease Remaining:	
NPV:		N/A		Contingency on	Remaining Release:	
IRR:		N/A		Contingency %	on Remaining Release:	

Submitted By 21 MAR 2006

M. Amone Director, Projects & Modifications

Finance Approval:

Jeres

2016-02 Date:

Date:

Line Approval (Per OAR Element 1,1 Project in Budget):

C. Brown ntroller, Engineering & Modifications Stu Seedhouse Director, Station Engineering, Darlington

Date:

. **Loo**6





ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

2/ BACKGROUND & ISSUES

Purpose of the AHS

Extraction steam from any one single operating unit provides adequate heating steam to meet the needs of the station. However, when all four units are shutdown and there is a possibility of heavy water freezing, an alternate supply provided by the AHS is required to maintain general heating and the availability of Group I safety systems. Group II systems are protected with electric heaters fed from the Emergency Power System and are therefore not impacted.

Planned station outages requiring the use of the AHS typically occur every 6 years with the next in 2009, however, there is a real and ongoing risk of a forced shutdown should any of the following events occur:

- A Design Basis Accident (DBA).
- A common safety system fails.
- Darlington is found to be operating outside of the boundaries of the Safe Operating Envelope (SOE) and is un-repairable.
- The design of Darlington is found to be inadequate to meet the safety basis of the plant. .
- A generic problem is found on a significant production component. ٠
- A labour disruption, regulatory order or other external disruptions.

A system with an unavailability of approximately 1x10⁻² has been deemed necessary to mitigate the risks of such an unplanned event.

Regulatory Issues

In 1987, the AECB questioned Darlington's crediting of reactor decay heat and heat transport thermal energy to provide sufficient building heating until such time as portable heaters could be distributed throughout the station. The ability of portable heaters to heat such a large area was also further questioned. In response, Darlington committed to maintaining a sufficient number of construction boilers until a permanent solution was put in place. Reference Action Item Al#851312.

During the 1997 vacuum building outage, a capacity test of the CBH was performed which demonstrated the ability of the facility to provide adequate heating. AI #851312 was subsequently closed out.

Due to ongoing legacy issues with the CBH, routine project status reports are provided to the CNSC to demonstrate Darlington's commitment to a long term action plan to ensure a reliable supply of auxiliary heating. The latest of these are NK38-CORR-00531-12553, NK38-CORR-00531-12666 and NK38-CORR-00531-12915 associated with REG M Action Items #28060617 and #28060618. The next required update is at the end of Q1 2006.

CNSC correspondences, NK38-CORR-00531-12240 and NK38-CORR-00531-12358, document CBH compliance issues (see SCR D-2004-00415 & D-2004-01239) and Darlington's commitment to resolving the issue of the Backup Heating Fuel System by December 2007.

Existing Conditions



The current CBH facility, consisting of four electric boilers and eight oil-fired boilers, is approaching its end of life. x was placed into service at the time of site construction (some 27 years ago). Even at that time, the oil-fired oilers were previously used (average age is now >40 years) and were obtained from other construction sites. Several of these boilers require major repairs and/or re-tubing. The electric boilers which supply the majority of the load are also aged and will require major refurbishment in the coming years.

Last printed 2/23/06 9:00 AM



ÓNTARIO power	OPG Confidential	Page: 4 of 11
GENERATION	ENGINEERING & MO BUSINESS CASE	

For the short term, compensatory actions are implemented every fall to survive the impending winter. This is very expensive (in excess of \$0.5M base OM&A costs per year in corrective maintenance alone and in 2003/ 2004, an additional \$1.2M for a rental boiler) and imposes unacceptable risk to the station.

It is projected that at least \$0.5 M per year in corrective maintenance will continue until the CBH is replaced.

In 2004, SCR D-2004-08451 was initiated due to concerns about the structural adequacy of the CBH. The assessment of the building concluded that the building structure had degraded and will not support all loads required by the Building Code. Until a new facility is constructed, work request (WR# 449004) has been initiated to have the CBH structure strengthened.

It has also recently been determined that it is not possible to establish a realistic unavailability for the CBH since the equipment is old and the design documentation is minimal and in some cases non-existent. It is also very time consuming with minimal potential for returns.

Refurbishment of CBH

A detailed conceptual study examining possible alternatives, including refurbishment of the existing CBH, was performed in 2000. At that time, limitations of the existing facility were recognized and the preferred alternative was a system which predominately relied on the bulk electrical system, i.e. electric heaters/boilers, due to its perceived reliability. However, as a result of the LOBES event of 2003, a new study was undertaken in 2004 to examine alternatives which did not rely on the bulk electrical system. Two main options were identified; co-generation and oil fired. Due to the much higher cost and timeline and the need for an environmental assessment, co-generation was ruled out. Although black start capability is currently not a design requirement of the AHS, it is economically retrofit into an oil fired system if the need should arise.

A draft report recently prepared by Darlington Projects Design also concluded that refurbishment of the existing facility while technically feasible was not recommended due to the high cost and risks involved. (Ref. draft Engineering Report NK38-REP-73110-10001)

Links to Other Projects

Both Darlington and Pickering have similar requirements to provide auxiliary heating steam. However, due to different plant configurations, the final solution is expected to be tailored to suit the specific station configuration. Pickering requires a minimum capacity of 21,000 Kg/hr of heating steam, whereas Darlington requires approximately double that capacity.

The Design Units from both Darlington and Pickering are in consultation with each other to maintain a consistent approach and design basis.

There are no direct links to other projects. However, maintaining turbine hall roof dampers of the Powerhouse Steam Venting System (PSVS) open, as is the current practice will necessitate an increase of approximately 10% of AHS capacity.

Project #34002 is currently addressing deficiencies with PSVS including the need to maintain these dampers open.

Although, the decision to close these dampers when the AHS is required is a possibility, it is not currently practical. These dampers are not maintained and tested (air supply is disconnected in the field) and may not close when required. In addition, it will take a team of operators (a commodity that is not available when the station is in an emergency four unit shutdown and the weather is freezing outside) and control maintenance personnel (who may be in a similar position) to make this happen.



Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

3/ ALTERNATIVES AND ECONOMIC ANALYSIS

Do Nothing (Not Recommended)

This is not recommended as:

- the risk of severe equipment damage exists should the AHS be required under very harsh conditions due to the limited capacity and unknown reliability.
- · Regulatory issues will not be addressed as the building and oil feeder piping are not fully compliant.
- the CBH was never designed as a permanent system and is costly to maintain.

<u>Alternative 1 – Install new Auxiliary Heating System</u> (Recommended)

We recommend installing a completely new Auxiliary Heating System Facility located adjacent to the existing Construction Boiler House, outside of the protected area.

The new facility will be primarily oil-fired and will utilize existing services and infrastructure to the extent possible. 'Black start' capability, if required in the approved design requirement, will be provided, otherwise, the design will be conducive to a retrofit should the need arise in the future.

This is the recommended alternative as it is the lowest cost option that satisfies the business objective. It provides for 'black start' capabilities and is expandable to accommodate future needs (i.e. station de-commissioning and/ or new construction).

his Developmental Release BCS will be utilized to complete the Preliminary Engineering (Project Definition Phase) and the Full Release BCS. The PEP will also be prepared as a deliverable of this release.

Alternative 2 - Delay the Recommendation (Not Recommended)

This is not recommended as the station will continue to:

- be at risk of severe equipment damage should the AHS be required under very harsh conditions.
- not address regulatory issues associated with the building and piping system for which we have committed to resolve by December 2007.
- perform costly annual maintenance of CBH as it was never designed as a permanent system.

Alternative 3 - Do Less (Not Recommended)

The 'Do Less' alternative involves partial refurbishment of the existing facility which is costly and will not meet the business objectives of the project.

Alternative 4 - Do More (Not Recommended)

This is not recommended as there is no way to include additional features without adding cost. The recommended alternative satisfies the business objectives

Alternative 5 - Other - Co-generation Plant (Not Recommended)

A Co-Generation plant, estimated at \$100M is not recommended as the break even rate is estimated to be not achievable. There also does not appear to be any corporate drivers to merit this alternative at this time.

n addition, it is unlikely that real estate will be available at Darlington to site the cogeneration plant in such a way that the steam transmission lines can be kept reasonably short. Also, delays due to the likely need for an environmental assessment will make meeting the project schedule impossible.

OPG Confidential

6 of 11

Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

Alternative 6 – Other – Electric boilers in Unit 4 (Not Recommended)

We do not recommend the installation of electric boilers in the Unit 4 Powerhouse Extension Bay, with power supplied from the Bulk Electric System (BES) as the space available in the Unit 4 Powerhouse Extension Bay is not adequate. In addition, this alternative does not cater to a black start capability should that be deemed as necessary.

Alternative 7 – Other – Relocate the REPG from PND to DND (Not Recommended)

We do not recommend using the Pickering REPG (22.5 MW) turbine generator as:

• this system is undersized.

ARIO**pow**

- it still requires a boiler facility and associated costs to produce steam.
- it is an inefficient method of producing steam (using jet-engine fuel to produce electricity, to produce heat to produce steam).
- it is very complex and costly to operate and maintain.

As this system is owned by OPG and is available in 2007, it will be explored further as part of this release and considered a potential alternative until proven otherwise.

Alternative 8 – Other – Use of Gas Fired Boilers (Not Recommended)

Ve do not recommend the use of a gas fired boiler facility since natural gas is currently not available on site and would be very costly to supply. Since the facility operates very infrequently, the higher cost of fuel oil is far outweighed by the capital cost of supplying natural gas. The use of natural gas would also introduce a hazard to the site which currently does not exist.



Page:



ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

4/ THE PROPOSAL

This Developmental Release BCS will be used to:

- validate the recommended alternative.
- complete the necessary design and procurement documentation to secure an external design contractor i.e. Design Plan, Design Requirements, Technical Specifications, Design Agency Interface Agreements, Request for Proposals
- complete all required assessments and sufficient detailed design to support preparation of a Full Release BCS
- fund the use of a third party estimator (Helyar).
- complete all necessary project management documentation required for this phase of the project including the Project Execution Plan
- Prepare a Full Release BCS.

Milestones below are for this Developmental Release BCS only.

Milestones Finish Date (D/M/Y)	Description
31-Mar-06	Developmental Release BCS approved
30-May-06	Issue the RFP for an external design agency
30-Jul-06	Award design agency contract (PO)
30-Nov-06	PEP approved
28-Feb-07	Full Release BCS approved

5/ QUALITATIVE FACTORS

N/A

ON LARIOPOWER GENERATION

OPG Confidential Page: 8 of 11 ENGINEERING & MODIFICATIONS

BUSINESS CASE SUMMARY

6/ RISKS

21011				
Description of Risk	Description of Consequence	Risk Before Mitigation	Mitigating	Risk After
Cost			ACIIVILY	nonsfinn
Project requires additional funding	The funding requested may not be adequate to complete necessary design activities.	Medium	Competitive bid process will be used to secure the design contractor. PO will be awarded as a 'Fixed Price' contract. A general contingency of a bis available.	Low
Scope				
Increase in project scope.	Higher cost/ longer schedule	Medium	Original project scope was larger than is now being proposed. The current scope as defined in the preliminary design requirements has been fine tuned and agreed to by all stakeholders as the minimum required to meet station and regulatory requirements. A formal scope change control process will be used to control scope.	LOW
Schedule				
Piping (oil-feeder from SG tanks) will not be code compliant by Dec. 2007	CNSC commitment will not be met. Darlington will not be allowed to use fuel oil piping from the SG tanks to the existing boilerhouse.	Ч ^в ін	Seek a deferral that can be achieved on the present schedule and/ or ensure that the piping is completed first.	Гом
Resources				
Lack of Project Designers.	Project deliverables delayed, with a delay in the project schedule.	High	Design activities will be contracted out to the extent possible to a known design agency to minimize the involvement of station resources.	Medium

FIN-TMP-PA-005 (Supersedes N - 10207 BCS)

ONIARIOPOWER	OPG Confidential	dential	Page: 9 of 11	
GENERATION	ENGINE	ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY	DIFICATIONS	
Technical Commercially available boiler systems are very mature and widely used in other industries. Technical risk is considered tow.		NIA		्रम्
Regulatory See Schedule Risk.	a the state of the first of a state of the s	High	High	Low
Environmental New Certificate of Authorization may be required for new facility.	Not granted due to increased emissions.	Medium	Environmental Group has been consulted. Initial assessment is that a new C of A will not be required. If conditions support this assessment change, an application will be submitted as early as possible in the design phase.	Low
Health & Safety				1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
Investment System may not meet requirements	Solution is known and technology is very mature.	Low Low	No mitigation required.	N/A



Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Final AFS	Targeted PIR Approval	PIR Responsibility
	Date:	Date:	(Sponsor Title)
N/A	Choose Month Choose Year	Choose Month Choose Year	N/A

Comments:

This is a Developmental Release BCS only. PIR will be developed for Full Release.

	Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it? (person / group)
1.					
2.					
3.	1				
4.					
5.	<u>-</u>				



Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

Auxiliary Heating System Project 16 - 34000

Developmental Release Business Case Summary D-BCS-73110-10001-R000

Attachment "A"

Project Cost Summary

\$000's Capital	LTD Prior Years 2005	2006	2007	2008			Total	LTD This Mth	LTD
Project Management (OPG)		270			7		1,184		0.0%
Engineering & Drafting (OPG)		360	289	323	3		972		0.0%
Material	Ninge								010 10
Installation – PWU, BTU									
Contract - Project Mgmt	F								
Contract - Design									
Contract - Installation									
Contract - Other									
			-						
			10 00 10 00						
				a farmer and a					
									H
									-
									~
Interest (Capital Project Only)	-								
Sub Total	H.								
(excl Contingency)	-	(1975)							
General Contingency			th to all	1 mil 1 mil 1	1 pt 1 8-217.	A 13.104			
Specific Contingency	Ranth.								
Grand Total	Registration -		900	S.	Section of	1.1.1		18.11	
		2,200	\$ 10,350	a 10,955			7 23,505	N/A	N/A
2006-2010 Business Plan		2,000	9,000	9,525	11-78 AC 16-		20,525	N/A	N/A
Variance to Business Plant	1-10-10-2	1	¥ - 1	a i i	SE DING	2 Marin	20,020		NZA
(excl Contingency)							-	N/A	N/A

Removal Costs included in above	0
Definition Costs included in above	0
Estimate Name, Quality, etc	Conceptual Estimate +60% to -25%
Design Complete:	Zero to Minimal

Reviewed Byz

Approved By:

27 FEROG Date:

Robert Black Manager (Strat IV), Design Projects

ALE

oject Manager

23FEB2006 Date:

Last printed 2/23/06 5:00 AM

FIN-TMP-PA-005 (Supersedes N - 10207 BCS)

ONTARIOPOWER GENERATION

22

BUSINESS CASE SUMMARY

Calandria Vault Inspection 13 - 46537

Full Release Business Case Summary N-BCS-30673-10000-R000

Routing	Location	Action	Signature	Date
Carl Daniel Manager, Components & Equipment	P42-E2	Submit BCS	See BCS	Date
Martin Reid Director, Station Engineering	P42-E3	Review BCS	see BCS	
John Coleby Senior VP, Pickering A	P42-E3	Review BCS	nee BCS	
Pierre Charlebois Chief Nuclear Officer	P826A-1	Review BCS		guly 21/1
Don Power Director, Investment and Business Planning	H07-J20	Approve BCS	Doan	Non 1/2
lim Hankinson President and Chief Executive Officer	H19-A24	Approve BCS	Att Wikmen	any 1/0
		Choose One		1 O rate
RECEIVED by P. R. Charlebois		Choose One		
JUL 1 1.806		Choose One		-
Refer to	(A.m.)	Choose One		
and the second		Choose One		
		Choose One		
		Choose One		
	· · · · · · · · · · · · · · · · · · ·	Choose One		
		Choose One		
Ball nior Financial Analyst 2-4084	P82-3B6	Return For Distribution		





July 18, 2006

Jim Hankinson President and Chief Executive Officer

Funding Release for Pickering A Calandria Vault Inspection Tooling

Your approval is requested for a release of \$23.9 Million to develop and fabricate tooling for the Pickering A Calandria Vault Inspection Program. This work is included in the OPG Nuclear project portfolio as Capital Project 46537 in the 2006 Business Plan.

Recommended by:

John Coleby Senior Vice President Pickering A

Pierre Charlebois Executive Vice President and Chief Nuclear Officer

Approved:

AND ON

Jim Hankinson President and Chief Executive Officer



1. Background

The Pickering A calandria vaults were originally designed to be vented to atmosphere through the station stack, but early in the life of the reactors these vents were sealed off to reduce station noble gas emissions. As a result, humidity levels within the stagnant vaults became high, which was worsened by chronic leakage from the biological shield cooling system within the vaults. The combination of high humidity, air and radiation created a nitric acid environment, resulting in substantial corrosion of carbon steel components within the calandria vault of each unit. The extent of this corrosion was such that, in the mid-1990s, the carbon steel ring thermal shield inlet and outlet lines had to be removed and replaced with stainless steel flexible hoses using remotely operated robotic equipment.

Uncertainty in the health of the carbon steel components within the calandria vaults was a factor in the decision not to refurbish Pickering Units 2 and 3 and return the units to service.

For Units 1 and 4, the OPG Reactor Assembly Aging Management Plan has identified several components within the calandria vault for inspection to assess their continued fitness for service. To complete these inspections, and to implement repairs should the need be identified, remote tooling must be developed to deliver inspection and repair end-effectors to the internal areas of the calandria vaults. Capital Project 46537 has been included in the OPG Nuclear project portfolio to design, fabricate, and test the calandria vault inspection and repair delivery system. The estimated cost of this capital project, including the design but not fabrication of repair end-effectors, is \$23.9 Million. The decision to proceed with the fabrication of repair end-effectors will be made after initial inspection results are available.

In 2005, \$350k was released to secure developmental proposals for the inspection and repair delivery system from vendors. Two vendors, MacDonald, Dettwiler and Associates (MDA) and Areva provided proposals, and a decision has been made to establish a fixed-price contract with MDA for the design and fabrication of the tooling.

2. Preparatory Timeline

A high-level timeline for Pickering A calandria vault inspection is provided in Appendix A, showing all elements of the program from tooling design through fabrication to ultimate use in the field.

Delivery of the complete remote inspection tooling is linked to the Fall 2008 planned outage on Unit 4, when the first comprehensive inspections are planned. In order to meet this schedule, it is necessary to initiate the design and fabrication of the delivery system at this time.

In parallel with the design of the delivery system, the design, fabrication and in-service testing of non-delivery system inspection equipment (inspection end-effectors, etc) will take place. During tool proving, inspection of selected Unit 2 calandria vault components (those which do not require the remote delivery system for access) will allow engineering staff to gauge the general condition of calandria vault components and assess the risk of failure. It is possible that unfavourable inspection results from Unit 2 could drive a decision to initiate the design and fabrication of vendor designed end effectors for repair of high risk piping.

If Unit 2 inspection results do not lead to initiation of the repair tooling development, this decision can be deferred until Unit 4 and Unit 1 are inspected with the new delivery system. The risk associated with the failure of carbon steel components in the calandria vault is primarily economic. As such, should components be found to be in a degraded condition







requiring repair, it is assumed that a case could be made to restart the unit following the inspection campaign and that fabrication of the repair end-effectors would proceed with the unit in operation. In the event that inspection results that do not permit restart of the unit, fabrication and testing of the repair tooling would be required on outage critical path.

Key decision points in the timeline include:

- Release of funding for inspection equipment design and fabrication (this request), which
 includes design of the remote delivery system, design and fabrication of inspection
 equipment and in-service testing of inspection equipment in Unit 2.
- Selection of a suitable vendor and contract award for remote delivery system design and fabrication. (MDA will be awarded a fixed-price contract upon approval of funding.)
- Decision to proceed with design and fabrication of repair end-effectors, based on
 preliminary inspection results from Unit 2 calandria vault. If design and fabrication of repair
 tooling does not proceed at this point, this decision will be repeated after Unit 1 and 4
 inspections.

3. Funding Requirements and Recommendation

The OPG Nuclear Business Plan for 2006 – 2010 includes a capital project entry of \$23.9 Million for development of calandría vault inspection tooling.

With fixed-price proposals now in-hand from two vendors, we have been able to confirm the cost projection of \$23.9 Million for design and fabrication of the remote delivery system and the inspection tooling. A detailed breakdown is provided in the attached Business Case Summary. It is recommended that approval be granted for full release of this project funding.

Depending on inspection results, future requests may be made to release project funding for repair end-effector design and fabrication.











Appendix A – Timeline for Pickering A Calandria Vault Inspection Project



ONTAR	IOPOW GENERAT	

Document Number: **Revision:** N-BCS-30673-10000

Page:

1 of 13

BUSINESS CASE SUMMARY -- OPG CONFIDENTIAL--

R00

CALANDRIA VAULT INSPECTION 13-46537

BUSINESS CASE SUMMARY FOR FULL RELEASE N-BCS-30673-10000-R00

1. RECOMMENDATION:

Full release of 23.9M\$ in Capital funding is recommended for implementation of the Calandria Vault Inspection (CVI) Project at Pickering A. This project will provide the capability to reach and deliver inspection and repair end effectors to all the specified calandria vault components. The inspection data acquired with this equipment will allow OPG to determine the condition of the Pickering A calandria vaults and assess the risk of future component failure.

Background

The Pickering A calandria vaults (CVs) have been exposed to moist corrosive environments since shortly after the reactors were placed in service. Corrosion has resulted in past leaks requiring repairs using remote tooling. Inspections were last performed in the mid 1990s, hence the current condition of the Pickering A Calandria vaults is uncertain. Reliability of the Calandria vault drying system which was placed in service in the early 1990s to mitigate against the moist corrosive environment has been inconsistent.

Previously, approximately \$660K was spent on Project scoping using funding from the Pickering A Return to Service budget. Subsequently, a developmental release of 350K\$ was issued to complete Phase 1 of the Project under Project #46552. The major deliverables for Phase 1 were two vendor conceptual proposals for the design and fabrication of a CV manipulator arm for inspection and repair of CV components.

Capital Project 46537 has been included in the OPG Nuclear project portfolio to develop calandria vault inspection capability. The strategy is to develop the tooling in time to carry out an inspection on Unit 2 (a laid-up Unit), then on Unit 4 in 2008. The expected capital cost of this project is 23.9M\$, consistent with the current approved Business Plan amount. The cost of executing the inspection campaigns in Units 1 and 4 will be separately funded (cost estimated to be 1.5M\$ for Unit 4 and 2.5M\$ for Unit 1). As well, any required development of repair end effectors, the need for which will not be known until the inspections are complete, is not within the scope of this project (cost to design, build and test repair tooling is estimated to range between 10-12M\$).

An NPV and IRR are not applicable; however an assessment has been done which shows that the cost of developing the inspection capability is far out-weighed by the risk-adjusted loss should a calandria vault component fail before the capability to deliver repair tooling is available.

Project 46537 Cash Flow for Recommended Alternative	2006	2007	2008	2009	2010	Total
Estimated Capital	8,132	12,759	2,982	-	-	23,873

* includes 350K\$ developmental release under Project #46552 to be capitalized under Project #46537

2. SIGNATURES

Bv: Date

Equipment Mar, Pickering A

Reviewed 1006-Martin Reid Date

Director Engineering, Pickening A

owed By: John Coleby

SVP Pickering A

Recommended By:

1.00.-> Pierre Charlebois Chief Nuclear Officer

<u>()</u> y 21/01. Øate

Finance Approval By:

Don Power

Date Director Investment and Business Planning

Line Approval per OAR Element 1.1.2: Date

ankinson resident and Chief Executive Officer







Document Number: N-BCS-30673-10000	Revision: R00	Page: 2 of 13
BUSIN	SS CASE SUMM	ARY
OP	G CONFIDENTIAL	

3. BACKGROUND & ISSUES

Background

The Pickering A calandria vaults (CVs) were originally designed to be vented to atmosphere through the station stack, but early in the life of the reactors these vents were sealed off to reduce station noble gas emissions. As a result, humidity levels within the stagnant vaults became high, which was worsened by chronic leakage from the biological shield cooling system within the vaults. The combination of high humidity, air and radiation created a nitric acid environment, resulting in substantial corrosion of carbon steel components within the calandría vault of each unit. The extent of this corrosion was such that, in the mid-1990s, the carbon steel ring thermal shield inlet and outlet lines had to be removed and replaced with stainless steel flexible hoses using remotely operated robotic equipment (the CV is an inaccessible room with high radiation fields that houses the reactor vessel and dump tank in the Pickering-A units - remote tooling is the only option for inspection and repair work in this area).

To minimize further corrosion in the Unit 1 and 4 calandria vaults, a project has been initiated to improve the reliability of the Calandria vault drying system by replacing the drying units. The new dryers are expected to be installed in the Spring of 2007. In addition, on-power leak sealant will be proactively added to the biological shield cooling system in the hope of minimizing minor leakage into the Calandria vault. These actions will not reduce the ingress of moisture into the CV from other paths.

For Units 1 and 4, OPG's Reactor Assembly Aging Management Plan has identified several components within the calandria vault for inspection. To complete these inspections, and to implement repairs should the need be identified, remote tooling must be developed to deliver inspection and repair end-effectors to the internal areas of the calandria vaults.

The need to inspect Units 1 and 4 is driven by:

- a) OPG's desire to re-assure itself that the Calandria Vault components are not in danger of imminent failure, thereby potentially resulting in serious process or structural failures in the Pickering A units.
- b) OPG's commitment to manage its nuclear fleet in a manner which enhances the confidence of employees, the public and regulatory authorities in the safety of its nuclear reactors.
- OPG's desire to make commercially sound decisions about future investments in Pickering A, c) – by assuring itself of the condition and life expectancy of all of the major components in the Units, prior to making significant on-going investments in other components (e.g. execution of boiler chemical cleaning and large scale feeder replacement).

Based on these priorities, the key decision to be made in this Business Case is not whether or not to invest in equipment which would facilitate the inspections (and potential repairs) of the Calandria Vault components in Pickering A, but how quickly should the capability be developed in light of the risks which may arise. The recommended Option attempts to balance the risk of not being ready to repair an unexpected failure in a Calandria Vault component with the potential costs of spending too much up-front to mitigate the risks, only to find that conditions are better (i.e. no need for repairs) or worse (i.e. irreparable flaws) than expected¹.

There are two reasons for initiating this project in time to allow inspections in the P841 outage. Firstly, there is a pressing need to understand the condition of Pickering A calandria vaults before significant expenditures are made on other large sustaining projects (execution of boiler chemical cleaning and large scale feeder replacement). Secondly, the lack of recent calandria vault condition information leaves OPG open to unexpected leaks and/or failures of CV components. Initiating the project as soon as possible will reduce the window of exposure where OPG does not have the ability to locate failures and initiate repairs activities.



Repairable failures include most cooling water lines. RTS segment vent lines, helium line anchors, shielding plate supports. Failure of an RTS bracket resulting in displacement of the RTS segment is considered irreparable.



TARIOPOWER	Document Númber:	Revision:	Page:		
	N-BCS-30673-10000	R00	3 of 13		
GENERATION	BUSINESS CASE SUMMARY OPG CONFIDENTIAL-				

Previously, approximately \$660K was spent from the Pickering A – Return to Service budget in 2005 on the project scoping. Subsequently, a developmental release of 350K\$ was issued to secure concept proposals for the inspection and repair delivery system from Areva and MacDonald, Dettwiler and Associates (MDA). These proposals have been received and evaluated by the project team.

4. ALTERNATIVES AND ECONOMIC ANALYSIS

Base Case: Do Nothing - Not recommended

The Do Nothing option makes no attempt to prepare for the possibility of catastrophic component failure in the calandria vault. As such, the risk is that a catastrophic failure² of a critical component forces the unit down with essentially no forewarning. The resulting impact is an outage of approximately 20 months for a repairable failure or permanent shutdown for an irreparable failure.

In the event of a biological shield cooling line leak that is within the operating limits but not sealable with on-power leak sealant, the unit would continue to be operated until the leak exceeds operating limits. This would result in an increase in calandria vault dewpoint and would increase the corrosion rate of carbon steel components in the vault if the dewpoint exceeds the critical value, thus increasing the probability of subsequent catastrophic failures².

The 'do nothing' option subjects OPG to ongoing uncertainty in assessing the probability of Calandria vault component failures between now and the planned end of life for Units 1 and 4 (early to mid-2020s).

There is regulatory risk associated with the "do nothing" option as the CNSC has expressed an interest in the state of the Pickering A Calandria Vaults. While the overall risk to the public is judged to be acceptably low, certain failures could result in a serious process failure and the probability of serious process failures must be kept acceptably low as part of our licensing requirements. For example, failure of certain RTS brackets could lead to an RTS segment falling on moderator system piping inside the calandria vault resulting in a loss of moderator inventory accident.

There is reputational risk associated with the "do nothing" option. Should a CV component fail requiring a protracted outage to repair there could be negative public perceptions of OPG ability to manage the nuclear fleet, especially in light of the recent large expenditure in returning Pickering Units 1 and 4 to service.

Engineering has estimated that the probability of failure is likely to remain above 20% over the balance of plant life. If a failure were to occur in one unit, this would indicate that the CV conditions are such that the probability of a failure on the other unit is also high. In order to estimate the financial consequences of failure, it was assumed that there is a 20% probability of a failure resulting in a 20 month outage while the inspection and repair tooling is designed, fabricated, tested and crews are trained and deployed for inspection and repair activities. The cost of this initial failure is the lost revenue over 20 months plus the escalated cost of the inspection tooling being developed for this project (23.9M\$ estimated price of the project plus a 30% premium for fast tracking escalated by CPI). It is then assumed that there is an 80% probability of a failure on the other unit one year later which would require a 4 month inspection/repair outage (shorter duration attributed to availability of tooling and trained staff).


The cost of repair tooling is not included in the consequence of a future failure because the cost will be roughly the same and will be incurred in roughly the same timeframe, either shortly after a failure in the do nothing case, or in the preceding period in the case where the CVI project is pursued and the inspection capability allows planning for pre-emptive repair.

Performing the initial inspection and repair does not reduce the probability of future failures to zero. For earlier failures, the probability of a subsequent failure on the same unit will be higher as the





² Catastrophic failure defined as a failure that requires immediate shutdown of the unit. The failure itself may be repairable or irreparable (see Footnote 1 on previous page).



window of exposure is larger. In order to avoid further complicating this financial evaluation which already contains a relatively large number of assumptions, the financial evaluation conservatively does not take into account the impacts of subsequent failures on the same unit.

The financial evaluation compares the Net Present Cost of the risk of a future failure in a given year (calculated by multiplying the cost of the failure times the probability of failure) to the Net Present Cost of developing the inspection capability. The Do Nothing option would be considered only if the Net Present Cost of the failure is lower than the Net Present Cost of the CVI project. Table 1 shows that the Net Present Cost of the Do Nothing option exceeds the Net Present Cost of failures in Years 2008 and 2014³. The Net Present Cost of failure declines with time, because of discounting; however, the analysis showed that it remained higher than the Net present Cost of the CVI project throughout the life of the Units. However, near the end of life of the units, should there be a major failure, OPG would be unlikely to invest in major tooling to fix the failure unless there was a strong financial case to be made, hence the Net Present cost of the failure is shown only until 2014.

	2008	2014
NP Cost of CVI Project (2006\$ PV)	\$17.8 M	\$17.8
NP Cost of Failure (2006\$ PV)	\$44.2 M	\$32.6 M
Difference	\$26.4 M	\$14.8 M

Table 1: Net Present Cost of Calandria Vault Component Failure compared to CVI Project

This table shows that, should OPG develop the calandria vault inspection tooling and be ready to repair a failure, OPG would be approx \$26 Million ahead should the failure occur in 2008 or \$15 Million ahead, should the failure occur in 2014.

The sensitivity of this analysis to critical parameters is discussed in Section 6.

Alternative 1: Full Project Release –Recommended

In this preferred alternative, the inspection tooling is designed, fabricated and tested in time to carry out the full inspection scope in the P841 and P911 outages. With this alternative, a remote manipulator will be developed to reach all required inspection locations in the calandria vault, including the previously inaccessible North side. The deliverables for this alternative include:

- 2 CV manipulator arms,
- ultrasonic and video inspection end effectors for the CV manipulator arm,
- mock-ups for tool testing, and training,
- horizontal and vertical video on extension booms to provide overview visuals of the CV internals and for field of view cameras during CV manipulator arm operations,
- A robotic vehicle and associated video and ultrasonic inspection end effectors,
- Site preparations for unit inspections,
- Field testing of all inspection equipment in Unit 2,
- Training and procedures,
- Project management and engineering,

All inspection equipment will be tested in mockups and then field tested in Unit 2 prior to deployment in Units 1 and 4. The field testing of non arm based inspection equipment in Unit 2 will take place in early to mid 2007. This will provide Engineering with some general information on the condition of the Pickering A calandria vaults. The most likely outcome is that conditions will be similar to those observed in the mid-1990s, reaffirming the need for detailed inspections of the



³ Note that all costs are presented in net present values and have been adjusted for tax implications of lost revenues or capital expenditures.





ONTARIOPOWER	Document Number:	Revision:	Page:		
	N-BCS-30673-10000	R00	5 of 13		
GENERATION	BUSINESS CASE SUMMARY - OPG CONFIDENTIAL				

calandria vault components. All 4 possible outcomes to these Unit 2 field trials are described in Table 2.

The decision regarding the need to proactively develop repair tooling will be made following the Unit 2 field trials of non-arm based inspection tooling. The estimated cost for design, build and testing of repair end effectors for the most likely failure modes is 10 to 12M\$.

In this proposal, two CV manipulator arms are being purchased, one for field use and the second for training of inspection staff. This second arm will also be used to test inspection and repair end effectors and will be available as a spare in the event of a significant failure of the first arm. Finally, the staggered delivery of the arms may allow sufficient time to make modifications to the second arm at the manufacturer's facility in the event that problems are uncovered during commissioning of the first arm.

The cost for conducting the inspection campaigns on Units 1 and 4 will be covered by Outage OM&A and is estimated to be 1.5M\$ for P841 and 2.5M\$ for P911 (part of the P841 training cost covered by the project to provide initial training to IMS execution personnel).

As discussed in the do-nothing option, the 20%+ probability of future repairable catastrophic failure and the resulting financial consequences make the project viable for all failures out to near the end of unit life.









Document Number:	Revision:
N-BCS-30673-10000	R00

Page:

BUSINESS CASE SUMMARY

6 of 13

- OPG CONFIDENTIAL-

Table 2

Possible Outcomes of Non Arm Based Inspections in Unit 2

Potential Unit 2 inspection results	OPG response	Probability
Calandria vault conditions much better than expected	Decision not to proceed with the CVI project	Extremely low Calandria vault conditions were poor in the mid-1990s and they will not have improved in the intervening period of time.
Calandria vault conditions much worse than expected. Irreparable failure is likely and/or scope of observed damage puts into question ability to operate the unit reliably until the planned end of unit life	Decision not to proceed with the CVI project. Large sustaining expenditures on Pickering A units 1 and/or 4 would be reconsidered to take into account the potential that the calandria vauit structures may limit the lives of the units.	Low. The non-arm based inspections will provide only limited information on the calandria vault conditions: - only general visual information will be required from stand off cameras - only limited pipe wall thickness measurements possible - difficult to estimate degradation rate due to limited previous inspection data, The CV manipulator arm is required to obtain information on the condition of RTS brackets, which represents the biggest concern to future operation of the unit
Calandria vault conditions reveal minor localized leaks or wall thickness measurements significantly below those obtained in the 1990s, indicating continued progression of corrosion despite the operation of the calandria vault dryers and imminent component failure requiring unit shutdown (i.e. catastrophic repairable failure).	Proceed with CVI project. Initiate design/build/test of ' repair end effectors (as a separate project or a superseding BCS for this project)	Medium - Low
Calandria inspection conditions similar to that observed in the mid 1990's	Proceed with CVI project. Assess need for proactive development of repair end effectors.	Medium - High







NTARIOPOWER	Document Number: N-BCS-30673-10000	Revision: R0
GENERATION		SS CASE

ASE SUMMARY NFIDENTIAL-

R00

Alternative 2: Design Only of the CV Manipulator Arm and Inspect Unit 2 with Non-Arm Equipment - Not Recommended

In this alternative, the design of the CV manipulator arm would be completed but the decision on fabrication would not take place until the Unit 2 inspection results are evaluated.

In order to meet the current P841 outage, the CV manipulator arm design must be completed in December 2006, fabrication must begin immediately thereafter and long lead materials must be ordered and received by the vendor in January 2007. The Unit 2 inspections are scheduled to take place between January and April of 2007. A decision to limit spending to the design of the CV manipulator arm would have several significant negative consequences on the project:

- The delay of up to 5 months would increase the cost of the arm and the project, and would likely result in the loss of key members of the vendor project team,
- The delivery of the CV arm would be delayed by at least 5 months, depending on the delivery times for critical path long lead items,
- The arm would not be ready for a Spring P841 outage, and in fact would be at significant risk for a Fall P841 outage.
- Delaying the front end of the project reduces the time available for critical training and field trials in Unit 2 prior to performing the Unit 1 and 4 inspections.

The perceived benefit of this option is that it would limit OPG expenditures until some Unit 2 inspection results are available to provide some indication of the current conditions in the Pickering A Calandria vaults. As discussed in the previous alternative and presented in Table 2, the likelihood that the Unit 2 inspections will suggest that no further inspections are required in Units 1 and 4 is considered to be very low. Inspection is the only means by which the current state of degradation in Units 1 and 4 can be determined with any degree of confidence.

In light of the very high probability that the CV manipulator arm will be required and the detrimental impacts of this option on the delivery schedule for the CV manipulator arm, this option is not recommended.

Alternative 3: Design Only of Inspection and Repair Equipment (No Fabrication) - Not Recommended

This option involves the design of the CV manipulator arm and all other inspection equipment. Since there would be no Unit 2 inspection in this option, the decision would be made upfront to proactively design repair end effectors for repairable components deemed to be most at risk of failure. Actual fabrication and deployment of the equipment would be deferred until the first catastrophic failure (i.e. failure requiring a unit shutdown). The perceived benefits of this option are to:

- defer the cost of fabrication, inspections and repairs to the future, and
- reduce the duration of a repair outage by approximately 5 months (assuming that the failure is repairable with one of the pre-designed end effectors).

The cost of this option is estimated to be in the order of 8M\$ (2006 dollars) and the project would not result in the acquisition of a fixed asset. The design would provide a financial benefit to OPG if it were to reduce the duration of a future repair outage. In reality there are several factors that could affect the value of this "design asset":

- the design would likely be considered obsolete within 5-8 years,
- the length of time required for procurement of long lead items and fabrication of the CV manipulator arm would be longer than in Alternative 1 because of the lack of continuity of the vendor project team members,
- the cost of fabrication would likely be significantly higher than in Alternative 1
- Fabrication of inspection equipment would be required before the actual failure could be located,
- The failure could be to a component for which a repair end effector had not been predesigned,







NTARIOPOWER	Document Number:	Revision:	Page:
	N-BCS-30673-10600	R00	8 of 13
GENERATION	BUSINE	SS CASE SUMM/ S CONFIDENTIAL	

- The actual time savings would be reduced by the time required place a PO for the fabrication of the inspection and repair equipment,
- The vendor could become unavailable to fabricate the designed equipment due to insolvency or unavailability of resources,
- The critical phase of assembly, testing and troubleshooting would not have taken place in the design phase.

This option would not allow small non-catastrophic leaks to be detected and repaired in a planned way to minimize the ongoing degradation of CV components. In the absence of inspection information, it is quite possible that the first indication of a significant leak could occur after significant degradation has taken place in the calandria vault, at which point the need for repair could be widespread, thus increasing the duration of a repair outage.

This option subjects OPG to ongoing uncertainty in assessing the probability of Calandria vault component failures between now and the planned end of life.

There is regulatory risk associated with this option as the CNSC has expressed an interest in the state of the Pickering A Calandria Vaults. While the overall risk to the public is judged to be acceptably low, certain failures could result in a serious process failure and the probability of serious process failures must be kept acceptably low as part of our licensing requirements.

This option is not recommended as it does not provide OPG with a tangible asset nor does it provide any information on the condition of the calandria vaults and the probability of future failures resulting in protracted outage(s).

Alternatives considered but rejected

Use of old manipulator arm with new inspection end effectors

- The old arm was unable to access many components on the South side of the calandria vault, and none of the components on the North side
- Control of old arm was very coarse. While it was used out of necessity when repairs to the RTS inlet and outlet lines were required to return the units to service, the risk of damage to components during inspection activities is deemed to be far too great.
- The dexterity of the manipulator was very limited

5. THE PROPOSAL

It is recommended that OPG proceed with Alternative 1, Full Release of funding for the CVI project. With this alternative, a remote manipulator will be developed to reach all required inspection locations in the calandria vault, including the previously inaccessible North side. The deliverables for this alternative include:

- 2 CV manipulator arms,
- ultrasonic and video inspection end effectors for the CV manipulator arm,
- mock-ups for tool testing, and training,
- horizontal and vertical video on extension booms to provide overview visuals of the CV internals and for field of view cameras during CV manipulator arm operations,
- A robotic vehicle and associated video and ultrasonic inspection end effectors,
- Site preparations for the unit inspections,
- Field testing of all inspection equipment in Unit 2,
- Training and procedures,
- Project management and engineering







ONTA	RIO	ŶÛ	t?
			TION

Document Number:	Revision:	Page:
N-BCS-30673-10000	R00	9 of
BUSINE	SS CASE SUMN	IARY

13

- OPG CONFIDENTIAL-

6. QUALITATIVE FACTORS

Proceeding with the recommended option will allow OPG to proceed expeditiously with the development of inspection capability for Pickering A Calandria vault to address the risk of potential failures of Calandria vault structures. Notwithstanding the significant cost ramifications of such a failure, there would be significant negative consequences on OPG's public image in the event of a significant failure.

Expeditious development of non-arm based inspection capability in parallel with development of the arm will provide management with some urgently needed information on the general condition of the calandria vaults. This information would allow OPG to better understand the risk of premature shutdown of the Pickering A units and the potential impacts on other large Pickering A sustaining projects.

OPG has other evolving inspection needs which may be able to use some of the robotic equipment developed for CVI. Feeder and Calandria vessel inspections at Pickering and Darlington are the most obvious examples.





7. RISKS

Risk calegory	Description of Risk	Description of Consequence	Rek Betore	Miligrating Activity	Rick After
Cost	Cost of project significantly higher than \$23.9M.	Need to obtain further capital funding to complete project	Medium	Estimates generated by project team members with extensive experience. Fixed price contract for CV manipulator arm.	Low
ğ	Vendor not able to obtain SR&ED*lax credit which was assumed in proposal pricing (due to OPG tax status, or other limitation) "Scientific Research and Experimental Development	Vendor price for manipulator arm would increase by SR&ED tax credit assumed in proposal. If OPG is eligible to obtain the SR&ED tax credit but unable to transfer it to the vendor, it would be applied at the corporate level and would not be transferred down to the project. As such, the required funding to the project would have to be increased by this amount although the net cost to the corporation would be zero.	Medium	Obtaining clarification from OPG tax specialist.	Low
Scope	Deliverables not clearly defined	Additional schedule and cost pressures	Medium	Prepare delailed design requirement documents for major deliverables and include key stakeholders in reviews.	Low
Scope	Manipulator arm may cause loads on south accessible area structural steelwork that exceeds limits	Modifications could be required to south accessible steelwork	Medium	Vendor to provide manipulator arm loads at preliminary design review to allow station civil engineering to assess load capability of existing steetwork and identify any required modifications in advance of the P841 outage. Any such modifications are not within the current scope of the project.	Med-Low
Schedula	CV manipulator arm not ready for P841 Spring outage	Unable to properly assess probability of failure in Unit 4 RTS bracket and hairpins until 2010	High	Fixed price and schedule contract with vendor. Potential to move Unit 4 Spring 2008 outage to Fall 2008. Thorough review of requirements, constraints and risks with vendor upon awarding of contract.	Medium

|--|

Page: 11 of 13 BUSINESS CASE SUMMARY -- OPG CONFIDENTIAL--

Risk category	Risk category Description of Risk	Description of Consequence	Risk Before	Mitigating Activity	Risk Atter
Schedule	Outage extension as a result of CV inspection	If the duration of the inspection window extends beyond the available	Medium	Will demonstrate feasibility of assumed durations in mockup training and Unit 2 field trials.	Med/Low
	9	roat, we outage could be extended, resulting in significant lost revenues to the station.		Second arm will be available as a contingency in the event of failure of the first arm.	
				Sequence of inspection targets will be optimized to ensure highest value data is acquired as early as possible in the inspection window.	
Schedule	Vendor labour disruption	Vendor schedule delay resulting in delayed delivery to OPG. The marginal float in the schedule means that this would likely result in an inability to meet the P841 outage.	Medium	Vendor is currently in a labour disruption with the engineering union at its Brampton facility. It is anticipated that resolution of this disruption should result in a 3 year collective agreement which will bracket the CVI arm contract with the vendor.	Med-Low
Resources	Limited availability of key IMS personel for development of inspection end effectors.	Delay in completion of P2 field trials and threat to ability to complete P841 inspections	Medium	Assign top priority to CVI project for critical IMS technical staff.	Fow
Technical	Inspection equipment unable to provide required results due to CV conditions	Inadequate inspection information reduces confidence in ability to operate Pickering A units to end of design life	Med-High	Mock-ups will be prepared to attempt to simulate actual conditions including corrosion and required surface preparation	Med-Low
Technical	Inspection equipment fails to meet design specifications during Unit 2 field trials	Deficiencies identified at this late stage will put the Unit 4 inspection at risk due to the very short period of time available to take corrective actions.	Med-Low	The arm will be extensively tested in a full scale mock-up prior to acceptance from the vendor. Design deficiencies are expected to be identified at this point. The arm will then be used for training in the same representative mockup. Problems with equipment reliability are expected to be identified at this point. Disassembly and assembly of the arm for transportation between inspection points during training will demonstrate the capability of the inspection crews, the quality of the procedures and the robustness of the arm.	ΓoΨ

1	tion All is at Mirror and	t	1		-
A A A		N-BCS-306/3-10000 R0	10 Lage	12 of 13)
	GENERATION	BUSINESS CASE SUMMARY OPG CONFIDENTIAL	E SUMMARY IDENTIAL		
Rist: category	Description of Risk	Description of Consequence	Risk Betom	wrighting Activity	Risk After
Technicat	Repair end effectors are not going to be built by the arm manufacturer	There is the possibility of interface problems between the arm and end effector manufacturers.		The design requirement for the manipulator arm specifies the need for services for potential repair end effectors. Dexterity at the end of the manipulator arm should be maximized to allow greater simplicity in the repair end	Med-Low
				The manufacturer for repair end effectors will be provided with the necessary interface information during their design process.	
				The project will request that prototype tooling be developed and tested in the mockups prior to finalizing the design.	
				Integration testing will be performed in the full scale mockup prior to field trials in Unit 2 and deployment in Unit 4.	
Regulatory	CNSC could request additional inspections	Additional schedule and cost pressures	Low	Inspection scope basis is sound and well documented in the appropriate engineering documents.	Low
Environmental		No significa	ant environmental risks	No significant environmental risks associated with this project	· · · · · · · · · · · · · · · · · · ·
Health & Safety	Certain Calandria vault failures could result in operational transients	Damage to station structures and/or components. Significant outage and project costs to	or Low	Past inspection results and analysis have concluded that the risk is low. Proceeding expeditiously with full scope of inspection will further reduce this risk.	Low
Health & Safety	Unit 2 CV inspections will be scheduled in parallel with Unit 2 Safe Storage work	locate and repair Unique hazards may exist during specific activities such as defuelling or dewatering of Unit 2.	g or	The CVI project work will be scheduled and assessed by the Safe Storage organization, thus ensuring proper precautions are built into the execution work packages.	Low
Investment	Project is cancelled after Unit 2 field trials	Costs incurred up to that point (up to 12.7MS) may need to be written off to OM&A	to Low	Engineering judgement is that results from Unit 2 trials are very unlikely to result in cancellation of inspections in Units 1 and 4	Low
Investment	Vendor bankruptcy during design of CV manipulator arm	Recovery of design information from bankrupt company will be of limited value and would be complicated by Intellectual Property issues. May need to return to competing vendor likely at higher cost.	m d Y r	Supply chain will confirm financial viability of the winning vendor during commercial review of proposals.	Low

ONTARIOPOWER	Document Number: N-BCS-30673-10000	Revision: R00	Page: 13 of 13
GENERATION		ESS CASE SUM G CONFIDENTI	
	· · ·		

7.0 RISKS (continued)

The information presented in this BCS is most sensitive to the following parameters:

Duration of Forced Outage. The base financial analysis was performed using a 20 month outage duration from failure to return to full power. This span of duration is a best guess estimate. From the time of failure, video inspection capability would have to be developed to locate the failure and determine its repairability and the extent of condition. From that point, repair tooling would need to be designed and constructed, and site modifications and training would have to take place prior to execution of the repairs in situ. Repairs may need to be performed to many components to maximize the reliability of unit operation going forward. A sensitivity case was run assuming an outage duration of 14 months instead of 20 months. This represents a 30% decrease in lost revenue and therefore has a significant impact on the risk adjusted NPV of a future failure. Despite the significant decrease in lost revenue, the project continues to be economically justifiable for postulated failures out to near the end of lives of the Pickering A units.

Probability of Failure. The financial analysis was performed using a constant 20% probability of failure. As a sensitivity case, the probability can be assumed to vary with time, starting at 10% in 2008 and increasing to 30% to end of life. With a 10% probability of a 2008 failure, the Net Present Cost of failure is higher than the Net present Cost of the CVI project. Even if the probability were only to increase to 11% by 2014, the Net Present Cost of failure for a 2014 failure would still remain higher than the Net Present Cost of the project. The Net Present Cost of failure is higher than the base case for any failure beyond in 2015 as the probability of failure continues to increase to 30% at station end of life.

The probability of failure does not go to zero after an initial failure and subsequent repair outage. The conditions that resulted in the initial failure will continue to exist and degrade unrepaired components. The financial evaluation in this BCS conservatively does not consider repeated forced outages or outage extensions as a result of ongoing failures.

Timing of a Failure. The cost benefit of this project depends largely on the assumed timing of a postulated calandria vault component failure. Failures near the end of life naturally present less and less of a financial risk to OPG, not taking into account the potential for life extension of Pickering A units.

Electricity prices. The cost implication of a future failure is significantly affected by the assumed price of electricity. The current price of electricity is simply escalated by the CPI rate. However, should electricity prices prove to be higher, the financial case for the recommended alternative becomes stronger.


8. PIR PLAN

A comprehensive PIR will be conducted within 6 months of the Unit 2 field trial of the manipulator arm. The PIR will focus on:

- Ability of manipulator arm to access all required locations within the calandria vault
- Ability of inspection equipment to demonstrate compliance with established acceptance criteria
- Adherence to project budget and schedule as measured by project CPI and SPI.







Appendix A

 Table A.1 Sensitivity to Lower Outage Duration (14 months first unit & 3 months 2rd Unit)

	2008	2014
NP Cost of CVI Project (2006\$ PV)	\$17.8 M	\$17.8
NP Cost of Failure (2006\$ PV)	\$33.6 M	\$24.3 M
Difference	\$15.8 M	\$6.5 M

Sensitivity to Probability of Failure

The probability of failure is impossible to quantify precisely. The limited inspections completed in the mid 1990s indicate that significant corrosion had occurred and attempts to quantify the wall loss in carbon steel piping provided marginally credible results. No additional Non Destructive Examination (NDE) has been completed since this time, therefore the current state of Calandria vault components is unknown and corrosion rates and possible progression of stress corrosion cracking cannot be quantified. If the environmental conditions in the vault had remained at pre-1990's levels the probability of such a failure prior to end of life would be 100%, i.e. severe leakage was observed in all the units in the early 90's and in Unit 3 as late as 1997. The beneficial effect of installing driers in the units in 1992 and the future improvements when additional driers are installed in 2007 will reduce the probability of future failures significantly. However, an improvement greater than 80% is deemed to be unlikely, i.e. the residual failure risk after improving the drier system is judged to be unlikely to be below 20%, as such the base case was done with a 20% probability.

A sensitivity case was done with an increasing probability from 10% in 2008 to 30% at near end of plant life. The results are shown below in Table A.2. A probability of 11% is used in 2014 for illustration purposes to demonstrate that only a slight increase in probability is required to keep the project viable. In reality, a linear increase would make the 2014 probability closer to 20% which would make the case very similar to the base case (a net benefit to OPG of \$14.9M). With a 30% probability of failure in 2018, the Net Present Cost of a failure is significantly larger than the Net Present Cost of the CVI project.

	2008	2014	2018
NP Cost of CVI Project (2006\$ PV)	\$17.8 M	\$17.8 M	\$17.8 M
Assumed probability of failure	10%	11%	30%
NP Cost of Failure (2006\$ PV)	\$22.1 M	\$17.9 M	\$32.1 M
Difference	\$4.3 M	\$0.1 M	\$14.3 M





Project Engineer

cument Number:	Revision:	Page:
BCS-30673-10000	ROO	A2 of 6
BUSIN	SS CASE SUM	MARY

- OPG CONFIDENTIAL-

Appendix B

Table B-1: Project Summary of Estimate

ONTARIOP	ALRS IN DRUG	P	ROJECT		Date	29 Jur	ne 2006
G	ENERAT	ION S	ummary of E	stimate	Project #	13-46	537
Facility	Name		Pickering A				
Project			Calandria Vault Ir	spection			
Years (k	\$ 1		2006	2007	2008	TOTAL	%
Project N		ement				and the second second	
Engineer							
Permane		terials		· · · · · · · · · · · · · · · · · · ·			
2 Mani	ipulato	or Arms	17				
		nd Effectors					
Non A	rm Eq	uipment					
Other							
TOTAI	L Perr	nanent Mater	als				
Augmen	ted St	aff			-		
Testing/0	Comr	nissioning		19 19 19 19 19 19 19 19 19 19 19 19 19 1			
Expense	S						-
Training							
Interest							
Continge	ency						Control Or
TOTAL			8,132	12,759	2,982	23,873	
Notes:	1	Schedule	Start date:			June 2006	
			In-service dates			Feb 2008	
			(include % for p				
	2		Escalation rates				
	_		es provided by Co	rporate Fin	ance	-	
	3		noval Costs of:	<i>.</i>	-	0	
	4	Includes Def	inition Phase Cost	s of:	~	350	
Prepare	d by:			Appro	ved by:		

Table B-2: Comparison of Estimated Cost Versus Approved Business Plan

Project Manager

Project 46537 Cash Flow for Recommended Alternative	2006	2007	2008	Total
Estimated Capital	8,132	12,759	2,982	23,873
Approved Business Plan (2006-2010)	8.057	12,734	3.083	23,874
Variance Over Plan	75	25	(101)	(1)

	ONTARIOPOWER	Document Number: N-BCS-30673-10000	Revision: R00	Page: A3 of 6
9	GENERATION		ESS CASE SUN PG CONFIDENT	


Appendix C

Project Efforts to Limited Committed Costs Before Unit 2 Inspections are Complete

There is a small probability that the Unit 2 inspections could result in a decision not to proceed with the CVI project. As such it is prudent to limit the amount of money that OPG is committing prior to obtaining some inspection data on calandria vault conditions. OPG's standard contract wording allows cancellation for convenience at any point at OPG's discretion.

To limit OPG's committed costs before the Unit 2 inspections are complete, Supply Chain will negotiate down the front end loading of vendor proposed payment schedule. The project will also give priority to early development of non-arm inspection equipment that will provide the most meaningful information on CV conditions to allow a decision to be made as early as possible.

The attached Figure D-1 shows the logic for the Alternative 1 (recommended) and the forecast of committed funds at monthly intervals. The expected committed amount at the end of the Unit 2 inspections is 12.6M\$.







Document Number: Revision: N-BC3-30673-10800 R00

Page: A5 of 6

BUSINESS CASE SUMMARY - OPG CONFIDENTIAL-

Appendix D

Key Project Milestones

TCD	Description
May 2006	Winning bid selected - COMPLETE
July 2006	PO issued to vendor
December 2006	Final Design of Manipulator arm complete
January - April 2007	Field trial of non-arm inspection equipment in Unit 2
September 2007	Delivery of first CV manipulator Arm
November 2007	Delivery of second CV manipulator Arm
February 2008	Field trial of CV manipulator Arm in Unit 2 and in-service declaration
March 2008	Inspection of Unit 4 (inspection costs not in the project)
September 2009	Inspection of Unit 1 (inspection costs not in the project)





ONTARIOPOWER GENERATION

OPG Confidential

Page: 1 of 17

BUSINESS CASE SUMMARY

DNGS Construction Change Room 16 - 31718

Full Release (Phase 1) Business Case Summary D-BCS-28200-10004-R000

Routing	Location	Action	Signature	Date
Joe Walshe Mod Team Leader, Design Projects 701-3661	P72-3	Prepare BCS	RAQU	- Jan 21/0
lan Fung PL, Design Projects 701-3866	P72-3	Review BCS	The Frency	Jan 2108
Stephanie Tham Section Manager, Design Projects 701-4203	P72-3	Review BCS		Tau 21/08
Dianne Gaine Manager, Design Projects 701-4181	P72-1	Review BCS	Ciner His	Jen 2008
Mark Arnone Director, Projects & Modifications 701-6063	P72-1	Review BCS	De e	5 FEB 2408
Axel Kleer Business Planning & Strategic Support 400-7720	TCHH7-A5	Review BCS	Millees	14F.bus.
James Whyte tanager, Maintenance Production 03-7505	D01-A2	Review BCS	J-22k	11 Forthe Zoog
Stu Seedhouse Director, Operations & Maintenance 703-7496	D01-OSB2	Review BCS	SSuch	12 feb 2000
Wayne Robbins Site VP, Darlington 703-7499	D08-ES3	Submit BCS	SEech for	12 fe la 2009
Randy Leavitt Director, Nuclear Investment Management 702-5085	P823-315	Approve BCS	Falanit	Ful 25, 2008
Jim Beech VP, Nuclear Finance 400-7226	TCH07E19	Approve BCS	120	1-1-2
Tom Mitchell Chiëf Nuclear Officer	P826A-1	Approve BCS	Muhled	3 Manos
Don Power, VP Corporate Investment Planning	TCH07D06	Approve BCS	Hover	Man 18/08
Pierre Charlebois Chief Operating Officer	TCH19A21	Approve BCS	the second	Man 18/08
Ball Senior Financial Analyst 702-4084	P82-3B6	Return For Distribution		

OPG Confidential

Page: 2 of 17

BUSINESS CASE SUMMARY

DNGS Construction Change Room 16 - 31718

Full Release (Phase 1) Business Case Summary D-BCS-28200-10004-R000

1/ RECOMMENDATION:

ONTARIOPOWER

Approval is requested for this Full Release of a total \$13,304 K Capital, (including contingency) to complete both the construction of a new "mobile" Construction Change Room (CCR) c/w Lunchroom facility and the de-engineering of the removal of the old CCR. The new CCR is to be constructed in time to support the 2009 Vacuum building outage (VBO) at Darlington. The timeline for the new CCR is extremely tight and full station and vendor support will be required to complete this project on time.

The objective of this project is to decommission and remove the existing CCR and construct a new CCR for DNGS maintenance and contract staff to provide a safe and effective work environment. The new CCR will have an increased capacity over the previous change room, which will relieve overcrowding and congestion, improving current health and safety inefficiencies.

A construction estimate based on a substantially completed design package is used as the basis for this cost estimate. This is used in lieu of a third party Helyar estimate due to the time constraints involved.

This Full release (phase 1) will cover:

- Issuance of a Request for Proposal (RFP) for a construction contract for the proposed new CCR.
- Issuance of a construction PO for buried service relocation & construction of the new CCR
- OPG support of construction of the new CCR
- Partial AFS of new CCR prior to 2009 VBO. Construction of the building will be complete enough that it will be used in support of the 2009 VBO
- Final AFS of the new CCR following the VBO and outage D931 to ensure completion of Engineering Change Control
 process, and full station turn-over
- The issuance of a Full release phase 2 BCS to support the demolition of the old CCR
- A Constructor's estimate for the demolition of the old CCR to support the full release phase 2 BCS

The Full Release Phase 2 BCS in Q1 2009 will incorporate the removal and decommissioning of the existing CCR.

This project will be executed in several phases between 2007 and 2009:

- 2007/2008 Detailed Design has been completed
- 2008/2009 Construction of new CCR and turnover to OPG
- 2009 Removal and decommissioning of existing CCR

The timeline for the completion of the new change room is extremely tight. Full station management support, including relaxation of certain activities milestones in station work processes is required to adhere to the schedule as planned. Approval has been obtained from the Director of Operations & Maintenance for the project to be exempt from Integrated Online Work Scheduling per N-PROC-MA-0022. However, it is the intent of the project to follow N-PROC-MA-0022 to the extent possible.

Furthermore, due to the risks associated with this accelerated implementation schedule, it is recommended that a station contingency plan be available for the 2009 VBO to mitigate contractor change facility needs should this project be delayed.





ONTARIOPOWER GENERATION

	Contraction of the second s
OPG Confidential	Page: 3 of 17

BUSINESS CASE SUMMARY

\$000's (incl contingency)	Funding	LTD 2007	2008	2009			.	Late	n Total
Currently Released	Developmental	1,204	426						1,630
Requested Now	Full - Phase 1	(693)	11,685	2,312					13,304
Future Funding Req'd	Full - Phase 2	,		1,086					1,086
Total Project Costs		511	12,111	3,398	•	•	•	• • • • • • • • • • • •	- 16,020
Other Costs									•
Ongoing Costs							~~~····	···· ••···	*
Grand Total		511	12,111	3,398	-	•	-	• • • • • • • •	6,020
Investment	Туре	Clas		(IEV) Impact of	Ec Yaka		RR	Disc	ounted Payback
Value Enhar	ncing	Capi			1	11	3.		NA

22 feb 2008 Date:

/8/08 /Date:

Ma.

Submitted By:

5See

Wayne Robbins Site VP, Darlington

Finance Approval:

Donald Power

Director, Investment & Business Planning

VP-Corporate Investment Planning

Line Approval (Per OAR Element 1.1 Project in Budget);

A Pierre Charlebois

Chief Operating Officer

9 Jun 19 108 Date:

ONTARIOPOWER GENERATION

OPG Confidential

Page: 4 of 17

BUSINESS CASE SUMMARY

2/ BACKGROUND & ISSUES

internets.

The existing CCR was installed in the early 1990's and is nearing its end of useful life nominally rated at a maximum of 20 years for a mobile type building design. This facility was not designed for its current capacity and hence is congested and inefficient when utilized at or near capacity during outages and major projects. The Design Agency that performed the Conceptual Study for the new Maintenance Facility and new CCR had recommended that a new change room be constructed instead of relocating or refurbishing the existing CCR due to doubt that the existing CCR could survive relocation.

Due to changing work force demographics since DNGS was first built, many of the permanent staff and contractors hired for project and outage work are more regularly women. The current CCR does not have sufficient women's change room facilities. There are insufficient lunchroom facilities to accommodate the required contractor staff to support station activities such as major outages or large projects. The proposed new CCR will be approximately 19,000 sq. ft. and as per the project charter (D-PCH-28200-10002) developed by Darlington Maintenance, the capacity is required to increase from the old CCR as follows:

- Women's change room from 24 to 150 personnel
- Men's change room from 450 to 500 personnel
- Lunchroom from 125 to 225 personnel fixed seating capacity

The expected occupancy level of the new CCR is 100 – 150 people during low periods, and 350 – 500 people during peak (unit outage) periods. The timeline for peak periods is about one month prior to an outage to the end of the outage, based on a 3 month planned outage. These capacity estimates were provided by the DNGS Contract Management Office (CMO) and are based upon the current occupancy of the existing CCR and the current outage schedule at Darlington.

A Design Agency, Acres Sargent & Lundy (ASL) was commissioned to perform a conceptual study on the project. ASL provided one conceptual layout and three cost estimates for the different construction methods selected to provide a permanent CCR in the most cost effective and expeditious manner to meet our tight timeline. The construction options provided by ASL are "Modular", "Relocatable", and "Mobile" and are identified in section 3 "Alternatives and Economic Analysis.

- The "Modular" building will be constructed as uniform structure throughout. It will be constructed on site using prefabricated wall sections, which will provide better control of quality and specification compliance at all phases of construction.
- The "Relocatable" building will be assembled on site from prefabricated structures that are built, cut and transported in large sections from the manufacturing site. This will not allow full quality control and specification compliance on the construction site. The sections joints will be sealed, and depending on the quality of seals installation, the structure may be susceptible to leaks.
- The "Mobile" building will also be assembled onsite; however it will consist of prefabricated trailers attached together to meet OPG's specification. This is the preferred option.

The new CCR is required to be completed before the start of the DNGS 2009 Vacuum Building Outage (VBO) and the demolition and decommissioning of the existing CCR will be scheduled after the 2009 VBO Outage. The basis for this time frame is to ensure both the old and new Construction Change Rooms are available to facilitate the expected large influx of contract staff during the 2009 VBO Outage. The "Mobile" building design selected for the change room has a life span of approximately 20 years and will be able to support maintenance activities for DNGS beyond the current expected end of life of 2018 to approximately 2029. Decisions will need to be made in regards to continuing maintenance costs to extend the mobile CCR life beyond its expected 20 year lifespan.

A Design Agency, Wardrop Engineering Inc (WEI) has been commissioned to perform the preliminary and detailed design for the project. Upon stakeholder COMS review of the preliminary engineering package provided by WEI, it was determined that greater provisions for security are required

The scope of the project shall be expanded to include these security

Estimates for 6 new Whole Body Monitors are also included in this release, and these were not included in the developmental release.

A construction estimate based on a substantially completed design have been used for this estimate instead of a normal third party estimate based on full design due to very limited time constraints.



OPG Confidential

Page: 5 of 17

BUSINESS CASE SUMMARY

3/ ALTERNATIVES AND ECONOMIC ANALYSIS

\$ 000's	Status Quo	Full	Incremental Delay	"Modular"	All 4 A#5
		Cost	Cost		
Revenue			an and an and a second and a second a s		andre diedelichen im 12. die 12. das eindet in das die gegenzeigt. Geschichten
OM&A					
Capital		(12,440)		(14,892)	(13,666)
VPV (after tax)	(5,276)	(10,221)	anna an	(12,010)	(11,115)
mpact on Economic Value (IEV)	N/A	(4,945)		(6,734)	(5,839)i
RR%	N/A	· · · · · · · · · · · · · · ·		~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	
Discounted Payback (Yrs)	N/A	· · ·		· · · · ·	· · · · · · · · · · · · · · · · · · ·

Status Quo - Not Recommended

This option is not recommended as the necessary change room and lunchroom capacity will not be in place to support the large number of contract staff expected to be onsite during the 2009 VBO. Other station contingency plans will have to be in place to mitigate the large influx of contractors. Furthermore major repair and renovations will have to be considered for the existing change room for it to continue to operate. A new CCR will be required in the future as the existing CCR is not expected to survive beyond 2012.

Alternative 1 - Build a new "Mobile type" CCR and remove existing CCR - Recommended

This option is recommended as a new CCR is required to replace the existing life expired CCR and provide a safe and effective work environment for the next ~ 20 years. The "Mobile" type building option (consisting of pre-fabricated trailers) has a manufacturer recommended nominal life of 20 years and will be available to support future maintenance activities should DNGS life extension become a reality to ~ 2029. It will also increase the capacity of the women's change room to address this identified demographic deficiency and provide a larger lunchroom to meet the projected future DNGS contractor needs with regard to outages and large projects as identified by stakeholders. The new CCR will be available to support future outage, project, and VBO maintenance activities. The "Mobile" building meets the requirements of the charter and is the estimated least costly option.

There are significant risks associated with this implementation schedule as the timeline for the completion of the new change room is extremely tight. The "Mobile" construction option provides the lower schedule risk, based on timelines provided by constructor during conceptual study. The Mobile building will also provide the lowest cost risk as the entire structure of the new CCR will be assembled offsite; therefore contractor delays associated with work performed inside the protected area are minimized. Decisions will need to be made in regards to continuing maintenance costs to extend the mobile CCR life beyond its expected 20 year lifespan.

Alternative 2 - Delay Project - Not Recommended

Delay Project 1 year

This option is not recommended as the CCR would not be available for the VBO. Furthermore, major repair and renovations will have to be considered for the existing change room for it to continue to operate. The full cost of such renovation cannot be accurately determined at this point. A new CCR will be required in the future as the existing CCR is not expected to survive beyond 2012.

Alternative 3 – "Modular Type Building Option" - Not Recommended

Build a new Construction Change Room / Lunchroom Facility (CCR) using "Modular" Construction

This option is not recommended. Although the Modular type building would provide a safe and effective work environment for the next 30+ years, it is estimated as the most costly option. It also carries a higher schedule and cost risk than the mobile option as the majority of the work is required to be performed onsite inside the protected area.

The NPV for this option has been calculated using the 20 year life span of the new Mobile facility, until 2029



Alternative 4 - "Relocatable Type Building Option" - Not Recommended

Build a new Construction Change Room / Lunchroom Facility (CCR) using "Relocatable" Construction

This option is not recommended although the "Relocatable" type building will provide a safe and effective work environment for the next 30+ years. It is more costly than the recommended "Mobile" option. This option also carries a higher schedule risk than the mobile option.

6 of 17

The NPV for this option has been calculated using the 20 year life span of the new Mobile facility, until 2029.

Alternative 5 - N/A - Not Recommended







4/ THE PROPOSAL

The Following are the objectives and deliverables for this Full Release Phase 1 BCS:

- Issuance of a Request for Proposal (RFP) for a construction contract for the proposed new CCR
- Issuance of a construction PO for buried service relocation & construction of the new CCR
- OPG support of construction of the new CCR
- Partial AFS of new CCR prior to 2009 VBO. Construction of the building will be complete enough that it
 may be used in support of the 2009 VBO
- Final AFS of the new CCR following the VBO and outage D931 to ensure completion of Engineering Change Control process, and full station turn-over
- The issuance of a Full release phase 2 BCS
- A Constructor's estimate for the demolition of the old CCR to support the full release phase 2 BCS

5/ QUALITATIVE FACTORS

The successful completion of this project will improve the following

Staff Relations



 New larger capacity change rooms and a lunchroom which will relieve overcrowding and congestion and result in improved staff morale.

Health and Safety

- Increased site capacity of DNGS women's change room to reflect changing demographics to ensure compliance with Occupational Health and Safety requirements.
- New improved larger capacity change rooms and lunchroom will relieve overcrowding and congestion and hence improve health and safety inefficiencies.

ONTARIOP GWEEN

OPG Confidential Page:

8 of 17

BUSINESS CASE SUMMARY

6/ RISKS

Description of Risk	Description of Consequence	Risk Before Mitigation	Mitigating Activity	Risk After Mitigation
Cost				
COSI for demolition of existing CCR exceeds conceptual estimate of	Potential increase in cost of the project	High	Cost to remove the CCR was estimated by ASL in the 2006 conceptual study. -Constructor estimate will be obtained upon completion of detailed design of the CCR demolition -Full Release Phase 2 BCS will be issued for	Medium
The tight timeline may prevent the project from obtaining an accurate estimate for the demolition of the existing CCR	Potential increase in cost of the project	Medium	Adopt a phased funding release strategy. Full Release Phase 1 BCS in Q1 2008 for the construction of the new CCR, and the Full Release Phase 2 BCS in Q1 2009 for the removal and decommissioning of the	Low
Construction estimate based on substantially complete design is used for full release BCS	Potential increase in scope and cost	High	-Draft construction specification and design packages used for estimates -Rough scope description used for design packages not yet available to ensure the items at a minimum be considered in the cost estimate	Medium
- X				No.
Risk *** Risk *** Limited Implementation timeline could result in discovery items in both design and construction phases	Potential increase in the cost, scope and schedule of the project	4 B H	-Close involvement with constructor and design agency during both design and installation phases -Mitigation actions to be considered for outstanding items for partial AFS	Medium
Unanticipated Buried services may require additional relocation effort	Increase in cost and schedule	Medium	Cursory drawing review has been conducted to identify any possible services that may require relocation. Field survey was completed during Preliminary Engineering.	Low

|--|

UNITRUTUN	OPG Confidential		P489e: 9 of 17	
GENERAI	10N BUSINESS	S CASE SUMMARY	(RY	
			Foundation design to require minimal excavation.	
		Medium		Low
Schedule				
Overall schedule is too tight to complete implementation of the new CCR	Inadequate change room facilities available to support DNGS VBO	48H	-Constructor Estimate acquired for Full Release (Phase 1) BCS -Management support required to relax certain milestones for work processes -Stage design and construction activities to maximize parallel work activities -Using prefabricated mobile design to construct the new CCR	Medium
Lead time for OOD material			ZUUS VEU requirement	
	CUCK pre-rapricated components not procured in time to meet construction schedule for new CCR prior to VBO	Medium	Prepare Full Release BCS in Q1 2008 to secure funding for LLM, as building estimates and lead times will be known	Low
Lesign deliverables not on time.	Delay to schedule.	Medium	Select approved vendor, provide clear scope & deliverables. Review progress regularly & establish and monitor effective design performance metrics.	Pow
Complications in regards city building inspection of new CCR	Delay in schedule	ЧġН	-Contact Clarington township regarding inspection -Pre-arrange inspection -Delegate construction vendor to contact the city directly for inspection	Modium * Lou * (WP)
*** Schedule Risk ***	Delay in Schedule	High	-Specify EPSCA consideration to be built into	Low
Complications in regards to acceptance of non-unionized fabricated structure onto our site			the construction contract -Consult with CMO SPOC early	
		, , ,		+-
Technical			TAS TER EMALL FION J. BEEN	80/21 XFW
				· · · · · · · · · · · · · · · · · · ·

INTARIOPOWER Generation
NO

Page: BUSINESS CASE SUMMARY OPG Confidential

10 of 17

Medium 2.0 L * (05P)	-Engage investment finance and long term strategic planning group in reviewing cost and benefit calculation -Clear identification of cost and benefits of new CCR -Seek cost efficiency in both design and construction phases	Medium	value of invested capital not fully realized	cannot justify proceeding with the project.
Low	-All health and safety hazards will be identifed, as testing and analysis will be performed on the existing CCR materials prior to demoliton	Medium	Health and Safety Hazards are possible (Asbestos, PCBs, mold etc.)	nazardous materials may be present in existing life-expired CCR Investment
MO	Waste Disposal Plan to be developed by design agency to ensure proper disposal of all material	Low	Waste Disposal could have environmental impact	Hazardous materials may be present in existing life-expired CCR
Low	-Preliminary briefing with CNSC -Station management concurrance -Submit CNSC correspondance early	Medium	Delay to project	CNSC's concurrance for commercial build Environmental
Low	All required CNSC correspondance and approvals will be obtained as required so as not to impact the overall project schedule	Medium	Delay to project schedule for approvals	Regulatory or IAEA Approval may be required to add a building to the site layout

* 45 PER E-MAIL FROM J. BEECH MAR 17/68

7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Final AFS	Targeted PIR Approval	PIR Responsibility
	Date:	Date:	(Sponsor Title)
Simplified	Dec 2009	Dec 2010	Director, Operations and Maintenance

The final AFS for the removal of the existing CCR will be determined for the Full Release Phase 2 BCS, therefore the targeted PIR approval date will be implemented in the next BCS.

Comments:

	Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it? (person / group)
1.	Construction of new CCR	Not in service	New building will be available in time to support VBO	Successful Partial AFS	DNGS Maintenance
2.	Demolition of existing CCR	In Service	Demolition complete following D931	Successful AFS	DNGS Maintenance
3.	· · · · · · · · · · · · · · · · · · ·				<u>.</u> ,.,.,,
4.	· · · · · · · · · · · · · · · · · · ·		· · · · · · · · · · · · · · · · · · ·		
5.				• · · · · · · · · · · · · · · · ·	



Appendix "A"

Glossary (acronyms, codes, technical terms)

Acronyms

NPV CM PO DTL OPEX LLM TBD PIR PWU VBO BTU PEP	Business Case Summary Construction Change Room Power House Annex Request For Proposal Quality Control Station Condition Report Acres Sargent and Lundy Net Present Value Control Maintenance Purchase Order Design Team Leader Operating Experience Long Lead Material To Be Determined Project Implementation Report Power Workers Union Vacuum Building Outage Building Trades Union Project Execution Plan Available For Service Impact On Economic Value Internal Rate of Return
IRR	Internal Rate of Return





OPG Confidential

Page: 13 of 17

BUSINESS CASE SUMMARY

Appendix "B"

Project Funding History

Release Type	Month	Year	2006		ulative Va 2008	2009	2010	2011	2012 Later	Total
Developmental	Jul	2007		1,204	426					1,630
Full (Phase 1)	Feb	2008		(693)	11,685	2,312		,		13,304
Full (Phase 2)	Oct	2008				1,086		1		1,086
								Î		0
										0
										0
					1			-		0
										0

LTD Spent	Dec	2007	511		. 511
			/_ /_ / /. /	-k	· · · · · · · · · · · · · · · · · · ·

Comments:







Appendix "C"

Financial Model – Assumptions

Project Cost Assumptions:

- OPG staff will provide project management and support role during design and implementation
- Design and Installation work will be performed by contractors
- Estimated costs include utility tie-ins.

Financial Assumptions:

Current P3 resource costs were used thru 2009. Escalation rate of 3% was used for 2010 and 2011

Project / Station End of Life Assumptions:

Darlington end of life ~ 2018, (2040+ with refurbishment)

Energy Price / Production Assumptions:

Operating Cost Assumptions:



- Additional ongoing Utility costs new CCR to old CCR:
 - Acres Sargent & Lundy calculated Delta of 100KW electrical consumption Current Energy Cost of \$0.0466/kWh @ escalation rate of 2% per annum.
 - Acres Sargent & Lundy calculated Delta of 27,000 ft3 water consumption Current Regional Municipality of Durham rate of consumption of \$0.437/m3 @ escalation rate of 2% per annum.
- Any extra janitorial costs have not been included.

Other Assumptions:

- Construction estimate is a constructor's estimate based upon substantial completion of the detailed design, and a construction specification provided by the design agency WEI.
- Construction Material costs are included in the cost of the installation contract.
- Costs for appliances and furniture are not included.
- Costs of providing walkways, parking lots, external lighting and landscaping, are not included.



ONTARIOPOWER GENERATION

Page: 15 of 17

BUSINESS CASE SUMMARY

DNGS Construction Change Room 16 - 31718

Full Release (Phase 1) Business Case Summary D-BCS-28200-10004-R000

Attachment "A"

Project Cost Summary

\$000's Capital & OM&A	LTD Prior Yr 2007	This Release 2008	This Release 2009	Future Release 2009				Later	Total
Project Management (OPG)	71	639	116	299		- Janna Jarres			1,125
Engineering & Drafting (OPG)	21	210	41	64				ì	335
Material								1.00	
Installation - PWU, BTU	TRE		130 annon	ale marine	- Assisted	S DE MARSON	经进行增长时	- Meterica	e open te
Contract - Design	<u>i</u>		station in		in the second	e la competito	and the second	# showing the	time -
Contract - Installation		Starle	Sallinger - 10		San Carlos Carlos	1000000		A CONTRACT	1221
Contract - Other				國防地区部	出现的问	的研究的影响	10000000000		
Security	Allows				和認識的	h neshtarin	Wine Resident		1221
Interest (Capital Project Only) Project Costs (ercl contingency) General Contingency				特別的 なけ) - 		enesean Shikant		5 55 80 5.12 1 557 80 5.12	
Specific Contingency							Sec.		
Project Costs (inci contingency)	511	12,111	2,312	1,086	er inde				16,019
2008-2012 Business Plan		1					8		•
Variance to Business Plan	511	9,316	1,778	835	14 14				12,440
Committed Cost					1				-
Inventory Write Off Required			· · · · · · · · · · · · · · · · · · ·						-
Spare Parts / Inventory				2					·
Total Release (excl contingency)	l								
Total Release (incl contingency)	511	12,111	2,312	1,086	s				16,019
Ongoing OM&A (non-project)					\$ _ %	· · · · · · · · · · · · · · · · · · ·			
Removal Costs (incl in above)	148	41	120	602		1	Ha rende		910

Design Complete		Up to - 40%	Quality of E	stimate	Budget + 30 ⁴	% to - 15%
3 rd Party Estimate	Yes	OPEX used	Yes	Lessons Lea	arned	N/A
Reviewed by Sponsor	Yes	Budgetary Quote(s)	Yes	Phase 1 Act	ual Used	No
Similar Projects	No	Contracts in place	Yes	Competitive	Bid	Yes

The estimated variance(s) to the 2008-2012 Business Plan will be addressed through the portfolio management process. A PCRAF is not required

Reviewed By: Jan 21/0 Stephanie Tham 4 Date:

Project Manager

Approved By:

id h Dianne Gaine

12:

Eng & Mods Manager (Strat IV)

Date:



Page: 16 of 17

BUSINESS CASE SUMMARY

DNGS Construction Change Room 16 - 31718

Full Release (Phase 1) Business Case Summary D-BCS-28200-10004-R000

Attachment "B"

Project Variance Analysis

	77	Chool	se One		
Capital	2007 2007 2008	Comments			
Project Management (OPG)	71	947	1,125	178	
Engineering & Drafting (OPG)	21	254	335	81	······································
Material					
Installation PWU, BTU					
Contract - Design				tion of the	
Contract - Installation		Contraction of the			······································
Contract - Other		10000000000000000000000000000000000000	Card States		1
Security		and the second stand	and the second s	gerine .	
		Vilo Strephyle	Line of species	÷	
Interest (Capital Project Only)	- U				
Project Costs (excl contingency)					
General Contingency					
Specific Contingency					
Project Costs (incl contingency)	510.514	11497	16172	4675	
Committed Cost				0	
Inventory Write Off Required				0	
Spare Parts / Inventory				0	
Total Release (incl contingency)	510.514	11497	16172	4675	
Total Release (axcl contingency)	V				
Ongoing OM&A (non-project)				0	
Removal Costs (Incl in above)				0 ////	edition in the

Comments:

A new constructor's estimate based on the significant completion of the change room design. The estimate is greater than the initial conceptual estimate of the new CCR.

There have been changes to the design contract for the new CCR, as provisions for new security requirements, the requirements for the electrical tie-ins and requirements for the foundation have been revised from the initial scope of the contract. The additional cost has not been determined however it is estimated to be and has been included in this release.

The developmental release did not account for security personnel that will be required during construction of the new change room. Security must be present during activities that occur within the vicinity of the site security fence.

Cost increase in Material is represented by the Whole Body Monitors that are required for new CCR. At the time of the developmental release, the project was not accountable for the cost of these item and the second and the installation contract price.

and the second second



Attachment "C"

Key Milestones

Co	mpletion	Date	Description
Day	Mth	Yr	- Description
29	Feb	2008	Full Release Phase 1 BCS (FR1)
29	Feb	2008	Detailed Design Complete
1	Apr	2008	Installation Work Plans Assessed (Preparation for Trailers)
3	Apr	2008	Installation Contract Awarded (ICA)
14	Apr	2008	Long Lead Items Ordered
14	Apr	2008	Start of Installation (SOI)
18	Jul	2008	Installation Work Plans Assessed (Installation of Trailers)
26	Sep	2008	Commissioning Workplans Assessed
15	Mar	2009	Full Release Phase 2 BCS (FR2)
23	Mar	2009	Partial AFS (New CCR)
23	Sep	2009	Final AFS (New CCR)
		+	

A Project Execution Plan (PEP) will be approved by Feb 2008

Comments: Milestones associated with the demolition of the existing CCR will be incorporated into the Full Release Phase 2 BCS when an accurate timeline for demolition activities can be established.

ONTARIO OVER GENERATION

BUSINESS CASE SUMMARY

Main Control Room HVAC 16 - 33293

Superseding Business Case NK38-BCS-73920-10002-R000

Routing	Location	Action	Signature	Date
Luke Frawley			a	when an in the state
Project Leader II	DW/7.00	0 0.00	1 1 0	, ,
Design Projects	BW7 02	Prepare BCS	L' Franky	24 April 6
8-703-3564				1 1 1 1 1 1 1 1 1
Tom Cvitkovic			10	
Section Manager	BW7 02	Deview DCC	1111	and the
Design Projects	DVV7 02	Review BCS	Ohn Att	24 April 20
8-703-3571			VI COUV	
John Taras			100-	. 1 . 2
Section Manager	DM17.00	Device DCC	J. The	24An 07
Project Management Office	BW7 02	Review BCS	1 least	c m
8-703-3528				V
Terry Chong				
Manager	DUNT OO	D : D00		
Design Projects	BW7 02	Review BCS	Junet bund	750 2.4
8-703-3520		į		25 Ap-2007
Steve Cochrane		***** *******************************	\	
Section Manager	00000		1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	
Field Engineering	D06 PO	Review BCS	- lochan	71 10007
8-703-3704			, Coc man	26 APROT
ff Lehman				
anager			O	
erformance Engineering	D08 ES2	Review BCS	Phil	OIMAY OT
8-703-7325			11 to prove	
Don Williams COUL and			V	
Manager 2007/01/19				
Projects Design	D08 ES3	Review BCS	$\lambda \sim \lambda_{\rm ell}$	03 May 2007
8-703-1963			Frank Illens	Contract 200, 1
Axel Kleer		r	1 NA	1
Senior Financial Analyst				1
Nuclear Finance	P82	Review BCS	Milling	ICN 03
8-400-7720			mypret	15N/m07.
Stu Seedhouse			· · · · · · · · · · · · · · · · · · ·	+
Director			II	
Station Engineering	D08 ES3	Review BCS	S Viel.	13 Hay 2017
8-703-7584			- A Car	· · · ·
Mark Amone				
Director			entry /	1
Projects and Modifications	P72	Review BCS	T. C. Martine	IS MAY 2017
8-701-6063				
Randy Leavitt				
Director				
Corporate Investment Management	P82	Review BCS		May 17 2007
3-702-5085			E E DE DE LE DE	m ? · · · · · · ·
Vayne Robbins				
Senior Vice President			" All	
Darlington Nuclear	D08 ES3	Submit BCS	Thingtoblad	207-05-23
3-703-7499		(and the second s	your vous
	+			
n Power		1		
ce President	H07 D06	Review BCS	A lange	Vier stor 1
Corporate Investment Planning			V. Jakerra	your you
J-400-7172				1 1



OPG Confidential	Page:	2 of 15

1090. 2.

BUSINESS CASE SUMMARY

Jim Beech Vice President Nuclear Finance 8-400-4226	H07 E19	Approve BCS		Juse H/c?
Tom Mitchell Chief Nuclear Officer 8-702-5294	P82 6A1	Approve BCS	Juriching.	Juns/07
R. Ball Senior Financial Analyst 702-4084	P82-3B6	Return For Distribution		





ONTARIOPOWER	
GENERATION	

Main Control Room HVAC 16 - 33293

Superseding Business Case NK38-BCS-73920-10002-R000

1/ RECOMMENDATION:

Approval is requested to reduce the scope of the planned modifications to the Main Control Room (MCR) HVAC system, to focus on absolute requirements to meet the project objectives, and remove optional elements that would otherwise drive costs beyond the previously released amount of \$11M. No additional funding is requested under this superseding BCS.

The original business objective for this project was to address the following deficiencies in the MCR HVAC system:

- · High temperature excursions that threatened reliable operation of the units
- · Health and Safety concern with the lack of proper filtration and humidification

Much of the work to meet these objectives has been completed to date, and real benefits have been confirmed in the current MCR environment.

A Full Release BCS releasing \$6M for this project was approved in May 2001. Subsequently in July 2003, a Superseding BCS for a total release of \$11M was approved. By June 2005, it became apparent that up to an additional \$3M would be required to fully complete all required and optional elements of the project scope.

To mitigate this cost increase, a review of the project was initiated to separate the absolute requirements (needs) from the optional requirements (wants). As the result of the review, in April of 2006, the Darlington Project Approval Committee approved a plan to reduce the number of modifications, thereby keeping the estimated cost of the project within the currently released amount of \$11M. (See the Background section for a summary of the changes to this project). The reduced scope will still address the business objectives of the Main Control Room HVAC project.

be Life-to-Date actual cost of the project is \$9.750M vs. \$11.0 M full release. The remaining field work and closeouts in this proposal are well understood and defined. The risks associated with this plan of action have been assessed and mitigated to provide assurance that the remaining funds will be sufficient to complete the reduced scope of this project.

\$900's (incl contingency)	Funding	LTD 2006	2007	2008	2009	2010	2011	Later	Total
Currently Released	Superseding	9,750	983	237	30	••••••••••••••••		dan marin Suban marin	11,000
Requested Now	Superseding				e e e e e e e e e e e e e e e e e e e		1		
Future Funding Reg'd	None								
Total Project Costs		9,750	983	237	30	-		· · · · · · · · · · · ·	11.000
Other Costs					· · · · · · · · · · · ·				
Ongoing Costs	-								-
Grand Total		9,750	983	237	30		· +· ·		11.000
Investment Sustainin	Type	Clas Capit	s Iai	(IEV) Impact of	n Ec Value		IRR	Discounted	Payback

Submitted By;

Wayne Robbins

2007-05-23 Date:

Date

Senior Vice President, Darlington Nuclear

Finance Approval

Jim Beech Vice President, Nuclear Finance

R Element 1.1 Project in Budget). Approval (Per

Tom Mitchell Chief Nuclear Officer

Date

ONTARIOPOWER GENERATION

BUSINESS CASE SUMMARY

2/ BACKGROUND & ISSUES

The project originated in late 1999 as a post construction clean up work order and continued under OM&A Project # 38276 for definition and scoping and for certain maintenance activities to ensure continued operation of the major system components.

It was soon determined that replacement / installation of major equipment such as cooling coils, humidifiers and filters were essential to address the issues related to temperature, humidity and air quality in the Main Control Room (MCR) and the adjacent Computer Equipment Rooms (CER).

In May of 2001 a Full Release BCS was approved for \$6,040k for the aforementioned modifications as well as provision of required redundancy for Glycol System RV and Pump Seal Supply (absolute requirements) and major modifications to the ducting, systems and controls and a comprehensive monitoring and diagnostic system (optional requirements).

In July of 2003 a cost variance Superceding BCS was approved for \$11,000k. The variance in cost was mainly due to low original estimates. (A full explanation of variances was provided in that BCS).

In June of 2005 the balance of the project scope was reviewed and the forecast to complete was estimated to be \$14,000k excluding contingency. Upon this estimate the project status in the Major Projects Status Report turned "Red" indicating major project cost and schedule issues. To recover the project back to "green" status a project recovery process was initiated. In this process the balance of the scope of the project was analyzed against the following absolute requirements:

- Temperature and Relative Humidity
- Address Toxic Gas report by positive blocking of the Maximum (90%) Air Dampers
- Redundant RV and Pump Seal supply to resolve the singleton issues associated with these components failure of any of these singletons would have resulted in MCR HVAC shut-down

At present the major modifications (cooling coils, humidifier and filter replacements) and the Glycol System redundant RV and Pump Seal supply have been completed. Temperatures have decreased in the target areas and Relative Humidity values have increased especially during dry winter months. The new filters are performing as expected and the ergonomic and employee health and safety issues with the old electrostatic filters have been eliminated.

Those elements of the remaining scope which met the above requirements were classified as "needs" or absolute requirements and the rest as "wants" or optional requirements. In April of 2006, the station Project Approval Committee (PAC) accepted the following recommendations:

- Complete positive blocking of the Maximum (90%) Air Dampers
- Replace Minimum (10%) Air Dampers
- Review Temperature and Relative Humidity measuring instruments in the Control Room and provide field instruments if needed

Subsequent to PAC meeting, the requirements for Temperature and Relative Humidity measuring in MCR and CER were reviewed and it was determined that additional field instruments were not warranted.

5 of 15

3/ ALTERNATIVES AND ECONOMIC ANALYSIS

\$ 00016	Status Quo	Alt 1 (Recom	mended)	Alt 2 A Delay	A 3
Revenue		Cost	Cost		<u> Alexia</u>
OM&A				-	
Capital	(9.282)	(6,281)	(540)		
NPV (after tax)	(7,369)	(5.116)	(420)		
Impact on Economic Value (IEV)	N/A	2,253	6,949		
IRR%	N/A	N/A	N/A		1
Discounted Payback (Yrs)	N/A	N/A	N/A		÷

Status Quo - Not Recommended

Continuing with the full scope and requesting an additional \$3.0M is not recommended. In April of 2006 the Station Project Approval Committee approved the reduce scope to meet the absolute requirements only, and complete the project within the previously-approved release of \$11M.

Alternative 1 - Complete the Reduced Scope and Close-out - Recommended

It is recommended that the scope be reduced to the following absolute requirements:

- Disable free cooling feature by capping the maximum outside air dampers, this will address the requirements set forth in Senior Vice President's memo to CNSC: "Darlington NGS – Safety Report Analysis Update: Toxic Corrosive Chemical Rail Line Accident", dated Oct 12, 2004.
- · Replacement of the minimum outside air dampers.
- Documentation clean-up and close-out significant engineering effort-is required to revise design documentation
 associated with the reduced optional scope and to close out the project.

A rigorous scope analysis was done in 2005 and recommendation was made to eliminate the optional requirements from the scope of the project. The elements of the scope that have been eliminated are of discretionary nature, as approved by the DNGS PAC in April 2006.

Alternative 2 - Delay Project - Not Recommended

N/A

Alternative 3 – N/A - Not Recommended

Alternative 4 – N/A – Not Recommended

Alternative 5 - N/A - Not Recommended



4. 1



4/ THE PROPOSAL

1) Complete the following scope within the remaining funds of the project:

- Disable free cooling feature by capping the maximum outside air dampers, to address the requirements set forth in Senior Vice President's memo to CNSC: "Darlington NGS – Safety Report Analysis Update: Toxic Corrosive Chemical Rail Line Accident", dated Oct 12, 2004.
- · Replace the minimum outside air dampers.
- · Complete the documentation clean-up (revise design packages for the optional scope) and close-out the project.

2) Delete the following scope:

- Ducting Systems and Control Modifications
- Comprehensive Monitoring System
- Removal of obsolete equipment (tanks and pumps).

The project will be closely monitored and controlled to ensure that the remaining scope is completed within the approved funds.

5/ QUALITATIVE FACTORS

The main qualitative factor of this initiative (cost growth reduction) is to drive a business type behaviour in the organization and encourage all the project teams/stakeholders to limit the project scope on the absolute requirements of the station



RIO CENERATION	יור אין
ONTAR	Condemander of the second second second

7 of 15

BUSINESS CASE SUMMARY

6/ RISKS

Description of Risk	Description of Consequence	Risk Before Mitigation	Mitigating Activity	Risk After Mitigation
Cost increase - negligible risk	Cost growth may cause project costs to exceed release.	Medium	The reduced scope is well defined. The estimate is based on commitments from supporting departments and input from third party estimating group. Approx	Low
Scope Scope is defined and 90% designed. Risk of scope growth is low	Scope growth may cause cost increases and schedule extensions to exceed the release limits.	Medium	The scope is limited to blocking max outside air dampers and associated exhaust dampers, replacement of the minimum air dampers and documentation clean-up. The risk of scope growth is negligible and approx is still avaitable within current release for any unforeseen work.	No
Schedule Station emerging priorities.	Emerging Station priorities may cause schedule extensions resulting in slippage of milestone dates in release.	Medium	The schedule is based on resource commitments, (e.g., Design, Field Engineering and installation contracts), Work Management procedures with some float. WOs are scheduled on IPG Plan. This will minimize schedule risk.	LOW
Resources Re-allocation of key resources such as design and field engineering to other projects.	Key resources not available when required may cause schedule extensions and cost growth.	Medium	Commitments obtained from key resource providers. The project will maintain close communication with IPG to ensure the priority is maintained.	Low

IN THIS CONTRACTION	
NO	-Sector Contraction

8 of 15 Page:

BUSINESS CASE SUMMARY

Technical Relative Humidity target levels may not be achievable.		Medium	Agreement reached with Design and key Low stakeholders to revise RH targets to reflect
Regulatory	exceed the release limits.	NIA	achievable humidity levels.
Environmental		AIA	
Health & Salety Conventional Health & Safety risks during implementation.	Conventional Heath & Safety risks will be present during the implementation of the project but will be closely monitored and	Low	COMS and JSA as well as adherance to all Low station safety procedures will eliminate/ minimize this risk.

Same -ł ţ ģ 1 4 Investment ļ ł

ł

Į

i 1

ł

j.

I ļ

T.

NIA

7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Final AFS	Targeted PIR Approval	PIR Responsibility
	Date:	Date:	(Sponsor Title)
Simplified	Mar 2008	Jun 2009	Performance Engineering

RACH COST

Comments:

	Measurable Parameter Current Baseline		Targeted Result	How will it be measured?	Who will measure it? (person / group)
1.	Maximum Air (90%) Dampers: -leakage rate	Max Air Dampers are jumpered closed but not capped, leakage rate unknown	Max Air Dampers covered with zero leakage	Testing as per design documents	Field Engineering/ Performance Engineering
2.	Minimum Air (10%) Dampers: -leakage rate -closing time	-leakage rate unknown -closing time <20sec	-leakage rate 1% or less -closing time <20sec	Testing as per design documents	Field Engineering/ Performance Engineering
3.	Temperature Exceeds 22 Deg C		20 to 22 Deg C	Testing as per design documents	Field Engineering/ Performance Engineering
4.	Humidify (RH)	Below 20% RH	Target minimum 35%, maximum 45% RH	Testing as per design documents	Field Engineering/ Performance Engineering
5.	Air Filtration	Pre-filtration only. Electrostatic agglomerator not functional. Ingress of poorly filtered air into MCR and CER.	Filtration efficiency of 90% to 95% as per manufacturer test reports. Pressure drop during operation less than 625 Pa.	Efficiency as per test reports verified by Design. Pressure drop measured during testing and commissioning.	Field Engineering/ Performance Engineering

ONTARIO	Powen
	GENERATION

+*********

Page: 10 of 15

BUSINESS CASE SUMMARY

Appendix "A"

Glossary (acronyms, codes, technical terms)

CER	Computer Equipment Room
AFS	Available for Service
HVAC	Heating Ventilation & Air Conditioning
MCR	Main Control Room
RV	Relief Valve
BCS	Business Case Summary
PAC	Project Approval Committee
RH	Relative Humidity
PIR	Post Implementation Review
ASHRAE	American Society of Heating, Refrigeration & Air Conditioning Engineers

ONTARIO	GENERATION
---------	------------

Appendix "B"

Project Funding History

and the second

\$ 000's		All	Existing		ed Reise ulative V	alues	continge	ncy)			
Release Type	Month	Year	2001	2002	2003	2004	2005	2006	2007	Later	Total
,		2							1		0
Full	May	2001	2.130	1,840	2,070				1	1	6,040
Superseding	Jul	2003		4,037	1,800	2,830	2,333		ĺ		11,000
Superseding	Jan	2007					• • • • • •	9,750	983	267	11,000
		Choose				;					0
		Choose								• · · · · · · · · · · · · · · · · · · ·	0
		Choose				ſ					0
		Choose			- · · -					1 · · · · · · · · · · · · · · · · · · ·	0

LTD Spent Dec 2007 2,473	1,564 1.651 1.836	1,780 446	9,750
--------------------------	-------------------	-----------	-------

Comments:







Financial Model – Assumptions

Project Cost Assumptions:

Appendix "C"

N/A

Financial Assumptions:


Interest = 6%

Project / Station End of Life Assumptions:

2018

Energy Price / Production Assumptions:

N/A



N/A

Other Assumptions:

N/A





Page: 13 of 15

BUSINESS CASE SUMMARY

Main Control Room HVAC 16 - 33293

Superseding Business Case NK38-BCS-73920-10002-R000

Attachment "A"

Project Cost Summary

\$000's Capital	LTD Prior Yr 2006	This Release 2007	This Release 2008	This Release 2009		N. A		Later	Total
Project Management (OPG)	1,306	64	30	4		And a state of a	accontençajas suos	100 X 10 X 10 X 10	1,404
Engineering & Drafting (OPG)	481	245	137	26				1	889
Material									
Installation - PWU, BTU									
Contract - Design				+1					
Contract - Installation								-	
Contract - Other	<u> </u>			(A) les les					-
Interest (Capital Project Only)							No. of Concession, Name		1
Project Costs (exc) contingency) General Contingency	PY .					12120	93.38 ⁷⁷		
Specific Contingency	1.1								2 - C
Project Costs (incl contingency)	9,750	983	237	30	-				11,000
2007-2011 Business Plan		1,039	-]	10400000000000	1,039
Variance to Business Plan	9,750	(136)	212	30			7		9,856
Committed Cost									
nventory Write Off Required					· · ·	····· ŕ			
Spare Parts / Inventory	• • • • • •					. !			
Total Release (excl contingency)	9,750	903	212	30	98 - <u>A</u> 1987				10,895
Total Release (incl contingency)	9,750	983	237	30	•				11,000
grandro DUF Adora pretor					*				
Remonal Contartifict Industry						- A. P. C.	1. M.	nara m 1. Mi	

Design Complete		Up to - 40%	Quality of E	stimate	Release + 15	5% to - 10%
3" Party Estimate	Yes	OPEX used	Yes	Lessons Le	arned	Yes
Reviewed by Sponsor	No	Budgetary Quote(s)	Yes	Phase 1 Act	tual Used	Yes
Similar Projects	Yes	Contracts in place	Yes	Competitive	Bid	No

The estimated variance(s) to the 2007-2011 Business Plan will be addressed through the portfolio management process. A PCRAF will be approved by May 2007

Reviewed By: 24 Tom Cvitkovic



Project Manager

Date

Approved By

Terry Chong Eng & Mods Manager (Strat iV) 25 Apr 1.207 Date



Page: 14 of 15

BUSINESS CASE SUMMARY

Main Control HVAC 16 - 33293

Superseding Business Case NK30-BCS-73920-10002-R000

Attachment "B"

Project Variance Analysis

	1	Choos	se One	1	and the second		
Capital	LTD Dec 2006	Last BCS Jul 2003	This BCS Jan 2007	Variance	Comments		
Project Management (OPG)	1306	603	1404	801	Low initial estimate, schedule extensi	on	
Engineering & Drafting (OPG)	481	773	889	116	Low initial estimate, schedule extension	on	
Material		021	100				
installation - PWU, BTU			And an eine			-	
Contract - Design	1						
Contract - Installation							
Contract - Other	-			-			
、,,.				3. S			
nterest (Capital Project Only)					The second se	1	
Project Costs (excl contingency)	200.0						
General Contingency					- 1011	-	
Specific Contingency					The factor		
Project Costs (incl contingency)	9750	11000	11000	U			
Committed Cost	· · · · · · · · · · · · · · · · · · ·	` +		0			
nventory Write Off Required	,			0			
spare Parts / Inventory				0	·		
Total Release (incl contingency)	9750	11000	11000	0		100	
Total Release (excl contingency)	9750	9400	10895	1495		0.536	

0

Removal Costs (incl in above)

Comments:



ONTARIOPOWER GENERATION

BUSINESS CASE SUMMARY

Key Milestones

Co	mpletion I	Date	
Day	Mth	Yr	Description
18	05	2007	(PTA) Work Package Assessment Complete
13	08	2007	(SOI) Start of Installation Dampers
14	01	2008	(AFS) AFS Damper Mods Complete
19	02	2008	(DCP) DCP Rev03 - Complete
28	04	2008	(AFS) Final AFS
13	03	2009	(PCM) Project Complete
		 	
		L	

A Project Execution Plan (PEP) will be approved by Jun 2007

Comments:

Approved PEP (NK38-PEP-73920-10001) will be revised by June 2007.

ONTARIO GENERATION

BUSINESS CASE SUMMARY

DND: Chiller Replacement to Reduce CFC Emissions 16 - 33631

Full Release (Phase 1) Business Case Summary D-BCS-73910-10002-R002

Routing	Location	Action	Signature	Date
A. Yen Project Leader, Design Projects 703-3557	BW7-02	Prepare BCS	a.fa-	APR.26,2007
M. Guy Project Manager, Design Projects 763-3550	BW 7-02	Review BCS	RUGun	APR 2 6 2007
J. Taras Section Manager, Project Mgmt Office 703-3528	BW7-02	Review BCS	\$ Jaras	Apr 26/07
T.Chong Manager, Design Projects 703-3520	BW7-02	Review BCS 🛸	July	2629-2007
J. Lehman Manager, Porformance Engineering 703-7484	D08-ES2	Review BCS	All	or may of
D. Williams Mapager Projets Design 703-1963	D08-ES3	Review BCS	Sill	04 M . 207
A. Kleer Senior Ponocial Analyst (2-4110/400-7720	P82-3	Review BCS	Milkleer	0411/ 2007
Amone Orocler, Projects & Modifications 701-6053	P72	Review BCS -	Del-e	04 MAY 30001
W, Robbins Senior Vice President, Darlington 703-7499	D08-ES3	Submit BCS	pychobbus	20070507
R. Leavill Director, Investment Management 702-5086	D08-ES3	Approve BCS	The and the	S20]·02·10
D. Power VP, Corporate Investment Planning 400-7172	тсн07-D06	Approve BCS	a same	2007-05-18
J. Beech VP. Nuclear Finance 400-7226	ТСН09-D06	Approve BCS	Anto	2007-05-18
T. Mitchell Executivo Viec Preggigm & CNO 702-5294	P82-6A	Approve BCS	Muitcher	31-1494-07
	· · · · · · · · · · · · · · · · · · ·			
R Ball		Destrees		
- An Call Senior Empirical Analyst 22-4084	P82-3B6	Return For Distribution		

Γ_{3}	20	80	: 1837	\$ e	12534
1.1	11.22	しょもい	163845	8218	しょうシンター

No. of the local division of the local divis	CONTRACTOR OF CONTRACTOR	Southern States	10000	A		ACCURATE OF		記録					
							A period	AND AND A	Actesia	2	<u>n</u>	Anna A	

DND: Chiller Replacement to Reduce CFC Emissions 16 - 33631

Full Release (Phase 1) Business Case Summary D-BCS-73910-10002-R002 RECOMMENDATION: alah

Approval of this Phase 1 Full Release is requested, to

- Reduce the total project cost from previously-estimated 23.245M\$ to 14.9M\$ (Capital)
- increase the approved amount from 6 369MS to 10.44MS for this Phase 1 ÷
- Furchase 11 chillers all at once instead of individually, thereby achieving significant price savings
- Justall three chillers under this phase and the remaining eight in Phase 2. ÷
- Complete the detailed engineering and procure the materials for the additional scope to improve the chiller system pedennance

The hospess objective of this project is

- To replace the 11 existing chlorofluorocarbon (CFC) based water-cooled chillers at Darlington with units that use an approved refrigerant by January 1, 2015 in order to comply with Environment Canada's 2003 Halocarbon Regulations
- To improve the performance of Darlington chiller systems at low load conditions.

A particl release of \$6.4M was approved in May, 2006 to complete the detailed engineering, procure 2 chillers and install the T-pipe lie-lins. The detailed engineering is scheduled to be completed by Q4 2007

During the detailed engineering, it was realized that significant savings in design/engineering costs could be realised and the costly installation strategy was not necessary if the manufacturer were to supply the chillers with the same power voltages and nozzle oriontations as the present ones, i.e. custom-make the chillers to fit OPG's specific needs. The preferred menufacturer agreed to this, while also offering a significant discount if all 11 chillers are procured at the same time.

In addition, a close examination was made of certification/registration requirements. It was found that the requirements ginally proposed are not necessary and thus additional savings were realized. Specifically

- CNSC Gode & Classification and TSSA Registration were exempted per newly issued N-PROC-MP-0040 and 0082 0
- CRN for individual component within the chiller package is not required since the Darlington chiller system is not a redistored system.
- PEO storups on vendor's drawings are not required

As a result is a new astimated that the project can be completed for 14.9M\$ (Capital). The experience gained during the installation of first three chillers will be used to estimate the remaining work for the Phase 2 Release.

S000's (incl contingency) Funding	LTD 2006	2007	2008	2009	2010	2011	Later Total
Currently Released Parity	2,889	3,480	n na na manana na n	nnarrenne vier de en als annes es ar presad sur ĝinas de			i met demonsteristissementaliseren internetienen. 19359 :
Requested New Full - Phase 1		(2,075)	3,046	1.200	1,200	700	4.071
Future Funding Regid Full - Phase 2				1.800	1,660	1,000	4,460
Total Project Cests	2,889	1,405	3,046	3,000	2,860	1,700	* 14,900
Other Costs				nanon a ni si anan unders fano nassandis e s - -		*** * * ** ** ***	••••••••••••••••••••••••••••••••••••••
Ongoing Costs	1						······································
Grand Total	2,889	1,405	3.046	3,000	2,860	1,700	- 14,900
Investment Type Sustaining	Clase Cipit	3 al	(IEV) Impact (8,7)	on Es Value 78)	IRI NV	l	Discounted Payback

Date

Date

Submitted By 2007-05-07 W Reddin Senior VP Carlington Emanus Appendi 2007-01-18

VP, Grobert Emano

ine Approval (Per OAR Element 1.1 Project in Budget):

Mitchell 2007-05-31

Mitchell -Enerutive-Vine-President-& CNC Date



21 BACKGROUND & ISSUES

Regulation Requirement

Halocarbons are chemical substances that include, among other components, halogen (bromine, chlorine and/or fluorine) and carbon. They are used specifically as refrigerants in air-conditioning and refrigeration systems, fire extinguishing agents in fire extinguishing systems and blowing agents in the manufacture of foams and as solveots. Halocarbons pose a double-edged environmental problem. Firstly, most of them contribute to the depletion of the stratospheric ozone layer. Secondly, they are greenhouse gases which contribute to climate change. Hydrocarbons are identified by an alphanumeric code, with R-11 being the most common refrigerant in use.

Environment Canada's 2003 Federal Halocarbon Regulations mandate the phase-out of equipment containing CFCs. The following specific excerpts of the regulations apply:

- "Effective January 1, 2015 no person shall operate or permit the operation of any chiller [containing CFCs]" (Section 20)
- Between January 1, 2005 and December 31, 2009 an overhauled/recharged chiller is allowed to
 operate for one year from the date of charging. An overhaul does not constitute the replacement of
 parts in the course of OPG's normal maintenance.
- The one-year grace period for repairs disappears on January 1, 2010.

The Ontario Government is seeking to phase-out CFC refrigerant on January 1, 2012, 3 years earlier than Federal (segulation) This change impacts the TRF chiller which is under Ontario Provincial jurisdiction.

in addition, the poor performance of the existing 3-way control valve is identified as impacting the chiller operating at the low load condition. Darlington requested to replace the 3-way valve and its controller in order to improve the performance of chiller system.

Project Scope

Dariington has total twelve (12) chillers inside operating island. One of TRF chillers was replaced with a chiller using R-134a as refrigerant in 2002 through Project # 31531. This project will replace Darlington's eleven (11) R-11 refrigerant water-cooled chillers with R-134a refrigerant water-cooled chillers:

- 2 chillers (2x100% configuration) in Central Service Area (CSA) provide cooling to CSA and Main Control Room (MCR). CSA chiller is in-service year-around and has no off-season.
- 8 chillers (2x100% configuration) in Reactor Auxiliary Building (RAB) provide cooling to RAB and the instruments for shutdown system. RAB chiller is off-service from November to April.
- Lobiller (2x100% configuration) in Tritium Removal Facility (TRF) provides cooling to Heavy Water Management Building (HWMB). TRF chiller is off-service from November to April.
- Eleven (11) 3-way control valves and controllers for each of new chillers.

A revised Project Execution Plan is projected to be approved in Aug. 2007.

The chiller installation includes the removal of the existing chillers, at a total value of \$330K. There is no significant salvage value to be realized from the existing/old chillers due to the age of the equipment and the phase-out of R-11 refrigerant.

-		
ONTARIO E E E	OPG Confidential	Page: 4 of 16
all the second		(2) set a subset of the set of
GENERATION	BUSINESS CASE SUMM	ARY

Technical/Design Requirements

The eleven chillers and other required materials were originally estimated to cost the however the lowest acceptable bid came in at the following the technical/design requirements, the following changes have significantly reduced the cost of 11 chillers down to the following the technical design requirements are supported by the cost of 11 chillers down to the following the technical design requirements are supported by the cost of 11 chillers down to the following the technical design requirements are supported by the cost of 11 chillers down to the following the technical design requirements are supported by the cost of 11 chillers down to the following the technical down to the following technical down to the cost of 11 chillers down to the following technical down te

- Canadian Registration Number (CRN) for each individual Pressure Boundary (PB) component in the chiller package is not required per CSA B51 (PB Code) since Darlington chiller system is not a registered system. However, the vendor shall supply Darlington the chiller with one CRN per CSA B52. (Refrigeration Code)
- The requirement for vendor's drawings to be PEO stamped was eliminated from the Technical Specifications as per N-LIST-01300-10000
- Due to the changes above. OPG is able to look for a proposal directly from the chiller manufacturer, instead of seeking the proposal through a commercial grade dedicator.

Optimized Installation Strategy

We optimized the new installation strategy as per the following changes, resulting in a reduction in the estimated installation cost from the estimated cost from the estimated installation cost from the estimated cost

- Based on a Constructability Operability Maintainability and Safety (COMS) screening conducted at the scoping phase in 2004, we had planned a costly strategy to install T-pipe tie-ins and "3rd chiller" (to provide backup during the installation) for the replacement of the 2 CSA chillers. Now, based on keeping the chiller physical configuration the same, thereby reducing installation duration and risks, we are able to replace the 2 CSA chillers without having to use a backup. The stakeholders agreed to proceed with this new installation strategy by re-assessing the COMS requirements.
- We requested the vendor to supply the chillers with the same power voltages and similar nozzle opentations, which will minimize the field work.
- As a result of this installation strategy change, we are able to lower the estimated engineering cost from the strategy and project management cost from \$1.4M to \$1.1M respectively due to:
 - * The detailed design schedule (design agency) being shortened by 4 months (Fixed price)
 - The work load of OPG project team being significantly reduced.

Installation Schedule

We will use the chiller off-season, November to April, to replace RAB chillers. Two RAB chillers were selected as part of the scope of Phase I to gain installation/commissioning experience and confirm the installation cost. In addition, the TRF chiller will be replaced in Phase I to ensure that Darlington will comply with Ontario CFC regulation. The following is the planned chiller replacement schedule:

2008	Q1 2009	Q1 2010	Q1 2011
2 RA8 chillers (Q1)	1 CSA chiller and	1 CSA chiller and	
1 TRF chiller (Q4)	2 RAB chillers	2 RAB chillers	2 RAB chillers

ONTARIO PORTA GENERATION

OPG Cosfidential

Page: 5 of 16

BUSINESS CASE SUMMARY

5 (c.

3/ ALTERNATIVES AND ECONOMIC ANALYSIS

	Alt 1 (Rec	ommended) Alt 2	Alt 3	Alt 4 Alt 6
\$000's	Choose One Full	Incremental P Delay		
- Andreas (1996) Andreas (1997) Andreas (1997)	Cost	Cost Cost	ing a particular de la construcción de la construcción de la construcción de la construcción de la construcción El construcción de la construcción d	
Project Cost	(11,603)	(13.066)		
NPV (aller fax)	(8,778)	(8,950)		
Impact on Economic Velue, (IEV)	(8,778)	(8.950)		
	· N/A	· · · · · · · · · · · · · · · · · · ·	:	
Oscourteo Payback (Yrs)	N/A		· · · · · · · · · · · · · · · · · · ·	

Stop the Project - Not Recommended

We do not recommend stopping this project as OPG must demonstrate to the public that the company is environmentally responsible and complies with all Federal and Provincial Environmental Regulations.

To do nothing will force OPG to replace the existing R-11 chillers when they are broken down. As well OPG would face the environmental penalty after the regulation effective January 1, 2015 and would be forced to replace those R-11 chillers any way at much higher cost.

Alternative 1 - Replace eleven R-11 chillers and eleven 3-way control valves - Recommended

vve Mile Stelenske

We recommend this alternative as it allows us to procure all 11 chillers and start replacing the existing R-11 chillers in order to comply with the halocarbon regulatory deadline of January 1, 2015. The strategy is to install the chillers, then learn from this release and obtain a Phase 2 release to install the remaining eight chillers. This othernative also makes an emergency replacement possible if any of the existing R-11 chillers fail prematurely since all 11 new chillers will be stored in OPG's warehouse.

Alternative 2 - Delay Project - Not Recommended

- There will be no one-year grace period (refer to Glossary) after January 1, 2010. Any failed chiller must be replaced instead of having it overhauled or recharged.
 - A temporary chiller is required since the lead time is about one year to deliver a chiller. It will cost more to order one chiller and the additional costs in engineering and temporary tie-in for a temporary chiller.
 - We are not able to conduct an emergency replacement of a chiller if an existing chiller needs to be overhauled/ recharged since there are no new chillers available. In this case, we have to install a temporary chiller (an off-the-shelf chiller) to meet the need of the emergency before the Darlington specified chiller is delivered and installed.

Alternative 3 - Do Less - Not Recommended

We do not recommend doing less since all eleven (11) R-11 chillers must be replaced in order to comply with Federal and Provincial Environmental Regulations

Alternative 4 - Do More - Not Recommended

We do not recommend doing more as the scope of this release aligns with the project objective addressed in Project Charter

Alternative 5 - - Not Recommended



4) THE PROPOSAL

The major project deliverables for this project are as follows:

This Release

- Procurament of all 11 chillers and 11 3-way control valves with controllers.
- Complete the detailed engineering for replacing of 3-way control valve.
- Revision of Project Execution Pian NK38-PEP-73910-10001
- Installation/commissioning of 2 RAB chillers and 1 TRF chiller
- Declaration of 2 RAB chillers and 1 TRF chiller in service
- Full Release BCS Phase 2.

Release Phase 2

- Revision of Project Execution Plan NK38-PEP-73230-10001
- Installation/commissioning 11 3-way control valves
- * Installation/commissioning of the remaining 2 CSA chillers and 6 RAB chillers.
- Declaration of the remaining 2 CSA chillers and 6 RAB chillers Available for Service
- Declaration of 11 3-way control valves Available for Service
- Post Implementation activities
- Project close-out



- The addition of refrigerant leak detection and an alarm system will provide an automated early warning system. These additions have a positive benefit to worker and environment health and safety and also on equipment health monitoring
- Improvement of equipment reliability due to new technology with commensurate reduction in ongoing maintenance and spare parts

7 65 16 、学の得に OPG CONDERN

ANTENNOS DONO DONANONO

SXSX/3

and the second second

Description of Risk	Description of Consequence	Risk Bafore Mitigation	Witgating Activity	Risk Affer Mitigation
Gost Since the detailed engineering has not been completed to date. the detailed installation scope has not been finalized.	The cost estimate in Project Cost Summary needs to be adjusted	Meclum	 The cost will be adjusted at Phase 2 BCS as per actual Phase 1 installation cost. Phase 2 bootingency is available. 	- And
The vendor drawings are not available.	 The design agency may claim delay charges due to a lack of vendor's information. The milestone of issuing DCP packages may be missed. 	hedium	 Actively support Supply Chain to get the the chilter PO issued ASAP. Intend to introduce incentive or penalty into the PO to encourage the vendor submit the drawing as early as possible. Reserve encourage the contingency for delay charges. 	Low
Scons. 1999				
The poor performance of the existing 3-way control existing 3-way control valve/controller has been identified as a contributing factor to poor chiller performance at low load, however, replacement alone may not be sufficient to allow reliable operation at low load.	Additional modifications may be required impacting both cost and schedule.	Medium	 Detailed investigation into the low load performance issues will be conducted. The most cost effective solution will be adapted. Reserve control specific contingency for the additional engineering. 	Nedum
See Cost and Technical				
Schedule				And and the property of the contract of the second s
Very tight installation window.	The installation will be delayed one year if the off-season is missed.	Low	Expedite completion of RAB chiller DCP.	Low
Long lead time required for	The off-season will be missed if the		Expedite delivery of 2 RAB chillers to meet installation schedule.	Aon

BUSINESS CASE STRAMARY BUSINESS CASE STRAMARY In Schedulet at countor at countor at countor at one for schedulet at any low are not evalible are not eva		 A Balls Balls <l< th=""><th></th><th>· · · · · · · · · · · · · · · · · · ·</th><th></th></l<>		· · · · · · · · · · · · · · · · · · ·	
 Interther to the replaced (PFU) mu, at extension and the regulation form of the replacement of the regulation of the state of the replacement of the regulation of the regulation term in order to commit the regulation term in order to commit a second of 2009. Intern the chiller is operated at very low medium is the regulation term in order to commit a second of 2009. Intern the chiller is operated at very low medium is the regulation term in order to commit a second of a 2009. Intern the chiller is operated at very low medium is the regulation term in order to commit a second of a 2009. Intern the chiller is operated at very low medium is the regulation term in order to commit a second of a 2009. Intern the chiller is operated at very low medium is the regulation term in order to commit a second of a 2009. Intern the chiller is operated at very low medium is the regulation term in order to commit a second of a 2009. Intern the chiller is operated at very low medium is the regulation term in order to commit a second of a 2009. Intern the chiller is operated at very low medium is the regulation term in order to commit a second of a 2009. Internation term in an order to a second of a second of		and the second	¹ A = 1 × 1	- And the second second	
01 The officer to be represented information of the mark of			<pre>contraction of the contraction of the contract</pre>		
Uf The offset to be represented in the end of t	on first installation.				
Non The installation/commissioning using the installation/commissioning using the installation/commissioning using the installation lactor. geam happen if resources are not available. Low 1) Work with Contract Management Office to select an installation lactor. geam happen if resources are not available. Scheoue the commissioning tasks in FG to the installation lactor. when the chiller is operated at very low Medium See scope tick when the chiller is operated at very low Medium See scope risk usal Commissioning tasks in FG to the commondances etc. in the chiller typs. advis beyond the design margin leading to chiller typs. advis capacity specified advis capacity sp	The new TRF chiller (RFU freplaced in 2002) currently has difficulty running at low toad condition.	The chiller to be replaced (RFU2) may not be allowed to shut down for replacement as per the scheduled period, Q4 2008.		(FUT in O4 2007 to verify in ty 1 can't meet the tow the replacement will ing next TRF outage, Q1 20	2) 10
 The installation/commissioning will not be reacted in an ansallation feature of missioning will not be reacted in an ansallation feature. The installation features are not available to the installation feature of the commissioning tasks in IPC to reserve the Mischanical Maintainer resources are not available to the commissioning tasks in IPC to reserve the Mischanical Maintainer resources (Commissioning task) when the chiller is operated at very low medium be operated at very low medium be office to availy control verse to components, such as a day beyond the design margin leading to chiller typs. Chiller tips. The new chiller available margin leading to chiller typs. The new chiller available to the commission area available to the commission area available to the commission area available. Chiller tips. Ch					
When the childer is operated at very low load (<10%), some components, such as lity of beyond the design margin leading to chiller rips.	Availability of the installation team and commissioning team	The installation/commis happen if resources are	Low	 Work with Contract Management Office to select an installation team in order to commit to the installation labour. Schedule the commissioning tasks in IPG to reserve the Mechanical Maintainer resource. (Commissioning team) 	80
When the chiller is operated at very low Medium See scope risk ed 3-way control values, controllers etc, in Medium See scope risk 40% 3-way control values, controllers etc, in See scope risk 40% beyond the design margin leading to A0% 1 chiller trips. Chiller trips. and chiller trips. Control values, controllers etc, in tity of beyond the design margin leading to Control values, controllers etc, in tity of beyond the design margin leading to Control values, controllers etc, in tity of beyond the design margin leading to Control values, controllers etc, in tity of beyond the design margin leading to Control values, controllers etc, in tity of beyond the design margin leading to Control values, controllers etc, in tity of beyond the design margin leading to Control values, controllers etc, in tity of capacity specified Control values, controllers etc, in tity of capacity specified Control values, contrect test report for each individual control values	· · · · · · · · · · · · · · · · · · ·				: •
When the chiller is operated at very low Medium See scope risk ed 3-way control valves, controllers etc. in Medium See scope risk 40% 3-way control valves, controllers etc. in Ao% Deyond the chiller system may be operated 40% beyond the design margin leading to Ao% Deyond the design margin leading to It of the rew chiller may not achieve the Low 1) Project team will witness the tests to ensure that the new chillers achieve the capacity specified fills fills The new chiller may not achieve the Low The new chiller may not achieve the Low 1) Project team will witness the tests to ensure that the new chillers achieve the capacity specified by the manufacturer The commissioning may be delayed if Medium 2) The manufacturer aperformance test report for each individual chiller. Chiller Deperator and Maintainer are not familer 1) Project Team has reserved 40 hours of chiller.					
The new chiller may not achieve the capacity specified. Low 1) Project team will witness the tests to ensure that the new chillers achieve the capacity 0% ~ 100% (RAB & TRF chillers) and 10% ~ 100% (CSA chiller) specified by the manufacturer The commissioning may be delayed if 2) The manufacturer will provide a performance test report for each individual chiller. The commissioning may be delayed if with the new chillers 1) Project Team has reserved 40 hours of basic training, provided by the manufacturer.	Jow Load Operation Project team has identified hat the capacity of the existing chillers is about 40% nigher than that required furing normal operation. However, the stakeholders would like to keep capacity of he new chillers the same as he existing one in case of any emergency event.	When the chiller is operated at very low load (<10%), some components, such as 3-way control valves, controllers etc. in the chiller system may be operated beyond the design margin leading to chiller trips.	and a second	See scope risk	×
The commissioning may be delayed if Medium 1) Project Team has reserved 40 hours of Operator and Maintainer are not familiar basic training, provided by the manufacturer, with the new chillers	Chiller Performance	ay not	o T	 Project team will witness the tests to ensure that the new chillers achieve the capacity 0% ~ 100% (RAB & TRF chillers) and 10% ~ 100% (CSA chiller) specified by the manufacturer The manufacturer will provide a performance test report for each individual chiller. 	,
	Operator and Maintainer raining	The commissioning may be delayed if Operator and Maintainer are not familiar with the new chilters	Wedium	1) Project Team has reserved 40 hours of basic training, provided by the manufacturer. In order for the Operators to initially startup a	Low

	OPG Carrière		1.5. m. 1. m 1. m. 1. m 1. m. 1. m. 1 m. 1. m. 1 m. 1. m.	
		2048	ŝ	
		ESS CASE SURMARY		
		· · · · · · · · · · · · · · · · · · ·	chiller and the Mampaners to conduct basic maintenance before the first chilter is commissioned Additional training will be provided as required. 2) The manufacturer will provide a service engineer to supervise the initial settings and commissioning for each chilter	ask be and
ired as per code CSA B52 loop)	The chiller cannot be operated without a valid CRN.	P P	 Vendor is required to supply the chiller with a valid CRN. The preferred vendor the has the experience to apply CRN for its customers. 	the Low
Environmenta l				
eôe	The chemical impacts the environment	t Low	A refrigerant leakage detection and atarm system is provided for each chiller.	m Low
Health & Safety				
or serious	The event may impact project schedule and costs.	≷ C	Work to be performed per existing OPG safety rules, procedures and OH&SA regulations. Any non-standard conditions will be identified via workplans and pre-job briefings.	b ≡ b b
Large amount refrigerant Poter leakage that may pose an the st increased risk to station staff. mech	Potentially create a chemical hazard to the staff who are working in the mechanical room.	Γο	The refrigerant leakage detection and alarm system is interlocked with the mechanical room ventilation fan system. The ventilation fan system will automatically activate to reduce the refrigerant concentration when the refrigerant leakage reaches the set point.	cal to nt.
invostment				
No risk is identified				



.....

BUSINESS CASE SUMMARY

7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Final / Date:	vrs []	Targeted PIR Approval Date:	PIR Responsibility (Sponsor Title)
				Manager
Simplified	May 2011		Dec 2011	Performance
	: :		a a a a a a a a a a a a a a a a a a a	Engineering

na orazona orazona

Comments:

Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it? (person / group)
 Environment Canada's 2003 Halocarbon Regulations 	Will not be in compliance with the regulations after 2014.	Comply with the regulations	The new chillers with approved refrigerant in service	All AFS signatories sign-off "Declaration of Available for Service" N-FORM-10091
2	· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·	ματοποίος του το	
3	· · · · ·	· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·
		۰		ι το
		· · · · · · · · ·		
				······································

ONTARIO FORMERS

BUSINESS CASE SUMMARY

Appendix "A"

Glossary (acronyms, codes, technical terms)

- CEC Chierefluorocarbon
- CRN Canadian Registration Number
- PEO Professional Engineer of Ontario
- CSA Canadian Standard Association
- PB Pressure Boundary
- CSA Central Service Area
- RA8 Reactor Auxiliary Building
- TRE Tritum Removal Facility
- COMS -- Constructability Operability Maintainability and Safety
- P8 code (CSA 851) Governing requirement for Pressure Boundary system
- Refigeration Code (CSA B52) Governing requirement for refrigeration system
- Evaporator -- Heat exchanger, in which refrigerant cools down chilled water
- Condenser Heat exchanger, in which refrigerant is cooled by water or air
- Water-cooled chiller Refrigerant is cooled by water
- Refrigerant loop A closed refrigerant loop inside chiller, including compressor, refrigerant sides of evaporator and condenser, etc.
- Chiller Package Chiller mechanical package, including refrigerant loop, evaporator and of condenser, etc.
- R-11 CEC based religerant
- R-134a Approved non-ozone depleting refrigerant without phase-out time
- Federal Halocarbon Regulation Phase-out CFC based refrigerant equipment on January 1, 2015.
- One-year grace period Overhauled/recharged chiller can only be allowed to operate for one year from date of charging effective from January 1, 2005 to December 31, 2009.
- T-pipe tie-in A new system will tie-in to the existing system through a T-pipe.
- "3^{eff} chilter" configuration Due to project scoping phase and conservative approach, an installation strategy was proposed to
 - Instell T-pipe tie-ins first
 - Install a new chiller (3rd chiller) at new location with new piping system, new power/instrument cables, new monorail, new plinth etc. before replacing the 2 existing CSA chillers.
 - Replace one of the existing CSA chillers with a new one.
 - Dismantle another existing CSA chiller and associated piping, cabling etc.

0	Sugar State	1000	ß	3022200000					
					100.24 100.24	and the second	A	TI(JN

Appendix "B"

OPG Confidential

BUSINESS CASE SUMMARY

Project Funding History

5410 5	5/400			ous Reie Cum	ases (inc ulative V						
Rolease Type	Month	Year	2004	2005	2006	2007	之间的	2009	2010	Later	Total
[]]eestermentel	April	2004	520								520
i i deren i i i i i i i i i i i i i i i i i i i	Feb	2005		620		(* 1					620
Policy and	Jan.	2006		No	300			na anna an taonachta ann			300
$T^{(n)}(t^{(n)}) \mapsto t^{(n)}$	Мау	2006	500	576	3,367	1.926		on y conservations and an and an and	And and a first of the second s		6,369
				<pre>cq************************************</pre>	2	2				(m	0
a sarwarya		leann tean an ga an tarat ag		4		2	2	f - Maria Politica and Coloriana	a salati an an an an Anna Anna Anna Anna Anna A		0
		· · · ·		}		······································	8	n de la constanta de la constanta en seconda de server se	ante ante ante ante ante ante ante ante	an a	0
1.199.2021					2						0
										Service in a service of the service	

LID Spam	501	576 1	,812	*	2,889
Comments:	 		n a martin a substitution (* 1990)	2. 20. Sec. Comparison of the state of th	ан мар самбалай бан таралай тара бан бан 90 мин тара тара тара тап банад байлаганан ан катан жалан ана т

The development lunding was approved for Project # 16-38433. Project number changed because the funding changed from OM&A to Capital.

ONTARIO FORE

BUSINESS CASE SUMMARY

Appendix "C"

Financial Model – Assumptions

Project Cost Assumptions:

- * The additional scope is added to this project as per request of project sponsor.
- The detailed engineering for the chiller replacement packages has been completed at about 80% and the cost for Design Agency is fixed.
- The additional scope will be initiated from the problem identification process.
- The chillers proposed by the manufacturer meet the technical requirements.
- OPG has received the quotation for the chillers.
- Project bas a budgetary quotation for the installation cost. The installation cost will be adjusted at Full BCS Phase II as per the actual installation cost.

Financial Assumptions:

NPV discount rate = 7%

Project / Station End of Life Assumptions:

Station and of life at 2018

Energy Price / Production Assumptions

N/A

Operating Cost Assumptions

The new chillers have the same operability as the existing ones. Operating costs for the new chillers will be the same as the existing ones or slightly lower.

Other Assumptions:

 For Alternative 2, a 2-year delay: it is assumed that a failure would occur, necessitating purchase and installation of a temporary chiller at a cost of the second ONTARIOF DER GENERATION

OPC Confidential

Page: 14 of 16

BUSINESS CASE SUMMARY

DND: Chiller Replacement to Reduce CFC Emissions 16 - 33631

Full Release (Phase 1) Business Case Summary D-BCS-73910-10002-R002

Attachment "A"

Project Cost Summary

	LTD	This	This	Fulure	Future	Future			
\$000's	Prior Yr	Release	Release	Release	Release	Release			
Capital	2006	2007	2008	2009	2010	2011		Later	Total
Project Management (OPG)	450	153	157	120	120	110	-		1,110
Engineering & Draiting (OPG)	487	176	80	65	65	70			943
Material					,				R
Jastailation - PWU, 8711									
Contract - Design					antan in Karing	Silenteta anti			
Contract installation					entert vervisst ogs	laan oo lagt di in ing			
Contract - Other						na gang nganga Sanggang Sang	ang sa sa sa s Agasarta	andar ang ang ang ang a ang ang ang ang ang ang ang ang ang ang	
Interest (Capital Project Only)			n an						
Ptoject Costs (excl condugency)									
General Contingency		<u>an an a</u>					Jefe Deter		
Specific Centingency								and we are shown a	
Project Costs (Incl contingency)	2,889	1,405	3,046	3,000	2,860	1,700	1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1	Munin Santein	14,900
2007-2011 Business Plan		583	4,500	4,000	3.850	4,019			16,952
Variance to Busineos Plan	2,889	5 Partie	(1,904)	(1,400)	(1,290)	(2,469)	and the	A. Los P. L.	(3,652)
Commissed Cost			a i v i ve vi v nijej ve jaken di kange	1			e daline fostener destruire ne fining grands	genety) when in the set of the system of the set	2019 in an in 1212 integrating 1712 in 1717 in
Inventory Write Off Required				*******	and a second second second				*
Spare Parts / inveniory						• · · · · · · · · · · · · · · · · · · ·			· · ·
Total Release (excl contingency)	2,889	1,105	2,596	2,600	2,560	1,550			13,300
Total Release (incl contingency)	2,889	1,405	3,046	3,000	2,860	1,700	harrien greete produkte alexander de		14,900
Ongoing OMAA (non-project)		ang et av wir son of tage at least start of e		enopera vela, valore a port					
Removal Costs (incl in above)	H ERE AND		90	080	90	60		all search and	330

		Basis of Es	timate			
Design Complete	,	Up to - 40%	Quality of Es	stimate	Release + 15	% to - 10%
3 ¹⁴ Party Estimate	Yes	OPEX used	Yes	Lessons Lea	irned	Yes
Reviewed by Sponsor	No	Budgetary Quote(s)	Yes	Phase 1 Act	ual Used	N/A
Similar Projects	Yes	Contracts in place	No	Competitive	Bid	Yes
		Variance to Bus	iness Plan			

The estimated variance(s) to the 2007-2011 Business Plan will be addressed through the portfolio management process. A PCRAF will be approved by May 2007

Reviewed By Approved By: APR 2.6 2007 26 Np1-200 M. Guy T. Chonig Date: Date: Project Manager Eng & Mod& Manager (Strat IV)

ONTARIO FIRENERATION

BUSINESS CASE SUMMARY

DND: Chiller Replacement to Reduce CFC Emissions 16 - 33631

Full Release (Phase 1) Business Case Summary D-BCS-73910-10002-R002

Attachment 'B'

Project Variance Analysis

		Choos	e One		
Capital	LTD Dec	Last BCS May	This BCS Apr	Variance	Comments
	2006	2006	2007		Loop work lood due to the phonen of
Project Management (OPG)	450	1,395	1,110	-285	Less work load due to the change of installation strategy
Ingineering & Dratting (OPC)	487	1,794	1,143	-651	Less work load due to the change of installation strategy
Material					n an
nstallmon - PWU, BTU					
Contract - Design			n an		
Contract - Installation		te date with grap filled and	ina na kanaka da . Da da na kanaka da .	ne Cranes In Cranes In	
Contract - Other	na 2018. Ngjarit		nana ang ang ang ang ang ang ang ang ang		
nierest (Capital Project Only)					D
Project Costs (exc) continuency				ander and an and an an and an and an	
Seneral Contingency	alla incorrection				
Specific Contingency					
Project Costs (Incl contingency)	2,889	23,245	14,900	-8,345	
Committed Cost				0	
oventory Write Off Required				0	
Spare Parts / Inventory	H. Barre, D. Dirace Science Association and a factors Strategies and Science Association and a strategies of the science of the science of the science of the science		1111 J. J. B. B. M. H.	0	
Total Nelease (incl contingency) Total Release (citcl contingency)	2,889 2,889	23,245	14,900 13,300	-8,345 -6,301	
A MARTA A BARAMANANA ALAMA MANTALANANANA KATAN	an a	n 12,994	escholouutii	here and on the	
Oncolleg OM&A (wav-project)				0	
Removal Costs (Incl in above)	ng paping talang kang ban ng pang di di Sanna pang barta pana ang pang pang pang pang pang pang	0	330	330	Removal costs: \$30K/chiller

Comments:



.....

BUSINESS CASE SUMMARY

liacisment "C"

Key Milestones

Ç.	mpletion C	late	Description
Day	MA	Yr	ν
29	06	2007	LLA - Long Lead Time Material Contracts Awarded
15	10) 1	2007	DCP - Issue DCP package for RAB chillers, detailed engineering completed.
07	2000 - 100 -	2007	DCP - Issue DCP package for TRF chillers, detailed engineering completed
07		2007	DCP - Issue DCP package for CSA chiller, detailed engineering completed.
1.36		2007	ICA - Award Installation labour (2 RAB & 1 TRF) contract
14		2007	PTA - Ready for installation, work package assessed and ITP issued - U1-RFU1
11	61	2008	PTA - Ready for installation, work package assessed and ITP issued - U2-RFU1
04	02	2008	SOI - Start of Installation of UI-RFU1 chiller
10	63	2008	SOI - Start of Installation of U2-RFU1 chiller
30	03	2008	DES – Preliminary Engineering for 3-way valve completed
20	- 66	2008	AFS - Declaration AFS for U1-RFU1 chiller
20	1.5 4 0	2008	AFS - Declaration AFS for U2-RFU1 chiller
31	10	2008	FR2 - Full Release BCS Phase II Approved
03	11	2008	SOL Start installation of TRF chiller
23	12	2008	DCP Detailed enginnering for 3-way valve completed.
26	06	2009	AFS - Declaration AFS for TRF chiller

A Project Execution Plan (PEP) will be approved by Aug 2007

Comments:

Page: 1

: 1 of 22

BUSINESS CASE SUMMARY

FH Computer Replacement 16 - 33815

ONTARIOPOWER GENERATION

Full Release Business Case Summary D-BCS-69740-10002-R000

Routing	Location	Action	Simoture	
S. May			Signature	Date
TE/O, DCCs	DCDFB	Prepare BCS	Stephenmay	8 June Der
S. llott				S SUMALECT
Section Manager, FH Technical	DOSB-2	Review BCS	<151 m	
E. Hung			CHART THE REAL	1 Juno
Section Manager, DCCs	DESB-2	Review BCS	1-11	
Wm. Owens			Care from	opre12, 27
Manager, Darlington Fuel Handling	DOSB-2	Review BCS	tothe .	11 June 07
R. Hohendorf				Il ganeo
Manager, Computers and Control Design	P82-5	Review BCS	All II	1) 12 200
D. Zerkee			- many	Jene 13, 2007
Manager, Investment Management	P83-3	Review BCS	A. S.	13500 67
R. Leavitt				10 001
Director, Nuclear Investment	P82-3	Review BCS	Flandet	June M. 200
Dermarkar				
Director Engineering Services	P82-6	Review BCS	11 d	17
3. Duncan	·····		11the	14 Jun 2007
Director, DNG Operations & Maintenance	DOSB-2	Review BCS	4-1 A.	
Beech			1 part in a start	See Franks
ice President, Nuclear Finance	P82-3	Review BCS	170	
/. Robbins				
enior Vice President, Darlington	DESB-3	Review BCS	Haynakable	3-07-06-27
Power		<u> </u>	1	
ce President, Corporate Investment anning	TCH-7	Review BCS	Q	A i
Mitchell			- aven	Jus 1/07
nief Nuclear Officer	P82-6	Approve BCS	Mantchey	0.1
			Convert	7 Aug 2001
	· · · · · · · · · · · · · · · · · · ·		} 	•
Bail				
or Financial Analyst	P82-3B6	Return		
-084	102.000	For Distribution		

ONTARIOPOTER **OPG** Confidential Page: 2 of 22 GENERATION

BUSINESS CASE SUMMARY

FH Computer Replacement 16 - 33815

Full Release Business Case Summary D-BCS-69740-10002-R000

RECOMMENDATION:

We recommend the approval of a release of \$12,470K (including contingency) to perform detailed engineering and installation of replacement equipment for Fuel Handling (FH) Control Computers and their peripheral devices. This project is an essential part of the Life Cycle Management Plan. The Business Objective of this release is to ensure that the Darlington FH computer systems operate reliably by relieving them of urgent age-related reliability problems. This release is needed in order to protect station generating capacity from an inability to fuel the 4 Darlington Nuclear Generating Station (DNGS) reactors due to failures in FH Control Computer system.

Computer internals and peripheral equipment replacements must be provided quickly to prevent loss of reactor re-fuelling capacity. Control console teleprinters are failing and must be replaced within the next 24 months. The stock of spares is expected to be exhausted by 2009.

This release will provide for the design of replacement FH CPUs and their offline testing facilities. An FH system simulation testing facility will be created to prove the replacement computers and their adjusted FH Control Computer software prior to their subsequent installations. A facility that will be a source of system control components that are known to be good will be set up to support regular effective maintenance subsequent to the computer replacements.

This release will provide for FH software updates to address legacy Human Factors Engineering issues, and provide necessary data access and display for today's FH operating environment. The FH operators' console will be modified to comply with Human Factors Engineering requirements that will support safe and reliable FH System operation.

This release will provide for the design of replacements for the control console teleprinters, operators' keyboards, main disk drives and interface boards, video display generators, main FH Control Computer internal interconnection busses, changes to e Human-System Interface, and computer surveillance and maintenance terminals. The paper plant will also be brought up date.

The installation of this equipment will take place starting in 2008 through 2012.

\$000 s (incl contingency)	Funding	LTD 2006	2007	2008	2009	2010	2011	Later	Total
Currently Released	Developmental	1.422		44 · · ·	i	2669 			1.422
Requested Now	Partial	(643)	1,450	3.593	2.339	1,919	1.865	525	11,048
Future Funding Reg'd	Full								
Total Project Costs	- · · · · · · · ·	779	1,450	3,593	2,339	1,919	1.865	525	12.470
Other Costs		·····	······································	· ·	• • •••••••••				
Ongoing Costs	· ····································						· · · · · · · · · · · · · · · ·		·····
Grand Total		779	1,450	3,593	2,339	1,919	1,865	525	12.470
Investment Sustainin		Clas Capit		(IEV) tripact o 5,051,4	C2200000000000000000000000000000000000	IRA 335.1		Discounted 3.3	the second s

Submitted By:

207-06-27 Date:

Lucy 1/07 Date:

W. Robbins Site VP. Darlington Nuclear

Finance Approval;

R Power

Director, investment and Business Planning VICE PRESIDENT Corporate Investment Planning Line Approval (Per OAR Element 1.1 Project in Budget): Madue

Date:

T Mitchell Chief Nuclear Officer.

2/ BACKGROUND & ISSUES

This project received its first funding in September 2005. The project has carried out developmental engineering in order to determine the best alternatives for resolving the age-related problems of the FH control computer system. The campaign also examined the candidate solutions for their value in view of a possible a life-extension of the

As well, the main Fuel Handling (FH) video interface monitor screens in the Main Control Room were successfully

This project supports initiative number 244 in the Darlington "Plant Reliability List". The Fuel Handling (FH) control computer systems are not expected to survive until the station's pressure tube end of life without the proposed device replacements. Weaknesses affect its central processing units and supporting subsystems and interfaces,

Reactor fuelling capacity (thus generating capacity) cannot be maintained in the long term unless action is taken to replace equipment that is now failing or about to fail. The CPUs will be out of spares by 2011. The console teleprinters must be replaced sooner, within the next 2 years.

FH Control Computer System Description

The Fuel Handling Control Computers direct the automated reactor fuelling process at the Darlington Nuclear Generating Station. Three pairs of PDP-11 computers control the trolleys, bridges and Fuelling Machine heads. Those computers are located in the Main Control Room area. An additional 4 computers control the new fuel loading into the mobile Fuelling Machine head and used fuel discharge processes in the Fuelling Facility Auxiliary Area buildings. Another PDP-11 is used for Fuelling Machine head setup and maintenance in the plant's Central

All of these computers must be functioning reliably in order to maintain automated fuelling capability. Automatic fuelling capability is required to stock the reactors with fuel that will keep reactor power levels in a range that will ensure economical nuclear fuel burn up and prevent unit de-rating or shut down.

Two trolley fuelling systems must be available in order to maintain adequate fuelling capacity. The FH systems equipment thus have marginal redundancy. The FH systems must have high reliability from the FH control computers as it cannot afford to have reduced capacity for any extended period.

Problem Areas

Maintenance of the FH control computer systems is becoming increasingly difficult. The control computer equipment in the FH system is nearly 30 years old. A trend of increasing obsolescence of control equipment components was recognized in 2002. That trend that has continued and many critical parts can no longer be obtained, and no support from the original equipment manufacturers is available for the computers.

- The most critical age-related problems in the Fuel Handling Control Computer systems are in the
 - Main computer console tele-printers,
 - Disk drive sub-systems,
 - Custom operator keyboards, •
 - Video Display Generators, .
 - Computer backplanes, .
 - Human-System Interfaces,
 - Central Processors and power supplies, and
 - Inadequate Component and Software Test Facilities.

Page: 4 of 22

BUSINESS CASE SUMMARY

Operator's Main Console

The existing Fuel Handling main panel was designed prior to now-compulsory Human Factors Engineering (HFE) reviews. The main panel layout exhibits a number of flaws because of this. One of the most serious problems is that operator must have his/her back to the main panel displays in order to enter data in another computer during times when high panel vigilance is required. Serious HFE problems were formally recorded in "Human Factors Assessment of the Control Centre Arrangement" [R-2] in 1997. This project addresses those as well as subsequently identified problems such as poor information grouping in displays, line-of-sight to outer panels, and inadequate indication of used fuel transfer status.

Main panel switches and indicators are labeled inconsistently among panels and their associated operating and design documentation. These problems are described more fully in "Fuel Handling Human Factors Issues" [R-1]. An attempt was made in 2005 by the Main Control Room Furniture project to resolve panel peripheral visibility and operator seating orientation. The work was unsuccessful in resolving these issues since the engineering resources needed to relocate main control interfaces to a new desk were not within the scope of that project.

Main Computer Console Tele-Printers

The tele-printers are old-style LA120 computer terminals that are used for direct communication with the FH Control Computers. They produce a printed record of all the FH machine control operations, errors and events. They are also used for computer start up, shut down, maintenance operations and emergency system control.

The LA120 tele-printers suffer from failing key-switches, and mechanical failures of the feed mechanisms, carriage drive and print heads. There are no more print heads available. The only source of the spare parts is from previously failed LA120's. Main circuit board electronic components are becoming increasingly unavailable

Disk Drives and Sub-System Controllers

Non-repairable and Insufficient Spares

The disk drive controller used on FH computers is obsolete, unsupported by any manufacturer, and not repairable. When the boards were purchased, a less than optimal number of spares were obtained. The controllers use a protocol that will soon be obsolete. There appear to be 2 options to prevent this weakness from shortening the computer's' life expectancy. The disk controllers could be replaced so that they work with an easily replaceable type of disk drive. Alternatively, long-life drives that are compatible with the existing controllers could be put in

Custom Operator Keyboards

The automatic input and semi-automatic control keyboards are subject to failures related to key-switches, memory chip failures and various electronic component failures. The power supplies of the semi-automatic keyboard are out of spares. The power supplies are increasingly difficult to repair due to their physical design and difficulties with obtaining replacement electronic components. The last of the failed keyboards are being cannibalized for

Display Generators

Each of the 6 Main Control Room FH computers is connected to a Ramtek model RM9400 video Display Generator (DG). The DG is required all the time when a fuel handling system is transferring nuclear fuel. If a DG becomes unavailable, an entire fuelling system is unavailable for service. Interruptions in operation of the video generator leave the operator without automatic fuelling control and without access to the system status data provided via the FH computers. Fuelling runs have to be suspended until a DG repair can be performed.

Instances of degraded performance of these units have coincided with slow operation of the control computers. ulting in stalls during the high-risk transfer of irradiated fuel from the F/M heads.

Computer Backplanes

The FH computer boards are plugged into a common back-plane via board-edge connector sockets. This

ONTARIOPOWE GENERATION

OPG Confidential

Page: 5 of 22

BUSINESS CASE SUMMARY

backplane is prone to non-repairable failures with age. Each back-plane contains from 54 to 264 sockets. Each socket has dozens of individual connections that are made by an unsoldered compression wire wrap using very fine gauge wire. When one of these connections fail, it is extremely difficult to localize. This is made more difficult on FH computers, since they lack a connection for a logic analyzer like the one added to the DCC computers by

Human-System Interface

The FH Control Computer software contains numerous long-standing deficiencies in video display data presentation. For instance, there are identical displays for similar equipment that is located in different buildings at the station. The building is selected when the display is active. If the display is exited to check on other status, the selection of equipment will change and the drive the equipment in the wrong building. These and many other problems were important enough that work was started to correct a number of these problems in 1994. That work was inadvertently abandoned due to changes related to funding and other re-organization issues when Ontario Hydro changed to OPG. The software shipment that was started needs to be finished. As well important problems that were identified in the Human Factor Engineering survey of the FH control system need to be resolved.

Central Processors (CPUs)

The FH Control Computers use model QED95 Central Processing Units. The QED95 CPUs were used to replace the original model PDP-11 CPUs when a significant processing performance was needed to reach the commissioning target for system response. The QED95s perform well but make use of a memory storage technology that is has a wear-out period that is entered about 10 years from when they are loaded with their program. The memories can't be re-written. As well, the board construction prevents replacement of those

he number of spares CPUs that were originally purchased assumed a lower failure rate and greater ability to repair them than was seen after they were placed in service. There have been ongoing failures in the CPUs of an undetermined nature. This situation is complicated by having too few spares to get to the station end-of-life. We expect that the stock of spare QED95 CPU's will be exhausted by 2012 based on the observed failure rates.

CPU Power supplies

These power supplies are not expected to last for the life of the station and are at best only marginally adequate for their present use.

There have been ongoing refurbishments of the power supplies. The power supply reliability can't be ensured since many electronic components required by this refurbishment campaign are expected to become completely unavailable in the next few years. Some of these components are those most susceptible to aging, and thus needing replacement (for example, electrolytic capacitors). These parts have limited shelf lives as well and so a strategy of increasing inventory to maintain parts availability wouldn't help since the parts could fail in storage

The present power supplies were designed for the original PDP-11 CPU, not the present QED95 CPU. CPU lockup during brown-outs or computer re-starts can happen, as seen during the Bulk Electrical System Failure of the Northeast grid in 2003. An uninterruptible power source is required instead of the existing switch-style supplies in

FH System Simulator

The problems that need to be resolved by a computer simulation of the FH system are:



Insufficient time to fully commission the FH system control on-line

No test facilities for proving protective logic in OpData (FH machine control programs) No test bed for representative integration testing of FH application software changes

Allows Off-line Commissioning of CPU Replacement

GENERATION

Page: 6 of 22

BUSINESS CASE SUMMARY

The simulation of the Fuel Handing system equipment will be developed to support the testing and commissioning of the CPU replacements in an off-line environment. This will make a retrofit of all 3 FH trolley control systems possible, while maintaining sufficient on-line fuelling capacity to support operation of the 4 Darlington reactors. For DCC computer systems, commissioning can be done during outages. This possibility does not exist for Fuel Handling systems, since they continue to operate through Unit outages. Unit outages present additional demands to FH, since the fuelling equipment redundancy is reduced when one system is dedicated full time to support reactor inspection equipment.

Although the upcoming Vacuum Building Outage (VBO) presents a time when reactor fuelling is not required, the constraints on the FH system operation make it an unsuitable to commission the processors and software. The time required to perform the commissioning work will exceed the length of the upcoming VBO. The commissioning testing will require the trolleys to traverse full length of the fuelling duct. As well, ports that cross containment boundaries would need to be opened, which is inappropriate activity for this kind of outage.

Provides a Needed Software Test Bed

The Fuel Handling system simulation will be used to verify changes to the complex fuel handling software. This will help ensure that software changes do not adversely affect the operation of the Fuel Handling Systems. A realistic off-line testing facility has not been available to verify fuel-handling software. Most of the control programs were developed during plant commissioning before reactor fuelling began. This method is obviously no longer available.

Hot Spares System

A standalone computer system is required to pretest and provide a stock of ready hot-swappable computer and control components for the fuel handling systems. This facility is available for computer systems of similar complexity, such as the common process and reactor controller DCCs. The absence of the Hot Spares system has resulted in significant delays in returning Fuel Handling computer and peripheral equipment to service.

This facility for FH Control Computers existed at one time. However the system was disassembled and removed by the plant computer maintenance group in 2004 so that a second DCC maintenance computer could be installed in its place. The FH Hot Spares system has not been reinstated since that happened. Some components for that system are missing due to their consumption as spare components in the running systems and will need replacement.

Surveillance and Monitoring Terminals

The Field Monitor and External Protective Operator Display computers are used to perform monitoring of system conditions and updates to programs in the Auxiliary Control Equipment Computers. These IBM-PC compatibles are obsolete as is their operating software. The spares for both of these computer systems are exhausted and they can't be repaired.

Related Projects

Lessons learned from projects 40505 (FH Typer), 33509 (Obsolete Computer Components) and 33977 (DCC Replacement) will be used by this project. Project 40505 replaced a tele-printer on the Pickering FH control interface that was similar to the Darlington FH console tele-printer. Project 33509 has provided replacements for certain critical DCC subsystems that use the PDP-11 computer. Project 33977 has started the design and manufacture of the new CPU that will be used to replace the PDP-11 CPUs in various DCC Computer systems. This computer CPU will also be used to replace the FH Control Computer's QED95 CPU.



Page:

BUSINESS CASE SUMMARY

7 of 22

3/ ALTERNATIVES AND ECONOMIC ANALYSIS

\$ 000's	Status Quo	Alt 1 (Recommended)		All 2	An 3	·	
		Full Cost	Incremental Cost	Delay	All J	Alt 4	Alt 5
Revenue OM&A	(20.071,403)	(1,879,309)		(6.219,845)			
Capital	(1.041)		(11010.000)	(0.219,045)	(3.854.015)	(1,564,501)	
NPV (after tax)		(10,337)	(9,558)	(17.033)	104 0001	• • • • • • • • • • • • • • • • • • •	
	(5,883,511)	(832,841);	(832.062)	(2,665,336)	(24,820)	(27.870)	
Impact on Economic Value (IEV)	N/A	5,050,670	5.051.449	3.218,175	(1.697,000)	(761.474)	
the second se	N/A	237.0%	335.1%	41.3%	4,186,511	5,122,037	
Discounted Payback (Yrs)	N/A I	3.4	3.34	10.1	138.8%	237.0%	
				10.1	3.4	3.4	

Stop the Project - Not Recommended

This involves rejecting the recommendation and not providing the requested scope. The impact would be a loss of automated reactor fuelling capacity by 2011. Experience with the Darlington Fuel Handling (FH) control system in 2006 supports the assumptions of failure rates stated in the first BCS for this project. Substantial parts of the FH control computer system must be replaced before 2010 to support continued safe fuelling of Darlington's reactors. The FH System weaknesses with their probability of contributing to unit de-rating and shutdown are:

- Disk drive sub-system 2.
 - P = 1 in 2010
- З. Display generators P = 1 in 2011
- 4 Operator keyboards P = 1 in 2012 Central Processor (CPU) 5.
- P = 1 in 2013 Computer backplanes 6
- P = 1 in 2014 7. Operator's console
- P = 0.8 by 2020 8. Human-system interface P = 0.7 by 2020
 - 9. **Test Facility** P = 0.7 by 2020

Attachment D shows graphs of reactor fuelling loss probability in both cases of stopping the project and proceeding with alternative #1. The failure of a Fuel Handling system to run is expected to reduce the number of reactors that can be fuelled from 4 to 2. Due to redundancy requirements, mechanical failures due to aging and so forth, 3 units are not supportable with 2 fuelling systems. The second failure will reduce the serviced reactors to 1. A planned station out of service date of July 2050 is assumed for the cost of lost generation.

Alternative 1 -Replace Main CPUS and Peripherals by Emulators - Recommended

The computer's central processor (CPU) would be replaced by a processing unit which is based on a hardware emulation of the originally installed PDP-11/70 computer. It would execute all the software now used to fuel the

Largest Savings in Software

This alternative allows the automated fuelling system to continue operation using the existing custom FH application software. This ability is important, since the existing Fuel Handling software was written in a language that will not permit it to run on any other family of computers. The system specific language was used in order to speed the operation of the computer programs and to support the large number of complex functions operating on the same computer.

The retention of the same software represents an estimated savings of about 6 million dollars, in addition to avoiding the operational and other risks inherent in developing new software code.

s alternative will result in minimal impact to existing software programs and guarantees greater compatibility in the existing FH systems than a software emulation approach. This alternative has already proven to be cost effective in an installation of an earlier vintage of hardware emulator, in the Darlington FH systems.

ONTAR	OPO ER
	GENERATION

Available Technology

The CPU emulator, the QED970, is based on an enhanced design of an existing product, the QED95. The same company that is providing DCC life extension support for the CANDU 600 control computers will be used to acquire the QED970 emulators.

Renovate the Peripheral Equipment

The use of the QED970 CPU will provide a platform for the upgrading or replacement of the video display generators, consoles, control keyboards and printing terminals, all of which have exhibited significant design and/or maintainability issues

Alternative 2 - Delay Project - Not Recommended

Past delays to the start of this project have removed all substantial float time between computer system replacement component design, and installation and the ability to fuel the reactors without substantial disruption. Experience with the Darlington Fuel Handling control system in 2006 supports the assumptions of failure rates stated in the first Business Case Summary for this project. The successful replacement of the main control panel video screens barely kept ahead of the obsolete video unit failures. At one point, a Fuel Handling equipment delay caused rescheduling of installations. This would have resulted in the loss of 1 trolley fuelling system during the fall outage. This was averted by exceptional efforts by FH Maintenance, who was installing the new monitors, by reallocating work. This near miss underscores the need to continue without delay.

Delaying the project would result in a dramatic increase in cost to extend the FH control computer life due to a missed opportunity to buy from what is expected to be the last production run of the QED970s in 2009. In the best case, there would be cost increases to provide another production run. The cost of a subsequent run would likely be higher since the market for these devices is very small, and the customers will be those with mission critical ystems whose replacement cost would justify a substantial outlay for hardware. If components on these boards become obsolete before a production run could be arranged, re-engineering of the boards may be required at extra cost.

There is a risk that the QED970 design staff would not be available to do this re-engineering. In that case a separate engineering campaign would be required in order to develop another emulator for FH. Investigations by the DCC replacement project placed the cost of that work tentatively at 10 million dollars.

Alternative 3 - Replace Main CPUS and Peripherals with State-of-Art Equipment - Not Recommended

A full replacement of the PDP style control computers with new technology is not recommended for this phase of the Fuel Handling computer aging management strategy.

This would be an opportunity to have the software prepared to modern standards, which could increase the reliability, robustness and functionality of the controller's software. At that time, the redesigned software would be more easily portable, thereby reducing future costs of hardware replacement.

Would Need More Time Than Available

Although this alternative may be the best option for long term supportability, there is not enough time or internal resources to execute this alternative before the existing computer equipment fails irreparably. Replacement of the existing CPUs must be done before 2011, given the current number of spare units and failure rates. Other peripheral devices must be replaced sooner. A re-writing of the controller software, testing it with a system simulator with adequate category 3 quality assurance standards and its installation is expected to take a minimum of 4 years. The consequences of lost fuelling capability and subsequent generation loss resulting from project delays when changing to this type of control system is too great to start down this path at this time.

Best Cost Recovery Only when Entire Trolley Control Replaced

he feasibility of replacing the FH control system auxiliary (FFAA) controllers was examined in the preliminary engineering phase. The intention was to only replace the FFAA main controllers. We determined that commercially available equipment would be suitable for the control application. However another custom device would be required to allow compatible communication with the main controller. This device would not be required after the

ONTARIOPOWER GENERATION

OPG Confidential

Page: 9 of 22

BUSINESS CASE SUMMARY

main controllers were replaced by a modern style controller. As a result, the significant investment in the custom communication adapter device would be lost. It would be better to carry out a replacement of both main and auxiliary controllers together to make best use of modern technology. As well this should be done when there is not as much concurrent work in this project. The concurrent work is needed to replace equipment before system operability is lost. Full focus should be applied to a controller "re-hosting" to new technology in order to transfer the knowledge to OPG from any outside design agencies that might be involved.

Alternative 4 - Two-Stage Repalcement of Main CPUS and Peripherals - Not Recommended

A Two-Stage Replacement of Main CPUS and peripherals is not recommended for this phase of the Fuel Handling computer aging management strategy.

In comparison with alternative 1, this alternative would entail a slightly reduced scope of changes to the FH software and teleprinters. However the CPUs would still be replaced. Subsequently, the replacement CPU equipment would be replaced with state of the art computers, or Programmable Automation Controllers (PAC).

This could increase the reliability, robustness and functionality of the controller's software. This would increase the ease of maintenance for the hardware and software if the life of the DNGS plant is extended. In comparison with alternative 3, this avoids the generation losses that would likely occur due to the time needed to re-design the control software and install a new technology system. The new CPUs that are displaced by the new PACs could be returned for stores, ensuring that the DCCs, that also use the new CPUs, would have plentiful spare parts.

Would Need Retention of Rare Knowledge

Although this alternative may be a very good option for long term supportability, and power generation support, here is no way to be certain that people skilled in Fuel Handling controls and PDP-11 computers will be available for the extended duration of the project. A re-writing of the controller software, testing it with a system simulator with adequate category 3 quality assurance standards and its installation is expected to take a minimum of 4 years longer than the Alternative 1 replacement. Due to full use of those resources in the first part of the project it would effectively coordinate additional work by external design agencies.

The consequences of the failure to complete the project could be a loss of several million dollars of investment capital.

Alternative 5 – - Not Recommended



ONTARIO	COVER GENERATION
Contraction of the Contraction o	

Page: 10 of 22

BUSINESS CASE SUMMARY

4/ THE PROPOSAL

The modifications required by this project can be classified as directly age related or design related. The age related changes are needed to prevent loss of system function as parts degrade and become non-repairable. These changes affect the Main Control Computer, Display Generator and Tele-printers.

The design related changes address simple and time-compounded design misconceptions. These changes fix long standing problems and thus provide a sound base upon which future modifications can be made. These changes improve the Fuel Handling Human-System Interface. The Fuel Handling (FH) operators will experience improvements in reliability and function of the main control keyboards, FH controller software, the Main Control Room FH Panels, and the Operator's desk, as well as improved access to control computer data.

The modifications are outlined in more detail in the following paragraphs.

Aging Related Improvements

Main Control Computer

The Main Control Computers' central processors will be replaced in the CSA and FFAA control computers by new software compatible QED970 units.

Prior to the installation of these new units, which have a long lead time, a number of obsolete components will be removed from the FH control computers to increase system reliability. These components are potential sources of system malfunction since they are no longer required but affect the computer main bus. These components include RL02 disk drives and interfaces, video printer switches, and some high and low speed network communication adapters.

Maintenance documentation will be brought up to date with the existing configuration and kept current as changes are made.

The main disk drives and controllers will be replaced by new interfaces to the main bus and long-life sold state

The existing computer software/hardware test facility will be upgraded in order to fully test the new central processors, computer configuration and attendant software changes. It will be equipped with a computerized simulation of the FH field equipment so that performance of the new computer components can be realistically gauged and verified for used in the plant.

The original hardware maintenance facility will be re-established. Also, in support of maintenance, the life of key maintenance and supervisory computer tools will be extended. These include the External Protective Operator Display, Protective Ladder Software Test Tool and Field Monitor computers, which will be upgraded to use commercially available components and software.

When the main Central processors are replaced, the main computer cabinets will be optimized. The main power supplies will be replaced with more efficient and reliable units at that time. The main backplane segments that hold the processors and adapter boards will be replaced as well. **Display Generator Replacement**

The Ramtek Model RM9400 video display generator will be replaced by a computerized device that will produce displays based on the instructions sent by the control computers. This will greatly reduce the amount of change to the control computer software. **Tele-Printers Replacement**

be Model LA120 tele-printers will be replaced by IBM PC-compatible computers. They will allow operators to cess the control computers in the same way as they do now. The new equipment will provide fast access to a rger amount of each system's operating history in order to support returning systems to service more quickly.

OPG Confidential Page:

Field Monitor and EPOD Replacement

The surveillance and maintenance computers will be re-hosted in new computer hardware. The software will be updated as necessary to ensure easy maintenance.

Design-related Improvements

Automatic and Semi-Automatic Control Keyboards

The keyboards will be replaced by commercially available keyboards. Keystroke signals will be mapped by a small computer that will communicate with the main FH control computers.

FH Controller Software

The software in the main control room FH computers will be modified to correct problems related to information display. The software corrections will span approximately 4 shipments in order to shorten commissioning time and reduce the risk of unexpected interaction between concurrent modifications. Main Control Room FH Panels

Switches and Indicators labels will be changed to eliminate confusion about the purpose of switch or state of the devices. The Labeling will be made consistent between panels and documentation.

Un-used switches and indicators will be removed from the panels. The FFAA computer re-start switch will be replaced to prevent accidental operation. The Irradiated Fuel related indicators will be upgraded to ensure that they provide information in appropriate to their function during the fuelling process. **Operator's Desk**

The Video Display terminal count and position will be optimized when a new desk is put in place. The desk will place the operator so their line of sight will be towards the panel during reactor fuelling. Improved Access to Computer Data

The tele-printers will be connected to a network so computer log and IO data is easily accessible to FH operators and technical support staff. Predefine monitoring screens will permit timely monitoring of Fuel Handling in a post ransient situation. Electronic files retrieval will be simplified to eliminate computer history data loss.

5/ **QUALITATIVE FACTORS**

Completion of this project will result in more reliable Fuel Handling System Performance. Some key benefits are:

- Maintenance effort will be reduced .
- Spare parts supply will be made adequate
- System health reports concerns will be addressed .
- Forced loss rate escalation due to failures of current equipment will be avoided •
- Dependence on a single supplier for support of the Fuel Handling Systems will be eliminated ٠
- Obsolescence of peripheral equipment (e.g. LA120 terminals, Display Generators, disk drives, keyboards) . will be addressed
- Operator issues associated with Input Devices will be addressed ٠
- Risks associated with software changes will be mitigated by providing a FH Simulation facility. ٠
- On-line fuelling of Darlington reactors can be maintained by the new FH Simulation facility which will avoid . taking FH systems out of service for extended periods in order to commission new software and hardware.

ON... RIO GENERATION

OPG Confidential

12 of 22

BUSINESS CASE SUMMARY

6/ RISKS

Description of Risk	Description of Consequence	Risk Before Mitigation	Mitigating Activity	Risk After Mitication
Design Agency costs may be higher when contract negotations proceed	Higher costs of external support providers who do not fully understand the work scope.	Wedium	Provide tightly defined scope to supply chain for inclusion with requests for Proposals, thus reducing likilhood of bidders underestimating effort required. Use contingency funding.	Ĕ
Scope The Customer (FH Operations) changes expectations of the project's deliverables.	Reluctance by Operations to sign-off on AFS for equipment	Medium	Have FH manager sign-off on Project Plan so there is a clear understanding of the deliverables and schedule	Low
Schedule Changes to supply the				
orights to supply chain policy or staffing results in extended delays to arrangement of contracts for design and supply	Loss of coordination of project segments increases interest costs and may delay overall time to project close-out	Medium	Obtain Sevice level agreement signed with Supply Chain	Low
Delays due to failure of other FH equipment	Failure of mechanical components of FH system delays equipment installations since the focus of FH Maintenance will be shifted to re-stablishing fuelling capacity rather than installing new equipment.	-6 H	Obtain agreement from FH Maintenance section manager to work with the project to blend FH work with project installations following return to service of failed equipment. This will minimize work-bumping	۲. ۲.
Delays due to reactor closure plug replacement	The FH control systems will have less idle time in which to install replacement equipment if the all the reactor closure plugs need to be replaced (now being proposed)	ЧĜН	Perform as much commisssioning work as possible for the replacement equipment in simulated environments. This will reduce the length of the installation and commisioning time needed in the Main Control Boom	Low



13 01 22 Page: OPG Confidenti



other Low dancy	e if to Low	be to to	ig Fow			
Coach and provide mentoring to other members of the DCC group so redundancy	key member leaves Diversify allocation of design contracts to decrease effects	this project can ber than waiting Nuclear new-bu	Secondary agency (MAPPS) is providing design oversight and can carry on the design process if primary designer is lost	Formal communication to Darlington Licensing Section to inform them of this risk, asking that this project be informed immediately of a change in regulator policy in this area, so we have more time to comply		
Medium	Medium	Medium	Medium	Low		
<u>§</u>	Possible schedule delays in implementation of Hot Spares system, controller display problem fixes, and FH CSA system simulator	Nuclear station refurbishment and promises of new-build are increasing demand for traditional supplier's services. New-build contracts may be considered more lucrative and result in suppliers	Restart of CPU hardware design process adding extra cost and delay to schedule and possible derating	Delay to the implementation of the processors results in delay in CPU installation schedule. Non-recoverable failure of old CPUs results in decrease fuelling capacity and unit derating		
Loss of internal resources with knowledge of fuel handling software	External design agency becomes unavailable to the project due to their commitments to other customers during the design	Potential suppliers fail to bid for parts of the project	Loss of primary design resource for CPU replacement (QED, Inc)	Regulatory Change in regulator's policy may require more time consuming administrive overhead in order to put the new CPUs in service	Rovitoninental No risks identified.	No risks identified





OPG Confidention BUSINESS CASE SUMMARY

No risks identified		

15 of 22

BUSINESS CASE SUMMARY

Page:

7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Final AFS Date:	Targeted PIR Approval Date:	PIR Responsibility
Simplified	Feb 2012	Jul 2013	(Sponsor Title) Manager, Fuel Handling

Comments:

DOMNER	Measura Paramet	er Current Baselin	e Targeted Result	How will it be measured?	Who will measure it?
· ··~ · · · ·	1. Central processing u function relia	ably	No failures in 12 months folowing installation of new CPUs	Functional failure count per SCI 69740 health report	(person / group) Fuel Handling Technical, System Engineer
	 The deficits indentified in 2005 Humar Factors anal have been resolved. 		The elements from the report that were scoped for this project are resolved	Post implementation comparison against baseline.	for 69740 OPG Human Factors Engineering group
3	operate reliat	oly. data	r Less than 2 failures per device type per year following installation of devices	Functional failure count per SCI 69740 health report	Fuel Handling Technical, System Engineer for 69740
4 .	maintenance strategy is act	equipment in service	A sufficient quantity of serviceable spares are available	Less than 4 trolley system-days per year are lost due to delays in obtaining replacement equipment	Fuel Handling Technical, System Engineer for 69740
	Commissionin time does not impede the ability to maintain adequate zone levels in the 4 Darlington reactors	unavailable due to FH control computer malfunctions during commissioning	No units shut down or de-rated due to the effects of commissioning this project's elements	Darlington outage report and Darlington SCR database	Fuel Handling Technical, System Engineer for 69740

BUSINESS CASE SUMMARY

	<u>Appendi</u>	x "A" Glossary (acronyms, codes, technical terms)
CPU		Central processing unit, the heart of the FH controller. It executes program instructions to control the input – output equipment and so the field devices of the FH system.
CSA		Central Service Area of the Darlington Plant. This is the location for the main trolley and FM head control computers.
DCC		The Digital Control Computers that control the reactors. Also used to refer to the Darlington computer design group.
FFAA	,	Fuelling Facility Auxiliary Area. This abbreviation is used to refer to the equipment contained in either of the 2 buildings used to load, discharge and store nuclear fuel. The buildings are adjacent to the extreme east and west ends of the 4 reactor buildings.
LA12(C	The model number of the printing terminal used as the primary interface with the FH control computers. It works similarly to a "dumb" terminal, but communicates by printing on tractor eed paper instead of by graphic display on a video monitor.
PDP-1	c	The "Programmed Data Processor", originally produced by the Digital Equipment Corporation of Maynard Mass., USA in 1978. The DN FH computers were originally model PDP-11/70, he 21 bit addressing version.
RM94	a	his is a model of video display generator that is used to receive computer instructions from PDP-11 computer and turn them into video signals. The signals are sent to special nonitors when the images are viewed.
QED9	si	his is a "work-alike" computer processing unit for the PDP-11/70. It was built in 1993 to upport life extension of systems that used PDP-11/70 computers that had a large ivestment in software. This allows the existing computer systems to run using the same oftware. These are used in the FH computers.
QED97	de	his is a more modern "work-alike" computer processing unit for the PDP-11/70. It is being esigned to replace the QED95. The new design addresses the maintenance issues with the d QED's so that they will last at least to the DN station's end of life.

References

1 NK38-REP-63500-10002 R00, "Fuel Handling Human Factors Issues", OPGI, 2005

2 NK38-REP-66000-001 R00, "Human Factors Assessment of the Control Centre Arrangement", Greenley & Associates, 1997



OPG Confidential

Page: 17 of 22

BUSINESS CASE SUMMARY

Appendix "B"

Project Funding History

Choose Release Type	Month	All Year	Existing a	Cum 2006	ulative Va 2007	lues				
Developmental	Sep	2,005	1.422	2000	2001 7	2000	2009	2010	2011 Later	Total
Full	May	2,007	(·····	11048.					1,422
· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·		······································	· · ·	11040.			· · · · · · · · · · · · · ·	······	11,048
	یت مدرستان در ۲۰۰۰ ز			, ;	سور ، سمر، ،	·······		· · · · · · · · · · · · · · · · · · ·		0
·	;	····					·~·			0
					······	· · · · · · · · · · · · · · · · · · ·	·			0
										0
						i	į			0
	• • • • • • • • • • • • • • • • • • • •				·····		· · · · · · · · · · · · · · · · · · ·		ź	0
LTD Spent	Dec	2006		······································	· ·		·····			
CID Obein	Dec	2006	·	779	· •	d .				779

Comments:

The project is included in the 2006-2010 Business Plan at a value of \$6.9 Million. A variance to the 2006-2010 Business Plan of \$3527K will be addressed via inclusion in the 2008 Business Plan. A Project Execution Plan (PEP) is scheduled for completion by Q3 2007.

OPG Confidential

Page: 18 of 22

BUSINESS CASE SUMMARY

Appendix "C"

Financial Model – Assumptions

Project Cost Assumptions:

The device that will be used to replace the CPU will be the same one used for the Darlington DCC computer replacement. The development of the device will be successful and meet the schedule included in the contract with the vendor of the device.

Financial Assumptions:

Not applicable.

Project / Station End of Life Assumptions:

The Station End of Life is assumed to be extended by a refurbishment with a new end of life of April 1, 2050.

Energy Price / Production Assumptions:

\$49.50 per Megawatt-hour. Nominal 900 MWe net output, 97% capacity.

Operating Cost Assumptions:

Darlington Station operating funds will be used to pay for spare computer component that are purchased by this project and are consumed during the station's life after the closure of this project.

No Additional staff will be required to run the new equipment. Training costs will be small since the new equipment will be very similar in operation to the equipment that is replaced.

Other Assumptions:

Contracts with external suppliers and design agencies can be arranged within 130 days or less. OPG supply chain will support expeditious contract arrangements with appropriate external resources.

The project will be free to identify capable and appropriate qualified suppliers and design agents as required, subject to technical governance. OPG policy interpretations will not artificially constrain the selection of external resources in order to shorten the Approved Suppliers List.

OPG Confidential

Page: 19 of 22

BUSINESS CASE SUMMARY

FH Computer Replacement 16 - 33815

Full Release (Phase 1) Business Case Summary D-BCS-69740-10002-R000

Attachment "A"

1

Project Cost Summary

Capital	LTD Prior Yr 2006	This Refease 2007	This Reluase 2008	This Release 2009	This Release 2010	This Release 2011	This Release		
ect Management (OPG)	153	164	162	179	172	147	2012	¿ Later	Total
neering & Dratting (OPG)	299	406	482	437	381		148	·	1,125
erial			1	191	မူဂၢ	145	148		2,298
Illation - PWU, BTU						1	Providence in Contractory		
ract - Design	1								
ract - Installation	-				-			Contraction of the second	
ract - Other									
est (Capital Project Only)				-	and the second strength of				
ct Costs (excl contingency)	CONTRACT OF	10000	A	States of the owner	and and the state of the				-
ct Costs (excl contingency) ral Contingency	Concoline State			Contraction of the second					
ct Costs (exc) contingency) ral Contingency fic Contingency									
ral Contingency			1 502	1220					
ral Contingency	779	1,450	3,593	2,339	1 :919 i	1,805	525		12,470
ral Contingency fic Contingency ct Costs (Incl contingency) 2010 Business Plan	779 872	1,450 1,450	2,544	900	1,129		S25		12,470 6,895
ral Contingency fic Contingency ct Costs (incl contingency)	779	1,450	Contraction of the local division of the loc	and the second se	and the second strends of the	1,865	× 525 423	•	
ral Contingency fic Contingency et Costs (Incl contingency) 2010 Business Plan ince to Business Plan bitted Cost	779 872	1,450 1,450	2,544	900	1,129		1	•	6,895
ral Contingency fic Contingency ct Costs (Incl contingency) 2010 Business Plan Ince to Business Plan	779 872	1,450 1,450	2,544	900	1,129		1		6,895
ral Contingency fic Contingency ct Costs (Incl contingency) 2010 Business Plan nce to Business Plan witted Cost ory Write Off Required	779 872	1,450 1,450 (51)	2,544 348	900	1,129 416	1,501	423	•	6,895 3,527 -
ral Contingency fic Contingency ct Costs (Incl contingency) 2010 Business Plan ince to Business Plan inted Cost ory Write Off Required Parts / Inventory	779 872 (93) 779	1,450 1,450 (51) 1,399	2,544 348 2,892	900 983 1,883	1,129 416 1,545	1,501 1,501	1	•	6,895
ral Contingency fic Contingency ct Costs (Incl contingency) 2010 Business Plan ince to Business Plan inted Cost ory Write Off Required Parts / Inventory Release (excl contingency) Release (incl contingency)	779 872 (93)	1,450 1,450 (51)	2,544 348	900	1,129 416	1,501	423	•	6,895 3,527 -
ral Contingency fic Contingency ct Costs (Incl contingency) 2010 Business Plan ince to Business Plan inted Cost ory Write Off Required Parts / Inventory Release (excl contingency)	779 872 (93) 779	1,450 1,450 (51) 1,399	2,544 348 2,892	900 983 1,883	1,129 416 1,545	1,501 1,501	423	•	6,895 3,527 - - 10,422
ral Contingency fic Contingency ct Costs (Incl contingency) 2010 Business Plan ince to Business Plan inted Cost ory Write Off Required Parts / Inventory Release (excl contingency)	779 872 (93) 779	1,450 1,450 (51)	2,544 348	900	1,129 416	1,501	423		

Basis of Es	stimate			<u></u>
 Up to - 15%			Conceptual	1/2 COC(1) DEC
 OPEX used	Yes			+ 60% to - 25% Yes
	No			N/A
Contracts in place	No	Competitive		+- <u>N/A</u>
<u>No</u> Yes Yes	No OPEX used Yes Budgetary Quote(s) Yes Contracts in place	Up to - 15% Quality of E No OPEX used Yes Yes Budgetary Quote(s) No Yes Contracts in place No	Up to - 15% Quality of Estimate No OPEX used Yes Lessons Lesson	Up to - 15% Quality of Estimate Conceptual No OPEX used Yes Lessons Learned Yes Budgetary Quote(s) No Phase 1 Actual Used Yes Contracts in place No Phase 1 Actual Used

The estimated variance(s) to the 2008-2012 Business Plan will be addressed through the portfolio management process. A PCRAF will be approved by Jul 2007.

Reviewed By:

12,0 Hung roject Manager Date:

Approved By: kine 13, 2007 R. Hohendorf

Eng & Mods Manager (Strat IV)

Date:

Page: 20 of 22

de

ONTARIOPOTER GENERATION

BUSINESS CASE SUMMARY

FH Computer Replacement 16 - 33815

Full Release (Phase 1) Business Case Summary D-BCS-99740-00002-R000

Attachment "B"		Project V	ariance /	Analysis	
Choose One	LTD		se One This BCS		
	Dec 2006	Sep 2005	Apr 2007	Variance	Comments
Project Management (OPG)	153	483	1127	644	Close integration of multiple work segment requires more oversight
Engineering & Drafting (OPG)	299	310	2296	1986	It is more efficient to have OPG staff perform work that requires a lot on site
Material	-				specific information
Installation - PWU, BTU	· ·				
	-				
Contract - Design					
Sounder Duoign		and the second second			des des services de la companya de l
Contract - Installation					
Contract - Other					
					and the second
nterest (Capital Project Only)					
Project Costs (excl contingency)	-		-		
Seneral Contingency	1			contraction of the second	
ce inc Contingency	Contractory Theorem	-			
ommitted Costs (incl contingency)	779	8756	12470	3714	~ ~
iventory Write Off Required			······	0	—·· · ··· · · · · · · · · · · · · · · ·
pare Parts / Inventory	···- · ·	· · · · ·	·	0	
otal Release (incl contingency)	779	8756	12470	0 3714	
otal Release (excl contingency)	779	6895	10422	3/14 3527	1997
ngoing OM&A (non-project)		Colors Startman			ر
emoval Costs (incl in above)				0	
omments	ž.,			0	

Comments:

In order to perform the installations of replacement equipment in the manner required to prevent critical system failure, more project oversight is required. However, this is expected to provide more rapid recovery of investment, thus offsetting the higher project management costs.

HE MELL A LANS HE WE LE

BUSINESS CASE SUMMARY

Attachment "C"

Key Milestones

Completion Date		Date	
Day	Mth	Yr	Description
9	JUL	2007	Video Monitor Replacement Close-out Complete
03	DEC	2008	Obsolete Equipment Removal AFS
17	DEC	2008	Main Console AFS
20	MAY	2008	Protective Display Terminal Replacement
13	NOV	2009	FH System Simulator in service
26	FEB	2010	Control Keyboard Replacement AFS
30	AUG	2010	Teleprinter Replacement AFS
22	SEP	2010	Field Monitor Replacement In Service
01	APR	2011	Computer Backplanes AFS
22	APR	2011	CPU Replacement AFS
24	NOV	2011	Display Generator AFS
28	FEB	2012	Human System Interface Software AFS
09	NOV	2012	Final Project Close-out

A Project Execution Plan (PEP) will be approved by Jun 2007

Comments:




ONTARIOPOTER	OPG Confidential	Page: 22 of 22
GENERATION	ENGINEERING & MC BUSINESS CASE	

Attachment D


Figure 1 below shows the probability of non-repairable Fuel Handling Computer System based on not proceeding with this project. There are several components that could influence this eventuality. Each is shown on a separate line. The graph in Figure 2 shows the same risk factors with probabilities of failure influenced by the actions of proceeding with alternative 1 of this project.

Figure 1 -- "Stop the Project"



FH Computer Failure Induced Generation Loss Probability Without Project

Figure 2 - "Alternative 1"



FH Computer Failure Induced Generation Loss Probability with Project



Page: 1 of 14

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

Darlington DCC Replacement 16 - 33977

Full Release (Phase 1) Business Case Summary D-BCS-33977-10001-R001

<u>Routing</u>	Location	Action	Signature	Date
Eric Hung, Section Manager Darlington DCCs 703, 1293	D08-ESB2	Prepare BCS	a thing	No they feb
Richard Hohendorf Manager, Computers and Control Design 702, 5077	P82-5f-6	Review BCS	1775	Ney 17 12006
Ron Ball Senior Financial Analyst 702, 4084	P82-3b-6	Review BCS	C22	23 May oc
Gord Brown D. Zerskere Controller, Engineering & Mods 702, 5059	P82-F3-A6	Review BCS	par p. 2.	1
Fred Dermarkar Director, Engineering Services 401, 8243	P82-6-C	Review BCS	ILL	23 May 2006 30 May 2006 12-2000 CC
JP Froats VP Engineering & Mods 5044	P82-6-E	Review BCS	affant.	12-June CE
mith SVP Darlington	D08	Review BCS	Section	
PR Charlebois EVP and Chief Nuclear Officer 702, 5294	P82-6-A	Review BCS		July and to be
D. Power Director Investment & Business Planning 400-7172	H7 D06	Approve BCS	Stated	Ary Jol
J. Hankinson President & CEO	H19 A24	Approve BCS	SATAWiemon	ang 1/20 ang 22/06
R. Ball ior Financial Analyst 1241	P72-2	Return For Distribution		



OPG Confidential

Page: 1 of 14

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

Darlington DCC Replacement 16 - 33977

Full Release (Phase 1) Business Case Summary D-BCS-33977-10001-R001

Routing	Location	Action	Signature	Date
Eric Hung, Section Manager Darlington DCCs 703, 1293	D08-ESB2	Prepare BCS	MISY-Cos	KHy F6
Richard Hohendorf Manager, Computers and Control Design 702, 5077	P82-5f-6	Review BCS	mat	May 17/2006
Ron Ball Senior Financial Analyst 702, 4084	P82-3b-6	Review BCS	Ch-	2314
Gord Brown D 2 C + E +	P82-F3-A6	Review BCS	pa D. 2.	
Fred Dermarkar Director, Englneering Services 401, 8243	P82-6-C	Review BCS	INT	23 May 06 23 May 06 30 May 2000 12 mins oc.
JP Froats VP Engineering & Mods 702, 5044	P82-6-E	Review BCS	Effort_	12-surat of
G. Smith SVP Darlington	D08	Review BCS	Sector	20 June 2-10
PR Charlebols EVP and Chief Nuclear Officer 702, 5294	P82-6-A	Review BCS	Carl	
D. Power Director Investment & Business Planning 400-7172	H7 D06	Approve BCS		
J. Hankinson President & CEO	H19 A24	Approve BCS		
D				
Ball enior Financial Analyst 11-8241	P72-2	Return For Distribution		

۰.

- - - **.**



ONTARIOPOWER

GENERATION

OPG Confidential

2 of 14*

Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

Darlington DCC Replacement 16 - 33977

Full Release (Phase 1) Business Case Summary D-BCS-69100-10001-R001 1/ RECOMMENDATION:

We recommend an additional release of \$16.0M (\$22.1M total including contingency) for the Darlington Digital Control Computer (DCC) Replacement Project.

The business objective of this project is to avoid a shutdown of a unit due to the unavailability of the CPUs in a dual DCC configuration due to either a component failure or a lack of available spares. A shutdown of this nature would be lengthy as a replacement DCC would have to be engineered and installed. This objective is consistent with the Darlington DCC Life Cycle Strategy as defined in NK38-REP-69000-10001.

The existing DCC hardware is obsolete and will not operate for very much longer with the required system availability. An associated project (Replacement of Obsolete Computer Components 33509) has been successful in replacing some of the subsystems (memory, power supplies, mag tape units etc) whose reliability or maintainability was threatening the overall DCC performance. However the limit of useful subsystem replacement has been reached and it is necessary to replace the core of the DCC system.

A partial release of \$6.1M was approved in Sep 2003 to replace the Sequence of Events (SEM) and Common Processes (CP) computer, and perform initial preliminary engineering for the replacement of the Darlington DCC's. At the time, it was assumed that we could use "off the shell" PDP-11/70 emulators for all 3 applications. However, after spending \$1.2M of the current release, to complete the preliminary engineering (including the "design challenge" process) we have identified sarious design issues that prevent the use of "off the shell" technology in a nuclear control application.

We are now recommending the re-design of an existing PDP emulator from Quickware, with QA oversight from an independent and external source. Although the need to redesign (with oversight) has driven the estimated cost of the project from \$14.8M to \$22.1M, a rigorous RFP process has determined this to be the most viable and cost effective solution for all 3 applications. Moving to a full release at this time will allow us to keep costs down and ensure compatibility amongst the 3 systems. (See Attachment B for details).

This project is listed in the 2008-2010 Business Plan at \$82.2M; with \$15.5M allocated for this work and \$86.7M targeted for DCC replacement under a Life Extension program beyond 2010. This funding request is Intended to sustain the operation of the control computers until retubing takes place. Only minimal functional improvements will be made. This request is consistent with the 2006 Budget; however, changes in the estimate for the 2007 to 2011 timeframe will need to be addressed in the next Business Plan. A Project Execution Plan (PEP) will be approved by 19 May 2000; 2 June 2006

\$000's Capital		Including Contingency	Excluding Contingency			Excluding Contingency
Released to Date:	Full (Phase 1)	6,050	5,261	Mar-06	Spent Life to Date:	.231
Requested Now:	Ful	16,008	13,921	2008-2010	Apprid Business Plan (Tot Prod:	Non-second state of the second state of the se
Cumulative Release:	Total to Date	22,05#	19,182	2006-2010	Businees Plan Variance;	15,521
Total Project Estimate:	+30% to -15%	22,058	15.182	2006	Budget (Current Year)	3,661
Current Year Estimate:	2006	3,134	2,728	2006		2,727
Type of Investment:	Sustaining	NA	NA	Cumulative Rela	Budget Variance (Current Yr)	(1)
NPV:			NA NA	Contractove meno	ese Hemaining:	17,951
RA:			the state of the s		Remaining Release:	2,875
			N/A	Contingency % o	n Remaining Release:	18.0%

Date

Submitted By:

P R Charlebois EVP and Chief Nuclear Officer

Finance Approval:

Line Approval (Per OAR Element 1, 1 Project in Budget):

D. Power Director Investment & Business Planning Date:

J. Hankinson President & CEO

Date:





3 of 14

Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

2/ BACKGROUND & ISSUES

Darlington DCCs

Project 33977 addresses several issues, which present risk to the continuing performance and operation of the Darlington Digital Control Computer (DCC) systems:

- Hardware obsolescence. The current computers are of obsolete 1970s technology (DEC PDP11 minicomputers).
- Diminishing support from the Industry. There is no OEM support and, unlike other CANDU stations, the hardware and software used at Darlington are unique. The few manufacturers of PDP emulators are ceasing production, and PDP expertise is disappearing quickly.
- The availability of spare parts in the marketplace has dwindled to a very small number of suppliers, and the quality and history of available spares is questionable.
- Certain key components, such as computer backplanes, are prone to wear out as a result of troubleshooting activities. This situation will deteriorate with time. The backplanes are cannot be reproduced.
- Pending shortage of in-house engineering resources. Large numbers of the original design team are eligible for retirement.
- The skill set required to repair the PDP equipment is disappearing, and the skills are not taught in trade schools.

The business case for the initial release for project 33977, approved in 2003, requested funding in the amount of \$6.05M, including contingencies, and provided for the replacement of the five Sequence of Events (SEM) Computers and the Common Processes Computer (CP). The business case indicated that approval of a further amount, then estimated at \$8.7M, would be requested later (in approximately 3 years) when a path forward was confirmed. This further funding would be required to complete the replacement of the Unit Computer DCCs and the Ramtek Display systems.

A highly skilled team, following a rigorous Software Quality Assurance (SQA) program, undertook the original design of the Darlington control software. This represents an enormous investment, both financially, and In expended time. Any attempt to recreate the software using modern Operating Systems and computer platforms would be extremely expensive and time consuming. Thus, at present, only solutions to the DCC maintenance and support issues that enable the investment in the control software to be retained are being considered.

At Darlington NGS, computers are used in Sequence of Event Monitoring Systems, the Common Processes monitoring System, the Unit DCCs and the Fuel Handling systems. All these systems use models from the Digital Equipment Corporation (DEC) family of PDP11 processors. Although this family was popular at the time of the Darlington engineering design, in the early 1980s, it is believed that Darlington represents the only instance in which this type of computer is used in a nuclear control application.

The provision of replacements for the Digital Equipment Corporation (DEC) line of processors is a specialty and declining field. Basically there are two types of replacement products:

- Hardware emulators, in which the instruction set of the original PDP11 is emulated in the replacement computer, using modern custom-designed hardware to replace the functions of the DEC equipment.
- Software Emulators, usually based on a PC platform, using a commercial, or custom operating system. The original DEC computer language is emulated by the PC, using the software resident in the "host computer".

the state of the state

- and the second s





ONTARIO	POWER Generation

OPG Confidential	Paget	4 of 14
ENGINEERING BUSINESS C		

Hardware emulators are relatively complex to design, and require considerable engineering knowledge and understanding of the operation of the original DEC computer hardware, and peripherals. While using modem technology, they do, however, provide for an almost exact emulation of the performance of the original DEC computer. As such, this would allow the transfer of the existing DCC control software to the emulator, with minimal issues with respect to instruction timing, while maintaining compatibility with the existing peripherals.

An RFP process was initiated, which identified Quickware as the most viable and cost effective provider of a hardware-based PDP Emulator, suitable for use in the Darlington DCCs. (Quickware has already provided an earlier model of hardware emulator used in the Fuel Handling systems at Darlington.) Subsequently an OPG internal design challenge process was initiated, which resulted in the development of a detailed design specification for the hardware emulator. The recommended approach will involve re-design of the original Quickware product to meet the additional requirements for operation in the Darlington DCCs.

At the time of the initial release of funds it was assumed that an "off the shelf" product would be able to replace the original DEC computers. However the detailed engineering performed under the initial release of funds identified serious design issues in the available off the shelf emulator products that would prevent their use in a nuclear application. The re-design of the Quickware project, under the oversight of a rigorous QA program, has been identified as the most cost effective and risk free approach. The cost estimate refinement resulting from the preliminary engineering activity, plus the identified increased engineering work due to the unavailability of a suitable existing product has resulted in an increase in estimated project costs from \$12.9M to \$19.2M.

Ramtek Display Systems

Under the initial release for project 33977, an experienced software consulting company determined that replacement of the existing aging display generators by modern compatible is feasible. The analysis also identified that the phased implementation of a replacement display system on the DCCs at power would be complex, and would best be carried out in conjunction with a future unit outage. It is therefore recommended that the Ramtek replacement should be first implemented in the SEM and CP systems.

Required Annunciation Improvements


Operational Experience Review of CANDU stations including Darlington Nuclear Generating Station, has demonstrated that original control room annunciation design does not fully support current operational goals and user needs in the main control room across all plant states. Improvements to the Darlington MCR Annunciation System (SCI 60312) are needed to improve alarm conditioning to inhibit nuisance alarms, which occur during reactor start-up/shutdown and during, upsets.

Specific assessments of the Darlington Loss of Bulk Electrical System (LOBES) upset and outage related Operational tasks (i.e. Shutdown and startup, equipment out-of-service declaration) were conducted to characterize the annunciation system deficiencies and user needs. The Annunciation Improvements segment of Project #33977 will focus on the elimination of the identified conditioning and suppression deficiencies. Further, the Darlington Authorized Training Section has identified Turbine Trip as another upset that has excessive Operator workload demands due to Annunciation deficiencies analogous to the LOBES event. These nuisance alarms will also be addressed.



1 . .





Page: 5 of 14

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

3/ ALTERNATIVES AND ECONOMIC ANALYSIS

GENERATION

Stop the Project (Not Recommended)

ONTARIO**power**

Stopping the project is not a viable option. The life limiting components at this point are the availability of the CPU backplane and the floating-point processor. Currently, the entire supply of healthy spares has been used. This is especially true for the CPU backplane. It is "wire wrapped" and the board contacts are made mechanically. The probability of these components breaking down will increase with time, in proportion to the number of card reinsertions, typically made during "troubleshooting". Another important factor is that, most likely, the members of the original DNGS design team, as well as the currently available hardware vendor will become un-available in the next 3-5 year timeframe, since the market demand is small and the existing experts in the technology are aging. "Stopping the project" now will cost the corporation considerably more in the future, as the result of eliminating the most economical and risk-free option.

Unavailability of the CPUs in a dual DCC configuration, due to either component failure, or lack of available spares, would cause a complete shutdown of that unit, with associated loss of production. The shutdown would be lengthy, until a replacement DCC could be engineered and installed.

Alternative 1 - Replace the PSP11 Computers in the DCCs by a Hardware Emulator (Recommended)

The preliminary engineering work, performed under the initial release of funds for this project, has identified a suitable hardware-based emulator, for use in the Sequence of Events (SEM) systems, the Common Processes (CP) system, and the DCCs. The proposed product is from the same company (Quickware) that supplied the emulators currently in use in the Fuel Handling Systems at Darlington NGS. Re-design of the product is required, and this work, by the vendor, should proceed, with QA oversight provided by another company (L-3 MAPPS) to minimize long-term support risks.

- Hardware emulation is accepted by the CNSC as a "low risk" replacement technique, thus no regulatory
 approval is likely to be required.
- L-3 MAPPS, who have submitted a joint proposal with Quickware, have a history of providing equipment and support to OPG (as CAE).
- L-3 MAPPS is developing nuclear support as a long-term corporate goal, and have received a long-term contract for the supply of a Varian Computer emulator, and associated long-term support, from the COG
- L-3 MAPPS has the capability to continue the design effort associated with the PDP11 emulator design, testing and production, should unforeseen issues affect the capabilities of the Quickware organization.
- The QED 95, developed by Quickware, is currently in use on the Fuel Handling Systems at Darlington. (Note: this product can no longer be manufactured, due to obsolescence of certain parts, and also has limitations that would prevent its use in the Darlington DCCs).
- The Quickware organization has the capability to adapt the design of the redesigned emulator to address OPG technical concerns with respect to failure modes, error checking and detection, and packaging. The design can also utilize successful OPG initiatives, completed under project 33509, to resolve obsolete DCC equipment issues (e.g. power supply replacements).

A hardware-based emulation solution has a lower risk of issues developing with respect to compatibility with existing control software, than with a software emulator. This is consistent with the approach successfully used to replace the DCCs at Pickering A.







OPG Confidential Page: 6 of 14 ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

Alternative 2 - Delay the Recommendation (Not Recommended)

Action on this issue has already been delayed to the point where the availability of the most economical and least risky alternative could disappear. Further delay would lead to a level of DCC performance risk that is unacceptable to the overall objectives of OPG. In addition, experienced Darlington staff members who are critical for the success of the project will be lost due to retirement in the next few years. As well, the number of potential suppliers will also diminish as the demand for PDP11/70 compatible products declines. The cost of doing the project (if at all possible) will be substantially higher.

Alternative 3 - Do Less (Not Recommended)

The do less option involves the "piecemeal" replacement of equipment in the Darlington DCCs in order to resolve specific problems as they evolve. Project 33509, Obsolete Equipment Replacement, has already taken this approach, and has resulted in providing solutions to maintenance, and longer-term support issues associated with the memory, Moving Head Disk (MHD) Mag Tape unit (MT) and Power Supplies. Project 33509 has taken this "do less" approach to its limit of effectiveness, and now the maintenance and long-term support issues associated with the CPUs themselves and the Display systems must be addressed.

Alternative 4 - Do More (Not Recommended)

Complete DCC Replacement by Modern Digital Control System (Not Recommended)

An alternative approach to the use of PDP emulators as replacements for the CPUs in the Darlington DCCs would be to replace the complete DCC via a modern digital control system. This would offer newer technology and better support from the industry.

However, in this approach, there are a number of significant implications:

- The DCC control software would have to be re-written, which would require a large software team, working within a rigorous QA program. This is not be required if the existing CPUs are replaced by emulators. Additionally there may be process complications in faithfully transferring the control implementation from the existing control system
- There may be high risk in obtaining CNSC licensing approval (completely new control software).
- Significant, and very costly, re-arrangement of the field wiring would be required in a complete DCC replacement.
- Unlike alternative 1, the complete replacement of the DCC by a modern digital control system cannot be
 performed in a staged manner, and thus an extensive outage would be required, such as that available in
 retubing. Planned outages of sufficient duration are not planned within the period during which DCC
 replacement must occur.
- This approach would be resource intensive, and would require lead times considerably longer than those for alternative 6. Thus the risks of outages due to DCC failure would increase significantly beyond 2010, if this approach were to be taken.

These disadvantages outweigh the benefits and the cost of this alternative (even if outages of sufficient duration were available) would be several times greater than of the recommended alternative, should we decide to extend the life of the station by way of a re-tubing initiative.

A complete DCC replacement by this approach is included in the long-term business planning for Darlington, with a conceptual cost of \$60M. This approach would only be re-examined if a decision to extend the life of the station by retubing were made.



ONTARIO	POWER GENERATION

OPG Confidential 7 of 14 ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

Alternative 5 - Other - Replace the PDP 11 Computers in the DCCs by a Software Emulator (Not Recommended)

This alternative offers comparable overall cost to the recommended alternative (hardware emulator) based on current estimates. However, even though the costs are comparable, this alternative has considerably greater technical and regulatory risks.

The system architecture would be much more complex than the current DCC implementation. It would involve three interacting systems (SimH, Operating System, and a new hardware platform). Ensuring that the fault tolerance and fault detection of a software-based emulator is equal to or better than the existing PDP 11/70, would be difficult. The nuclear regulator will likely have significant concerns since the use of a software-based emulator replacement on a nuclear unit.

- The various failure detection and handling schemes inherent in the current, PDP11 based design, would need to be re-assessed.
- Several new failure modes will be introduced by the introduction of a software emulation product, and will require significant assessment (e.g. issues with the newly introduced operating system, instruction timing
 The interface with the DEC Units of the system.
- The Interface with the DEC Unibus is a weak point in most software emulators, and will require significant engineering and development to ensure a secure design is in place.
- There are uncertainties with respect to the discovery of new significant technical issues, as the design develops. This in turn would result in greater uncertainty and risk with respect to cost and schedule.

A detailed study was undertaken to compare the hardware and software emulation alternatives. Report NK38-REP-69100-10004, dated 10 February 2006, was produced, and concluded that the hardware emulator is the best approach based on DCC unavailability risk.

Alternative 6 – Other – Replace the Darlington DCCs using the Varian DCC emulator being produced for Pickering B and other CANDU stations as part of a COG joint project. (Not Recommended)

The Varlan emulator cannot run the Darlington DCC software. Redesigning the Darlington DCC software to run on the Varian Emulator is probably infeasible, would cost several times more than the recommended alternative, and would incur substantially greater regulatory and technical risk.

Alternative 7 - Other -







OPG Confidential	Page: 8 of 14	
ENGINEERING BUSINESS C		- net

4/ THE PROPOSAL

This project will replace the PDP11 computer based control systems and the display system with emulator based systems that will:

- Ensure the reliability (99.9%) of the DCC, Common Process Computer (CP) and Sequence of Events Monitoring (SEM) Computers for the current life of the station;
- Provide needed annunciation improvements;
- Prevent obsolescence and avoid shortage of spare parts;
- Provide an upgrade path for future plant life extension (beyond 20 years), if necessary.

The recommended approach is:

Obtain a replacement as soon as possible.

In terms of having a replacement as soon as possible with least risk, the hardware-based emulation option (Quickware/L-3 MAPPS) is the best choice. The software-based emulation approach (SimH) requires a much greater internal engineering effort as well as larger schedule and regulator risk. Hence the following is recommended:

- Keep the DCC healthy (complete the planned improvements per Project 33509). The fewer number of stalls, the fewer number of times the DCC needs to be disturbed. This will reduce the possibility of accidental damage to DCCs (especially the backplanes whose connections are made mechanically);
- Continue searching for "used" spare parts qualified for use.
- Implement the replacement as soon as possible:
 - Complete negotiations with L-3 MAPPS/Quickware to clarify and resolve the remaining price structure, and terms and conditions issues.
 - Award the contract to L-3 MAPPS for development of a PDP11 based emulator, based on enhancement of the Quickware design;
 - Complete discussions with L-3 MAPPS with respect to detailed work plans and schedules, to ensure the proposed project is adequately resourced to meet the required schedule.

Proceed with the design and procurement of an emulator for the Ramtek display systems.

Proceed with the design and implementation of Annunciation Improvements, to address nulsance alarms received during turbine trip events and during planned outages.

Milostones Finish Date (D/M/Y)	Description	
2-Jun-08	Revise PEP and obtain approval	
26-May-06	Award of contract for hardware emulator	
15-Oct-07	Re-design of hardware emulator complete	
21-Jan-08	Prototype hardware emulator available	
24-Nov-08	Functional testing of emulator complete	
30-Jun-09	Emulators installed in SEM systems	
31-Dec-09	Emulator installed in CP	
30-Jun-11	Emulator installed in DCCs	
31-Dec-09	Ramtek replacement design complete	
30-Jun-11	Ramtek replacement installation in DCCs	
31-Dec-08	Annunciation improvement software programming complete	
31-Dec-10	Annunciation improvements installed	

and the second second second







OPG Confidential	Page: 9 of 14
ENGINEERING & MODIFIC BUSINESS CASE SUMM	

5/ QUALITATIVE FACTORS

Completion of this project will result in more reliable DCC performance. This will result in:


- The reduction of maintenance effort.
- The elimination of spare parts shortages.
- In conjunction with project 33509, the return the health status of the DCC and CP computers to green (from yellow) and maintain them at that level.
- The improvement of the Annunciation Alarm Conditioning, eliminating the operator work-around caused by nuisance annunciation messages.
- The introduction of newer technology, which will be easier to support and maintain by less experienced staff, greatly reducing the requirement for legacy knowledge.












6/ RISKS

I







ļ





Page: OPG Confidential 115

12 of 14

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Final AFS	Targeted PIR Approval	PIR Responsibility
	Date:	Date:	(Sponsor Title)
Simplified	Dec 2010	Jun 2011	E Hung Section Manager Darlington DCCs

	Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it? (person / group)
1.	DCC Emulator Passes Acceptance Test.	Existing PDP11 performance.	Funtionality demonstrated by system tests.	Suite of tests based on performance of original system.	QA oversight
2.	Emulator Functions in SEM systems, CP and DCCs.	Existing PDP11 Operation	SEM, CP and DCC S/W and H/W Check programs function normally in an extended test. Same or better operation using system utilities to measure system loading and performance.	Monitor for system stalls, and errors detected.	and the second s
3.	Number of System Stalls reduced.	System Health is "White".	System Health returns to "Green".	System health reports	System engineer.
4.	System spares situation retums to "Healthy" state.	Some parts in short supply.	Sufficient Spares to reach End of Life.	Inventory of Spares is acceptible.	Darlington DCCs/. Control Maintenance
5.	Frequency of nuisance alarms during startup and shutdown.	Established by historical data	Significant reduction in number of nuisance alarms.	Ops acceptance of reduction in alarms.	MCR system engineer



OPG Confidential		Page:	13 of 14
ENGINEERING BUSINESS C	& MODIFI	CATIONS	

Darlington DCC Replacement 16 - 33977

Partial Release Business Case Summary D-BCS-33977-10001-R001

Attachment "A"

ONTARIOPOWER GENERATION

Project Cost Summary

\$000's Capital	LTD Prior Years 2005	2006	2007	2008					
Project Management (OPG)	238	189	and in the local division of the local divis	189	2009	2010	2011	2012	Total
Engineering & Drafting (OPG)	282	678		1,183	+	108	81		1,18:
Material	7500078		1,010	1,103	705	303	118		4,035
Installation - PWU, BTU	1						100		
Contract - Project Mgmt									
Contract - Design									
Contract - Installation	1					the state of the second			
Contract - Other								and in state of the	
nterest (Capital Project Only)									- 4
nterøst (Capital Project Only) sch Todal and Contingency)	-								
incl Contingency) ontingency									A
ich Total nici Contingency) ontingency tand Total	1,243	3.135	5.560	4103	4.281	3.216	1000 COL	in the second	11:57:0:00
kth Total met Contingency) ontingency		3.1.35 2,727	5.MQ 2,600 (4.283	1.214 2.973	122	in the second	12.054

Removal Costs included in above	1
Definition Costs included in above	0
Estimate Name Overlite	Budget Estimate +30% to -15%
Design Complete:	Up to ~ 15%

Approved By

Reviewed By:

May U.c.6 Date: 24/1-9 E Hung Project Manager

R Hohendorf

the first the product of the second

Eng & Mods Manager (Strat IV)



14 of 14

Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

Darlington DCC Replacement 16 - 33977

Partial Release Business Case Summary D-BCS-33977-10001-R001

ATTACHMENT "B"

TOTAL PROJECT COST VARIANCE TABLE

\$000's Choase One	Last Release day/mth/yr	This Release day/mth/yr	Variance	Explanation
Project Management (OPG)	1,038	1,183	145	Longer project duration
Engineering & Drafting (OPG)	3,637	4,639	1,002	Additional verification required for new produc
Installation - (OPG)	257	260	3	
Material				
Contract - Project Mgmt				
Contract - Design	-			
_				-Alto - Ale
Contract - Installation	7			
Contract - Other				
	7			
			The second	
				A CONTRACTOR OF
			Contract in the	
terest (Capital Project Only)				
ub Total set Contingancys	12,509	19,182	0,735	
ntingency	1,933	2,876	943	
and Total	Contraction of the		100000000000000000000000000000000000000	
	74,879	22.058	7,234	





Page: 1 of 23

DND - DARLINGTON STATION ENGINEERING BUSINESS CASE SUMMARY

DND Feeder Replacement ALARA/Optimization 16 - 34008

.NIARIOPOWER

GENERATION

Full Release Business Case Summary D-BCS-33160-10005-R001

Routing	Location	Action	Signature	Date
M. Christiaans Senior Technical Engineer Ext. 1089	D08-ES2	Prepare BCS	M.E. Christians	
D. McKenzie Section Manager - Feeders & Reactor Maintenance Engineering Support Ext. 1624	D08-ES2	Review BCS	DBANK	Na 16/200
I. Khan Manager - Feeders & Reactor Maintenance Ext. 1478	D08-ES3	Review BCS	JANG.	N 3V 16/200
A. Brooks Senior Financial Analyst Ext. 1504	D08-ES3	Review BCS	Brooks.	Nov 21/26
J. McIntee Controller, Darlington Ext. 1324	D08-ES3	Approve BCS	and the	Nover/06
Seedhouse stor Station Engineering 7584	D08-ES3	Review BCS	Rtal	36 Mir Louis
Gregory O. D. Smith Senior VP Darlington Ext. 7488	D08-ES3	Submit BCS	Cov	Det/2016
R. Leavitt Director Investment Management - Nuclear	P823-315	Approve BCS	Palaesot	Dec 18, 2006
J. Beech Vice President Nuclear Finance	TCH09F26	Approve BCS	$\frac{1}{2}$	Dec 19, 2006.
D. Power Director VICE PRESIDENT, Corp. Investment and Businees Planning	/nv.TCH07D06 REC'DJan.3/07	Approve BCS	Dree	Jan 8/07
Piene R. Charlebots T. Mi+chell Second Chief Nuclear Officer Ext. 5294	P826A-1	Approve BCS	Minhilan	11 Marco
roks / Financial Analyst 	D08ES3	Return For Distribution		



DND - DARLINGTON STATION ENGINEERING BUSINESS CASE SUMMARY

DND Feeder Replacement ALARA/Optimization 16 - 34008

Full Release Business Case Summary D-BCS-33160-10005-R001

1/ RECOMMENDATION:

Approval is requested for \$11,700K (including contingency) full release capital funding to provide tooling and capability in order to optimize feeder replacement durations and reduce radiation dose associated with feeder replacements. The work is planned to meet the D611, D721, D811 and D1111 outage schedules and subsequent outages for feeder replacements as per the business plan. The tooling and capability developed under this project will also improve efficiency of the fuel channel reconfiguration and single fuel channel replacement executions.

Based on the economic analysis performed to determine impacts of the new tools on feeder replacement windows the NPV of the project is +\$56.8M compared with the base case (feeders replaced in series with 2 ice plugs per feeder for fuel channel isolation) for the assessment period of 2006 to 2011 (Attachment-B). If we expand the assessment period to 2014 the NPV of the project becomes +\$97.8M (See the modelling assumptions in Section 4). The radiation dose savings due to improved tooling and methods are expected to be equivalent to \$3.7M.

The tooling and capability developed under this project is justified on its own merit. However, the NPV described above is based on an assumption that the 2nd set of advance feeder cut and weld tooling will be available by spring 2008.

However, if OPG decides to not pursue 2nd set of tooling and/or is deferred then NPV of the project will decrease to 235.4M for the assessment period of 2006 to 2011 and \$57M for the assessment period of 2006 to 2014.

ote: 2nd set of advance cut & weld tooling is being purchased under a separate project by Science & Technology Div.

The recommended work under this project will provide Darlington the following capability:

- Isolate more than 8 fuel channels (FC) on each reactor face, without having to bring the fuelling machine (FM) back to the reactor face. This capability is required by Spring 2008 outage (D811).
- Optimize feeder replacement durations by allowing parallel work and reduce dose associated with feeder replacements from 8 REM/feeder to 3 REM/feeder.
- Meet the 2007 2011 Business Plan and Generation Plan projections for feeder replacements.
- Execute a proactive feeder replacement schedule in order to ensure that the feeder replacement issue is managed to avoid the risk of forced outages or forced outage extensions.

Reduction in the radiation dose exposure due to this project is expected to be as follows:

- Provision of maintenance platform wing extensions will mitigate the requirement to erect and disassemble scaffolding in the reactor vault, for each bridge movement, associated with accessing peripheral feeders for replacement. In D611, 3 of the 5 planned replacements are peripheral feeders.
- Availability of channel isolation plugs (CIP) for feeder replacement campaigns will mitigate the dose associated with ice plugging. 50% reduced ice plugging dose is expected for each feeder as only one ice plug will have to formed per feeder instead of two.
- Improved ice plug freeze jackets will support freeze jacket installation from beyond arms reach resulting in reduced operator dose uptakes from feeder cabinet work.
- A trolley mounted storage magazine will mitigate the need to manhandle shield plugs for campaigns greater

DND - DARLINGTON STATION ENGINEERING BUSINESS CASE SUMMARY

than 8 feeders per reactor face when CIP's are used. The channel isolation plugs replace the shield plugs in the end fitting supporting ice plug formation. Shield plugs have dose rates as high as 20 to 30 REM/hr contact.

 Reduced radiation fields associated with mini platform shielding improvements are expected to result in a reduction of approximately 2 REM per inspection campaign where these canopies are used.

Summary of work required to be completed under this project to meet the business plan objectives, mitigate future risks, and to support future improvements such as reduction in overall outage duration is indicated below. Details are given in Section 4.

- Qualify the Single Fuel Channel Replacement (SFCR) Platform as an Elevating Working Platform (EWP).
- Modify the SFCR Platform to add Wing Extensions to access reactor face areas, not reachable from the
 existing platform.
- Commission the existing 7 Channel Isolation Plug (CIP) and perform Available for Service (AFS). The
 existing CIP's were designed and developed under the feeder integrity project (FIP).
- Procure additional 15 CIP's to allow fuel channel isolations for the larger feeder replacement campaigns, Modify inlet CIP design to correct existing design deficiency.
- Modify the mini-platform shielding canopy roof, to minimize radiation dose uptake from the feeder cabinet.
- Modify the SFCR Shielding Canopy to increase access to the feeders at the reactor face.
- Design a modified closure plug as Channel Drain Tool (CDT) to allow fuel channel isolation with the reactor bridge at variable locations. This provides greater flexibility in fuel channel isolation.
- Develop and provide a fuelling machine (FM) trolley mounted storage magazine to store CIP's, shield plug, and closure plugs to improve the fuel channel isolation process. The magazine will allow storage of up to 20 items such as shield plugs, closure plugs, CIPs or modified closure plugs or any combination of those. Install a Fuelling Machine Trolley Control System modification to integrate Storage Magazine Controls.
- Upgrade the Fuel Handling Software to track more than 5 Channel Isolation Plugs and to interface with the Storage Magazine Control System.
- Design and fabricate new freezing jackets to allow formation/maintenance of more than 2 ice plugs.

Released to Date:		650	Spent Life to Date:		
Capital Requested :	Fue	10,150	2006-2010 Appr'd Business Plan (Tot Proj):		
Cumulative Release:	Total to Date	650	2006-2010 Business Plan Variance:		
Total Project Estimate:	+30% to -15%	11,700	2006 Budget (Current Year)		
Current Year Estimate:	2006	1,430	2006 Budget Variance (Current Yr)		
Type of Investment	Sustaining	NA U	Cumulative Release Remaining:		
NPV:		N/A L	Contingency on Remaining Release:		
IRR:		N/A	Contingency % on Remaining Release:		

A PCRAF will be issued to adjust budget variance for 2006 and transfer funding to 2007 and 2008.

UNTARIOPOWI

GENERATIO



ONTARIO power	OPG Confidential	Page: 4 of 23
GENERATION	DND - DARLINGTON STATIO BUSINESS CASE SU	
neviewed By:	The Leol Finance Approval:	Nov 24/06
I. Khan Manager, Feeders & Reactor Maintenance Darlington Operations & Maintenance	te: Controller, Dartington	Date:
Reviewed By: RKElent 3.		Dae 18, 2006
S Seedbouse Gr	Date:	

Submitted By: Da 4/2004 au 02

Date:

<u>Gregory O. D. Smith</u> Senior Vice President Darlington Darlington

Line Approval (Per OAR Element 1.1 Project in Budget):

Mutchell P.R. Charlebois T.N. Mitchell Chief Nuclear Officer Ontario Power Generation



DND - DARLINGTON STATION ENGINEERING BUSINESS CASE SUMMARY

2/ BACKGROUND & ISSUES

The feeders interface with the Reactor Primary Heat Transport (PHT) Inlet and Outlet Headers and the Reactor fuel channels. Hence, feeders are critical to the reactor operation. The requirement for feeder replacements in Darlington Units is as a result of higher than expected wall thinning due to Flow Accelerated Corrosion (FAC), identified during periodic inspections performed under the PHT Feeder Piping Aging Management Strategy and Plan and the CSA N285.4 Standard.

The actual feeder replacements are being performed under OM&A project 38460 in 2006 and under Outage OM&A 30461 from 2007 onwards. This project 34008 is intended to provide the required capability to perform those replacements efficiently and effectively. The current Business Plan and Generation Plan shows a total of 66 feeder replacements required in Darlington Units during 2006 to 2011 window. Reasons for this proposed work are:

- As Darlington Units age, the number of required feeder replacements increases. Hence the requirement to have a proactive approach to eliminate prohibitive number of feeder replacements in the later years. Feeder replacements have been advanced to be proactive on the feeder replacement schedule.
- The Business Plan was aligned with the optimal replacement schedule in order to ensure that the feeder
 replacement issue is managed to avoid risk of forced outages or forced outage extensions.

The current project estimate of \$9M differs significantly from the original estimate of \$4.5M. Initial estimates were made at a time when the project scope was unclear and the level of collaboration with Bruce power was enticipated to be of much greater significance. During the development phase, the project deliverables have been beined based on business plan commitments. Both the GE and IMS have provided estimated costs associated with the defined deliverables. It has been determined that collaboration with Bruce Power can not be realized for the tools and capability developed under this project.

Other considerations are:

- 1. Feeder replacement is a critical path activity during outages when the required window is greater is 10 days. Any opportunity to minimize feeder replacement windows is an economic benefit to the Corporation and provides greater fleet outage flexibility.
- 2. Darlington does not have capability to perform feeder replacements in parallel and our current fuel channel isolation tools have limitations. These tools do not allow parallel fuel channel isolations.
- 3. Feeder replacement is a dose intensive operation. There is a need to minimize dose uptake as per the ALARA principles.
- 4. Critical path analysis to identify outage windows in the Generation Plan were based on certain assumptions or optimization strategies. They are:
 - a) Capability to do feeder replacements in parallel on both reactor faces by 2008. For this, we also need to obtain an additional set of advanced cut and weld tooling. This is being addressed by Science & Technology Division under a separate project.
 - b) Greater flexibility in channel isolation. For this, we need to purchase a new and improved Channel Drain Tool package.
 - c) Develop capability to isolate more than 8 fuel channels on each reactor face, without having to bring the fueling machine back to the reactor face.
 - d) Fuel Handling Software upgrade to track installation of Channel Isolation Plugs (CIP) in more than 5 fuel channels.
 - e) Develop capability to form/maintain ice plugs in parallel on more than 2 feeders (ideally up to 4).



DND - DARLINGTON STATION ENGINEERING BUSINESS CASE SUMMARY

3/ ALTERNATIVES AND ECONOMIC ANALYSIS

Do Nothing - Base Case (Not Recommended)

The status quo (base case of feeders replaced in series with two ice plugs to isolate fuel channels) alternative is not recommended for the following reasons.

- 1. There will be a greater amount of dose expenditure for feeder replacements and we will not be following the ALARA principles.
- 2. This will cause extension of the outage durations ranging from one day to 28 days. Outage push is illustrated in Attachment-B.
- 3. Darlington will not meet the 2007 2011 Business Plan commitments. The Business Plan assumes capability to replace feeders in parallel will be in place by D811.

<u>Alternative 1 – Implement full Scope as per Proposal in Section 4 (Recommended)</u>

This is the preferred alternative. The tools and capability will be bought as one package.



- 1. It will minimize the dose expenditure for Feeder Replacement work and will follow the ALARA principles. The current estimate of approximately 8 REM/feeder will be reduced to 3 REM/feeder once these improved tools are in place.
- 2. Darlington will be able to execute a proactive feeder replacement schedule in order to ensure that the feeder replacement issue is managed to avoid risk of forced outages or forced outage extensions.
- 3. Darlington will meet the 2007 2011 Business Plan commitments, as capability to replace feeders in parallel on both reactor faces will be in place by D811.
- 4. It will save significant critical path time for feeder replacements. See attached economic analysis.
- 5. Based on the economic analysis performed to determine impacts of the new tools on feeder replacement windows the NPV of the project is +\$56.8M compared with the base case (feeders replaced in series with 2 ice plugs per feeder for fuel channel isolation) for the assessment period of 2006 to 2011 (Attachment-B). If we expand the assessment period to 2014 the NPV of the project becomes +\$97.8M (See the modelling assumptions in Section 4).
- 6. The radiation dose savings due to improved tooling and methods are expected to be equivalent to \$3.7M.
- 7. The tooling and capability developed under this project is justified on its own merit. However, the NPV described above is based on an assumption that the 2rd set of advance feeder cut and weld tooling will be available by spring 2008.
- However, if OPG decides to not pursue the 2nd set of tooling and/or is deferred then NPV project will drop to \$35.4M for 2006-20011 assessment period and \$57M for assessment period of 2006 to 2014.

Alternative 2 - Delay the Recommendation (Not Recommended)

The delay alternative is not recommended for the following reasons.

- 1. We will not be ready for feeder replacements for the D611 outage.
- 2. There will be a greater amount of dose expenditure for feeder replacements and we will not be following the ALARA principles.



- 3. We will not meet the 2007 2011 Business Plan commitments. The Business Plan assumes capability to replace feeders in parallel will be in place by D811.
- This will cause a significant extension to the D811 outage duration. The outage extension will be up to 24 days as illustrated in the Attachment-B.
- 5. This will not allow feeder inspections to be done in parallel with feeder replacements for minimum of days impact per outage.

4/ THE PROPOSAL

The recommended work includes completing all analysis, documentation, tooling design, fabrication and commissioning, modifications to existing tooling, and training to safely execute the Feeder Replacement ALARA/Outage Optimization project. The project deliverables are as follows.

1. SFCR Platform qualification as an Elevating Working Platform.

This is required for both feeder replacements and fuel channel reconfiguration. Work needs to be done to meet Ontario Health and Safety Act (OHSA) requirements (both legal and safety) and implement restrictions via procedures to use the current maintenance platform and reactor bridge as an elevating working platform (EWP). This is required for the Fall 2006 outage (D611). This task is complete.



2. SFCR Platform Wing Extensions.

Design, build, fabricate and commission wing extensions for East and West Maintenance platforms to access feeder areas, not reachable from the existing maintenance platform. This will eliminate the need to build scaffolds on critical path and save dose and critical path time. Required for feeder replacements in the Fall 2006 outage (D611). This task is complete.

3. Channel Isolation Plug (CIP) Commissioning and AFS.

Commission existing 7 CIP's and implement required updates to Fuel Handling Operating Sequence Code (Op Data) to allow installation and removal of CIP's using fuelling machine (FM). The CIP function is to allow a fuel channel to be isolated for feeder replacement with a single ice plug, rather than using two ice plugs which is the current requirement for channel isolation. The CIP was designed by GE and delivered in 2003 by IMS under the Feeder Integrity Project. It was not commissioned. These are required for feeder replacements in the Fall 2006 outage (D611). This task is complete.

 Procure additional 15 CIP's to allow fuel channel isolations for the larger feeder replacement campaigns such as Spring 2008 and Spring 2011. Modify existing inlet CIP's to correct existing design deficiency. Estimated cost is the superscript of t

5. Mini-Platform Shielding Canopy Modification.

This is required to extend the caropy roof to minimize radiation dose uptake from the feeder cabinet. This canopy is used regularly to execute feeder inspections. This is required for Spring 2007 outage (D741). Estimated cost is the provided in 2007.

6. SFCR Shielding Canopy Modification.



To increase the size of the access window to the feeders at the reactor face. This is required for feeder replacements and fuel channel reconfiguration. This is required for Spring 2007 outage (D741). Estimated cost is the second sec

Page: 8 of 23

DND - DARLINGTON STATION ENGINEERING BUSINESS CASE SUMMARY

7. Closure Plug Based Channel Drain Tool.

ontario**pow**

Re-design Channel Drain Tool (CDT) package to provide greater flexibility in fuel channel isolation. GE has already developed this tool for Bruce Power. It will require modification to meet Darlington's service conditions and requirements. This is required by Spring 2008 outage D811. Estimated cost is

8. FM Trolley Mounted Storage Magazine.

Design and fabricate a fuelling machine (FM) trolley mounted storage magazine to store CIP's, shield plug, and closure plugs to improve the fuel channel isolation process. Install a Fuelling Machine Trolley Control System modification to integrate Storage Magazine Controls. The magazine will allow storage of up to 20 items such as shield plugs, closure plugs, CIPs or modified closure plugs or any combination of those. Storage of these components eliminates the need to manhandle high dose shield plugs for numbers greater than 8 per face or the need to remove and re-install platforms to manage the 8 shield plug limitation. This is required by Spring 2008 outage. Estimated cost is


- 9. Upgrade the Fuel Handling Software to provide capability to track Channel Isolation Plugs in the reactor and to interface with the Storage Magazine Control System. This is required by Spring 2008 outage D811. Estimated cost is
- 10. **Design and fabricate Feeder Freezing Jackets** to allow formation of at least four ice plugs in parallel. The current freezing jackets impose limitation of two of ice plugs that can be formed and/or maintained. This prohibits parallel next feeder set up while replacing the current feeder. This is required by Spring 2008 outage. Estimated cost of **Carlos** in 2007.

Modeling Assumptions:

Key assumption is that Feeders will always be critical path activity during outages. Current experience suggests that actual allocated outage window is less than that marked for in the Generation Plan and therefore built into the Business Plan. In addition, for future larger campaigns, feeders will have greater potential to secure a complete hold on being the critical path activity. Therefore the benefit will be the incremental days between the base case and the alternative.

Base Case (Do not acquire new capability- Status Quo):

- Dual ice plugs or CIP/Ice plug combination will be required to isolate fuel channels/feeders.
- Feeder replacement duration is 38 hours per feeder (8 hours for set up + 30 hours for cut/weld). Due to limitations in isolation, draining, and fuel channel components tracking and storage capability set up is required for each feeder.
- A three day shuffle of existing CIPs (installed in fuel channels) is required for every five feeders beyond the
 first five. This is due to the fact that only a limited number of CIPs can be used in the reactor due to
 handling/tracking limitations of the CIP's in the reactor. The three days is required to pull platforms, bring in the
 fueling machine and return the platforms.
- All feeder replacements will be conducted in series (including feeder freezing as noted above).
- Restrictions and lack of flexibility due to isolation requirements will force planned parallel feeder inspections to be conducted in series with replacements for D611 (7 days) and D721 (5 days).



Additional Soft Factors (Not included in the economic model):

- FM will remain dedicated to feeder replacements as it will contain the removed highly irradiated shield plugs.
- Serial activities with dual ice plugs will place additional limitations on feeder inspection flexibility, i.e. less
 opportunity to do parallel work with feeder replacements.

The Base Case applies to D611 and will apply to D721 due to timing of the alternative implementation, therefore incremental feeder replacement impacts will not be looked at until starting in D811 except for the capability to perform feeder inspections in parallel to replacements in D611 and D721.

Alternative (Acquire proposed tooling and capability):

- For greater than 7 feeders total replacements⁽²⁾ will be conducted in parallel, the equivalent number of feeders determined as per following guideline:
 - Opposite faces (EastWest) will be executed 100% in parallel.
 - Same face replacements can be conducted in parallel for 50%⁽¹⁾ of their targeted feeders remaining after completing the shorter opposite face. This assumes both crews operate at the same pace. Note this really only affects D1111 outage for an equivalent of a 2 feeder savings.
- If second set of advance cut and weld tooling is not available all replacements will be conducted in series.
- Feeder replacement duration is 8 hours setup + (30 hrs cut & weld) x (equivalent number of feeder). There is
 a one time set up for the first feeder as the advancements provided under the alternative allow for preparation
 of the next feeder while replacing the current feeder. This applies to both parallel and series replacement. This
 reverts to 0 + 38 hours if not successful in implementing 4 ice plugs in series (post meeting addition).
- The commissioning of existing CIP, wing extensions and qualification of the SFCR platform as EWP allow feeder inspections to be conducted in parallel with replacements for D611 and D721.
- A contingency of will be applied to the estimated cash flow.
- The cost of the second set of advance cut and weld tools is 6M\$ plus contingency. A relatively small contingency of will be assumed for a repeat order of a developed technology, i.e. the total 6.72M\$ with contingency and overheads. Assume that the second provide will not and should not partner and the cost will be shared uniformly between Pickering and Darlington. All cash flow is in 2007.
- The cost of the second set of advance cut and weld tool will be factored into the benefit where the second set is credited in this analysis.
- Dose savings of 5 Rem per feeder at cost of 25 k\$ per Rem. The dose benefit will not be added to the bottom line but rather shown as an additional benefit (post meeting addition).
- Dose savings start in 2008.

Notes:

- 1. Percentage of Feeders targeted which are within three (3) rows apart and greater than four (4) columns apart is 50%.
- 2. A criterion for parallel vs. series planned replacement is > 7 feeders total, east and west combined.



Page: 10 of 23

DND - DARLINGTON STATION ENGINEERING BUSINESS CASE SUMMARY

Additional Soft Factors (not included in the economic model):

GENERATION

ONTARIOPORE

- Feeder inspections are more likely to be in parallel with each other (face/face).
- Some potential for greater FM flexibility toward fuelling operating units.

Feeder Replacement	Schedule as	per current	Business Plan
A CONTRACTOR OF STATE AND			

Outage	Year	Feeders	West	East
611	2006	5	4	1
721	2007	5	4	1
811	2008	16	8	8
931	2009	5	3	2
1021	2010	10	5	5
1041	2010	5	3	2
1111	2011	20	8	12
1231	2012	10	4	6
1341	2013	8	4	4
1321	2013	8	4	4
1411	2014	20	10	10

Economic Assumptions:

Energy costs conservatively applied at 49.5 \$/MW.

Outage overheads (for extensions) of 400 k\$/day applied.

- Discount Rate = 7%. (Mid 2006 dollars determined in NPV)
- Escalation not included as this is a very simplified analysis.
- This BCS release covers the necessary work required for the D611, D721, D811, D1111 Outages and beyond.

Milestones Finish Date (D/M/Y)	Description	\$. !
30-Dec-05	Partial BCS	
15-Mar-06	D611 Outage - Design Mod documents issued	
30-Apr-06	D611 Outage - Support documents issued	
27-Aug-06	D611 Outage - 90% Materials on-site	
27-Oct-06	D611 Outage - Tooling and equipment on-site	
12-Feb-07	D721 Outage - Design Mod documents issued	
12-Apr-07	D721 Outage - Support documents issued	
12-Aug-07	D721 Outage - 90% Materials on-site	
12-Oct-07	D721 Outage - Tooling and equipment on-site	······
28-Jul-07	D811 Outage - Design Mod documents issued	
28-Sep-07	D811 Outage - Support documents issued	
Jan-08	D811 Outage - 90% Materials on-site	
-Mar-08	D811 Outage - Tooling and equipment on-site	
31-Dec-08	Project Closure/Simplified Post Implementation Review	



Page: 11 of 23

DND - DARLINGTON STATION ENGINEERING BUSINESS CASE SUMMARY

5/ QUALITATIVE FACTORS

- 1. This preparatory work is required in support of the Feeder Replacement Program to allow us to deal with the results of the inspections performed under the PHT Feeder Piping Aging Management Strategy and Plan and the CSA N285.4 Standard.
- 2. Feeder Replacement Program is required to operate the component safely and keep them in a safe condition as required by the Nuclear Power Reactor Operating License (NPROL) license condition 5.2.



OPG Confidential DND - DARLINGTON STATION ENGINEERING BUSINESS CASE SUMMARY



Description of Risk	Description of Consequence	Rok Berore Magyan	Mitig.marg Activity	Risk After Mitagitum
 Funding may not be sufficient. 2006 estimated expenditure may not be possible due to late start of the project. 	 Not meeting project objectives and outage milestones. Cash flow adjustment will be required. 	Medium	Add a term contingency to cover this item. Bruce Power has already developed some of the tools. Potential partnering with Bruce Power will reduce project costs. GE/IMS will provide firm estimates.	Low
Scope Additional tooling/procedures are required to implement the plan.	Higher cost	Medium	A memory will cover for additional tooling and procedures.	Гом
Schedule D811 deliverables are on a very tight schedule	May not be able to meet Outage milestones	Medium	Provide strong Project oversight and schedule control. Hold regular oversight meetings and communicate any threats and issues ahead of time with Outage.	Low
Z ^M set of tooling pursued by Science & Technology Division may not be available for D811.	Training set will have to be upgraded to production set at a cost of the allow parallel feeder replacements. The upgraded training set will then be used as a back-up tool set. Potential for one or more tools in upgraded training set to become contaminated if production set tool failure occurs.	Low	Work with Science & Technology Division to provide strong oversight to acquire 2 nd set of advance feeder cut & weld tooling.	V. Low

	Ø		2	≥
		in	iĒ	Ξļ
		2	!	3
	2			
	湖			
	Ĉ		i 🐪	-1
J	0	C		
53		L		
	2	7		1
	-		5	1

dential 13 of 23 INGTON STATION ENGINEERING

DND - DARLINGTON STATION ENGINEERING BUSINESS CASE SUMMARY

400Kgs/hour for non-isolable air ingress into the vault. will require set-up time of a hours between each pair of feeders being replaced in parallel. This will impact on parallel. This will drop from \$53M to \$46M. interpretation of the limit. Regulatory non-isolable air from \$53M to \$46M. interpretation of the limit. N/A parallel. This will impact on project NPV. The NPV will drop from \$53M to \$46M. interpretation of the limit. N/A N/A hours between each pair of from \$53M to \$46M. interpretation of the limit. N/A N/A N/A N/A
--



DND - DARLINGTON STATION ENGINEERING BUSINESS CASE SUMMARY

7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Final AFS Date:	Targeted PIR Approval Date:	PIR Responsibility (Sponsor Title)
Simplified	June 2008	Dec 2008	Feeders & Reactor Maintenance

Comments:

A simplified Post Implementation Review will be done for the project as part of the project closeout. The PIR will evaluate the completion of steps which would lead to success:

	Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it? (person / group)
1,	SFCR Platform qualification as an Elevating Working Platform (EWP) completed.		To be qualified as a EWP.	Standard procedural compliance. OSHA and legal requirement compliance. Report issued.	Feeders & Reactor Maintenance.
2.	SFCR Platform Wing Extensions addition completed.	No access to peripheral feeders.	Provide approved extensions to the existing platform.	Ability to work on peripheral feeders, normally accessible only by scaffolding.	Feeders & Reactor Maintenance.
3.	CIP commissioning and AFS completed.	Isolation capability limited to one feeder at a time.	Isolation capability increased to at least two feeders in parallel.	AFS completed	Fuel Handling
4.	Mini-platform Shielding Canopy modification completed.	Existing shielding canopy provides limited dose reduction for feeder inspection and other reactor face work.	Extension of the shielding canopy provides better protection against radiation dose uptake.	Availability for reactor face work. Dose rate in the canopy reduced.	Feeders & Reactor Maintenance.
5.	SFCR Shielding Canopy modification completed.	Existing canopy provides limited access for feeder replacement work.	Increased access to both reactor faces for feeder replacements and fuel channel reconfiguration.	Availability for feeder replacements and fuel channel reconfiguration work program.	Feeders & Reactor Maintenance.
6	Re-design of CDT package completed.	Existing CDT is large size, it protrudes and can only be installed manually.	Capability to isolate at least 2 Fuel channel/feeder isolation at one time.	Capability to form Ice plugs in parallel Fuel Machine connected to fuel channel	Feeders & Reactor Maintenance.
7	Storage Magazine to be installed on FM Trolley available	No flexibility in channel isolation. Need multiple visits to Fuel Bay.	To store up to 20 Shield Plugs, CIPs, and Closure Plug.	Fuel channel components are managed locally. Visits to fuel bay by FM eliminated.	Fuel Handling

ONTARIO	POWER GENERATION
UNTANIU	GENERATION

Page: 15 of 23

DND - DARLINGTON STATION ENGINEERING BUSINESS CASE SUMMARY

8	Fuel Handling (FH) Software upgrade to track CIP locations in the reactor.	FH Operating Manual and Software cannot support use of multiple CIPs or the Storage Magazine on the FM trolley.	OM updated and Software upgraded.	Allow multiple CIP use and interface with the system control for the Storage Magazine on the FM trolley.	Fuel Handling.
9	Improved design freezing jackets available. Can form or maintain more than 2 ice plugs	The current freezing jackets impose limitation of two of ice plugs that can be formed and/or maintained.	Improved design freezing jackets available that are capable of forming or maintaining more than 2 ice plugs.	Can form or maintain more than 2 ice plugs.	Feeders & Reactor Maintenance.



Page: 16 of 23

DND - DARLINGTON STATION ENGINEERING BUSINESS CASE SUMMARY

DND Feeder Replacement ALARA/Optimization Project 16-34008

Full Release (Phase 1) Business Case Summary D-BCS-33160-10005-R000

Attachment "A"

Project Cost Summary

\$000's Capital	LTD Prior Years							LTD This Mth Dec	LTD
	2005	2006	2007	2008	2009	2010	Total	2005	16
Project Management (OPG)		50	120	120	120		410		
Engineering & Drafting (OPG)			100	100			200		
Contract - IMS &		1,020	4,130	1960		-	7110		
Contract - Other			50	50		-	100		
Contract - FH software upgrade		-	400	500	-	-	900		<u> </u>
						-	•	•	-
Interest (Capital Project Only)		30	200	50	15	-	295	- 1	0.0%
Sub-Total (and Contingency)	•	1,100	5,000	2780	120	-	9,000	-	0.0%
General Contingency (30%)		330	1,500	834	36	-	2,700	N/A	N/A
Total Contingancy	-	330	1,500	834	36	-	2,700	N/A	N/A
Grand Total (Inci Contingancy)	-	1,430	6,500	3,614	156	-	11,700	N/A	N/A
2006-2010 Business Plan		2,500	4,500	1,000	1,000		9,000	N/A	N/A
Var to Bus Plen (exci Contingency)	•	(1,400)	500	1,780	(880)		-	N/A	N/A

Removal Costs included in above	0
Definition Costs Included in above	0
Estimate Name, Quality, etc	Budget Estimate +30% to -15%
Design Complete:	Up to ~ 40%

Reviewed By

No116/2006 Date:

Douglas McKenzie

ct. Manager, Feeders & Reactor Maintenance Engineering pport.

Approved S NW. 16,0006 Date: ljaz Khan

Manager, Feeders & Reactor Maintenance **Darlington Operations & Maintenance**

ONTARIOPOWER GENERATION

OPG Confidential

Page: 17 of 23

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

Attachment - B

BCS Economic Analysis Assumptions

All assumptions have been derived from a meeting on 28 September 2006 with site feeder personnel and finance. Attendees were: Ijaz Khan, Doug McKenzie, Ann Brooks, and Bob Grandoni. The assumptions were further refined based on a challenge meeting on 2 November 2006. Attendees were: Ijaz Khan, Stu Seedhouse, Ann Brooks, John McIntee, Ian Mackenzie, Don Powers, Randy Leavitt, and Bob Grandoni.

This economic analysis contains the following elements:

- 1. Channel Drain Tool (CDT)
- 2. Fuelling Machine (FM) Trolley Mounted Storage Magazine
- 3. Channel Isolation Plug (CIP)
- 4. Fuel Handling (FH) Software Upgrade
- 5. Freezing Jacket Upgrade

The benefits from above begin in D811. The exception being the commissioning of existing CIPs, Platform extensions and SFCR platform qualification as Elevating Working Platform (EWP) for which benefit materialized for D611 & D721 in way of providing for feeder inspections to be in parallel with replacements. Simplified assumptions will be used to determine the impact and then predict an approximate incremental benefit.

Key assumption is that Feeders will always be critical path. Current experience suggests that actual allocated itage window is less than the marked for in the Gen Plan and therefore built into the Business Plan. In addition, in future, larger campaigns, feeders will have greater potential to secure a complete hold on being critical path. Therefore the benefit will be the incremental days between the base case and the alternative.

Base Case:

- Dual ice plugs or CIP/Ice plug combination will be required to isolate fuel channels/feeders.
- Feeder Replacement duration is 38 hours per feeder (8 hours for set up + 30 hours for cut/weld). Due to limitations in isolation, draining, and fuel channel components tracking/storage capability set up is required for each feeder.
- A 3 day shuffle of existing CIPs is required for every 5 feeders beyond the first 5. This is due to the limited
 number of CIPs and handling/tracking limitations of the CIP's in the reactor. The 3 days is required to pull
 platforms, bring in the fueling machine and return the platforms.
- All feeder replacements will be conducted in series (including feeder freezing as noted above).
- Restrictions and lack of flexibility due to isolation requirements will force planned parallel feeder inspections to be conducted in series with replacements for D611 (7 days) and D721 (5 days).

Additional soft factors not included:

- FM will remain dedicated to feeder replacements as it will contain the removed shield plugs.
- Serial activities with dual ice plugs will place additional limitations on feeder inspection flexibility, i.e. less opportunity to do parallel work with replacements.

Alternative:

- For greater than 7 feeders total replacements⁽²⁾ will be conducted in parallel, the equivalent number of feeders determined as per following guideline:
 - o Opposite faces (East/West) will be executed 100% in parallel.
 - Same face replacements can be conducted in parallel for 50%⁽¹⁾ of their targeted feeders remaining

18 of 23

Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

after completing the shorter opposite face. This assumes both crews operate at the same pace. Note this really only affects D1111 outage for an equivalent of a 2 feeder savings.

- If second set of advance cut and weld tooling is not available all replacements will be conducted in series.
- Feeder replacement duration is 8 hours setup + (30 hrs cut & weld) x (equivalent number of feeder). There is
 a one time set up for the first feeder as the advancements provided under the alternative allow for preparation
 of the next feeder while replacing the current feeder. This applies to both parallel and series replacement.
 This reverts to 0 + 38 hours if not successful in implementing 4 ice plugs in series (post meeting addition).
- The commissioning of existing CIP, wing extensions and qualification of the SFCR platform as EWP allow feeder inspections to be conducted in parallel with replacements for D611 and D721.
- A contingency of www.ll be applied to the estimated cash flow.
- The cost of the second set of advance cut and weld tools is 6M\$ plus contingency. A relatively small contingency of movil be assumed for a repeat order of a developed technology, i.e. the total 6.72M\$ with contingency and overheads. Assume that Bruce Power will not and should not partner and the cost will be shared uniformly between Pickening and Darlington. All cash flow is in 2007.
- The cost of the second set of advance cut and weld tool will be factored into the benefit where the second set is credited in this analysis.
- Dose savings 5 Rem per feeder at 25 k\$ per Rem. The dose benefit will not be added to the bottom line but rather shown as an additional benefit (post meeting addition).
- Dose savings start in 2008.

ONTARIO**po Ne**r

GENERATION

otes:

- 3. Percentage of Feeders targeted which are within three (3) rows apart and greater than four (4) columns apart is 50%.
- 4. A criterion for parallel vs. series planned replacement is > 7 feeders total, east and west combined.

Additional Soft Factors (not included in the economic model):

- Feeder inspections are more likely to be in parallel with each other (face/face).
- Some potential for greater FM flexibility toward fuelling operating units.

The Base Case basically applies to D611 and will apply to D721 due to timing of the alternative implementation, therefore incremental feeder replacement impacts will not be looked at until starting in D811 except the capability to perform feeder inspections in parallel to replacements in D611 and D721.

Feeder Replacement Schedule as per Current Business Plan

Outage	Year	Feeders	West	East	
611	2006	5	4	1	
721	2007	5	4	1	
811	2008	16	8	8	
931	2009	5	3	2	
1021	2010	10	5	5	
1041	2010	5	3	2	
1111	2011	20	8	12	
231	2012	10	4	6	
1341	2013	8	4	4	
1321	2013	8	4	4	
1411	2014	20	10	10	



Page: 19 of 23

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

Economic Assumptions:

Energy costs conservatively applied at 49.5 \$/MW. Outage overheads (for extensions) of 350 k\$/day applied. Discount Rate = 7%. Escalation not included as this is a very simplified analysis. CCA% = 20%

Outage Days Extension For Various Alternatives (Assumes 4 ics plugs):

	2006	2007	2008	2009	2010	2011
Outage	Dett	0721	D811	D931	D1021/41	01111
Do Nothing	7	5	24	1.3	13.6	27.8
Delay 2 year (with 2nd set tool)	7	5	24	1.3	0	0
Do Now (NO 2nd set tooling)	0	0	10	0	6.3	12.5
Do Now (with 2nd set tooling)	0	0	0	0	0	0

Summary of BCS Economic Analysis

PV & Total Outage Days:	To	2011	To 2014		1
Iternative Benefit Outcomes	NPV	Outage Davs	NPV	Outage Days	
2nd Tools & 4 ice-Plugs	\$ 58,346	79	\$ 97,840	140	Solution of and Set Tools Included in Benefit
2nd Tools & 2 Ice-Plugs	\$ 49,068	69	\$ 85,807	124	< DN Cost of 2nd Set Tools included in Benefit
No 2nd Tools & 4 Ice-Plugs	\$ 35,437	50	\$ 57.014	82	
No 2nd Tools & 2 Ice-Plugs	\$ 21,330	33	\$ 33,455	51	1

Inferred From Above:

Benefit 2nd Tools & 4 Ice-Plugs	\$ 21,409
Benefit 2nd Tools & 2 Ice-Plugs	\$ 27.758

 \$ 40,828
 < DN Cost of 2nd Set Tools Included In Benefit</th>

 \$ 52,352
 < DN Cost of 2nd Set Tools Included In Benefit</th>

Dose Benefits:

Dose Saving (Rem)	330	560
Dose Saving Equivalent NPV (k\$)	\$ 3,728	1 8176

Page: 20 of 23

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

BCS Economic Analysis (2006-2011)

Outage (D) 611 721 811 931 1021 1041	Year 2006 2007 2008	# Foeders	# West		Series vs	Impact as			h 2nd Set	T	Duration	o 2nd Set To	Г			Benefits	4
721 811 931 1021	2007	5 5		# East	Parašel in BP	impact on inspection (hrs)	Duration Base Case (hrs)	Ouration Alternative (ivs)	Benefit hrs	Benefit K\$	Alternative No 2nd Set	Benefit No 2nd Set (hrs)		efil No Set (k\$)	Dose Save (Rem)	Dose Equiv (k\$)	Escalation Factor
811 931 1021			4	1	Senes	168	描章	195	168	\$ 10,630	160	:63	1	REER	0	\$.	1.00
931 1021	2000	5	4	1	Senes	120	739	199) 199	120	\$ 7,711	190	1.10	1	7,711	Ō	5	1.02
1021	·	16	8	8	Parailei	0	824	248	576	\$ 38,161	488	336	\$	22,261	80	\$ 2,000	104
	2009	5	3	2	Series	0	190	158	32	\$ 2,098	158	32	\$	2,098	25	\$ 625	106
30.11	2010	10	5	5	Parallel	0	452	158	294	\$ 19,002	308	144	\$	9,307	50	\$ 1,250	1.08
	2010	5	3	2	Senes	0	190	158	32	\$ 2,068	158	32	\$	2,068	25	\$ 625	1.08
1111	2011	20	8	12	Paratiel	0	976	308	668	\$ 42,633	608	368	\$	23,486	100	\$ 2,500	1.10
1231	2012	10	4	6	Parafiel	0	452	158	294	\$ 18,812	308	144	ŝ	9,214	50	\$ 1,250	1.13
1341	2013	8	4	4	Parallel	0	376	128	248	\$ 16,412	248	128	\$	8,470	40	\$ 1,000	1.15
1321	2013	8	4	4	Paratel	0	376	128	248	\$ 16,412	248	128	\$	8,470	40	\$ 1,000	1.15
1411	2014	20	10	10	Parailei	0	976	508	668	\$ 46,700	608	368	\$:	25,727	100	\$ 2,500	1.17
OT Cost		-		1000			07 IV	40333	1937	AT 1 3	A#14						
ŧ	·····	Total	2000	2067	1004	-	2918	2011	2012	2011	214						
rolley Cost				-													
IP Court			-			8											
oftware Co																	
weze Jacke				-													
P& Wing C					10.00												
otal Cost w			-		-												
Set Tool						\$ -	<u>s</u> -	\$ -	<u> </u>	5 -	<u>\$</u> .						
parent Tol		1 12 /40 1	1,13003		A												
2/10/10/10/10	un oost 1	A NORA T	8. S.M.	the second s	of 2nd Set Te	ots included in	Panelle Whee	n Tasl Courts									
ith Ind Set	Tool						L PLOTS AND A S LUMA		v								
avings (kS)		\$ 122,303	用知的	\$7211	· 2.41	1 2000	2.07	42,5321		1 -1	\$						
enefit (days		79	70	5.0	24.0	1.3	13.6	27.8	0.0	0.0	0.0						
	NPV 3	\$ 55 595	To 2011	Successful	ly implemente	d 4 ice Plugs ii	Parallel		L	L							
) 2nd Set T	Tool																
vings (k\$)		\$ 77,561	100001		an and 1		100000000000000000000000000000000000000	1									
ment (days	a	<u>, ,,,,,,,,</u> 50	70	_		and the second		the second s	and the second se	Z	5						
I I I I I I I I I I I I I I I I I I I				5.0	14.0	1.3	7.3	15.3	00	0.0	0.0						
<u> </u>			/		у нартитиски	d 4 ice Plugs ir	i Patahai										
se impacts	\$		_														
vings (Ren	n)	280	0.0	0.0	80 0	25.0	75.0	100.0	0.0	0.0	00						
vings (k\$)	NPV =	7,000 1 3,128			2,000	\$ 6251		2.508									

<u>Variables</u>

ONTARIOPO E GENERATION

Description	Valve	Name	Notes
Fdr Rep Duration Base Case (hrs)	38	fdrrepbase	
Fdr Rep Duration Alternative (hrs)	30	fdrrepalt	
Setup duration Alternative (hrs)	8	setup	
Shuffle at number of fdrs	5	thresshuf	
Shuffle Duration (hrs)	72	shuffle	=3*24
Threshold for Parallel	7	threspar	
Outage Overhead per hour (k\$)	14.6	outhead	=350/24
jst Revenue per hour (k\$)	43.0	revlost	=878*49/1000
Analysis Period (0 = to 2011, 1 = to 2014)	0	period	

Page: 21 of 23

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

BCS Economic Analysis (2006-2014)

						·····		Wid	2nd Set 1	0018	N	o 2nd Set To	al	Dose	Benefits	1
Outage [D]	Year	# Feedors	# West	#East	Series vs Paradel In BP	Impact on Inspection (hrs)	Duration Base Case (hrs)	Duration Alternative (hrs)	Benefit fyrs	Benefit K\$	Duration Atternative No 2nd Set (hes)	Benefit No 2nd Set (hni)	Benefit No 2nd Set (k\$)	Dose Save (Rem)	Dose Equiv (k\$)	Escalation Factor
611	2006	5	4	. 1	Senes	168	190	892	168	\$ 10,630	190	166	1 10.630	n	5 .	1 00
721	2007	5	4	1	Series	120	1907	190	120	\$ 7,711	190	120	3 7713	ñ	1	1 02
811	2008	16	8	8	Parallei	0	824	248	578	\$ 38,161	488	336	\$ 22,261	80	\$ 2,000	104
931	2009	5	Э	2	Senes	0	190	158	32	\$ 2.098	158	32	\$ 2,098	25	\$ 825	104
1021	2010	10	5	5	Parallel	0	452	158	294	\$ 19,002	308	144	\$ 9,307	50		
1041	2010	5	3	2	Series	0	190	158	32	\$ 2,068	158	32	and the second		1,250	108
1111	2011	20	8	12	Parallel	Ö	976	308	668	\$ 42,633	608	368	\$ 2,068 \$ 23,486	25	\$ 625	1.08
1231	2012	10	4	6	Parallel	0	452	158	294	\$ 18,812	308	144		100	\$ 2,500	1 10
1341	2013	8	4	4	Paratel	0	376	128	248				\$ 9,214	_50	\$ 1,250	1 13
1321	2013	8	4	4	Parsile	0	376	128	248	\$ 16,412	248	128	\$ 8,470	40	\$ 1,000	1 15
1411	2014	20	10	10	Parallel	0	976	308		\$ 16,412	248	128	\$ 8,470	40	\$ 1,000	1.15
<u></u>	CUIT	1	10				310	346	668	\$ 46,700	608	368	\$ 25,727	100	\$ 2,500	1.17

Cash Flows and NPV:

ONTARIOPOWER GENERATION

đ	110	6al	2009	1 2007	2008		2000	2010		2011	2112	2013	2014
COT Cost											-	+-=-	
Trolley Cost						18			-			+	+
CIP Cost						1					+	+	
Software Cost					a service of		****			· · · ·	+		
Freeze Jacket						11			<u>-</u>	·	+		
CIP& Wing Com'n					Transferration of						+		
roject Total Costs	1					1					+		
otal Cost w/ Contg.				10000		5		\$	- 15		5 -	S .	s
Set Tool DNS	12					1			-+-		<u> </u>	<u> *</u>	· •
344 10010143													
Januari Total Cost Vith 2nd Set Tool					ost of 2nd Set							1	1
Januari Total Cost Vith 2nd Set Tool												1	1
Vith 2nd Set Tool avings (k3)		220,638	10.00		1. J. 10		20.25	\$ 21,5		42.839	1546,412		[5 774 3 7
Vith 2nd Set Tool invinge (LS)	5	220,638	7.0	5 .0	24.0	1	200	13.6				1 32423 20.7	27 8
Vith 2nd Set Tool Vith 2nd Set Tool Vith 2nd Set Tool Vith 2nd Set Tool	5	220,638	7.0	5 .0	1. J. 10	1	200	13.6		42.839	1546,412		
Total Cost Vith 2nd Set Tool NPV = KO 2nd Set Tool avings (k\$)	S	220,638 140 97,840	7.0	5.0 Success	24.0 Lutty Implement	tad 4 k	200	\$ 21,8 13.6 In Parallel		42.833 27.8	\$15,412 12.3	20.7	27.8
Total Cost Vith 2nd Set Tool NPV = KO 2nd Set Tool avings (k\$) enefit (days)	5	220,638 140 97,840	7.0 7.0 7.0 7.0 7.0 7.0	5.0 Success	24.0 Lutty Implement	tad 4 k	2000 1.3 In Plugs	\$ 21,8 13.6 In Parallel		42.833 27.8	\$15,412 12.3		27.8

Ceraste (izen)	310	0.0	0.0	80.0	25.0	75.0	100.0	50.0	80.0	100.0]	
Savings (k\$)	\$ 12,750	4 .		2 200	1 63	1. 1.175	2 5	1 1250	\$ 2.320	1 2.500	
NPV +	\$ 8135	To 2014			and the second sec			La contraction of	1.000		
	· · · · · · · · · · · · · · · · · · ·	E 10 4014									

ONTARIO **OFER** GENERATION

OPG Confidential

22 of 23

Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

	Tu	and the state	G	TRees	n 1		-	Threads & a			— — ,							
		4 Mile 2 A.S. 3 7 6 449 7 1	T FVRIDEN	AN HEY		New York		2	in Frankline	لتربوز للقدري	لي . مردين							
The second	<u>'A</u>	Ì			-													
		1																
	-			10 2017	Jacoust	laty ampian	erited 4 km i	nuge in Peret	ſ									
	NW NOW AD																	
	ave M																	
-	ning Halandary																	
and favore and the second seco	ta	in the second			1 004		17.1 19.1 19.2			ini ar			a		780 7		AN	
	ļ					10.01 12	D ,	;		÷ i		ŧ			Ŧ	÷	- f	-
	1		·		Ŧ -			+		1		-			İ		<u>)</u> 	1
	· · · · · · · · · · · · · · ·		214	**	238	ill'in							المعد الم	· ·····	+ ++++++++++++++++++++++++++++++++++++	<u></u>		-
i and the second s				· · · · ·	ì``[·						·	·····	<u> </u>			·		-
	1		∮/ ·	ļ :	1			t E								1	(1	-
			• • • • • • • • •				;	· ·			<u>1</u>		t.t		- F	T	fa sera	-
ىدەرىيىيەردە بىيەبىر بەرسەر سىيەمەرىيىتىدى. چېر بىيەر بىيەنىيەر ۋېرىيەرىيە بىيەر يېچى د									···+ ·· · ····	. American		. <u>†</u>				· † · · · • •		
میان این این میروند. په میند که این کار با این این میروند که میرون با این کار مراجع این میروند که میرون با این میروند این میروند این میروند این میروند ا	- Hourdana	- 遵		14. A 10	- and the second				······································				······································			در میرا همانم به و از میرا طبو ا		
	-	• • • • • • • • •	• ^ / · · · · · · · · · · · · · · · · · ·	••••••••••••••••••••••••••••••••••••••		 ر هر به محمد م ون	· · · · ·	· · · ·	······································								an in an the main frame	Time
2 - Mill Agistand, and selection of a support 24 - Sentin Manufactur, ganet support 24 - Sentin Alian, support	110	5 m 5	· +#	í	÷ •		•										-	2
A second product and a second probability of the second se	1 2 4			•														1
An Sealaite annan 17 Anna 2014	**									• •								
in 1 28 ; million (- such as M	***										2						-	
ht shant ata' anna an anna an anna an anna a' Shar V 19 - Anna anna Sharper, Sa' Angaran	***							, í		· `							ł	1
		**************************************		10 HIL				an a sugar su						الم سيبين				1
	·····	14	1.4	-		-	**************************************					ан н 1917-тар	- 	* • • • • • • • •	* 4	1		
							~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	· · · · · · · · · · · · · · · · · · ·		and the second data	en itteren							<u> </u>
			- FF	100		1.00	A	100 22	04 1				7.2.5	1.1	St. 12.			
in the second state of the			2.44 >7 * 42 					ر میر هند میشد.						lian se				
And Andreas Share Barris Sans			×***					ر میر هند میشد.						lian se	<b>11.</b>		-	
				20				ر میر هند میشد.			1		ser.			154		
				20							1		ser.					1
				201							14.3		ser.			154		1
				201							14.3		ser.			154		1
	attaining a			201							14.3		ser.			154		1
				2000 2000 2000 2000				. 11					- <b>5-87</b> - <b>5-87</b> - <b>5-86</b> 5-860	in a				
Man Control and a set of and a set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set				2000 2000 2000 2000				. 11					- <b>5-87</b> - <b>5-87</b> - <b>5-86</b> 5-860	in a				
Man Control and a set of and a set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set				2000 2000 2000 2000				. 11					- <b>5-87</b> - <b>5-87</b> - <b>5-86</b> 5-860	in a				
Man Section 2. Sec. 2. And 2. Sec. 2. Sec. 3.				2000 2000 2000 2000				. 11					- <b>5-87</b> - <b>5-87</b> - <b>5-86</b> 5-860	in a				
Man Section 2. Sec. 4. Act 5. Sec. 5.				2000 2000 2000 2000				. 11					- <b>5-87</b> - <b>5-87</b> - <b>5-86</b> 5-860	in a				
Her Constant, Salar Sala	***************************************			2000 2000 2000 2000				. 11					- <b>5-87</b> - <b>5-87</b> - <b>5-86</b> 5-860	in a				
Her Constant, Salar Sala				2000 2000 2000 2000				. 11						in a				
Her Section 2 and																		
Here in the second seco								. 11										
<pre>HTTP://www.inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/inter.com/</pre>																		
Her Schener, Sale La Ser, Sale																		
Her for the second seco																		
An effective of the development of the second secon																		
Attribute of the device of																		
<ul> <li>Statistics of the second /li></ul>																		
Alter for a stand of the stand	The second secon																	
<pre>Http://www.sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex.com/sci.ex</pre>																		
An Section of the device of the section of the sect																		



23 of 23

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

23 of

Page:

# Attachment - C

Description of Impacts of the new tools that will be designed and fabricated under this project:

# CDT (Channel Drain Tool)

The existing CDT design limits bridge movement (CDT protrudes). Consequentially, the parallel feeder activities are restricted to within 3 rows and greater than 4 columns apart. The impact of this restriction is that approximately 50% of the planned feeders will have to be replaced in series costing the corporation a significant outage time. This requires additional bridge movements and waiting for one feeder cut and weld activity to complete before the preparation for the next feeder can start. The impact is at least 8 hours per feeder for 50% of feeders to be replaced. The new design CDT (which will be a modified closure plug) will effectively address these restrictions and limitations imposed by the current CDT.

# FM Trolley Mounted Storage Magazine for Shield Plugs, Closure Plugs, CIP's

The FM has a capacity to swap one (1) closure plug at a time. As result, a run back to the fuel bay would be required for each channel undergoing feeder replacement for installing the CIP/modified closure plug and then to return the shield/closure plug. The proposed trolley storage magazine allows these items to be managed locally. The impact is 4 hours to run to the fuel bay twice vs. 0.5 hours to drop to the trolley twice per feeder.

# CIP (Channel Isolation Plug)

Currently Darlington has 7 CIPS (hold one CIP back as a spare for failure/discovery and credited 6) and will require greater than 20 CIP's in the Business Plan period. The project will commission the existing set of CIP's and procure 15 more. Not having sufficient CIP's will force use of 2 ice-plugs for the additional feeder replacements. This has two impacts;

- 1) Forces serial activities, and
- 2) Displaces parallel feeder inspection activities for already serial feeder replacements. The displaced inspections are 7 days critical path for D611 and 5 days critical path for D721.

# **FM Software**

Fuel Handling Operations can manually track using procedural barriers up to 5 CIP's installed in the reactor without causing increased risk to fuel cooling. The current FM software has no capability to track CIP's installed in the fuel channels. Replacement of greater than 5 feeders in one outage will require cycling the FM for a 3 day delay for every 5 feeders.

# Feeder Freezing Jackets

The current freezing jackets impose limitation of two ice plugs that can be formed and/or maintained. This prohibits parallel next feeder set up while replacing the current feeder. Therefore, it adds 8 hours of set up to each feeder targeted for replacement. It is therefore imperative to expand this capability to at least 4 ice plugs that can be formed or maintained in parallel.

ONTARIO GENERATION

25

Page: 1 of 24

**BUSINESS CASE SUMMARY** 

# CFC Chillers Replacement Project 13 - 40543

# Full Release (Phase 2) Business Case Summary P-BCS-73000-00001-R002

Routing	Location	Action	Signature	Date
M. Arnone Director, Projects & Modifications 701-6063	P72-1	Review BCS	m	That Zoo
T. Mitchell Site VP, Pickering B 701-3501	P41E3	Submit BCS	Minhall.	7ADV2000
P-Charlebois- The M. Heliely EVP and CNO 702-5294	P82-26A	Concurred By	Mutcheece	212006
R. Leavitt Director, Investment Management 702-5085	P82-3	Review BCS	Alawist	Nos.16, 2006
J. Beech VP, Nuclear Finance 400-7226	TCH 09 F26	Review BCS	九人	Jan 3 Zoal
D. Power Director of Invest & Bus Planning-VP 400-7172 Carp. Investment Pla	TCH 07 D06	Approve BCS	Fran	Jun 7/07
Hankinson Besident and CEO Recid Feb 1/07 10-2121	TCH19A24	Approve BCS	X Munna	-7 eb 8
R. Ball Senior Financial Analyst 702-4084	P82-3B6	Return For Distribution	C	





Page: 2 of 21

BUSINESS CASE SUMMARY

# CFC Chillers Replacement Project 13 - 40543

# Full Release (Phase 2) Business Case Summary P-BCS-73000-00001-R002

Lo / K. Osman	Dusiness Ca	se Summary	P-BCS-73000-00001-R0(	)2
roject Engineer, Design Projects 701-5034 / 701-3364	P72-3	Prepare BCS	Michael 6	003,2000
C. Misketis Project Leader II, Design Projects 701-2512	P72-3	Review BCS		Bet. 3, 200
G. Makdessi Project Manager, Design Projects 701-6617	P72-3	Review BCS	- ABE	3042006
D. McAuley Section Manager, PMO 701-4491	P72-3	Review BCS	outil	40000
R.Ludlow Manager, Design Projects 701-8055	P72-3	Review BCS	DII	6 00 766
R. Ball Senior Financial Advisor 702-4084	P823B-6	Review BCS	1 SE	2000006
G. Brown Controller, Engineering & Modifications 702-5059	P823B-6	Review BCS	1 G	20 Cr. Ces
Mark Elliot Prector of Station engineering PNGS B 1-2106	P41-E3	Review BCS		z4a+06

Page: 3 of 24

**BUSINESS CASE SUMMARY** 

# CFC Chiller Replacement Project 13 - 40543

#### Full Release (Phase 2) Business Case Summary P-BCS-73000-00001-R002 1/ RECOMMENDATION:

We recommend a Phase II full release for a total of \$22,377 K (including contingency) to complete the following:

The installation/commissioning of the three Reactor Auxiliary Bay (RAB) Chillers,

ONTARIOPOWER

GENERATION

- The detailed design and installation/commissioning of the three Service Wing (SW) Chillers
- The installation/commissioning of the Administration Building Extension (ABX) Chiller

The objective of this sustaining project is to replace the seven (7) existing Pickering CFC Chillers in order to:

- comply with the amendments by Environment Canada Federal Halocarbon Regulations-2003.
- remove some of the obstacles for returning the System Health status of each system from red/yellow to white, by addressing increasing maintenance on this aging equipment

provide contingency planning to meet regulation requirements prohibiting major chiller repairs after January 1, 2005. Failure to comply with this new regulation would result in significant fines, legal ramifications, and a significant impact to our

A Phase I full release of \$6.7M was previously approved in January of 2005. After progressing through the Phase I portion of the project, it was realized that the split of Phase I and Phase II work would need to be revised to accommodate a more cost effective installation sequence. Also during this project phase, it became apparent that both Phase I and overall project costs would be significantly higher than originally estimated. The estimated cost of work previously identified as Phase I is now \$16.8M versus the previously released \$6.7M. The overall project cost estimate is now \$22.4M versus the previously estimated \$9.4M due to discovery work, improved cost estimates after the completion of more detailed engineering, and receipt of more accurate vendor quotations.

e details of the cost increases and progress to date are outlined in the Background / Issues section of this BCS. SCR No. 2006-18017 has been raised to document the problems with the estimate used for the Phase I BCS.

With most of the engineering complete, RAB platform and chillers in place, RAB installation experience gained, and a third party cost estimate review, we feel confident that this project can be finished on time and within the cost estimate of \$22.4 M. The estimate includes a specific contingency of the state and a general contingency of for unforeseen issues.

Funding	LTD 2005	2005	2007	20.62	Tanka		· · · · · · · · · · · · · · · · · · ·	سربر ۱۰ با سیار بخت اخ
Full - Phase 1	4 006	الاست. المدار الم				2010	Later	Total
					{ ↓		· · · · · · · · · · · · · · · · · · ·	6,741
		932 j	<u> </u>	5,127	<u> </u>			15,636
	3 806	1 007			/ +			
	3,050	3,00/	8,843	5,127	844		-	22,377
			+				i i	
	7 806					-	·	•
voe	the second secon				844	-	- 1	22,377
¥		- 1			IRB WA		Discounted	
	Full - Phase 1 Full - Phase 2	Full - Phase 1         4,006           Full - Phase 2         (110)           3,896         3,896           Ype         Class	Full - Phase 1       4,006       2,735         Full - Phase 2       (110)       932         3,896       3,667         3,896       3,667         Ype       Class	Full - Phase 1         4,006         2,735           Full - Phase 2         (110)         932         8.843           3,896         3,667         8,843           3,896         3,667         8,843           3,896         3,667         8,843           Ype         Class         NPV or	Full - Phase 1         4,006         2,735           Full - Phase 2         (110)         932         8,843         5,127           3,896         3,667         8,843         5,127           3,896         3,667         8,843         5,127           3,896         3,667         8,843         5,127	Full - Phase 1         4,006         2,735         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009         2009	Full - Phase 1       4,006       2,735       2009       2010         Full - Phase 2       (110)       932       8.843       5,127       844         3,896       3,667       8,843       5,127       844         3,896       3,667       8,843       5,127       844         Graded       3,896       3,667       8,843       5,127       844         3,896       3,667       8,843       5,127       844       1000         State       3,696       3,667       8,843       5,127       844         State       State       State       State       1000       1000         State       State       State       State       1000       1000       1000         State       State       State       State       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000       1000	Full - Phase 1         4,006         2,735         2009         2010         Later           Full - Phase 2         (110)         932         8.843         5,127         844           3,896         3,667         8,843         5,127         844         -           3,896         3,667         8,843         5,127         844         -           3,896         3,667         8,843         5,127         844         -           Vpe         Class         NPV or JEV         IRB         Discounted

7 Nov acle

Date:

Altertilield T. Mitchell

Site V.P. Pickering

Finance Approvallen 11/0 -Power rector of Investment & Business Planning

i ine A (Per OAR Element 1.1 Project in Budget):

HB 8 J. Hankinsor President and CEO



**BUSINESS CASE SUMMARY** 

# 2/ BACKGROUND & ISSUES

Pickering "B" NGS has seven (7) CFC Chillers located in three separate areas that need replacement with non-CFC units (Reference: ECR 734369 and SCR P-2003-03155). This project will ensure that Ontario Power Generation (OPG) PNGS B complies with the Environment Canada amendments to the Federal Halocarbon Regulations 2003, and the potential changes on Provincial Legislation O/Reg 189. This regulation prohibits the re-charge of CFC refrigerant in any chiller unit by January 2015. Although OPG has made a commitment to the Ministry of Environment (MOE) to replace all their CFC chillers by 2012 (N-CORR-00521-00008), management has chosen a more aggressive deadline for completion by 2010.

Furthermore, should a chiller fail requiring the replacement or modification of an internal sealing device, internal mechanical part, or an evaporator or condenser tube, between January 1st, 2005 and December 31, 2009 that unit can be returned to service for up to one year, at which time it must be replaced with a chiller using an approved or non-ozone depleting refrigerant. Should a chiller fail catastrophically after January 1st, 2010, that unit must be replaced or charged with an approved refrigerant (non-ozone depleting) immediately prior to being brought back into service. The existing chillers are not suited to have their refrigerants changed to a non-CFC refrigerant. The only option is to replace the units.

The following activities were completed with Phase I funds:

- Preliminary engineering for the ABX, SW and RAB chillers is complete •
- Detailed Engineering is complete for ABX and RAB chillers ٠
- All RAB chillers have been delivered and installed on the newly erected chiller platform but not tied-in to the existing system
- The ABX chiller has been factory tested, accepted, and delivered to OPG
- SW chillers have also been factory tested and accepted and will be delivered in October of this year
- All pumps have been delivered to site
- Detailed engineering for the SW chillers is in progress.

Premature Chiller Failure Contingency Status:

- With the RAB Chillers installed with only the mechanical and electrical tie-ins outstanding, if an RAB Chiller failed and required replacement, the tie-ins could be completed within the 1 year grace period.
- Should the ABX Chiller fail, a TMOD would be prepared to tie in to the Admin Building chilled water system within the one year grace period. This TMOD would mimic a similar one that was successfully used in the past.
- 90% of the SW Chiller design is complete and if a SW Chiller suffered a catastrophic failure, with a change ٠ in installation schedule, a SW Chiller could be replaced within the one year grace period.

Extra expenditures that were incurred during Phase I of the project are as follows:

- Increased labor costs and firm quotes from potential vendors for installation were higher than originally ٠ estimated.
- Chiller vendor delays in submitting equipment documentation for approval resulting in less efficient use of ٠ design engineering hours,
- Poor quality of vendor documentation resulting in extensive document reviews and comments with multiple ٠ iterations back and forth prior to obtaining final approval.
- Electrical redesign to accommodate power supply constraints. Design changed from a 600V supply to using a 4kV supply which necessitated the specification and use of step down transformers and current transformers.



Discovery work for the RAB chiller design due to the realization that a structural column (M139) was discovered to have insufficient capacity to support the weight of the new air-cooled RAB chillers. This column had to be reinforced prior to both completion of the platform and installation of the chillers





**OPG** Confidential Page:

5 of 24

# BUSINESS CASE SUMMARY

- The Phase II funds will ensure that the following activities of the project are completed:
  - Installation of the mechanical and the electrical components of the RAB chillers; Commissioning and Available for Service Declaration.
  - Full installation of the ABX and SW chillers, commissioning and Available for Service Declaration, and
  - Close-out activities for the project.

GENERATION

The project schedule has been revised to reflect the current installation strategy and the previously encountered delays. The installation schedule is affected by both operational and weather constraints. For example, all outdoor work cannot be performed during the winter months. The adopted schedule for the recommended alternative takes these constraints into account while minimizing the overall project duration.

The release strategies considered were:

- (a) Prepare a superseding Phase I BCS documenting the change in cost of the original Phase I scope of work and request a release for \$16.9M. Then follow with a Phase II BCS requesting a release of \$22.9M to complete the project.
- (b) Superseding Phase 1A BCS requesting a release of \$19.8M to complete the revised scope of work included in Phase 1A (Includes the installation of the ABX Chiller, two SW Chillers, and two RAB Chillers). Then follow with a Phase II BCS requesting a release of \$22.4M to complete the project.
- (c) Proceed directly with a Phase II release of \$22.4M based on the new installation strategy, while documenting both the progress and issues associated with the original Phase I release.

Option (a) was not selected as it is a more costly option. Option (c) is preferable to option (b) as the relative crement in the amount released is low, there is adequate information to reasonably estimate the full project cost, ind the project schedule now requires a full release in October 2006 to commit to the installation contract.





Page: 6 of 24

**BUSINESS CASE SUMMARY** 

# 3/ ALTERNATIVES AND ECONOMIC ANALYSIS

		Alt 1 (Recu	ommended)	Att 2	An 3	Alt 4	AP 5	AR 5
\$ 000's	Do Nothing	Full Cost	Incremental Cost	Delay (2yrs)	Ph. I Install Schedule	Do Leas	Do More	AHLD
Project Cost	N/A	(11,126)	(5,926)	(11,759)	NA	N/A		the state of the s
NPV (after tax)	(14,499)	(15.011)	(10,758)	(13.803)	- · · · · · · · · · · · ·		N/A	<u>N:A</u>
Impact on Economic Value	N/A	N/A	·· · · · · · · · · · · · · · · · · · ·		N/A	N/A	N/A	N/A
IRR%	4		(7,934)]	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Discounted Payback (Yrs)	N/A	N/A	N/A	N/A	N/A T	N/A		1
Notes The flauses also	· · · · · ·	• • • • • • • • • • • • • • • • • • • •	and the second sec		10A ,	N/A	N/A	N/A

Note: The figures shown above are for the RAB Chiller portion of the project only. As outlined below, the Service Wing and ABX Chillers must be replaced to meet the 2015 environmental regulation implementation date since they are common to Pickering B and A and will therefore be required to operate after the 2014 Pick B end of life date. The justification for proceeding with the RAB Chiller replacement is based on a financial analysis since it only services Pickering B and could feasibly be delayed until after a decision is made for Pick B plant life extension. The financial justification is made by comparison of the incremental NPV's for the different alternatives strictly for the RAB portion of the project.

# Stop the Project - Not Recommended

onsequences of doing nothing are increased chances of encountering chiller failures as they are approximately years beyond their life expectancy and experiencing condenser tube erosion. Details of the probabilities of failures, consequences of failures, and current status of the various chillers are outlined in attachment "E". A summary of the consequences of failure are described below:

Failure of the ABX Chiller: Results in a loss of cooling to the Administration building where Pick A / B support staff, CNSC and TSSA staff are located. The 2014 end of life for Pickering B does not apply in this situation as Pickering A staff are also located in the Admin. Building and the chiller would have to be replaced by 2015.


<u>Failure of two Service Wing Chillers</u>: Results in a loss of cooling to the chemistry lab which provides critical services to both Pick A and B which can affect station operability and guarantees of shutdown during an outage. Again, the 2014 end of life date for Pick B does not apply as this affects Pick A as well and must be replaced by 2015 as required by the environmental regulation.

<u>Failure of two RAB Chillers</u>: Results in a loss of cooling to the Main Control Room and Control Equipment Room where a temperature controlled environment must be maintained at all times. A loss of cooling to these areas could potentially result in a four unit shutdown. These chillers do not affect Pick A and therefore the 2014 end of life date does apply. The probability of a dual unit failure of the RAB Chillers is estimated at 50% between now and 2015. However, based on the NPV calculated for the RAB portion of the project, with a low probability of revenue losses due to a four unit shutdown, it is a more costly option than the recommended option. The NPV for this alternative is NPV = (14,449).

# Alternative 1 - Continue project per Phase II schedule - Recommended

The ABX and Service Wing chillers should be continued as per the revised Phase II schedule (see attachment ") since they service Pick A and will need to be replaced by 2015 as mandated by the environmental ulations. The Pick B end of life 2014 does not apply to these chillers.

For the RAB Chillers, the financial analysis show that this is the most cost effective approach given the risk of a four unit shutdown and the subsequent revenue losses. The NPV = (10,758) for this alternative.



Successful completion of this project will fulfill environmental regulations and improve the current red/yellow status of each associated HVAC system health indicator.

# Alternative 2 - Delay Project - Not Recommended

The schedule can be delayed by as much as two years, and still meet the MOE commitment to replace all CFC chillers by 2012. This, however, would pose a significant threat to the station as the one year 'grace' period to replace failed CFC chillers, will be eliminated after January 1, 2010.

This option is not recommended for the ABX or Service Wing Chillers because the cost savings due to time value of money is relatively insignificant (approx. \$100K) and the project team is already mobilized to continue per the recommended schedule, and resources have already been committed based on this schedule.

The option of delaying by two years is not recommended for the RAB Chillers because the financial analysis shows this to be a more costly option than the recommended alternative. This is primarily due to the increased probability of a two unit RAB chiller failure potentially causing a four unit shutdown resulting in revenue losses, as well as additional de-mobilization / re-mobilization costs. The NPV = (13,803) for this alternative. Alternative 3 - Proceed with installation as per Phase I release schedule - Not Recommended

This alternative is no longer viable because this schedule change only affected the installation of the ABX Chiller and has no impact on the costs of the RAB portion of the project. However, had this schedule been used, additional overall project costs of approximately \$800 K would have been incurred.

# Iternative 4 - Do Less - Not Recommended

All seven CFC chillers are impacted by the environmental regulations; doing less will lead to non-compliance and un-reliable performance of the system. The technical requirements of the recommended option (Alternate 1) are acceptable. Additionally, the costs of the recommended option have been minimized through on-going review and challenge.

A comparison of this project to the Darlington CFC Chiller Replacement project shows that the two projects are very different, where the Darlington installation is a plug and play approach; Pickering's installation involves the relocation of the RAB and ABX chillers to the outside and the redesign of the Service Wing chillers. In addition, the QA requirements for the new chillers at Pickering were more stringent at the time of purchasing which resulted in more expensive design and equipment costs. Although using air cooled chiller designs for RAB and ABX chillers, increased costs, they benefited the station by reducing the already limited service water supply. The need to evacuate control room staff in the even of a refrigerant leak would also be eliminated by the relocation of the RAB chillers to the roof.

Increased costs due to replacement of the glycol pumps, design of a chiller platform, increased piping and piping design changes, the need for new power supplies, were incurred as a result of relocating the RAB Chillers to the outside. Based on current estimates, the 'per ton' cost of the Darlington CFC Chiller Replacement project comes to approximately \$10.4K/ton compared to this project which comes to approximately \$20.8K/ton.

# Alternative 5 - Do More - Not Recommended

The current scope of the project has effectively addressed the potential modification requirements. Adding scope at this stage would increase costs without making a meaningful contribution to the overall project objectives.





Page: 8 of 24

**BUSINESS CASE SUMMARY** 

# 4/ THE PROPOSAL

We recommend the completion of this project by the end of 2009. The key project milestones are shown in the table below:

Completion Date		Date	
Day	Mth	Yr	Description
22	Dec	2006	Complete DCP package for Service Wing chillers
21	Nov	2006	Start installation for all RAB chillers
21	Feb	2007	AFS of RAB chilled-glycol pumps and Relief Valve RV102
23	Feb	2007	Start tie-in installation for 1 st RAB chiller (058-73180-RFU4)
01	Nov	2007	Start tie-in installation for 2 rd RAB chiller (058-73180-RFU5)
01	Nov	2008	Start tie-in installation for 3 rd RAB chiller (058-73180-RFU6
01	Aug	2007	Start Installation and tie-in for ABX chiller
03	Aug	2007	Start Installation and tie-in for 1 st SW chiller (018-73430-RFU2521)
01	Feb	2008	Start installation and tie-in for 2 rd SW chiller (018-73430-RF02521)
02	July	2008	Start installation and tie-in for 3 rd SW chiller (018-73430-RFU2522)
02	July	2007	AFS 1 st RAB chiller
03	July	2008	AFS 2 rd RAB chiller
02	July	2009	AFS 3 rd RAB chiller
03	July	2008	AFS ABX chiller
14	Dec	2007	AFS 1 st SW chiller
19	June	2008	AFS 2 ^M SW chiller
18	Nov	2008	AFS 3 rd SW chiller
24	Dec	2009	Project Completion

# 5/ QUALITATIVE FACTORS

The following are the non-quantifiable benefits of the project. The major project measurable deliverables are listed in Section 4.

- Improve reliability of the chiller units in each area; hence reduce emergent-based maintenance costs.
- Improve safety by eliminating hazards due to refrigerant leaks in an enclosed space for the Reactor Auxiliary
   Bay and Administration Building (Air-cooled units are installed outdoors)
- Alleviate strain on Low Pressure Service Water (Safety-Related Support System) by replacing the Reactor
   Auxiliary Bay and Administration Building chillers with outdoor air-cooled units.





OPG Confidential Page: Page:

9 of 24

BUSINESS CASE SUMMARY

# 6/ RISKS

Flat After Mitigation		<u>-</u> ! !	·····	j ⁄   	
	 Low	Low			Low
	Include Contingency for the installation of the Service Wing Chillers. Apply only contingency on the RAB and ABX chillers. See Attachment "A" for Service Wing contingency. Independent 3rd party	BCS was conducted by Helyar. Vendor quotes are now available for all aspects of the project except for the SW chiller installation.	bmplet has t into s used		COMs Meeting and Walkdown were performed to minimize discovery work. Reviewed equipment history and are continuing to perform preventative maintenance on any support systems during modification. Initial documentation check was conducted. Pre-identifying documentation errors. Field Engineering involved early in the design phase. Multiple field walkdowns were done to determine scope of legacy issues. Any increased
History Betors Migators	ЧġіН	Medium			
Description of Consequence	Complete installation costs are not available in the cost esitmate. Therefore, project may over spend estimated budget	Cost push on the \$22.4M total			Increase in costs and impact on schedule
Description of Risk	BCS phase II preparation.	Further cost estimation on the total project			Discovery and Legacy Work (chiller system is 20 years old - Auxiliary equipment failure)


ENERATION	

_	
OPG Confidential	
ent	
ξġ.	
uo	
C .	
g	
õ	

10 of 24

Page:

BUSINESS CASE SUMMARY






i i i i i i i i i i i i i i i i i i i	Ĭ
استسایت س	
A E	
H/	Ĩ
(92	
	H
5	
	1

11 of 24

Page:





	OPG Confidential	ntial	Page: 12 of 24		
GENERAI	UTION BUSINESS	IESS CASE SUMMARY	IARY		
			implementation date.		
Environmental					
Unforseen chemical handling	Higher Cost. Annoximately \$50K up th	the Madine	and the second second star of the second	and the second se	ter and a first and and and and a first of the second second second second second second second second second s
procedures during this work	- <u>(</u> )		Ensure rerrigerant and materials (lubrication) brought on site are concurred by Environmental group. Extra costs are	materials (lubrication) are concurred by Extra costs are	Low
R-11 (CFC) refrigerant	Higher Cost. Approxmately \$50K worth	th Medium	Farly involvement with Discourt and	ngency.	
usposal more effort intensive than anticipated	in additional chemical handling charges		Meetings with this vendor show that there is no cost to remove R-11 refrigerant. Potential extra costs are included in specific contingency	risposal companies. In show that there is R-11 refrigerant. Included in specific	No No
Workplace Juliny of Service	مى مەرەپ مەرەپ بىلەر مەرەپ بەرەپ بەرەپ بىلەرلىك بىلىرى مەرەپ بىلىرى بىلەر بىلەر بىلىرى بىلىرىك بىلەر بىلىرىك بى 14. ئىلىرىكى بىلەرلىك بىلەر بىلەر بىلەرلىك بىلىك بىلىرى بىلىرى بىلىرى بىلىرىك بىلىرىكى بىلىرىكى بىلىكى بىلىك بىل				
MRPH event	regarive impact to Schedule due to delay for investigation.	Medium	Work plans will be reviewed by conventional safety prior to use. JSA to be prepared for crane/rigging and high hazard work. Lessons learned applied to prevent further incidence. Comprehension, work of an Operv	will be reviewed by conventional to use. JSA to be prepared for ng and high hazard work. arned applied to prevent further Comprehension work form Occord	Low
			• • •		- ( ) ( ) ( ) ( ) ( ) ( ) ( ) ( ) ( ) (
New childre concretion	المرابع br>المرابع المرابع br>ولم المرابع الم				
below expectation	More maintenance and operational related activites	Medium		ogy of the new Chillers is standard widely used in industry. They are tured by Trane, one of the world's in HVAC equipment. are factory acceptance tested and d by OPG Source Inspector prior to	Low
become obsolete through the life of the project.	Unable to purchase spare-parts; no service support from the vendor	Medium	Technology of chillers compared to the life Purchase spare-parts	changes slowly of the project. as part of the	Low
New regulatory requirements which change the acceptable eplacement refrigerants	Cost and schedule delay to re-engineer the chillers for a new refrigerant	Medium	equipment purchase orders. The selected refrigerants are not carceptable for use post 2015 but they also not on the list of refrigerants to phased out by 2030. Therefore there iminimum of a 24 year expectancy.	ders. rants are not only st 2015 but they are of refrigerants to be Therefore there is a xpectancy.	Low



1

OPG Confidential

tial Page: 13 of 24



BUSINESS CASE SUMMARY



# 7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targete	d Final AFS Jate:		PIR Approv ate:	al PIR Responsibility (Sponsor Title)
Simplified	Jul	2009	Jul	2010	Director of Station Engineering (Pickering
Comments:	· · · · · ·		·····	······································	A and B)

	Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it? (person / group)
1.	Design meets performance reliability criteria	Chillers meet system requirements using CFC refrigerant.	Replacement chillers to operate within design parameters using non-CFC refrigerant	Commissioning reports will document performance parameters	Projects
2.	Design meets performance reliability criteria	Not Applicable	AFS procedure to be performed and accepted	Final acceptance of AFS during final meeting.	Stakeholders
3. )	Removal of ozone depleting substance	Not Applicable	All ozone depleting substances pertaining to this project to be removed	Projects to ensure that all ozone depleting substances are removed from site.	Site Management Board
4.	Improve health status of chillers	System health reports shows RAB and SW chillers are yellow. No status is available for ABX	System health of chillers will be improved to white/green.	Compare system health reports from project initiation to project completion	Performance Engineering
5.		1		***** ********************************	

# Appendix "A"

Glossary (acronyms, codes, technical terms)

- RAB Reactor Auxiliary Bay
- ABX Administration Building Extension
- SW Service Wing

Free Cooling - HVAC systems rely on outside air for cooling (outside air temperature is below 12C); air is directly drawn into the building. Chillers and systems are turned off.

Cooling season - Time when chillers are operating.

Heat Load - "Heat" in the building.

ONTARIO	<b>POWER</b> GENERATION
---------	----------------------------

# Appendix "C"

# **Financial Model – Assumptions**

# **Project Cost Assumptions:**

Project Resources (e.g. Projects Design, Drafting office, Maintenance, etc.) provided estimates on monetary resources required to complete their work activities for the duration of 2006 to the end of project. Overtime is anticipated for Projects, Field Engineering and Maintenance resources. Allowances have been incorporated into the project cost.

Installation costs (including materials and installation contractor) for the RAB and ABX chillers are of release quality (+10 to -15%). Installation costs for Service Wing chillers are budgetary (+30 to -15%) since detailed engineering is not complete at the time of BCS issuance.

Project cost estimates have been verified by an independent third party review. **Financial Assumptions:** 

An interest rate of 6% per annum, labor escalation rate of 3% per annum and an NPV discount rate of 7% are used per corporate standards.

The following assumptions were used to calculate revenue losses due to a forced outage:

- Rates per MW hour: 2007 2008 2009 2010 2011 2012 2013 2014 2015
- \$55.3 \$56.2 \$54.1 \$51.8 \$49.6 \$48.4 \$49.3 \$51.7 \$54.2
  Probability of a two unit RAB Chiller failure between now and 2015 is estimated to be 50%. Spread uniformly over 9 years is approximately 5.6% per year
- Output from each unit is 516 MW
- Failure of two RAB chillers would result in a loss of cooling in the Main Control Room / Control Equipment Room servicing all four Pickering B units and would cause a four unit shutdown
- Optimistic duration for an overhaul or replacement is 4 weeks. Therefore the assumed duration of the forced outage is 28 days.

# Project / Station End of Life Assumptions:

All Obsolete chillers do not have salvage value; the RAB and ABX chillers are isolated and abandoned in place during construction. Old SW chillers are replaced with new chillers. There is no salvage value assumed for the SW chillers.

Pickering B end of life is 2014. The SW and ABX Chillers also service Pickering A. The RAB Chillers service Pickering B only.

# **Energy Price / Production Assumptions**

N/A in NPV calculations

# **Operating Cost Assumptions**

N/A in NPV calculations Other Assumptions:

No other assumptions

ONTARIO GENERATION Page: 18 of 24

BUSINESS CASE SUMMARY

# CFC Chiller Replacement Project 13 - 40543

# Full Release (Phase 2) Business Case Summary P-BCS-73000-00001-R002

Attachment "A"

# **Project Cost Summary**

\$000's	LTD Prior Yr	This Release	This Release	This Release	This Release				
Capital	2005	2006	2007	2008	2009			Later	Total
Project Management (OPG)	233	213	295	139	108	Paras a se		<b>1</b> ,, ,,, , ,, ,, ,, ,, ,, ,,	988
Engineering & Drafting (OPG)	1,477	989	860	811	210				4,347
Material								1	
Installation - PWU, BTU									
Contract - Design									-
Contract - Installation									-
Contract - Other									
Installation - Support		- • •							
Interest (Capital Project Only)									1
Project Costs (excl contingency)			And the second se					0.513	
General Contingency	-	_							
Specific Contingency									
Project Costs (inci contingency)	3,896	3,636	8,843	5,086	644	1036 - Q.			22,105
2006-2010 Business Plan	3.896	2,771	1,190	590	291				8,738
Variance to Business Plan		601	6,271	3,498	#REF!				10,24
Committed Cost									-
Inventory Write Off Required	5					1	£		
Spare Parts / Inventory	į								
Total Release (exc) contingency)									
Total Release (Incl contingency)	3,896	3,667	8,843	5,127	844				22,377
Ongoing OM&A (non-project)	NA								
Removal Costs (Incl in above)	NA							3	

		Basis of Estim	ate		es tet f
Design Complete	90 to 100%	Contracts in place	No	Competitive Bid	Yes
3rd Party Estimate	Yes	OPEX used	Yes	Lessons Learned	Yes
Reviewed by Sponsor	Yes	Sponsor Cost Estimate	Yes	Phase 1 Actual Used	Yes
Similar Projects	Yes	Contracts in Place	No	Competitive Bid	Yes

 Variance to Business Plan

 The estimated variance to the 2006 – 2010 Business Plan will be addressed through the portfolio management process.

 A PCRAF was approved in Jul 2006.

 Note: General contingency for the SW chillers (approx. \$1.1M) is included in the value for overall project specific

21

contingency. Reviewed By:

Approved By; 13 Oct, 2006 Name

Name Project Manager

Date:

Eng & Mods Manager (Strat IV)

Date:

2

ONTA	RIO			Ŵ	
		GF	NF	RAT	rion

### CFC Chiller Replacement Project 13 - 40543

# Full Release (Phase 2) Business Case Summary P-BCS-73000-00001-R002

Attachment "B"		Project V	ariance A	<u>nalysis</u>	
		Phase	Release		
Capital	LTD Aug 2006	Last BCS Dec 2009	This BCS Dec 2009	Variance	Commente
Project Management (OPG)	317	598	988	390	See Note 1 [Estimate]
Engineering & Drafting (OPG)	2232	2330	4347	2017	See Note 2 [Delay, Discovery, Re-Eng]
Material					
Installation - PWU, BTU					
Contract - Design					
Contract - Installation					
Contract - Other					
Installation support					
Interest (Capital Project Only)					
Project Costs (excl contingency)				A STATE OF A STATE	
General Contingency					
Specific Contingency					
roject Costs ( incl contingency)	5686	9401	22105	12704	
Committed Cost					
Inventory Write Off Required	· · · · · · · · · · · · · · · · · · ·				
Spare Parts / Inventory					
Total Release (incl contingency)	5686	9401	22377	12976	a second s
Total Release (excl contingency)	-				A the second
Ongoing OM&A (non-project)				0.13	
Removal Costs (incl in above)				1	

#### Comments:

Note 1 - Variance is due to adjustments from conceptual estimates to quality-release/budgetary estimates.

Note 2 - Increase in Engineering costs are due to: delay in design deliverables - Design Engineering (\$640K), discovery work - Design Engineering (\$94K), additional project engineering (\$350K total; \$230K worth in delays and \$120K worth in discovery work/scope creep), and adjustments from conceptual estimates to quality-release/budgetary estimates (\$933K).

Note 3 - increase in Materials costs are due to re-engineering, discovery work (\$286K) and adjustments from conceptual estimates to qualityrelease/budgetary estimates (\$748K).

Note 4 - Variance is due to adjustments from conceptual estimates to quality-release/budgetary estimates.

Note 5 - Variance is due to adjustments from conceptual estimates to quality-release/budgetary estimates. This variance includes impact of discovery work to reinforce column M139 and the change from the conceptual RAB platform design.

Note 6 - Original estimate was based on conceptual design and direct-hire labor rates of 2004; this new estimate is based on 100% detailed engineering for the RAB and ABX chillers, and 60% engineering complete for the Service Wing chillers and higher labour rates. In addition, installation hours have increased for this estimate. The variance due to increased labour-rates is \$880K. The variance due to increased labor hours is \$3261K

Note 7 - Variance is due to adjustments from conceptual estimates to quality-release/budgetary estimates.

Note 8 - Increase to Installation Support costs are due to emergence of a new project resource, Contract Management Office (\$332K). Their cost is included in this release. In addition, Field Engineering Costs have also increased for this release (\$757K).

Note 9 - 15% contrigericy is applied to the Reactor Auxiliary Bay and Administration Building portions of the project. 30% contingency is applied to the Service Wing portion of the project. Itemized contingences (as specified in Section 6) are included in the Specific Contingency.



Page: 20 of 24

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

# Summary of major issues

Underestimation - Conceptual Estimate to Quality/Budgetary estimate, including interest Delay in Schedule due to delay in Design deliverables Discovery Work, Re-engineering Labour rates based on 2004 for phase I vs. new rates of 2006 for Phase II Inventory write off and spare parts / inventory costs General Contingency Specific Contingency **Total** 

ð




<b>ONTARIC</b>	POWER
	GENERATION

OPG Confidential	Page: 21 of 24	
The second se		

Attachment "C"

# Chiller Replacement Schedule Business Case Summary Phase II Release

#### Friday, September 15, 2006



Page 1



Page: 22 of 24

# ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

# Attachment "D"

REIS Declaration Milestones				
AFS Milestone	Declare REIS date	% complete		
RAB Structural Steel Platform	30 July 2006	10%		
RV102, P1 & P2 Partial AFS	16 March 2007	3%		
RAB RFU4 – AFS meeting	01 August 2007	13%		
RAB RFU5 – AFS meeting	01 August 2008	13%		
RAB RFU6 – AFS meeting	01 August 2009	13%		
ABX RFU101 – AFS meeting	01 August 2008	15%		
Service Wing RFU2521 – AFS meeting	18 January 2008	11%		
Service Wing RFU2522 - AFS meeting	13 July 2008	11%		
Service Wing RFU2520 – AFS meeting	19 December 2008	11%		
	Total	100%		



BUSINESS CASE SUMMARY

Attachment "E"

	Chillers	Status of Existing Chillers	Status of New Chillers	Probability of failure between now and 2010 (with 1 yr grace period for	Probability of failure between 2010 and 2015 (no grace period)	Consequence of Failure	Cost Status
RAB Chillers	3 X 50% chillers (1.e. two available during cooling season. 4-	<ul> <li>Alt (3) are operational</li> <li>All are approx. 5 yrs.</li> </ul>	Bought and placed on platform, mechanical and electrical tie	1 Unit Failure: High, based on OPEX from SW Chillers and Pick A Chillers (PA Chillers were re-tubed over 10 yrs ago)	1 Unit Failure: Very High, based on OPEX and continued aging	1 Unit Failure: Loss of redundancy	- Approx. cost to complete is \$5.9M (excl. contingency)
	6 wks during peak of summer)		outstanding	2 Unit Failure: Medium-Low, based on OPEX and the potential for a common mode failure	2 Unit Failure: Medium-High, based on OPEX and continued aging	2 Unit Failure: MCR / CER Temperature rise (> approx. 24- 26 deg. C) resulting in a multiple unit forced shutdown (approx. average time at risk for repair is 4 weeks prior to 2010 and tonors	
ABX Chiller	1 X 100% chiller	- Operational	Bought and	(I.e. tube erosion) High, based on OPEX	Verv High based	Proceeding to the second of th	
	}	5 yrs beyond fife expectancy	on site, but not yet installed	and common mode failure (i.e. tube erosion)	on OPEX and continued aging	Loss of cooling to the new Admin Building resulting in discomfort to CNSC, and Pick A / B station support staff, and potential human performance issues There is a TMOD that can be used for to provide	Approx. cost to complete is \$2.3M (excl. contingency)
·						temporary partial cooling relief.	Approx, sunk cost is \$397 K
**************************************							NPV reduction with a 5 yr delay is approx. \$44K, the cost of implementing a TMOD
							In the event of a failure

ONTA. OF UNEN GENERATION



# Attachment "E" continued

Cost Status	Approx. cost to complete \$4.7M (excl. contingency) Approx. sunk cost is \$389 K NPV reduction with a 5 yr delay is approx. \$88K
Consequence of Failure	<ol> <li>Unit Failure:         <ul> <li>Loss of redundancy</li> <li>Loss of redundancy</li> <li>2 Unit Failure:                 <ul> <li>Loss of redundancy</li> <li>2 Unit Failure:</li></ul></li></ul></li></ol>
Probability of failure between 2015 (no grace	1 Unit Failure: 100% (1 unit has already failed) 2 Unit Failure: Very High, Based on OPSEd on Continued aging, tube erosion, and the fact that one has already failed
Probability of failure between now and 2010 (with 1 yr grace period for	1 Unit Failure: 100% (1 unit has already failed) 2 Unit Failure: High, based on OPEX, significant tube erosion, and the fact that one has already failed
Status of New Chillers	Bought and on site, but not yet installed
Chillers	- 1 failed beyond repair, due to condenser tube erosion - Remaining 2 units have 60% tube erosion - All are approx. 5 yrs beyond life expectancy
r of Chillers	chilters chilters available during cooling season, 4-6 wks during peak of summer)
	Chillers

ONTARIOPOWER	OPG Confidential	Page: 2 of 28
GENERATION	OPG Nuclea BUSINESS CASE SI	

# Auxiliary Power System 13 - 49104

# Full Release Business Case Summary P-BCS-50000-00004-R000

Routing	Location	Action	Signature	Data
T. Mitchell Sr Sile VP - Pickering B 701-3501	P41 E3	Submit BCS	Mutchace	Date
J. Coleby Sr Site VP - Pickering A 701-3260	P05 A2	Submit BCS	1 migun	14 NOV 05 14 Nov 2=8
P. Charlebois Chief Nuclear Officer 702-5294	P82 6A	Review BCS	Supple	28 Not + 5
D. Power Director investment & Business Planning 400-7172	H07 D06	Approve BCS		
J. Hankinson President and CEO 119 A2	H19 A2	Approve BCS		



R	P. R. Charlebois	
	NOV 2 2 2005	
Refer t	0:	

BCS Signations Sheet + Board approval Meno. JSB

R. Ball Senior Financial Analyst 702-4084	P82-3B6	Return For Distribution	1	T

<b>ITARIOPOWER</b>	OPG Confidential Pages 1 of 28
GENERATION	OPG Nuclear BUSINESS CASE SUMMARY

## Auxiliary Power System 13 - 49104

# Full Release Business Case Summary P-BCS-50000-00004-R000

Routing	Location	Action	Signature	Date
K.Shore Section Manager, APS Project (Acting) 701-6800	P24 AN	Prepare BCS	the Pro	2-No1-05
G.Kotwa Section Manager, PMO 701-3755	P24 B9	Review BCS	Kerylishwa	Nov 4/05
S. Guthrie Manager, APS Project (Acting) 701-5613	P24 AN	Review BCS Sign Roject Cost S	Shift	NOV 4/05
R. Ball Senior Financial Advisor 702-4084	P82 3 <b>B8</b>	Review BCS		
G. Brown Controller Engineering and Mods 702-5059	P82 3A6	Review BCS	Alla	4mov 105
M.Elliott Station Engineering, PB	P41 E3	Review BCS	- 22	05 11 05
A. Amone Virector, Projects and Modifications 01-6063	P72	Roview BCS Sign Project Cost Sur	Whe	11 2005

ATARIO <b>POWER</b>	OPG Confidential	Page: 3 of 28
GENERATION	OPG Nuclear BUSINESS CASE CUM	

### Auxillary Power System 13 - 49104

## Full Release Business Case Summary P-BCS-50000-00004-R000

#### 1/ RECOMMENDATION:

We recommend the release of an additional \$50.2M (total \$116.7M, including contingency) to complete all activities for the design, build and commissioning of an Auxiliary Power System (APS) Project at Pickering NGS, to be in-service by the 3rd quarter of 2007.

On August 14, 2003 Pickering NGS suffered a site wide loss of Class IV power as a consequence of a Loss of Bulk Electrical System (LOBES) event. As a result, Pickering NGS was unable to operate a High Pressure Emergency Coolant Injection pump for approximately 5 hours, until power was restored from the grid. In addition, all of the operating units tripped and subsequently could not be cooled down without significant economic penalty

The business objective of this project is to restore PNGS within it's licensing basis by enhancing standby power to:

- Be available to start an HPECI pump within 30 minutes of a LOBES event with no surviving units, and,
- Cooldown all 6 reactors to <90C within 24 hours of a LOBES event with no surviving units.

The above are the minimal regulatory requirements of the APS. The business objective will be met by providing a cost effective and reliable combustion turbine power generation facility that will provide back-up power to specific Pickering NGS loads following a LOBES event, should no units survive the transient.

Partial Release for \$66.5M has been approved to commit to purchase of the combustion turbine units, and progress engineering on schedule-critical items so as to maintain viability of the September 2007 in-service date.

As part of this partial release the station tie-in point has been reviewed and a cost/schedule savings can be ed by changing the station tie-in from the middle of the Station Electrical System (SES) bus to the end of the bus at U8. Changing the station tie-in point also changes the risks associated with the project. For the most part many of the IPB (inside plant boundary) risks are reduced or eliminated. Obtaining CNCS concurrence for

sequencing of load profile may be required (see Section 6/ Risks). Attachment B outlines the savings realized by

This project is part of the 2005 - 2009 business plan for \$200M. The 2006 Business Plan will be updated to reflect the cost estimates included in this BCS. The Project Execution Plan (PEP) was aport

S Millions Capital	SM Capital	Including Contingency	Excluding	the second s	Excluding
Released to Dele:	Partia	64.5			Contingenc
Requested Now:	Ful	50.2	_	Nov-05 Spent Life to Date.	
Cumulative Ralease:	Total to Date	116.7		2005-2009 Appril Business Plan (Tot Pro	x0: 1
Total Project Estimate:	+30% 10 -15%	·		2005-2009 Business Plan Variance:	
urrent Year Estimate:		118.7		2005 Budget (Current Year)	
	2005	16,6		2005 Budget Variance (Current Yr)	<b>S</b>
ype of investment: IPV:	Regulatory	NA	NA	Cumulative Release Remaining:	
R:			NA	Contingency on Remaining Release:	1
		CARGO AND THE OWNER	N/A	Contingency on Remaining Release:	1

Submitted By:

mtdill 02N012005

Tom Mitchell Senior Site VP, Pickering B

Finance Approval:

91 nvestment & Business Planning

Date:

Dete:

Jim Hankinson President and CEO

Senior Site VP. Pickering A

Submitted

John Coleby

Date:

Date:

Nu+ 22,248

Une Approval (Per OAR Element 1.1 Project in Budget):

### EXECUTIVE SUMMARY

### 1) BACKGROUND

On August 14th, 2003, Pickering NGS experienced a LOBES (Loss Of Bulk Electrical System) event for approximately 5 hours, thus losing grid-supplied power to the station. The three units operating at the time at Pickering NGS-B all shut down as a result of the event. This led to a total loss of Class IV power across the site (Pickering A and B).

Without Class IV power, a number of important systems were unavailable for use. As noted in the previous submissions (June 1, 2004 and September 22, 2005) to the OPG Board of Directors, the High Pressure Emergency Coolant Injection (HPECI) system pumps could not be run and the Pickering B reactor heat transport systems could not be cooled down without substantial economic penalty until power from the grid was restored.

Prior to the LOBES event, two key assumptions in the design basis for the station were;

- there is a 50% probability that an operating unit will keep operating following a load rejection and thus be able to supply station Class IV power, and
- the maximum duration of a LOBES event will be approximately one hour.

During the August 14th 2003 event, these design basis assumptions were not met - which placed continued operation of the station into question.



As noted in the previous submissions to the OPG Board of Directors, extensive communication took place with the CNSC following the LOBES event. The CNSC have accepted the principle of mitigation through the installation of an alternate power supply – with the previously-installed Remote Emergency Power Generator (REPG) as an interim solution to allow continued station operation. Following negotiation with the CNSC, the following are considered to be regulatory requirements for the standby power system at Pickering NGS:

- having an HPECI pump available to start within 30 minutes of a LOBES event.
- Cooling down the reactor heat transport systems of all Pickering NGS units within 24 hours of a LOBES event. This is a derived requirement of adequacy to address the fact that the original design basis assumption of grid power restoration time was not met.
- Starting unavailability/mission time unreliability of 10E-2 (for APS)
- Cost-effective protection from common mode events affecting the electrical grid

Over and above this, it is a CNSC expectation that current OPG efforts to ensure unit survivability will be pursued in parallel – to fully return HPECI to accepted licensing basis.

The proposed Pickering Auxiliary Power System (APS) is the recommended alternative to allow these regulatory requirements to be met, and, at minimal incremental cost, provide additional power to support operationally critical loads.





### **PROJECT DESCRIPTION**

The business objective of the project is to permit continued station operation by restoring Pickering NGS to its accepted licensing design basis. The recommended alternative is providing a source of standby power that will satisfy the regulatory requirements identified in section 1, during an event where grid power is unavailable and all units are consequently or coincidentally shutdown.

The recommended solution consists of a twin set of combustion turbines connected to the station's electrical distribution system, which will meet regulatory loads and provide margin to accommodate other needs critical to plant operation during shutdown. Critical plant needs during shutdown, supplied by Class IV power and to now be powered by APS, include: Main Control Room / Control Equipment Room air-conditioning systems (to minimize overheating risk to the unit Digital Control Computers); continued operation of the Chemistry Laboratory (to maintain system chemical control, particularly with respect to impact on reactor safety); and, additional equipment as backup to Class III powered safety systems for defence in depth.

The duplicate combustion turbine units provide the necessary system reliability to ensure that the overall power supply reliability to the HPECI system and reactor cooldown systems will be met. The system will be tied into the electrical grid through the Pickering switchyard to accommodate full power testing and to provide power to the APS system while the combustion turbines are not operating.



As an interim compensatory measure, OPG installed a backup power supply known as the Remote Emergency Power Generator (REPG) (reference previous June 29, 2004 submission to the OPG Board of Directors). This facility was declared in service on September 30, 2004. The REPG will provide power to start an HPECI pump, though not within the specified 30 minute limit. As a result of the tie-in point to the Pickering station, the REPG cannot complete a cool down of the reactors by forced primary heat transport circulation. In addition, being a single source of power, the REPG will not meet the reliability requirements, nor provide independence from common mode failure events such as ice storms since the power is routed to the station via the 230kV grid power lines. Unless another use can be specified and economically justified, the REPG unit will be sold on the open market with an expected return in the order of \$5M (highly dependent on market conditions). Cost recovery hasn't been included in this business case.

The cost of the APS solution is \$116.7M, including for contingency. This request is for an additional \$50.2M to the \$66.5M released as part of the submission on September 22, 2005. This amount is within the Business Plan estimate (\$200M) for this purpose. The cost estimate is based on analysis of the three major components of the project, namely:

- The Power Plant This is a commercial quality combustion turbine facility located on the Pickering NGS site, but outside of the nuclear Protected Area boundary. The commercial quality (versus nuclear quality) nature of the system, as well as its location outside the Protected Area, will minimize costs.
- Inside Plant Boundary (IPB) This is the portion of the system that routes power from the Power Plant into the Protected Area boundary and connects to the station electrical distribution system.
- 230kV Connection This is the portion of the system that connects the Power Plant with the Pickering NGS-B switchyard for full power testing and provision of power to system auxiliaries when the combustion turbines are not operating. It will also be commercial quality and located outside the Protected Area to minimize costs.

The APS will be placed in service by the Fall of 2007. A regulatory commitment is expected to be generated by the CNSC when the project schedule is submitted to them in January 2006.

Subsequent to the partial release BCS and decision to lay-up P2 & P3, the IPB station tie-in was revisited. There are considerable cost/schedule savings (~\$24M and 4 weeks) by connecting to P8 station electrical system. This proposal recommends connecting at P8 station electrical system bus.

### 3) **BENEFITS**

The primary benefit of this project is to allow continued station operation by restoring Pickering NGS to its accepted licensing design basis – by providing a source of standby power that will meet the regulatory requirements identified, during an event where grid power is unavailable and all units are shutdown. This will satisfy the CNSC requirements of HPECI availability and reactor heat transport system cooldown in the event of a grid loss. In addition, power will be available to other important plant systems normally supplied by Class IV power, and defence in depth will be enhanced by providing backup to Class III powered nuclear safety-related systems.

### 4) <u>KEY ALTERNATIVES</u>

### 4.1 Summary of Key Alternatives Reviewed

Alternative (BCS #)	Description	Cost \$M	Cost \$M (Including Contingency	Recommendation
0	Upgrade Existing Remote Emergency Power Generator (REPG)	N/A	N/A	<ul> <li>Not Recommended.</li> <li>Does not restore Design Basis</li> <li>Cannot supply all regulatory loads</li> <li>Does not meet 30 minute start-up</li> <li>Does not meet 10⁻² unavailability</li> <li>Subject to 230kV common mode fault</li> </ul>
1A	Install 2x100% CTUs Connected to Unit 8 SES Bus (Regulatory Loads Plus Important Loads)		116.7	Recommended.
18	Install 2x100% CTUs Connected to Unit 8 SES Bus		112.7	NOT Recommended.  • Unable to supply highly desirable loads
1C	Install 2x100% CTUs Connected to Centre of SES Bus		147.6	Not Recommended. the postulated benefit would be full APS voltage delivery for PA units, including unencumbered PHT pump operation for cooldown. This is approximately \$24M more than the recommended alternative due to increased costs associated with work inside the PNGS plant.



#### 4.1 Summary of Key Alternatives Reviewed Continued

Alternative (BCS #)	Description	Cost \$M	Cost \$M (Including Contingency)	Recommendation
2A	Supplement REPG and Connect to Ring Bus (Regulatory Loads only)		154	<ul> <li>Not Recommended.</li> <li>Technical Issue - feeding through the Station Service Transformer will result in unacceptable voltage drop.</li> <li>Heat Transport Pump modifications required to overcome tripping pumps when started in standard configuration</li> <li>Loss of generation revenue due to outage extensions to install Heat Transport modifications</li> </ul>
2B	REPG Supplemented with AddItional Generators and Connected to Secondary Side of Station Service Transformer (Regulatory Loads only)		156.5	<ul> <li>Not Recommended.</li> <li>Unable to supply highly desirable loads</li> <li>Engineering risks with new 3 winding parallel test transformers to overcome voltage drop problem.</li> <li>Considerable schedule risk</li> </ul>

Although not a regulatory requirement, providing power for important Class IV plant systems and backup to important Class III powered systems will provide additional defence in depth for safe operation of the plant during a grid loss event. Elimination of these loads would not reduce the combustion turbine size required, due to the limited number of sizes of combustion turbines available. The cost savings are thus marginal, and not commensurate with the value of providing the service for critical plant needs.

Several alternatives were considered that involve reuse of the existing REPG, but each presented significant schedule and/or technical risks and most could not meet the regulatory requirements.

The APS will be tied into the 230kV grid, which will allow for full power testing and supply to the power plant auxiliaries. This grid tie-in could facilitate future grid emergency power back-up or peak power operation. However, this would require an additional funding release and would require an environmental assessment.



### 5) KEY BUSINESS RISKS

An extensive risk assessment was documented, and mitigating actions put in place to reduce residual risks to "low". To ensure integrity, challenge meetings were held with key stakeholders (Corporate Finance, Risk Assurance Services, Financial Planning and others), and mitigating plans/contingencies adjusted accordingly.

Since the last submission on September 22, 2005, all Power Plant risks indicated as Medium have now been dispositioned as Low. The sole remaining Medium risk is Regulatory in nature and is:

 Obtaining CNSC concurrence for sequencing of load profile. The HPECI pump will not be started prior to PHT cooldown. The HPECI pump will be on AUTO and declared available for service once power is supplied to the SES bus. Cost for rework if CNSC concurrence is not received is estimated at \$24M, plus increased risks associated with the Inside Plant Boundary (IPB) work.

Overall contingency and or an of estimate) has been allocated based on approximately 15% of Design Engineering complete and mitigating actions to address cost and schedule risks associated with the challenging project schedule.

The above risk is being closely monitored.



.



### Appendix A Project Cost Summary

\$ Millions Capital	LTD Prior Years 2004	2005	2006	2007	2008	2009	Total	LTD This Mth Oct 2005	LTD
OPG Resources		1.3	3.0	2.8	0.3		7.5		
Power Plant									
230kV Phase 1								States and	
230kV Phase 2							1099	- et == - 1	-
Inside Plant Boundary (IPB)	7	in the second		Concernation of the	-	and a second			
Misc Contract	-			-title - cooke		TANG NEWS			
Escalation	-		Control of Soldier	1041 W 2000	2000	ميك ميكاني م			
Interest (Capital Project Only)		nic ran agiran	A 1991	And a short		1470.001	-		
Sub Total - (excl Contingency)				-	C-GOM-ING	Later of the second			encer Grate
OPG Resources				11.2	Contraction of the local division of the loc		100		
Power Plant					620000	··· 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1			
230kV Phase 1 (Swyd tie-in)	1					Silvester	786 ×		
230kV Phase 2	1				1. 10				
nside Plant Boundary (IPB)	7			1 8 - 78	State of	-			
Sub Total - Contingency									
Brand Total	0.0	18.6	74.8	25.0	0.3	0.0	118.7	NA	N/A
005-2009 Business Plan		45.0	100.0	55.0	0.0	-	200.0	N/A	N/A
ariance to Business Plan - ixcl Contingency)				and the second	2281. A	10317.1	Chilling I		

### Appendix B Key Milestones

Milestones	
Finish Date (D/M/Y)	Description
20/10/05	Outside - EPC - Agency Approval to issue PO (complete)
25/10/05	Start of Installation (complete)
15/12/05	Full Release Funding of APS Project
21/04/06	P681 230kV Switchyard Available for Service Declaration complete
30/05/06	Design Complete
15/06/06	All Major Contracts Awarded
19/02/07	All Regulatory Approvals Obtained
13/04/07	Power Plant - Mechanical Completion Finished
16/07/07	Power Plant – Substantial Completion Finished
27/07/07	APS Available for Service
28/09/07	In Service Declaration to CNSC



**BUSINESS CASE SUMMARY** 

Standby Generator Governor Upgrades Pickering B 13 - 49109 Capital 13 - 40528 OM&A

### Full Release (Phase 2) Business Case Summary NK30-BCS-54600-00011-R000

Routing	Location	Action	Signature	Date
David Calkin, Project Leader, Design Projects 701-3831	P72-3	Prepare BCS	D.all	Jah 30 2007
George Makdessi Project Manager, Design Projects 701-6617	P72-3	Review BCS	AS	30 5 au 2007
Joseph Leung Section Manager, Project Design 701-2635	P72-3	Review BCS	Joseph Keinf	700302007
Sepehr Ghorashi Section Manager, Process Scheduling 701-4491	P72-3	Review BCS	Esth.	742 2007 2017/01/30
Randy Ludlow Manager, Design Projects - Strat IV 701-8055	P72-3	Review BCS	BandyLull	
Alnoor Bhaloo Manager, Perf Engineering - Strat IV 701-3562	P41E3	Review BCS	plate	2007/02/02
Mark Arnone ctor, Projects & Mods 063	P72-1	Review BCS -	The	02 FEB 2007
Director Station Engineering 701-7078	P41-E3	Review BCS	Riper	F.b2-2007
Ron Ball Senior Financial Analyst 702-4084	P82-3	Review BCS	Son	Feb2-2007 2 Feb-07
-				
Financial Analyst 084	P82-3B6	Return For Distribution		

**BUSINESS CASE SUMMARY** 

Standby Generator Governor Upgrades Pickering B 13 – 49109 Capital 13 – 40528 OM&A

Full Release (Phase 2) Business Case Summary NK30-BCS-54600-00011-R000

Routing	Location	Action	Signature	Date
R. Leavitt Director Investment Planning	P82-3	Review BCS	PALow. X	Feb 6,2007
P. Tremblay Senior V. P. Pickering B	P41-E3	Submit BCS	HAT Way	Feb 2 (02)
J. Beech V.P. Nuclear Finance	H7-E19	Review BCS	12/0	1057/07
T. Mitchell Chiəf Nuclear Officer	P82-6	Review BCS	Mushen	F68/07
D. Power V. P. Corporate Investment Planning	H7-D06	Approve BCS	Allown	Feb 8/07 Feb 18/07
P. Charlebois Chief Operating Officer	H19-E21	Review BCS	Atulandye	Tob 20107
J. Hankinson dent & C.E.O.	H19-A24	Approve BCS	ATT	Mar 5/07
II Financiał Analyst 084	P82-3B6	Return For Distribution		



BUSINESS CASE SUMMARY

### Standby Generator Governor Upgrades Pickering B 13 - 49109 Capital 13 - 40528 OM&A

#### Full Release (Phase 2) Business Case Summary NK30-BCS-54600-00011-R000 1/ RECOMMENDATION:

We recommend a Phase 2 release of \$8.8M (total project \$23.3M) to complete the design, comprehensive installation work packages and installation/commissioning of governors on the remaining four (of six) Pickering B Standby Generators (SG's).

This project is one of five SG Upgrade projects designed to reduce the likelihood of a forced outage due to SG obsolescence and spare parts unavailability that has been negatively impacting reliability. The scope of these projects was based on a Pratt & Whitney (P&W) report IMR # 510 issued in May 1999 which focused on equipment obsolescence issues and the OEM's inability to support critical products. Phase 2 of this project (\$8.8M) and the Protective Relay project (\$1.8M) are the two outstanding initiatives of the overall program that is estimated to cost \$50M. We have a REGM target to complete this work by Dec 31, 2007.

Prior to the start of this initiative, Pickering B SG performance indicated a deteriorating trend. We were not able to consistently meet the design basis SG start reliability. Approximately 70% of the total SG trips identified in the P&W report could have been prevented by the SG Governor upgrade by ensuring consistent SG starting time bench marks within the start permissive logic. Continued degradation has the potential of severe, protracted adverse impact on SG performance and forced unit outages due to unavailability of Standby Class III Power redundancy. Forced shutdowns of operational Nuclear units can occur when SG unavailability is combined with other safety support system degradation, functional failures or operational restrictions (such as Class II UPS and SES).

At this time, two (2) Governors have been installed, placed in service, and a Post Implementation Reviews (PIR) has been completed. We have seen improvements in SG performance, as work has progressed and the SG health system recently changed from RED to WHITE. Project completion is a requirement to maintain system health WHITE assment. The total project estimate has increased \$1.2M to \$23.3M, due primarily to Vendor QA issues, material costs, and underestimated design costs. Lessons learned from Phase 1 have been incorporated into the Phase 2 estimate.

The current Integrated Operating Plan (IOP) schedule calls for the completion of four (4) SGs in 2007. However, due to the degree of difficulty in executing four installations in one year, we are recommending the installation of three (3) governors in 2007 and one early in 2008. This will involve an adjustment to the IOP schedule and an extension to the REGM commitment. However, if conditions prove favourable, we will install four (4) units in 2007.

\$000's (incl contingency)	Funding	LTD 2005	2006	2007	2008	2009	2010	Later	Tailet
Currently Released	Full - Phase 1	2,672	8,850	2,969	***********			Later	Total
Requested Now	Full - Phase 2		(1,186)	6,984	3,042		+	ļ	14,491
Future Funding Req'd	None			0,304	5,042		<b> </b>		8,840
Total Project Costs		2,672	7,664	9,953	2.040		}		-
Other Costs				3,300	3,042	*		•	23,331
Ongoing Costs									
Grand Total		2,672	7,664	9,953	3,042			·	
Investment 1 Sostalnin		Class Cap & Ol		Breakeven L 5.2% force	evel of Risk		IR A	Discounter	
Pierre Tremblay Senior Site Vice Pre	SMe		Date:	27	Approve	T.I	Mutal N. Mitchel ief Nucle	ll ar Officer	
V. P. Corporate Inv	estment Plannin	g ulsah	0-18/6 Opte:	7 Jin Har	there		t 1.1 Project i	in Budget): MA	A 5/07 Date:
an anasasan a	10.00	Ŏ							

**OPG** Confidential

Page: 4 of 18

**BUSINESS CASE SUMMARY** 

#### BACKGROUND & ISSUES

The Standby Generator Health system was rated as RED as recently as Q1 2006 due to functional failures on aging parts that are obsolete and no longer supported by the OEM. Over the last few years the SGs have experienced a number of functional failures that contributed to forced outages. The functional failures reduce redundancy and potentially could lead to a Pickering B units shutdown. Recent upgrades and maintenance have improved the system health rating from RED (Q1) to YELLOW (Q2/3) to WHITE (Q4). Project completion is required to ensure system reliability and resolve obsolescence of the governor system which is not supported by the OEM.

The SG system is an essential safety related support system which supplies Class III power to the electrical equipment required to ensure a safe shutdown of the reactor; continuous core cooling, and supply to essential loads in the turbine, water and air systems, in the event of loss of Class IV power. There are three SGs that support each pair of Pickering units (i.e. 056-54600-SG1/SG2/SG3 supports Units 5 & 6, and 078-54600-SG1/SG2/SG3 supports Units 7 & 8).

As per Abnormal Incidence Manual (NK30-AIM-058-09013-04.01), following are the impairments for the Standby Generator system:

- Coincidental unavailability of three SGs per pair of units will result in SG system impairment (system does not meet design intent). In this impairment, both Pickering B affected Units need to be shutdown within 24 hours unless approval has been given by the Duty Manager for continued operation beyond 24 hours. The minimum system requirement is to have at least one SG available per pair of units.
- If two of the three SGs are unavailable per pair of units, the system will be considered to have reduced redundancy or margin of safety and required action will be to suspend testing of remaining SGs and repair to be carried out on high priority basis for the affected SG.
- If one of the three SGs is unavailable per pair of units, the system will be considered to have reduced redundancy or margin of safety and required action will be to suspend non-emergency operation of remaining SGs above 3.5MWe in peaking mode and repair to be carried out on high priority basis for the affected SG.

The following projects represent the Pickering B SG Upgrade program:

	Pickering B Standby C	Jenerator Upgrade	Projects	
49033	SES/HPECI Power Supply Upgrade	Capital	12.7	Complete
49088	Standby Generator Upgrade	OM&A	1.0	Near Completion
40412 40628	Standby Generator Upgrade	Capital	11.0	Near Completion
49109 /40528	New Protective Relays Standby Generator Governor Upgrade	Capital	1.8	Developmental Stage
Total	Grandby Generator Governor Opgrade	Capital / OM&A	23.3 49.8	2 of 6 complete

See Attachment 'D' for summary of Pickering B SG functional failures extracted from the System Health Report.

BUSINESS CASE SUMMARY

### 3/ ALTERNATIVES AND ECONOMIC ANALYSIS

\$ 000's	Stop the	Alt 1 (Rec	ommended)	Alt 2	Alta	Alt 4	Alt 5
	Project	Full Cost	Incremental Cost	Delay 1 yr			
Revenue	(16,265)	(1,857)	(1,857)	(3,778)			<b>F</b>
OM&A	(9,847)	(2,466)	(2,007)	(2,316)			+
Capital	1,477	(22,872)	(12,995)	(13,385)			
NPV (after tax)	(12,401)	(20,782)	(12,401)	(13,353)			
mpact on Economic Value (IEV)	N/A	(8,381)		(952)			<u> </u>
RR%	N/A	N/A	N/A	N/A	~···		
Discounted Payback (Yrs)	N/A	N/A	N/A	N/A			

#### Stop the Project - Not Recommended

This is not recommended as we are at risk of an unplanned SG outage or possible forced unit outage due to SG obsolescence and a lack of spare parts. Moreover, the REGM commitment would not be addressed and we would have to write approximately \$ 5.4 M of capital charges off to OM&A

#### Alternative 1 - Proceed with Project - Recommended

ceed with upgrades to the SG Governor system and related controls as outlined in section 4 below to reduce increasing likelihood of an unplanned SG outage or forced unit outage. Because we cannot effectively install more than 3 governors this year, we will need to seek an extension to our REGM commitment and complete the final installation early in 2008. Completion of this work and the Protective Relay project will finalize the upgrades to the Pickering B Standby Generators and thereby remove the threat of a forced outage, maintain the Health System at white and satisfy a REGM commitment.

Due to the complexity of such an event (see Background Section), the likelihood of a forced outage due SG failure is not easily estimated. Lacking an accurate way to determine this level of risk, financial justification must be made on an assessment of whether there is a reasonable chance that the breakeven point for the incremental investment will be surpassed. Calculations indicate that the breakeven point is reached when the likelihood of a forced 30 day outage (involving 2 units) is 5.2% and the cost to repair is \$300K. Based on past SG performance (see Attachment D), we feel it is reasonable to assume that we would likely surpass this level of risk, should the investment not be made. Moreover, it makes sense to complete the last major initiative of the \$50M SG Upgrade program, so that we can realize the overall objective of SG reliability.

#### Alternative 2 - Delay Project - Not Recommended

This is not recommended as there is an increasing likelihood of an unplanned SG outage / forced unit outage and we would not be addressing the REGM commitment.

#### Alternative 3 – Install 2 of the remaining 4 - Not Recommended

Modifying only 2 of the remaining 4 Pickering B SG's is not recommended for the following reasons:

- a) OPG is locked into an Engineered Material Vendor contract totaling all six SG's (as per previous release),
- ) Increased likelihood of error when performing SG maintenance, as there would be two designs.
- c) Increased documentation effort as all the operating and maintenance documentation would need to reflect two designs.
- d) 68 percent of the project cost is with the first two SG's.



**OPG** Confidential

Page: 6 of 18

BUSINESS CASE SUMMARY

4/ THE PROPOSAL

We recommend continuing with the replacement of the existing SG Governor, sequencing/control relay logic, fuel delivery package and associated I&C monitoring for the remaining four Pickering B SGs.

### Scope Breakdown:

Governor fuel delivery system replacement New PLC based integrated governor and sequencer controls

Replace majority of the relay start/control logic with PLC

Independent over speed protection system (due to adoption of PLC)

Relay logic changes covered by Pratt & Whitney Study Report IMR 510

PLC based speed switches and timers

New Data event logger with expansion capabilities

New Machine monitor (temperature and vibration)

### Phase II major project deliverables are as follows:

- Update Project Execution Plan (a)
- Revise Vendor design packages as required (b)
- Complete Design Packages for remaining two SG's (first four SG's completed under Phase I) (C)
- Work Plans and Field Engineering Packages for remaining four SG's (d)
- Systems and equipment installation and commissioning remaining four SG's (e) **(f)**
- New and/or revised Operating and Maintenance Procedures for remaining SG's. (g)
- Project close out station document updates, PASSPORT updates (h)
- Post implementation review, lessons learned

The SG Governor Upgrade Project Execution Plan (PEP) NK30-PEP-54600-00001 defines the project scope to complete the deliverables. Finish dates in future based on current SG outage schedule. Should outages move, dates will vary accordingly.

### 5/ QUALITATIVE FACTORS

- 1. Lower system maintenance costs (Governor and logic failures being minimized) with the new Governor and start/control logic.
- 2. Improved diagnostic capabilities using new data logger and machine monitor, thus reducing forced SG outage troubleshooting times.
- 3. Elective and Corrective Maintenance backlogs expected to decrease due to replacement of instrumentation and





Idential Page: 7 of 18	SINESS CASE STAMADU
OPG Cont	BU

1

BUSINESS CASE SUMMARY

# 6/ RISKS

Description of Risk Cost	Description of Consequence	Risk Before Mitigation	Mittgating Activity	Risk After Mitigatio
Additional material may be required depending on as found condition of machine when disassembled for the retrofit modification.	Added material costs to replace broken or unusable existing equipment.	Medium	Added specific contingency for materials	Low
Increased OPG installation package preparation and design review costs due to Vendor documentation QA issues.	May not be able to complete installation packages within budget and schedule.	Medium	Specific Contingency included for increased installation package preparation effort. OPG Supply Chain working with the Vendor to improve documentation QA through OPG corrective action process.	LOW
May need to account for field discovery during installation phase.	Delay completion of tasks. May not be able to complete scope within allocated budget.	Medium	Specific Contingency included for Installation to minimize impact. Design phase comprehensive walkdowns complete. Increase scope only with management approval and funding allocation	Low
Integration complexities with SG Upgrade project and other Maintenance.	Delay completion of tasks. May not be able to complete scope within allocated budget.	Medium	Incorporating Lessons Learned. Specific Contingency included for Installation (see above) to minimize impact. Integrated work programs of SG Governor & SG Upgrade projects and station maintenance. Multiple station challenge reviews	Low
Schedule			conducted. Incorporating Lessons Learned.	
	Project may not meet current REGM deadline	HgH	REGM commitment date to be reviewed and extended as required.	Low
Jauvi uriven SG Outage	IOP process not being followed for	High	General contingency includes amounts for	Medium

ATON	
OPO GENF	
8	:

OPO Confidential Control Page BUSINESS CASE SUMMARY

8 of 18



٤,

	minor delays for the remaining 4 SG's. Many challenge reviews conducted to minimize hand-off / turn-over delays. Increased pre- outage preparation planning. Incorporating Lessons Learned. Recommend adding \$2.8M to 2008 B.P. budget against final SG installation delays to 2008. To be reviewed during 2008 Business Planning. Risk	Project integrated into station SG Low maintenance program. Added minor contingency to project schedule. Covered by Specific Installation Contingency discussed on previous page.	Use contract resources, if necessary. Low	Use contract resources, if necessary. Low General contingency includes overheads to administer contracts. Pre-arranged Ops support including a SPOC prior to outage. Permit walkdown prior to outage.	OPG added resources to assist Vendor in Low project co-ordination. Vendor added technical and project management resources. Vendor advancing production schedule for remaining SG's, Supply Chain exploring other contractual remedies.		3
		Medium	Medium	Medium	Hgh	Medium	
	design issuance milestones and installation package preparation. Delay installation and SG return to service. May not be able to complete scope within allocated schedule windows and budget.	Delay installation. May not be able to complete scope within allocated budget.	Delay completion of scope. Impact on design schedule for subsequent SG's.	Delay installation	Delays in subsequent design packages for remaining SG's. Delays in testing and material delivery	Delay return to service due to cumbersone SQA field change process. SG unavailability combined with other safety support system degradations (i.e., UPS, SES) may cause forced unit shutdowns.	
schedule and SO	maintenance window is very aggressive with little contingency. SG outage opportunities may change.	Delays caused by maintenance activities (unforeseen work) during SG outages could affect SG outage schedule	Limited engineering resources. Other project priorities.	(BTU and PWU). Competing with SG Upgrade project and other maintenance programs. Limited Ops resources during commissioning.	Engineered Material Vendor resources diverted to other contracts. Vendor has access to limited resources and has limited project management skills.	Commissioning / testing of complete modification on subsequent SGs. Possible software modifications during commissioning.	-



OPG Confidential Control Page: 8 of 18 BUSINESS CASE SUMMARY



í.	ć	n Low		Low	
	field implimentation. s Learned.	ed procedures.		have been installed	
	verification with field im Incorporating Lessons Learned.	Material to be sampled and scrapped in accordance with approved procedures.		The first two governors have been installed and are operating as designed	
	9 <u>1</u>	Medium Me		Low and	
		Environmental regulatory non- compliance		Rework, extra cost	
	None.	Scrapping of old material Envi	None.	Project does not satisfy the Rew Business Objectives	

いっかん しょうはたい しょうきん うけい しょうせい たんえいたい

-------

#### OPG Confidential

Page: 10 of 18

**BUSINESS CASE SUMMARY** 

MADY

### 7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Final AFS	Targeted PIR Approval	PIR Responsibility
	Date:	Date:	(Sponsor Title)
Simplified	Jun 2008	Dec 2008	Director - Station Engineering

### Comments:

	Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it? (person / group)
1.	Available For Service (first 2 SG's)	N/A	AFS and open items acceptance by stakeholders	Attach copy of AFS and open items with A/R's to PIR	System Engineer
2.	SG Machine performance Criteria Met	N/A	Commissioning results acceptance by Design	Signed Commissioning Report scanned in Passport	Project Manager
	Standby Generator (SG) System Health	Red	Removal of SG Governor and associated control systems as contributor to Red system status	Updated SG system health report indicating improved status for affected equipment	System Engineer
4.	REGM 28007285 complete	Dec 2007	SG Governor Project contribution to REGM completion	SMB REGM schedule review Milestone added to SG Outage Plan	Project Manager
5.				* 1943 (	



**OPG Confidential** 

Page: 11 of 18

#### **BUSINESS CASE SUMMARY**

#### Appendix "A"

### Glossary (acronyms, codes, technical terms)

AFS	Available for Service
BCS	Business Case Summary
B.P.	Business Plan
BTU -	Builders Trade Union
COMS	Constructability, Operability, Maintainability, Safety
CUSW	Direct Hire Building Trade Union (Electrical)
CWP's	Comprehensive Work Packages
DCN	Design Change Notice
ECC	Engineering Change Control
EPG	Emergency Power Generator
FAT	Factory Acceptable Test
FE	Field Engineering
FIPR	Field Installation Package Release
FME	Foreign Material Exclusion
HFE	Human Factors Engineering
IOP	Integrated Operating Plan
ITP	Inspection Test Plan
1&C	Instrumentation and Controls
IRR	Internal Rate of Return
NUCORDS	Nuclear Components Reliability Data System
NPV	Net Present Value
AR	Organizational Authority Register
OLW	Online Wiring
	Operations, Maintenance and Administrative
OM&A	expense
ONL	Online Wiring
OPEX	Operating Experience
Ops	Operations
O.T.	Overtime
PC1	Worker Protection Permit application Form
PEP	Project Execution Plan
PIR	Post Implementation Review
PFU	Predicted Unavailability Factor
PINO	Performance Improvement Nuclear Oversite
PLC	Programmable Logic Control
PSL	Power Supply List
PWU	Power Workers Union
QA	Quality Assurance
QCIV	Quality Control Inspection Verification
QSITP	Quality Surveillance Inspection Test Plan
REGM	SNSC Management Commitment
SCR	Site Condition Report
SE's	System Engineer
SES	Site Electrical System
SG	Standby Generator
SMB	Site Management Board
200	Single Point of Contact
JQA	Software Qualification Assurance
TSSA	Technical Safety Standards Authority
UPS	Uninterruptible Power Supply

**OPG** Confidential

**BUSINESS CASE SUMMARY** 

Appendix "B"

### **Project Funding History**

\$ 000's Release Type	Month	All Year	Existing		ned Relea Iulative V 2004		continge				
Developmental	and the second se	2,002	- 300		2004	<u>XUUD</u>	2006	2007	2008	Later	Total
Full (Phase 1)	Apr	2,004	87	0	1.010	7,712					300
Superseding	Feb	2,006	87	0	372	2,213	8,850	2,969	0	+	8,809 14,490
Full (Phase 2)	Jan	2,007	87	0	372	2,213	7,664	9,953	3,042	+	23,331
											0
											0
											0
											0

			07				
				070	0.040		
LID Spent	Dec	2,006				7.664	
							10,336
				1 3141			

.

#### **Comments:**

**OPG Confidential** 

Page: 13 of 18

BUSINESS CASE SUMMARY

He. 13 01 18

Appendix "C"

#### Financial Model – Assumptions

#### **Project Cost Assumptions:**

Cost estimates have been verified by 3rd party reviewer, Atlas Helyar. Task Identification Sheets (N-Form-11025) have been validated by all contributing resource groups. Actuals and lessons learned have been incorporated into estimates.

#### Financial Assumptions:

The breakeven point for this investment is reached when the probability of a 2 unit forced outage of 30 days reaches 5.2% and the cost of repair accumulates to \$300K. This is based on the following:

#### Loss of Revenue during forced unit outages:

(516MW for PB) X (85% Capacity Factor) X (24 Hours) X (30 Days) X (Rate MWH) X (2 Units).

#### Repair Costs during forced SG outages:

\$300K per year + 3% Inflation

#### Project / Station End of Life Assumptions:

Pickering B End of Life: 2014 Units 5, 6, and 7 2016 Unit 8

#### nergy Price / Production Assumptions:

2007 2008 2009 2010 2012 2011 2013 2014 2015 2016 57.0 56.2 58.2 55.6 54.4 54.2 56.3 60.2 64.4 67.1

#### Operating Cost Assumptions: N/A

Other Assumptions: N/A

**BUSINESS CASE SUMMARY** 

Standby Generator Governor Upgrades Pickering B 13 - 49109 Capital 13 - 40528 OM&A

### Full Release (Phase 2) Business Case Summary NK30-BCS-54600-00011-R000

Attachment "A"

#### **Project Cost Summary**

\$000's Capital & OM&A	LTD Prior Yr 2006	This Release 2007	This Release 2008					Later	Total
Project Management (OPG)	623	253	260		Accession of the	*		10010-707269	1,136
Engineering & Drafting (OPG)	1,874	1,018	374	-		<u> </u>			3,266
Material				Contraction of the local date		<u> </u>			
Installation - PWU, BTU	X								
Contract - Design							1000	The second second second	
Contract - Installation	1								1
Contract - Other									
OMA Project 40528				di canana	and division in the				
Interest (Capital Project Only) Project Costs (wet contingency) General Contingency Specific Contingency	Ĩ								
pject Costs (Incl contingency)	10,336	9,953	3,042						23,331
00 2012 Business Plan	10,336	7,083	2,230	-			••••••	~~~~~	19,649
Variance to Business Plan		2,060	566	•					2,626
Committed Cost	T								
nventory Write Off Required		1		·······	· · · · · · · · · · · · · · · · · · ·			į	
Spare Parts / Inventory	1	İ					·		
Total Release (excl contingency)	1						ł		_
Total Release (Incl contingency)	STORE G	9,953	3.042						
	200 <b>00-200</b> 00		00093979600						23,331
Ongoing OM&A (non-project)	1				1	I			
······································	~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~								000000000000000000000000000000000000000

Design Complete		100%	Quality of E	stimate	Release + 15	5% to - 10%
3 rd Party Estimate	Yes	OPEX used	Yes	Lessons Le	· · · · · · · · · · · · · · · · · · ·	Yes
Reviewed by Sponsor	Yes	Budgetary Quote(s)	Yes	Phase 1 Act	tual Used	Yes
Similar Projects	Yes	Contracts in place	Yes	Competitive	Bid	Yes

The estimated variance(s) to the 2007-2011 Business Plan will be addressed through the portfolio management process. A PCRAF will be approved by Apr 2007.

viewed By: 30 Jan 2007

George Makdessi Project Manager

Date:

Approved By: 31 Jan 2007 ant Randy Ludlow

Eng & Mods Manager (Strat IV)

Date:

**BUSINESS CASE SUMMARY** 

## Standby Generator Governor Upgrades Pickering B 13 - 49109 Capital 13 - 40528 OM&A

### Full Release (Phase 2) Business Case Summary NK30-BCS-54600-00011-R000

|--|

11.1.2

### **Project Variance Analysis**

		Total F	the second second second second second second second second second second second second second second second s		
Capital & OM&A	LTD Dec 2006	Last BCS Feb 2005	This BCS Jan 2007	Variance	Commenta
Phase 1					
Project Management (OPG)	623	668	623	(45)	As per actuals
Engineering & Dratting (OPG)	1,874	1,518	2,039	521	Vendor software changes QA, Rework, Field Change
Material	2,370	5,667	6,142	475	Commissioning Supp from Vendor, Increases to Misc
Installation - PWU, BTU	3,534	3,654	3,735	81	Mett As per actuals
Contract - Design	495	322	502	180	As above
Contract - Installation	386	260	392	132	056-SG3 Outage start delays, ES Fox/Crosby Dewar Increased Costs due to design changes.
Contract - Other	340	302	340	38	Training materials and hardware costs
OMA Project 40528	459	459	459	-	Sunk costs of previous OM&A project
Interest (Capital Project Only)	255	258	255	(3)	As per Actuals
Phase 1 (excluding contingency)	10,336	13,108	14,486	1,378	
neral Contingency		242	-	(242)	Materialized risk as outlined in last BCS brought into budget.
Specific Contingency	-	1,140	-	(1,140)	Materialized risk as outlined in last BCS brought into budget
Phase 1 ( Incl contingency)	10,336	14,490	14,486	(4)	•
Phase 2					
Project Management (OPG)		238	513	270	Outron Delana and I
		2.30	513		Outage Delays and increased support of Vendor
Engineering & Drafting (OPG)	-	450	1,227	111	Adjustments as per lessons learned and increased review effort of vendor design and field changes
Aaterial	-	186	440	254	Commissioning Support from Vendor, Increased Misc Matl costs (lessons learned)
nstallation - PWU, BTU	· ·	4,650	4,787	137	Adjustments as per lessons learned
Contract - Design	-	49	55	6 /	Adjustments as per lessons learned
Contract - Installation	-	393	344	(49)	Adjustments as per lessons learned
ontract - Other	-	100	100	-	
MA Project 40528	-	-	-	-	
iterest (Capital Project Only)	-	174	323	149 (	Cash Flow adjustments
hase 2 (excluding contingency)	· · ·	6,240	7,789	1,549	
eneral Contingency		1,409	86	(1,323)	ncorporation of lessons learned.
pecific Contingency		-	970	970 4	dentified risks going forward
hase 2 ( incl contingency)		7,649	8,845	1,196	
otal Project (incl contingency)	10,336	00.400		a an an an an an an an an an an an an an	······
eneral Contingency	10,330	22,139	23,331	(/ <b>), (197</b>	

someriolect mus contradency.	10,336 22,139	23,331	1,192
General Contingency	1,651	86	
Specific Contingency	1,140	970	
al Project (excl contingency)	10,336 19,348	22.275	2.927
mments:	00000000000000000000000000000000000000		

**OPG** Confidential

Page: 16 of 18

**BUSINESS CASE SUMMARY** 

Attachment "C"

### Key Milestones

Completion Date		Date	Burnet at
Day	Mth	Yr	Description
15	Apr	2007	Revise PEP
09	Feb	2007	5th SG Detailed Design Package 056SG2
07	May	2007	6th SG Detailed Design Package 078SG2
19	Feb	2007	056-SG1 (3rd SG) Installation Start (T-0)
07	May	2007	078-SG1 (4th SG) Installation Start (T-0)
22	Oct	2007	056-SG2 (5th SG) Installation Start (T-0)
15	Feb	2008	078-SG2 (6th SG) Installation Start (T-0)
10	Apr	2007	056-SG1 (3rd SG) AFS
06	luL	2007	078-SG1 (4th SG) AFS
21	Dec	2007	056-SG2 (5th SG) AFS
7	Apr	2008	078-SG2 (6th SG) AFS
30	Dec	2008	Project Complete

A Project Execution Plan (PEP) will be approved by 2007

#### **Comments:**






Attachment 'D'

## Pickering B Standby Generator 2005 & 2006 Failures / SCR Summary

Functional Failures (QTR/2YR)	Comm	non	056 SGs		078 SGs		Overall	
	Qtr	2 Yr	Qtr	2.Yr	Qtr	2 11	System Health	
21 2005		80.56	04	94	21	17 ->	20-22	
33 2005	\$112.22 Ø	100	14	64	14	16 4	Statist : : : : : : : : : : : : : : : : : : :	
Q2 2005	100.00	1000	24	84	24	16 4	200000	
04 2005	sine and		2014/202	See See	1->	16 ->	000000000000000000	
Q1 2006	<b>X12</b> 1986	112.258	1.000	100 10 100	00000000	101210-003		
Q2 and Q3 2006	8 (C = )	0.0	30303	12 33.70		1994年1月1日 1997年1月1日 1997年1月1日	VELLOW	
04 2006	19.3/18	10-1-20	8023 M		<b>TEX</b>	387.79%	WHITE	

### Pickering B SG Unavailable Hours per Year (Planned vs Forced/Outage Extension)



OPG Confidential

18 of 18

Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

Event Date	SCR	Equipment / Event Summary
Jan 04, 2005	P-2005-00131	056-54600-SG3 tripped during start-up of pre-outage test run on "PT Exhaust Temp.
Jan 18, 2005	P-2005-01151	078-54600-SG2 tripped during start-up of routine P-07 test run.
Feb 13, 2005	P-2005-02699	078-54600-SG2 tripped on "DC Lube Oil Pump Failure" during U7 P-05 routine test - defective pressure switch PS12.
Feb 18, 2005	P-2005-03115	056-54600-SG1 incurred a "Fuel Boost Pressure Low" (Test Mode only) start trip during U5 loss of class III bus test. It is a Peaking Mode only trip.
Feb 19, 2005	P-2005-03249	078-54600-SG3 failed to start and was rejected duringU7 P-5 test. Fault was traced back to a faulty T8 timer.
Mar 18, 2005	P-2005-05152	056-54600-SG3 tripped on "PT Exhaust Temp. High" during start- up of U6 UPSB backup test.
May 01, 2005	P-2005-07961	056-54600-SG1 tripped during start-up of P7 routine test run on "PT Lube Oil Sequence Falled". – It is a Peaking Mode only trip. Intermittent equipment failure.
May 22 , 2005	P-2005-09305	078-54600-SG3 tripped during start-up of routine P-07 test run on "Main Lube Pressure Low" - defective T8 timer.
Jun 18, 2005	P-2005-10865	056-54600-SG2 tripped on "PT Lube Oil Sequence Failed" during P7 routine test. It is a Peaking Mode only trip. Defective T11 timer.
Jun 28, 2005	P-2005-11400	078-54600-SG3 tripped during start-up of routine P-07 test run on "Main Lube Pressure Low" Defective T8 timer.
Jul 05, 2005	P-2005-11683	078-54600-SG2 failed to start.
Jul 06, 2005	P-2005-11734	Temperature Switch Non-Conformance.
Jul 07, 2005	P-2005-11779	Actual Past Unavailability due to SGs Failures
Aug28, 2005	P-2005-14142	056-54600-SG3 Unavailable.
Sep 19, 2005	P-2005-15563	Fuel leak at 056-SG3 fuel oil integrator FZ3399
Nov 22, 2005	P-2005-19625	078-54600-SG3 tripped during start up for routine test.
April 20, 2006	P-2006-06624	078 SG2 trip on startup. 078-SG2 started for supporting Unit 8 BUS transfer operation @ 10:52 on April 20/06. The machine tripped approximately 15 seconds into the start sequence. DC Lube Oil pump did not start as expected. Trip appears to be spurious.
Sept. 30, 2006	P-2006-16975	On 09/30/06 @ 4:00, CI 525 "056-SG1 Process Trouble" annunciated in MCR. Local inspection discovered "FIRE" window lit on. SG was declared unavailable (ref. SCR P-2006-16975 & WR# 520871). Fault was traced back to a defective R1 relay which caused this spurious alarm.
Dec 18, 2006	P-2006-24708	Standby Generation Impairment 078-SG1 tripped on routine test run./ During routine P-007 test run of 078-SG1on Dec 18/06, the machine started up with an initial frequency @ 63 Hz which was above the normal 61.2 Hz.

ONTARIOPOWER GENERATION **Review Flight Details** 

Search Select Review Passengers Purchase Itinerary Fares shown are the best available uniform rates at this time for the number of tickets requested and the selected travel times and dates. Fares are not guaranteed until you purchase your ticket. **Review your itinerary** Fare Meal Flight From То Date Depart Arrive Stops Duration Aircraft Type Service* AC602 Toronto, Halifax, Sun Jun-22 07:00 10:00 Ω 2hr00 321 Tango F Pearson Halifax Int'l Int'l (YYZ)(YHZ) Halifax, AC617 Toronto, Thu Jun-26 16:05 17:27 0 2hr22 763 Tango F Halifax Pearson Int'l Int'l (YHZ) (YYZ)F: Food for purchase onboard . **Review final quote details** Fare Summary Passenger Type Adult Flight 1 - Departing airfare (Tango) 129.00 Flight 2 - Returning airfare (Tango) 144.00 Surcharges 96.00 **Taxes, Fees and Charges** Canada Airport Improvement Fee 30.00 Air Travellers Security Charge (ATSC) 9.33 Canada Harmonized Sales Tax 1.30 Canada Goods and Services Tax (GST/HST #10009-2287) 19.92 Convert Total airfare and taxes before options (per passenger) 429.55 currency Number Of Passengers 1 for informational Grand Total - Canadian Dollars \$429.55 purpose only Looking for more rewarding travel? Your TANGO fare includes Move up to TANGO PLUS Air Canada Status Miles for More Miles! 25% (non-Status Miles) flying with us 100% Air Canada Status Miles Aeroplan Miles for every 1 for \$3 1 for \$2 dollar spent online Eligible for upgrade to Executive Class with a Super-Upgrades certificates Non-eligible Elite or Elite Special System Wide Upgrade Certificate (subject to the terms on the certificate). Not included (from \$15 cap per Complimentary Advance seat selection seat) (subject to availability) Flat fee for same-day \$150 CAD (no charge for fare Lower change fees! \$50 CAD (no charge for fare changes at the airport difference) difference) Move up to TANGO PLUS and enjoy valuable extras such as Air Canada Status Miles, complimentary advanced seat selection and lower change fees - all these great benefits for an additional amount starting from \$40 per one-way, per person.



Aeroplan Miles for booking on aircanada.com, but will earn Aeroplan Miles for flown travel.



Create a Profile

eligible bookings online. More...

• You can save your reservation preferences in your profile and retrieve them at any time.

If you are not a member, you may create a profile or click 'continue as guest' to book your flight (s) as a GUEST.





**BUSINESS CASE SUMMARY** 

### Additional Feeder Cut and Weld Tooling 10 - 62567

### Full Release Business Case Summary N-BCS-30320-10003-R000

Routing	Location	Action	Signature	Date
J. Xiao Section Manager Feeder Cut & Weld Tooling Project	P82-6	Prepare BCS	that	June 28, 201
K. Garel Manager Feeder Integrity Projects	P82-6	Review BCS	ABarel .	
R. Ball Senior Financial Advisor Nuclear Investment Management	P82-3	Review BCS	Rez	-25/160
D. Żerkee Manager Nuclear Investment Management	P82-3	Review BCS	4	25.3 67
R. Leavitt Director Investment Management	P82-3	Review BCS	Alenit-	June 29 2007
P. Spekkens Vice President Science & Technology Development	P82-6	Submit BCS	(54 A	
T. Mitchell hief Nuclear Officer	P82-6	Review BCS	Mutility	29 and 07
P. Charlebois EVP & Chief Operating Officer	H19A21	Review BCS		July 6107
D. Power V.P. Corporate Investment Planning	H7 D06	Approve BCS	Atown	July 12/07
J. Hankinson President & CEO	H19 A24	Approve BCS	Mananim	July 13/07
			0	001
Ball nior Financial Analyst 2-4084	P82-3B6	Return For Distribution		

OPQ Confidential

Page: 1 of 14

BUSINESS-CASE SUMMARY

### Additional Feeder Cut and Weld Tooling 10 - 62567

### Full Release Business Case Summary N-BCS-30320-10003-R000

J. Xiao Section Manager Feeder Cut & Weld Tooling Project	P82-8	Prepare BCS	trav	Fune 28, 20
K. Garel Manager Feeder Integrity Projects	P82-8	Review BCS	Aleson l -	1.7076
R. Bali Senior Financial Advisor Nuclear Investment Management	P82-3	Review BCS	1 Pzz	200
D. Zerkee Manager Nuclear Investment Menagement	P82-3	Review BCS		25 Jun 07
R. Leavitt Director Investment Management	P82-3	Review BCS		
P. Spekkens Vice President Science & Technology Development	P82-6	Submit BCS	Paul Spekton	28 Jun; 67
T. Mitchell Chief Nuclear Officer	P82-6	Review BCS		
P. Charlebols EVP & Chief Operating Officer	H19A21	Review BCS		
D. Power V.P. Corporate Investment Planning	H7 D06	Approve BCS		
J. Hankinson President & CEO	H19 A24	Approve BCS		
		-		
				·····
. Ball enfor Financial Arfalyst 02-4084	P62-386	Return For Distribution		

-1 CHITHO 3. 8.07 7.57 AM \$00 🔁

01/01/2007

ONITA DIOR CLASS	000 0
ONTARIOPOWER	OPG Confidential
GENERATION	BUSINESS CASE SUMMA

#### BUSINESS CASE SUMMARY

Page:

2 of 14

#### Additional Feeder Cut and Weld Tooling 10 - 62567

#### Full Release Business Case Summary N-BCS-30320-10003-R000

#### **RECOMMENDATION:** 1/

We recommend approval of a full release of \$15.8M to purchase 3 additional and complete sets of Cut and Weld Tools for feeder replacement. Based on lessons learned during the first usage of Cut and Weld equipment in the D611 outage, we recommend supplementing these additional sets with some new minor tools as well as incorporating some design improvements. Ownership and usage of the tools sets will be controlled under the same Cut and Weld agreements we currently have with AECL, B&W, and Bruce Power.

The Business Objective of this project is to generate additional revenue by reducing the length of outages in the 2008 to 2017 time frame by using the recommended new Cut and Weld tooling.

We estimate feeder replacement to be the critical path item for all Pickering A and Darlington outages in the 2008-2017 timeframe. The 3 sets of tools will make the following currently unachievable results possible:

- Conducting feeder replacement execution at 2 reactor faces in parallel when it is required.
- Completing concurrent training or one face execution at another Nuclear station, if it is required .
- Reducing feeder replacement time by using the new and improved tools ٠

DNGS has indicated the requirement for additional tooling to perform a concurrent 2-face campaign. We estimate that similar conditions can be expected regularly at both PNGSA and DNGS in the 2008-2017 timeframe. Additionally, outage delays are possible, if there is a shortage of tools due to an overlap in feeder replacement campaigns for OPG and Bruce Power stations.

e estimate that, between 2008 and 2017, we can generate additional revenue of approximately \$69.6 Million by using the new tool sets to reduce feeder replacement times and to mitigate the risk of outage delays due to tooling shortages. The NPV of this \$15.8M capital investment is estimated to be \$21M with an IRR of 40.5% and a discounted payback of 4.3 years.

A Full Release is required to make commitments to the supplier that will ensure tool availability by D811.

Date:

T G LOS	Later	2010	2009				N/A	Currently Released
15 700			1,484	9.289	4.990		Full	Requested Now
15,763	·		1,707	0,200		······································		Future Funding Reg'd
15 700		·····	1.484	9.289	4.990	•		Total Project Costs
15,763			1,404	5,205	1,000	······································		Other Costs
		······································				·····	· · · · · · · · · · · · · · · · · · ·	Ongoing Costs
15,763			.484	9.289	4,990	-		Grand Total

Submitted By:

See 1 the bar

P. Spekkens Vice President Science & Technology Development

Finance Approvat 07 D. Power Date: V.P. Corporate Investment Planning

Line Approval (Per OAR Element 1.2 Project not in Budget };

J. Hankinson President & CEO

Date:

<b>ONTARIOPOWER</b>	Pager 2 cF14
GENERATION	BUSINESS CASE SUMMARY

#### Additional Feeder Cut and Weld Tooling 10 - 62567

#### Full Release Business Case Summery N-BCS-30320-10003-R000

#### 1/ RECOMMENDATION:

We recommend approval of a full release of \$15.8M to purchase 3 additional and complete sets of Cut and Weld Tools for feeder replacement. Based on lessons learned during the first usage of Cut and Weld equipment in the D611 outage, we recommend supplementing these additional sets with some new minor tools as well as incorporating some design improvements. Ownership and usage of the tools sets will be controlled under the same Cut and Weld agreements we currently have with AECL, B&W, and Bruce Power.

The Business Objective of this project is to generate additional revenue by reducing the length of outsiges in the 2008 to 2017 time frame by using the recommended new Cut and Weld tooling.

We estimate feeder replacement to be the critical path item for all Pickering A and Darlington outages in the 2008-2017 timeframe. The 3 sets of tools will make the following currently unachievable results possible:

- · Conducting feeder replacement execution at 2 reactor faces in parallel when it is required.
- Completing concurrent training or one face execution at another Nuclear station, if it is required
- Reducing feeder replacement time by using the new and improved tools.

DNGS has indicated the requirement for additional tooling to perform a concurrent 2-face campaign. We estimate that similar conditions can be expected regularly at both PNGSA and DNGS in the 2008-2017 timeframe. Additionally, outage delays are possible, if there is a shortage of tools due to an overlap in feeder replacement campaigns for OPG and Bruce Power stations.

We estimate that, between 2008 and 2017, we can generate additional revenue of approximately \$69.6 Million by using the new tool sets to reduce feeder replacement times and to mitigate the risk of outage delays due to tooling shortages. The NPV of this \$15.8M capital investment is estimated to be \$21M with an IRR of 40.5% and a discounted payback of 4.3 years.

A Full Release is required to make commitments to the supplier that will ensure tool availability by D8-1.

Currently Released	N/A		1		1	1			
Requested Now	Full			4,990	9,289	1,484	+		15,7
uture Funding Regid					·				
Total Project Costs		-	ų	4,500	9,208	1,484	•		15,7
Other Coets									-
Ongoing Costs						1			-
Grand Total		•	-	4,990	8,289	1,484	•		15,7
Vice President			28, 07 Dele:	7.					
Paul Spekkens P. Spekkens Vice President Science & Technolo					wai (Par OAF	3 Element 1.2	Project no	ot in Burtoe	£
	gy Development			Line Appr	00	B.Element 1,2	<u>Protect n</u>	at in Buctoe	f Date:
Paul S P. Spekkene Vice President Science & Technolo Ficence Approval; D. Power	gy Development kment Planning		Dele:	<u>Line Appr</u> Li J. Hankine President I	on L CEO	<u>3 Element 1,2</u> (Supersede			Date:



**OPG** Confidential

BUSINESS CASE SUMMARY

#### 2/ BACKGROUND & ISSUES

The integrity of CANDU primary heat transport piping, which connects the header to the nuclear reactor's fuel channels, referred to as "feeder tubes", has become an issue as a result of two degradation mechanisms; thinning caused by flow accelerated corrosion, and feeder pipe wall cracking, which is believed to be caused by stress related corrosion or low temperature pipe elongation creep. OPG addressed these feeder degradation issues via the Feeder Integrity Project (FIP), which included a number of sub-projects. To address station concerns on feeder thinning, the FIP Cut and Weld sub-project, partnering with a similar team at Bruce Power, managed the development and acquisition of a set of advanced tooling to repair thinned sections of feeder tubing positioned beyond arms reach.

The Advanced Cut and Weld tooling for feeder replacement developed under the original scope (Project #10-33993) has been successfully used during the D611 Outage. Three sets of tooling were obtained, one for face use, one for back-up and a third for training. Following the first use of this one of a kind tooling in the D611 Outage, OPEX identified areas for performance improvements. Additional funding was subsequently released under Project #10-62562 to cover the improvements considered essential for P711 and D721 Outages. However, the existing tooling continues to be limited to feeder replacement at 1 face, 1 station due to the number of tool sets.

Since there has been only one feeder replacement outage, the reliability of the tooling has not been seriously tested, although there have been difficulties in getting some tools out of the station due to contamination. It is highly likely that there'll be attrition loss or contamination of tools as more feeder replacement campaigns are executed. In addition, Darlington has indicated the needs to execute feeder replacement concurrently on the two reactor faces starting in the D811 outage and then on a regular basis until 2017. Pickering A is expected to have the same requirement starting in the P911 outage. Analysis indicates this requirement will add 36 days to Darlington outages and 16 days to PNGS-A outages in the period from 2008 to 2017.

Furthermore, outage delays are possible, if there is a shortage of tools due to an overlap in feeder replacement campaigns for OPG and Bruce Power stations. Outage organizations are trying to maintain a 2-week gap between the outages of different stations (PA, PB and DA); however, there is a reasonable probability that this scheduling will not be maintained. An additional 3 sets of tooling will mitigate the risk of an outage delay due tool shortages.

We estimate that, between 2008 and 2017, we can generate additional revenue of approximately \$69.6 Million by using the new tool sets to reduce feeder replacement times and to mitigate the risk of outage delays due to tooling shortages.

ONTA	RIOPOWER	
	GENERATION	

**OPG** Confidential Page: 4 of 14

**BUSINESS CASE SUMMARY** 

#### 3/ ALTERNATIVES AND ECONOMIC ANALYSIS

\$ Millions	No Project	Full Cost 3 Tools in '08 Bruce 0% No-ROW	Incr Cost 3 Tools in '08 Bruce 0% No-ROW	Training Set '08 3 Tools in '09 Bruce 40% A-ROW incl	3 Tools in '08 Bruce 40% A-ROW Included	1 Tool in 108 Bruce 0% No A-ROW
Revenue OM&A	(69.6).	· ·· ··	·····	(5.0)		(25.0)
Capital		(15.8)	(15.8)	(14.4)	(12.8);	
NPV (after tax)	(32.0)	(11.0)	(11.0)	(12.9)	(9.0)	(10.0)
Impact on Economic Value (IEV)	N/A	21.0	21.0	19.1	23.1	(18.6)
IRR%	N/A	40.5%	40.5%	N/A	<u></u>	<u>13.4</u>
Discounted Payback (Yrs)	N/A	4.3	4.3	N/A	N/A	N/A N/A

We do not recommend this alternative because there is a more economic way to complete feeder replacements by using additional and enhanced Cut and Weld tooling collectively purchased and controlled under the same Cut and Weld agreements we currently have with AECL, B&W, and Bruce Power.

#### Purchase 3 Sets of Tools with NO A-ROW & NO Bruce Participation - Recommended Alternative 1 -

We recommend this alternative because we estimate that, between 2008 and 2017, we can generate additional revenue of approximately \$69.6 Million by using 3 additional and enhanced tool sets to provide tooling capability for concurrent feeder replacement campaigns, and to mitigate the risk of outage delays due to tooling shortages. The NPV of this \$15.8M capital investment is estimated to be \$21M with an IRR of 40.5% and a discounted payback of 4.3 years.

### Alternative 2 - Delay Project - Not Recommended

We do not recommend delaying the recommendation because the opportunity to generate more revenue is greater than the savings that can be derived from a delay.

### Alternative 3 – Upgrade Training Set for D811, 3 Sets with A-ROW / Bruce for '09 - Not Recommended

We do not recommend this alternative because the extra cost of the tools (\$1.6M) when compared the similar alternative (Alt 4) and the lost opportunity to generate more revenue (\$5.0M) make this alternative financially less acceptable (\$1.8M) than the recommendation.

### Alternative 4 – 3 Sets of Tools with A-ROW & Bruce Participation - Not Recommended

We do not recommend at this time as the Bruce Power participation has not been confirmed. If Bruce Power is confirmed at a later date, this alternative will be considered and there'll be an approx. \$3M saving to OPG. The trade off is that Bruce Power will share the tools with OPG, but this was the agreement on the original sets of tools. Exclusive ownership of the additional tools by OPG makes the existing tools more readily available to Bruce Power, resulting in effective sharing of all the tools.

### Alternative 5 – Purchase 1 Set of Tools with A-ROW & Bruce Participation - Not Recommended

We do not recommend this alternative because the lost opportunity to generate additional revenue (\$25M) by using the new tool sets to mitigate the risk outage delays make it financially less acceptable (\$7.6M NPV) than the Recommendation.

ONTARIC	POWER GENERATION
	OF HER WALLOIN

# 4/ THE PROPOSAL

External contractors AECL and B&W will be utilized, in keeping with AGREEMENT No. OPG/BP-01, July 15, 2004. Additional external welding equipment expertise will be utilized to ensure tooling improvements are warranted and proposals are sound. Base organizations will provide 1 FTE plus 1 augmented FTE's to support the assessment, specification, development and purchase of the new tool sets.

The scope of the Improved Cut and Weld Tooling project is as follows:

- a. Assess Needs and Improvement Opportunities. Obtain information from each station to determine the requirements for concurrent 2 face campaigns and risks of overlapping outages. Review OPEX and lessons learned on use of the tooling in Fall 2006 outage at Darlington (D611) and develop recommendations for improvements.
- b. Purchase the additional Tooling. Complete the required documentation for specification and purchase of the required tooling.
- c. Monitor the development and supply of tooling. Provide oversight to ensure tooling development meets the improvement and delivery schedule requirements.



## 5/ QUALITATIVE FACTORS

An increase in tooling efficiency will reduce worker dose uptake and lower risk of injury.



ONTARIOF ON WERE

OPG Confidential

BUSINESS CASE SUMMARY

6/ **RISKS** 

vescription of Risk	Description of Contectuence	Risk Betore Mitigration	Mitigating Activity	Risk After Miticett
Price increase from voodor				
budgetary quote to firm quote Bruce Power does not	Cost overrun	Medium	Obtain updated budgetary quote.	Low
participate		Medium	Early identification of Bruce Power interest through negotiations. They have expressed interest in the option recommended in this BCS and a letter of intent is expected soon.	Low
Discovery issues require	Cost outset in south a feat of			
additional scope		Medium	Increased scope to be addressed using Change Management Process (CPM), PM principles, and/or a superseding BCS	Low
Delayed award of contract	Outane criticel math outants		C.	
affects training and tooling delivery for D811 Outage		HgiH	Increased effort on the BCS process and contract negotiations.	Medium
Resources Lack of exnerion ad				
engineering support resources for this project	Schedule delay	Medium	Plan to use qualified contractor resources. High level of management oversight to track contractor performance.	Low
Technical Technical issues results in		*		
less than satisfactory tooling improvements or new tools	the period can be realized	Medium	Mock-up testing/training to prove tooling effectiveness. High level of management oversight to track contractor performance	Low



Confidential Page: 7 of 14. BUSINESS CASE SUMMARY



# 7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Final AFS	Targeted PIR Approval	PIR Responsibility
	Date:	Date:	(Sponsor Title)
Simplified	Jun 200 <del>9</del>	Dec 2009	Manager, Feeder Integrity Projects

	Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it? (person / group)
1.	Feeder replacement execution on 2 reactor faces in parallel	Work in series between reactor faces.	Work concurrently on 2 reactor faces if required. No project execution delays due to tooling shortage.	OPEX from post outage lessons learned.	Manager, Feeder Integrity Projects
2.	Availability of additional feeder Cut & Weld Tooling for training or execution at another station	Not available	No delays in training or feeder replacement (one face) due to tooling at another station.	OPEX from outages where feeder repacement overlaps at two nuclear stations.	Manager, Feeder Integrity Projects
3.					
4.					· · · · · · · · · · · · · · · · · · ·
5.			 		 

<b>ONTARIO</b>	POWER
	GENERATION

Page: 9 of 14

**BUSINESS CASE SUMMARY** 

Appendix "A"

Glossary (acronyms, codes, technical terms)

technical terms explanation embedded in the BCS



ONTARIO	POWER
	GENERATION

Page: 10 of 14

**BUSINESS CASE SUMMARY** 

Appendix "B"

# **Project Funding History**

Release Type	Month	Year	2007	2008	ulative V 2009	Weight 10 10 10 10 10 10 10 10 10 10 10 10 10	2012 2013 Later	Total
Full	Jun	2,007	4,990	9,289	1,484	4		15,763
				•				0
					·····			0
· · · · · · · · · · · · · · · · · · ·				·· ·				0
			!		····-		1	0
·····		Ì					· · · · · · · · · · · · · · · · · · ·	0
	· · · · · · · · · · · · · · · · · · ·		ا نو بـــــــــــــــــــــــــــــــ					0
	··· ~_ ~	; 						0



ONTARIO	POWER
---------	-------

Appendix "C"

Financial Model – Assumptions

#### **Project Cost Assumptions:**

Tool Cost based on Budgetary Quote from AECL and B&W.

#### Financial Assumptions:

7% WACC

#### Project / Station End of Life Assumptions:

DNGS 2017 PNGS-A 2023 PNGS-B 2014



# Energy Price / Production Assumptions:

49.50 MWH plus 2% starting in 2009

#### **Operating Cost Assumptions:**

Estimated number of outage extension days potentially saved when work on 2 reactor faces in parallel is:

# days	2008	2009	2010	2011	2014	2015	2017
PNGSA		2.5	8.3	5.4			
DNGS	5	3.3		6.3	9.4	5	7.2

#### Other Assumptions:

We are estimating that there is a 10% probability of a \$25M outage extension per year due to a tool shortage from conflicting outages among Pick A, B, Darlington and Bruce Power stations in the years 2008 -2017



ONTARIOPOWER GENERATION

OPG Confidential

Page: 12 of 14

**BUSINESS CASE SUMMARY** 

# Additional Feeder Cut and Weld Tooling 10 - 62567

# Full Release Business Case Summary N-BCS-30320-10003-R000

Attachment "A"

1

# **Project Cost Summary**

\$000's LTD Prior Yr Gapital 2007	This Release 2007	Future : Fielease 2008	2009	2010	2011				
Project Management (OPG)	10	180	90		EVIL	2012	Later	Total	<u>88</u>
Engineering & Drafting (OPG)	20	270	140		; 		i	284	****
Material							1	430	
Installation - PWU, BTU					105-1013	50005000	Contractor	Call Party Come	ľ
Contract - Design						infinitegr			
Contract - Installation									
Contract - Other									
Interest (Capital Project Only) Project Costs (acc) contingency) General Contingency Specific Contingency Project Costs ( frei contingency) 2007-2011 Business Plan Vaciance to Business Plan Committed Cost	4,990 4,530	9,289 8,469	1,484	· ·	-	-	-	15,764	1 1 10000 F 1 10000 F 1
								-	8
Inventory Write Off Required Spare Parts / Inventory				(i)				•	•
								•	
	- 4,000	• 3,980	9,84	•	-	•	*	15,764	
Origoing DM&A then-project) Removal Costs (Inci in above)									

esign Complete		N/A	Quality of E	Estimate	Release + 1	5% to = 10%
3 rd Party Estimate	<u>No</u>	OPEX used	Yes	Lessons Lea		· · · · · · · · · · · · · · · · · · ·
Reviewed by Sponsor	Yes	Budgetary Quote(s)	Yes	Phase 1 Act		Yes
Similar Projects	Yes	Contracts in place	No	Competitive		No No

The estimated variance(s) to the 2007-2011 Business Plan will be address of through the portfolio management process. A PCRAF is not required

Reviewed By Jim: 27, 200 1111 27 DOO 7 I. Xiao K. Garel Project Manager Date: Eng & Mods Manager (Strat IV) Date:



# Additional Feeder Cut and Weld Tooling 10 - 62567

# Full Release Business Case Summary N-BCS-30320-00000-R000

#### Attachment "B"

TANK REPORT OF THE PARTY

# **Project Variance Analysis**

	LTU N/A N/A	Choose One Last BCS This BCS N/A N/A N/A N/A	Variance	Comments
Project Management (OPG)		IVA IVA	0	
Engineering & Drafting (OPG)			0	
Material			í U	······································
Installation - PWU, BTU	Ĩ			
Contract - Design	1 1-10		Science 1	
Contract - Installation		Contraction of the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second seco	1	
Contract - Other	-			
		THE RESERVED FOR THE RESERVED	- (v =	
nterest (Capital Project Only)			ALC: NO	
Project Costs (excl contingency)	2			
General Contingency		The second of the second period period of the second period period of the second period		
Specific Contingency	-	and the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second se	had and a second	bude bot a strength of the
Project Costs ( Incl contingency)	0	0 0		
Committed Cost	u	0 0	0	
wentory Write Off Required			0	
pare Parts / Inventory		······································	0	
otal Release (incl contingency)		CTOTO De la companya de la companya de la companya de la companya de la companya de la companya de la companya	0	· · · · · · · · · · · · · · · · · · ·
otal Release (exci contingency)	0	0 0	0	
orant free and react containing and yr	0	0 0	0	
Incolas OUS S		2.7/11/2011/01/01/01		
Ingoing OM&A (non-project)			0	
emoval Costs (incl in above)			0	



ONTARIOPO ER GENERATION

**OPG** Confidential

Page: 14 of 14

**BUSINESS CASE SUMMARY** 

Attachment "C"

# Key Milestones

Completion Date		Oate	
Day	Mth	Yr	Description
29	May	2006	Project Charter (PCH) issued for use - Complete
08	Jul	2007	Full release Business Case Summary (BCS) issued
15	Jul	2007	Tooling Purchase Contract Awarded
15	Jan	2008	D811 Priority Tooling Mock-up Testing Complete
15	Feb	2008	D811 Tools & Equipment On-site
01	Oct	2008	Main Tooling Mock-up Testing Complete
15	Dec	2008	Main Tooling Package complete
15	Jun	2009	Project Close-out complete
	······································		

A Project Execution Plan (PEP) is not required

# Comments:

Primary scope (development and supply of tooling) of the project will be performed by the contractors which will be retained through the contracting process. Only resources required from OPG will be project management which is well defined. A PEP is not required.



and the second second second second second second second second second second second second second second second

ONTARIOPOWER GENERATION



**BUSINESS CASE SUMMARY** 

# Phase II Fire Protection Project 16 - 79016

# Superseding Business Case D-BCS-78000-10003-R000

Routing	Location	Action	Signature	Date
S. Bagshaw Project Leader, Design Projects 703-3554	BW702	Prepare BCS	1. Re-	- 04-Jul-07
T. Cvitkovic Project Manager, Design Projects 703-3571	BW702	Review BCS	Tyat	4-July 20
J. Taras Section Manager, PMO 703-3528	BW702	Review BCS	3. Taro	9. July 200
T. Chong Manager, Design Projects 703-3520	BW702	Review BCS	In Oly	12/1/100
J. Shemilt Manager, Projects Design, Darlington 703-1963	D08-ES3	Review BCS	Shemily	2007/7/13
J. Lehman Manager, Performance Eng., Darlington 703-7325	D08-ES2	Review BCS	Selma	18/07/07
A. Kleer Financial Analyst, Nuclear Finance 0-7720	P82-3A5	Review BCS	heller	25/07
M. Arnone Director, Projects & Modifications 701-6063	P72-2	Review BCS	Ple	26 July 2007-
R. Leavitt Director, Investment Management Nuclear 702-5085	P823-315	Review BCS	Flewort	Aug 1, 2007
S. Seedhouse Director, Station Engineering, Darlington 703-7584	D08-ESS3P	Review BCS	APL+	4009/07
W. Robbins Senior Vice President, Darlington Nuclear 703-7499	D08-ES3	Submit BCS	Jaynerablio	2.07-08-15
D. Power Vice President, Corp Investment Planning 400-7172	H07-D06	Review BCS		2. A. 2.5 ( )
J. Beech Vice President, Nuclear Finance 400-7226	H07-E19	Approve BCS		C. 1 27/8 1
T. Mitchell Chief Nuclear Officer 702-5294	P82-6A1	Approve BCS	muhlu	co/10/17
Ball Mor Financial Analyst 02-4084	P82-3B6	Return For Distribution		

ONTARIOPOWER GENERATION

#### **BUSINESS CASE SUMMARY**

# Darlington Phase II Fire Protection Project 16 - 79016

# Superseding Business Case D-BCS-78000-10003-R000

#### **RECOMMENDATION:** 1/

\$ 19.058 Million, including all Copital costs. \$ 185 k

will be written off to only.A Approval is requested for this Superseding release for 18.873M& Capital, to:

- Remove Turbine-Generator Dyking from scope as it has been deemed unnecessary by engineering as church review, and which would drive costs further beyond the previously released amount for this project, aclow.
- Write-off the costs incurred against the scope of work for removal (\$185K), and
- Approval for an over-variance to release of \$127K (including contingency), to complete close-out of this Capital project Capital project,

The business objectives of the Darlington Phase II Fire Protection Project were as follows:

- 1. Install Turbine-Generator Fire Suppression Upgrades (REGC).
- 2. Install Fire Detection Upgrades in the Main Control Room & associated areas (REGC).
- 3. Construct an Emergency Response Team (ERT) Facility (CNO Commitment).
- 4. Install Containment Dyking around each Turbine-Generator set.

The project is now 98% complete. The REGC and CNO commitments were met in 2002. All work on the Detection Upgrades and the ERT Facility is complete, including ECC closeout. With T-G Dyking removed from scope, the outstanding work for this project includes:

- Available For Service (AFS) activities and ECC closeout for the Suppression Upgrades,
- Project Closeout activities, including Post-Implementation Review. •

Recommended for scope removal is the Turbine-Generator Oil Containment Dyking modification. An engineering assessment concluded that the intent of containment dykes (to prevent the spread of burning lube oil) is already et. Removal of this work from scope will mitigate the need for an additional \$500K funding. To date, \$185K has

en spent in the design phase for this modification and this money should be written off to OM&A.

The cost over-variance for this project is attributed to the following:

- Discovery work & additional scope for the fire suppression upgrades: install new pressure relief devices . and reroute piping due to equipment interferences.
- Rework to change the ERT Facility modification from a Commercial Mod (CMOD) to a combination • Permanent Mod (PMOD) and Facility Mod (FMOD).

000's (incl contingency)	Funding	LTD 2005	2006	2007	2008	2009	2010	Later	Total
Currently Released	Superseding	18,412	306	28		······································	, da 2 a - 2 a - 2 a - 2 a - 2 a - 2 a - 2 a - 2 a - 2 a - 2 a - 2 a - 2 a - 2 a - 2 a - 2 a - 2 a - 2 a - 2 a	·····	18,746
Requested Now	Superseding	1		258	54				312
Future Funding Req'd		ţ-			1				•
Total Project Costs		18,412	306	286	54	+	•	•	19,058
Other Costs	Write Off			(185)				1	(185
Ongoing Costs			····						•
Grand Total		18,412	306	101	54	-	•		18,873

Submitted By:

Roblins de07-08-15 Date: Name, W. Robbins

Title:Senior Vice President - Darlington Nuclear

Finance Approval:

St27 -> Date:

Name: J/ Béech fitle: Vice President - Nuclear Finance Name: T. Mitchell

Line Approval (Per OAR Element 1.4 Variance)

Muhler 10/10/2007

Title: Chief Nuclear Officer

Date



## **BACKGROUND & ISSUES**

The Superseding Business Case Summary for this project. D-BCS-78000-10002 R000, was approved on September 12, 2002 for \$18.7M, including contingency. The project scope is as follows:

- Install a Turbine-Generator Fire Suppression System. This was a CNSC Regulatory Commitment, AR #28023793.
- Install a containment barrier around each Turbine-Generator set to control the flow of potentially burning lube oil and fire water. This modification is per a requirement in OPG Standard N-STM-78200-10000-R01, Fire Protection for Turbine Generator Areas
- 3) Install Fire Detection upgrades in the MCR, CER & associated areas. This was a CNSC Regulatory Commitment, AR #28023789.
- 4) Construct an Emergency Response Team (ERT) Facility. This was a CNO commitment.

#### Current Status:

- The REGC and CNO commitments were met in 2002.
- All Fire Detection Upgrades (item 3 above) are complete. The modification has been closed and there are
  no open items.
- The ERT Facility (item 4 above) is complete. The modification has been closed and there are no open items.
- The T-G Fire Suppression System installation (item 1 above), to meet the REGC is complete and Final AFS was obtained. However, during the Post-AFS period, the following issues were identified:
  - 1) Lack of required pressure relief capability in the suppression system (SCR D-2004-08302)
  - 2) Piping interference with adjacent equipment, preventing maintenance activities from being performed (SCR D-2004-05603)

As a result, the Final AFS was changed to a Partial AFS, to allow for resolution of these issues. This did not affect meeting the REGC. The field work to resolve these issues is complete, and Final AFS is pending.

The need for T-G Dyking (item 2 above) has been challenged. An engineering assessment has been
performed (see NK38-REP-78000-10004), concluding that the intent of containment dykes, to control the
spread of burning lube oil and fire water, is already met via the physical layout of the station, and fire
suppression capability in place. Removal of this work from scope will mitigate the need for an additional
\$500K funding.

#### **Over-Variance Contributors:**

ERT Facility

The ERT Facility was originally constructed as a commercial modification (CMOD). However, this was not accepted at the time of turn over (reference SCR-D-2003-02188). To obtain final acceptance, the CMOD was converted to a combination of facility modification (FMOD) and permanent modification (PMOD) (reference NK38-REP-28600-10002). The re-engineering to do this conversion, the cost for building maintenance until Final AFS, and the resulting impact on the project schedule, contributed to the over-variance for this project. Final AFS has been obtained and all work with the ERT Facility has been completed. There are no open items & it has been closed out.

 <u>T-G Suppression Pressure Relief & Piping Interference Issues</u> Resolution of the two T-G Suppression issues required DCP revision, re-design, additional field work, troubleshooting, AFS activities, and an overall extension to the project schedule.





Page: 4 of 14

BUSINESS CASE SUMMARY

## 3/ ALTERNATIVES AND ECONOMIC ANALYSIS

	1	Alt 1 (Reco	ommended)	Alt 2	Alt 3	Alt 4	Alt 5
\$ 000's	Status Quo	Full Cost	Incremental Cost	Delay	Do Lesa	Do More	NA
Revenue		•	-	-	•	-	
OM&A		-	-	· ·	•	-	
Capital	19,538	19,038	(500)		N/A	N/A	
NPV (after tax)	*******	, ,,,,				,, , , ,	
Impact on Economic Value (IEV)	N/A				• • • • • • • • • • • • • • • • • • • •		
IRR%	N/A		······································				
Discounted Payback (Yrs)	N/A	······································					

#### Status Quo - Not Recommended

The status quo for this project would include installation of T-G Dyking and would cost approximately \$500K in addition to the current over-variance requested. A recent engineering review demonstrated that the intent of T-G Dyking is already met through existing suppression & the physical layout of the station. This is a Non-Value-Enhancing project, and significant effort has been put forth to reduce scope where possible. The Regulatory and Management commitments have been met. This option is not recommended.

#### Alternative 1 - Complete AFS and Close-Out - Recommended

The project is now 98% complete. It is recommended that T-G Dyking be removed from scope, and proceed with AFS & closeout activities for the remainder of the project. This requires an over-variance to release approval of \$127K (less than 1% increase on the current release of \$18.746M). To date, \$185K has been spent in the design phase for T-G Dyking and this money should be written off to OM&A.

#### Alternative 2 - Delay Project - Not Recommended

Delaying is not recommended as this project is in the Closeout Phase and closeout activities must continue per ECC governance. Delaying the installation of T-G Dykes only is also not recommended as it is a non-value-enhancing modification that has been deemed redundant through engineering review.

#### Alternative 3 – Do Less - Not Recommended

With T-G Dyking removed from scope, there are no further opportunities to do less as the remaining scope is either in closeout phase, or already closed out.

#### Alternative 4 - Do More - Not Recommended

This is a Non-Value-Enhancing project, and significant effort has been put forth to reduce scope where possible. The Regulatory and Management commitments have been met.

#### Alternative 5 - N/A - Not Recommended



Page: 5 of 14

#### **BUSINESS CASE SUMMARY**

# 4/ THE PROPOSAL

- 1) Remove T-G Dyking from the scope of this project
- 2) Write-off \$185K to OM&A; the costs incurred to date for the T-G Dyke design
- 3) Approve \$127K over-variance to release for the completion of this project. Specifically:
  - AFS activities for T-G Sprinkler mods
  - Closeout activities for T-G Sprinkler mods
  - Project Closeout activities

# 5/ QUALITATIVE FACTORS

The drivers for these modifications were Regulatory & CNO Commitments aimed at improving the level of personnel and asset protection from fire. At the current stage for this project, Closeout, the qualitative factor for continuing is compliance with ECC governance.





ONTARIOPOWERS GENERATION

**OPG Confidential** 

6 of 14

Page:

BUSINESS CASE SUMMARY

# 6/ RISKS

1

Description of Risk	Description of Consequence	Risk Before Mitigation	Activity	Risk After Mitigation
Cost				
Risk of cost increase is low as the project is in Final AFS & Closeout. Cost to complete is well defined.	A/A	Low	N/A	Low
Scope (1) (1) (1) (1) (1) (1) (1) (1) (1) (1)				
Risk of new scope being added to the project is low as the project is in Final AFS & Closeout. All additional scope items were identified at previous AFS	A/A	Low	MA	Low
T-G Dyking not removed from scope.	Project will incur approximate additional \$500K in cost and schedule extension	Medium	Engineering evaluation performed to show T-G Dyking not required. Approval of this BCS will reduce the risk to tow.	Low
Station does not accept state of passing RVs in field	Maintenance work required to fix or replace RVs prior to AFS.	Medium	Independent Third Party Review obtained states passing RV is code compliant. Field walkdowns with station representatives to obtain acceptance.	Low
Maintenance work required to fix or replace RV's prior to AFS.	Missed AFS milestone	Medium	Independent Third Party Review obtained states passing RV is code compliant. Field walkdowns with station representatives to obtain acceptance.	Low
Resources				
Insufficient Design resources to complete closeout.	Missed Closeout milestone and ECC Action Tracking Assignments	Medium	Commitments have been obtained from Design and Drawing Office to complete outstanding work	Low



------

1

OPG Confidentia

Page: 7 of 14



# BUSINESS CASE SUMMARY



# 7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Final AFS	Targeted PIR Approval	PIR Responsibility
	Date:	Date:	(Sponsor Title)
Simplified	Aug 2007	Mar 2008	Manager, Performance Engineering

	Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it? (person / group)
1.	Project Objectives have been met			Review of Charter, PEP, BCS's	Manager, Performance Engineering
2.		· · · · · · · · · · · · · · · · · · ·	     		
3.		· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·		
1.	//////////////////////////////////////	· · · · · · · · · · · · · · · · · · ·	· · · ·		, , , , , , , , , , , , , , , , , , ,
5.	· · · · · · · · · · · · · · · · · · ·		· · · · · · · · · · · · · · · · · · ·		· · · · · · · · · · · · · · · · · · ·

ONTARIOPOWER GENERATION OPG Confidential

Page: 9 of 14

BUSINESS CASE SUMMARY

## Appendix "A"

# Glossary (acronyms, codes, technical terms)

AFS – Available For Service CER – Control Equipment Room

- CNO Chief Nuclear Officer
- ECC Engineering Change Control
- ERT Emergency Response Team
- MCR Main Control Room
- REGC Regulatory Commitment
- SCR Station Condition Record
- T-G Turbine-Generator



Page: 10 of 14

**BUSINESS CASE SUMMARY** 

And the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division

# Appendix "B"

# **Project Funding History**

\$ 000's		IIA,	Existing a		ed Relea		continger	ncy)			
Release Type	Month	Year	2006	2007	2008	2009	2010	2011	2012	Later	Total
Full	Aug	2002	18,718	28			,				18,746
Superseding	Jun	2007	18,718	101	54				1	÷	18,873
							1		*	**************************************	0
			, ,						1		0
					:					·	0
					1				++, 、 , , , , :	• · · · · · · · · · · · ·	0
			······································				· · · · · · · · · · · · ·		••••••••••••••••••••••••••••••••••••••		0
					1						0

LTD Spent May 2007 18,737			18,737
	e e e e e e e e e e e e e e e e e e e	· · · · · · · · · · · · · · · · · · ·	



ONTARIO	<b>POWER</b> GENERATION
---------	----------------------------

**OPG** Confidential Page:

11 of 14

BUSINESS CASE SUMMARY

Appendix "C"

# Financial Model – Assumptions

# **Project Cost Assumptions:**

T-G Dyking will be removed from the scope of this project ٠

#### **Financial Assumptions:**

N/A

# Project / Station End of Life Assumptions:

N/A

# Energy Price / Production Assumptions:

N/A

# **Operating Cost Assumptions:**

N/A

**Other Assumptions:** 



Page: 12 of 14

**BUSINESS CASE SUMMARY** 

# Phase II Fire Protection Project 16 - 79016

# Superseding Business Case D-BCS-78000-10003-R000

#### Attachment "A"

#### Project Cost Summary

Choose One Choose One	LTD Prior Yr 2006	This Release 2007	This Release 2008	This Release 2009				Later	Total
Project Management (OPG)	2,347	148	42	-		}		·····	2,537
Engineering & Drafting (OPG)	1,309	48	5	-	: 	1			1,362
Material									
Installation - PWU, BTU	Î								
Contract - Design						- 16.		10 H	
Contract - Installation									
Contract - Other			A MARINE AND	1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1	And while provided				
					in all the second				
						A	-		
Interest (Capital Project Only)									
Project Costs (excl contingency)									
General Contingency									
Specific Contingency									5
Project Costs ( incl contingency)	18,718	286	54					, <b>, , , , , , , , , , , , , , , , , , </b>	19,058
2007-2011 Business Plan	18,718	33	-	-	!				18,751
Variance to Business Plan		216	47						263
Committed Cost	1	. –		-					-
Inventory Write Off Required		(185)	· -	-					(185
Spare Parts / Inventory		-	-	-				1	÷ +
Total Release (excl contingency)	18,718	64	47	E Sector				T	18,829
Total Release (incl contingency)	18,718	101	54						18,873
Ongoing OM&A (non-project)		1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1							
Removal Costs (incl in above)				2					

Design Complete		100%	Quality of E	stimate	Release + 1	5% to - 10%
3 rd Party Estimate	N/A	OPEX used	Yes	Lessons L	earned	Yes
Reviewed by Sponsor	Yes	Budgetary Quote(s)	Yes	Phase 1 A	ctual Used	N/A
Similar Projects	Yes	Contracts in place	N/A	Competitiv	e Bid	N/A

Variance to Business Plan

The estimated variance(s) to the 2007-2011 Business Plan will be addressed through the portfolio management process. A PCRAF will be approved by Jul 2007.

Reviewed By: Tom Ouitkovic Date: **Project Manager** 

Approved By: Terry Chong Date Eng & Mods Manager (Strat V)



Page: 13 of 14

BUSINESS CASE SUMMARY

# Project Name 16 - 79016

# Superseding Business Case D-BCS-78000-10003-R000

Attachment "B"		Project	Variance	Analysi	<u>s</u>
		Full R	elease	and the second	
Capital	LTD May 2007	Last BCS	This BCS Jun 2007	Variance	Comments
Project Management (OPG)	2,350	1559	2537	978	And the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second
Engineering & Drafting (OPG)	1309	1855	1362	-493	······································
Material				400	
Installation – PWU, BTU		Part of the second second			
Contract - Design					
Contract - Installation					
Contract - Other	-		a for a state of the	2	
Interest (Capital Project Only)					
Project Costs (excl contingency)					
General Contingency	TG				
Specific Contingency					
Project Costs ( Incl contingency)	18737	18747	19058	311	
nitted Cost	······	····	0	0	
tory Write Off Required		••••••••••••••••••••••••••••••••••••••	-185	-185	Write Off T/C Dubing Deals
Spare Parts / Inventory			0	0	Write-Off T/G Dyking Design
Total Release (incl contingency)	18737	18747	18873	126	the second second second second second second second second second second second second second second second s
Total Release (excl contingency)	18737	17778	18829	1051	
Ongoing OM&A (non-project)	and the server			0	
	the second second second second second second second second second second second second second second second se	and the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second se			
Removal Costs (incl in above)			2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.2.	0	



Page: 14 of 14

**BUSINESS CASE SUMMARY** 

- Catting and

Attachment "C"

# Key Milestones

Co	mpletion	Date	Description
Day	Mth	Yr	
10	Aug	2007	RV Installation AFS
10	Jul	2008	Project Closeout
		-	
		- <u> </u>	
		+	
	1		
	+		
			/

A Project Execution Plan (PEP) was approved in May 1999 \$ 07-04-07



ONTARIO GENERATION

Page: 1 of 19

BUSINESS CASE SUMMARY

# Pickering 'B' Chemistry Standards 13 - 79147

# Superseding Business Case NK30-BCS-64510-00002-R000

Routing	Location	Action	Signature	Data
Joseph Ramani Project Engineer Design Projects 701-8205	P72-3	Prepare BCS	Jusiph Ramon	2014-03-26
Aman Shah CSA Design Projects 701-3889	P72-3	Prepare BCS		2007-03-26
Jeff Phillips Project Leader II Design Projects 701-3567	P72-3	Review BCS	9. Milli	2007-03-27
Vince Tzambazis Section Manager Design Projects 701-2520	P72-3	Review BCS	Juice Termisio	2007-03-28
Sepehr Ghorashi Section Manager (Acting) PMO 701-3062	P72-3	Review BCS	The the	2007.03.27
Randy Ludlow Manager Design Projects 701-8055	P72-3	Review BCS	RyLl	2001.3.29
Elio Fracalanza nager Chemistry 1-2126	P05 A2	Review BCS	and here	1. 14/07
anoor Bhaloo Aanager Performance Engineering 01-3562	P41-E3	Review BCS	Balac	Amiston
Bob Goodman Director Station Engineering 701-7078	P41-E3	Review BCS	Down	Ay 1/3
fark Arnone Director Projects & Modifications 01-6063	P72-1	Review BCS-	24	16 APRIL 2007-
R. Ball Senior Financial Analyst 02-4084	P82-3	Review BCS	CT2	17 an 07
		The second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second	RECEIV	hanter of the c
			MAR 2 2 . 387	
			eler ig	
Ball nior Financial Analyst 2-4084	P82-3B6	Return For Distribution		

ONTARIO GENERATION

BUSINESS CASE SUMMARY

# Pickering 'B' Chemistry Standards 13 - 79147

# Superseding Business Case NK30-BCS-64510-00002-R000

Routing	Location	Action	Signature	Date
R. Leavitt Director Investment Management 701-7078	P82-3	Review BCS	RALeasit-	April 19 607
P. Tremblay S.V.P. Pickering B 701-3501	P41-E3		Etables	April 20 /e
J. Beech V.P. Nuclear Finance 400-7026	H7-E19	Review BCS	12/05	1/2. 125/07
T. Mitchell Chief Nuclear Officer 702-5294	P82-6	Review BCS	primitilized	SUMPEOT
D. Power V.P. Corporate Investment Planning 400-7172	H7-D06	Approve BCS	A	May 7/07
P. Charlebois Chief Operating Officer 400-8470	H19-E21	Review BCS	the	
J. Hankinson President & C.E.O. 20-2121	H19-A24	Approve BCS	Mithikan	21/5
	-			······
	! 			· · · · · · · · · · · · · · · · · · ·
R. Ball Anior Financial Analyst 2-4084	P82-3B6	Return For Distribution		

Page: 3 of 19

BUSINESS CASE SUMMARY

# Pickering 'B' Chemistry Standards 13 - 79147

# Superseding Business Case NK30-BCS-64510-00002-R000

#### 1/ RECOMMENDATION:

ONTARIOPOWER

GENERATION

We recommend a superseding release to reduce the scope for this wide ranging project (8 modifications). However, we are recommending no change in the currently approved release of \$18.4M, as the scope reduction is offset by the issues summarized below.

The business objective of this old IIP project is to standardize and improve station Chemistry Control in order to enhance performance and increase the life of critical station equipment including pressure tubes, feeder tubes, boiler tubes, heavy water upgrader, moderator equipment and stator windings. Completion of this project is important to address several performance, safety, environmental, and reliability issues with modifications that will reduce work and lower costs. (See

In August 2004, the Board of Directors approved a total project cost of \$16.8M to complete seven (7) modifications designed to meet the Business Objectives of the project. Later in April 2005, funding was adjusted to \$18.4M to accommodate an eight modification, a CEM Environmental Software Module. In December 2006, the D₂0 Upgrader Feed Purification Modification was cancelled, triggering a \$1.0M write off of sunk costs to OM&A. At this time, four modifications are complete, Life to Date expenditures are \$15.0M (after write off), and \$3.4M is required to complete the project (see background for details).

The Variance details are as follows:

1	Rework is required to fix problems encountered during the commissioning of two modifications - Plugged strainers on the Boiler Water & Steam Sampling modification (\$1.0M) - Flow control problems on the Hydrogen Addition system (\$0.9M)	+\$1.9M
	Several issues were encountered during installation - Discovery issues with degrading interfacing equipment - Delays and mitigating activities resulting from late delivery of materials - Additional shift coverage and overtime resulting from shortened outage schedules - Increased Field Engineering due to changes in work processes such as Pressure Boundary	+\$1.5M

- 3 The D₂0 Upgrader Feed Purification Modification was removed from the project scope because the -\$2.0M installation could not be justified unless Pickering B's life is extended. Sunk costs totaling \$1.0M were written off to OM&A (Dec 06). Approved funding needs to be reduced by \$2.0M to reflect the new scope.
- 4 The risk associated with completing this project has dropped considerably as all but one of the modifications -\$1.4M is fully installed or designed. The contingency has been reduced to reflect the remaining risk.

Currently Released	Funding	the static	enni.	<b>CUUO</b> / / /	2008	2009	2010	Later Total
· _ · · · · · · · · · · · · · · · · · ·	Superseding	16,726	1,684			and a second second second second second second second second second second second second second second second	and a start and a start and a start and a start a start a start a start a start a start a start a start a start	24 Martin Martin and State
Requested Now	Superseding	(1,907)	398	1,510	<u></u> .		···· · · · · · · · · · · · · · · · · ·	18,410
-uture Funding Reg'd	None		000	·····				
Total Project Costs	· · · · · ·	14.819			<u>t</u> .,			-
Other Costs	• • • • • • • • • • • • • • • • • • •	14,019	2,082	1,510	······································	•		18.410
Grand Total		14.819	0.000	· · · · · · · · · · · · · · · · · · ·				
Investment T	- TORRE CROCK	Clas	2,082	1,510	Es Value			18.410

Submitted By:

-----

Reviewed by:

T. Mitchell Chief Nuclear Officer

------

Dater

Jen. P. Charlebois EVP & Chief Operating Officer

Date:

Date:

Hay 22107

inance App o Power . Pulnvestment & Business Planning LUICOAATS

Line Approval (Per OAR Element 1.4 Variance):

F. WAGN J. Hankinson President & C E.O.

# ONTARIO GENERATION

QPG Confidential	
------------------	--

Page: 4 of 19

BUSINESS CASE SUMMARY

#### BACKGROUND & ISSUES

Plant chemistry control is an essential element in the production of nuclear power. An effective Chemistry Program is required to achieve excellence in the Nuclear Power Industry. This project is a one time incremental effort designed to standardize and improve station chemistry control.

The Independent Integrated Performance Assessment (IIPA) identified that the general lack of chemistry standards at Ontario Power Generation Nuclear plants was a direct contributor to poor plant chemistry control, which in turn contributed to poor operational performance as well as equipment degradation. The IIPA found examples of specifications not being adequately addressed in the station chemistry control manuals, specification being chronically exceeded and chemistry excursions not reported. The chemical specifications had been written with the objective of minimizing the degradation of materials to prevent the premature end of the plant or its specific components. The general lack of the application of chemistry standards at OPG facilities was a direct contributor to poor plant chemistry control, which in turn contributed to poor operational performance.

The objective of this project is to implement the capital modifications necessary for compliance with the standardized chemistry program. Under this project we planned to implement the following seven modifications and develop CEM Environmental Software. The D₂O Upgrader Feed Purification modification was subsequently removed from the scope of the project since the business drivers do not justify proceeding with this modification at this time.

	Previous Release			90%s	This Request					Charles and the set
				LTD		Cost to C		I.		Statue
Modification	Est Cost	Conting ency	Total	Costs (End Jan. 07)	Write Off (Dec 06)	Installation & Rework	Conting ency	Total	Funding Required	
1 D20 Upgrader Feed Purification	2,034	931	2,965	1,000	(1,000)				(2.065)	cancelled
2 He Cover Gas Sampling	2,535	313	2,848	3,609	(1	795	179	4,583		
3 Boiler Water & Steam Sampling	4.485	358	4,843	5,102		989	1/3			3 units complete
4 HTS Hydrogen Control	1,879	503	2,382	1,423	······	303 879	264	6,238	1,395	rework
5 Isolation Valve to HTS IX Column		163	1.666	868		0/5	204	2,566		rework
6 Feedtrain Shutdown Chemistry	583		583	604				868	- Internet and the second second second second second second second second second second second second second s	complete
7 ICP Spectrometer	255		255					604		complete
CEM Environmental Software				283				283	28	complete
	1,638		1,638	1,638				1,638	-	complete
Sub Total	14,912	2,268	17,180	14,527	(1,000)	2,663	590	16,780	(400)	a de Cymers
Interest	1,230		1.230	1,441		189		1.630	400	
Grand Total	16,142	2,268	18,410	15,968	(1,000)	2,852	590	18,410	UUT	

# J ALTERNATIVES AND ECONOMIC ANALYSIS

	Stop the	Alt1 (Re	commended)	Alt 2	ANG ANG ANG
000°s	Project	Full	Incremental	Delay	
Revenue	jejski serski sersk N	Cost	Cost	1 year	
OM&A	(769)	(1,000)	0	. 0	the state of the state of the state of the state
Capital	600	(18,410)	(3,447)	(4 114)	
NPV (after tax)	(349)	(15,525)	(2.623)	(2.941)	· · · · · · · · · · · · · · · · · · ·
mpact on Economic Value (IEV)	N/A	(15.176)	(2,274)	(2,592)	······································
RR%	<u>N/A</u>	N/A	N/A	N/A	······································
Discounted Payback (Yrs)	N/A	N/A	N A	N/A	

# Stop the Project - Not Recommended

We do not recommend stopping this project because:

- The business objective of the project will not be met
- Several safety and environmental issues will not be addressed
- Cost saving opportunities will be lost
- The units will be configured differently
- The Boiler Steam and Water Sampling system cannot be fully placed in service as rework is required
- The HTS Hydrogen Control System is not fully meeting its design requirements
- Capital write offs to OM&A would be approximately \$0.6M

# Alternative 1 - Complete all Mods (except D20 Upgrader Feed Purification) - Recommended

We recommend completion of the following modifications at a remaining cost of \$3.4M (including contingency) to complete the project:

- He Cover Gas Sampling System
- Boiler Steam & Water Sampling System
- HTS Hydrogen Control System

# He Cover Gas Sampling System - Unit 5

Completion of Unit 5 will:

- improve reliability of moderator cover gas sampling and reduce the potential of an undetected explosive mixture
- add capability of on-line PHT cover gas sampling and reduce the potential of an undetected explosive mixture
- reduce risk of outage extension due to GC unavailability during unit start-up
- reduce control maintenance resources required to maintain the gas chromatograph
- complete the modification on the fourth and final Pick-B unit and provide constant configuration among the units



Page: 6 of 19

自动台口语台中心体出在一部合体增大的学

# Joiler Steam & Water Sampling System (All Units)

Completion of the rework required to resolve the plugging of newly installed strainers will enable heat exchangers to be placed in service and provide constant sample temperature. This will:

- improve accuracy of results which allows optimization of chemical addition rates in order to prolong the life
  of the feedwater equipment and boiler tubes; and also to prevent unnecessary discharges of excessive
  chemicals to the environment
- improve accuracy of Chemistry WANO Index
- eliminate Chem Tech resources to recalibrate for temperature changes (up to 6 hr per shift during fluctuating temperatures)
- eliminate action levels based on inaccurate results (example: erroneous high oxygen level could lead to isolation of condenser water boxes and associated unit derating)

# HTS Hydrogen Control System (All Units)

Completion of the rework on all units to correct flow control at low rates will:

- minimize excursions of high dissolved H₂ in the PHT system resulting in a potentially explosive mixture and increased rates of hydrogen absorption and hydrogen embrittlement.
- minimize excursions of low dissolved H₂ in the PHT system resulting in increased corrosion rates and potential shutdown limits.
- minimize Chemical Technician resources to take additional samples (1 hour/shift)
- minimize dose as the current sample point is in the RB
- enable injection via dual headers per design
- minimize potential to delay Unit start-up if the system is out of specification
- minimize Operator resources to purge excess hydrogen from the PHT
- optimize consumption of Hydrogen and Helium gases
- eliminate cost of maintaining metering valves (\$60k every five years)

# Alternative 2 - Delay Project - Not Recommended

We do not recommend delaying the project because it will increase the cost and delay the benefits. The project team is in place, the preferred contractor has been engaged and the work is scheduled in upcoming outages. This project has already been postponed several times and the work to complete (\$3.4M) is for the most part, rework required to commission modifications.

# Alternative 3 – Complete Original Project Scope - Not Recommended

We do not recommend completing the original project scope. The installation of the  $D_20$  Upgrader Feed Purification system cannot be justified unless the life of Pickering 'B' is extended. It has been removed from the project scope with confirmation from the Project Sponsor). This modification can be re-evaluated as part of a life extension initiative. Sunk costs of \$1.0M were written off to OM&A in 2006.

# D₂0 Upgrader Feed Purification (written off in 2006)

The business driver for this modification was to reduce the rate of deterioration of the upgrader packing by installing the UV oxidation unit currently owned by OPG (purchased outside this project). Reducing the rate of deterioration may have:

- reduced the number of drums stored on site which reduces the risk of drum leaks, environmental spills, and dose to workers
- prevented the cost associated with external assistance in processing drums of water contaminated with organics
- reduced the loss of upgrader capacity as a result of plugging (1 month outage per 7 years for each of 2

ONTARIOPOWER	OPG Confidential	Page: 7 of 19
GENERATION	BUSINESS CASE	2112835 8 10 %
State and an and the second of the second of the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second se		2000 Past

upgraders)

- prevented the cost associated with cleaning the upgrader packing in each of the two upgraders
- reduced the cost associated with charcoal consumption and disposal currently required to removed organics from upgrader feed
- allowed the upgrader feed specification (Total Organic Carbon less than 1 ppm) to be met which is one of the outstanding requirements to improve the upgrader System Health Window from Yellow to White

A decision to write off the sunk costs of \$1.0M was made in 2006 because at the current rate of deterioration, the upgrading capacity will remain above station needs until well past the current life of Pickering B. Alternate solutions are being investigated to reduce drum inventory. The cost of upgrader distributor cleaning and charcoal consumption are estimated at less than the cost of the modification

Alternative 4 –	-	Not Recommended
-----------------	---	-----------------

Alternative 5 – - Not Recommended

# **ONTARIO** GENERATION

OPG Contidention

Page: 8 of 19

BUSINESS CASE SUMMARY

# 1/ THE PROPOSAL

We recommend completion of the following modifications with the following targets:

- He Cover Gas Sampling System
- Boiler Steam & Water Sampling System
- HTS Hydrogen Control System

December 2007 December 2008 December 2008

# 5/ QUALITATIVE FACTORS

None other than what is stated in the Alternative section.





ON A CONCEPTION ペイオ からん オート ケステレー

San Shannan Sha

**OPG** Confidential

9 of 19

Page:

BUSINESS CASE SUMMARY

# 6/ RISKS

Description of Risk	Description of Consequence	Risk Before Mitigation	Mitigating Activity	Risk After Mitigation
	i de la sasta a			
Modification has not unscovery lissues on the Duplex Strainer modification. Installation and commissioning procedures have not yet been prepared. Modification has not yet been installed on any unit.	cost over run	Medium	A specific contingency of the has been applied to Duplex Strainer modification.	Low
There is risk of discovery issues on the Mass Flow Controller modification. The design is not complete.	cost over run	Medium	Design estimates (TIS Sheets) have been obtained from Projects Design. Design costs and progress reviews will be performed on a weekly basis to monitor actual costs versus estimate. A specific contingency of the MFC DCP to address unforseen design changes prior to the DCP	Low
Installation costs for the U5 Gas Chromatograph may be higher than budgeted due to delays or unforseen interferences.	cost over run	Međiug	revision. Scope of Work documents prepared and submitted to contractor to ensure full understanding of scope. TIS Sheets and Contractor Estimates have been received for all remaining work. A specific contingency of termining work. A specific contingency of termining work interferences. Another specific contingency of the has been added to this DCP in case there is a	Low
The scope of work for DCPs	cost over tue		compressed outage window during P751.	
406 & 601, is fairly well understood, however the designs are not finalized and		Mo	Preliminary COMS has been completed on the revision to DCP 601. Final COMS has been completed on the revisions to DCP	Low

GENERATION     Dec Confront.       Tary Increase or repending on rinput.     BUSINESS CASE       MFC on Hydrogen krinput.     EUSINESS CASE       MFC on Hydrogen rinput.     Mediation       MFC on Hydrogen krinput.     EUSINERSS CASE       MFC on Hydrogen stem is new setmisinew     EUSINESS CASE       Obtential for Delays     Any delays in the installation can impact     Low       Option 1000     Any delays in the installation can impact     Median       Option 1000     Any delays in the installation can impact     Median       Option 1000     Any delays in the installation can impact     Median       Option 1000     Any delays in the installation can impact     Median       Option 1000     Any delays in the installation can impact     Median       Option 1000     Any delays in the installation of the median     Median       Option 100     Any delays in the installation of the endiance     Median       Option 100     Tinius     Any delays in the installation of the endian     Median       Option 100     Tinius     Any delays in the installation of the endian     Median       Option 100     Tinius     Median     Median       Option 100     Schedule (In the cost section and a contingency applied.     Low       Prevision     Tinius     Median     Median       Prevision<					
GENERATION     BUSINE SS CASE       Tary Increase or repending on rinput.     BUSINE SS CASE       MFC on Hydrogen Kernology.     Low       MFC on Hydrogen stem is new setmology.     Low       Detential for Delays     Any delays in the installation can impact.     Low       Detential for Delays     Any delays in the installation can impact.     Mediur       Detential for Delays     Any delays in the installation can impact.     Mediur       Detential for Delays     Any delays in the installation can impact.     Mediur       Detential for Delays     Any delays in the installation can impact.     Mediur       Detential for Delays     Any delays in the installation can impact.     Mediur       Detential for Delays     Any delays in the installation of the extra Contractor costs. These delays     Mediur       Detential for Delays     Any delays in the installation of the extra Contractor costs. These delays     Mediur       Detential for Delays     Any delays in the installation of the extra Contractor costs. These delays     Mediur       Detail for Delays     Trinus     Conting the Outage and incur     Mediur       Detail for Delays     Trinus     Conting the Outage and incur     Low       Print     The schedule for the installation of the more costs     Mediur     Mediur       Provide for the revision of Dependentialy incur more costs     Incores the for the revision o		OPC Confidentia		Page: 10 of 19	
e or drogen cost over run drogen cost over run Delays Any delays in the installation can impact critical path during the Outage and incur extra Contractor costs. These delays were noted in the cost section and a contingency applied. The schedule for the installation of the MFCs and the Duplex Strainers will all be done using the IOP process. Delays on the IOP schedule will mean that the modifications will be impacted if Design does not meet their agreed upon dates for the proposed budget. The movel of project engineer (MTL) from DCP 406 or 601 will delay the schedule of the DCP and the project. The Modification would not be completed as per schedule.	GENERATI	ON BUSINES	CASE SUMMARY	lary	
MFC on Hydrogen cost over run stem is new echnology Potential for Delays Any delays in the installation can impact age Installation Early and delays in the installation can impact critical path during the Outage and incur extra Contractor costs. These delays were noted in the cost section and a contingency applied. The schedule for the installation of the MFCs and the Duplex Strainers will all be done using the Duplex Strainers will all be done using the Duplex Strainers will all be done using the Dipex Strainers will all be done using the Dipex Strainers will all be done using the the Dipex Strainers will all be done using the the propeed upon dates for the revisions of DCPs 406 and 601. T-26 milestones need to be met to ensure a timely installation and maintain their bCP 406 or 601 will delay the schedule of the DCP and the project. The Modification would not be completed the Modification would not be completed the the the the the the the the the the the	ope may increase or ase depending on holder input.		۱		
Potential for DelaysAny delays in the installation can impactage InstallationAny delays in the installation can impactage InstallationAny delays in the installation can impactage InstallationFortical path during the Outage and incurextra Contractor costs. These delayswere noted in the cost section and acontingency applied.ting T minusMFCs and the Duplex Strainers will all bedone using the IOP process. Delays onthe IOP ScheduleMFCs and the Duplex Strainers will all bedone using the IOP process. Delays onthe IOP schedule will mean that themodifications will have to remain opennonger and potentially incur more costsInstallation will be impacted if Designdoes not meet their agreed upon datesfor the revisions of DCPs 406 and 601.T-26 milestones need to be met toensures areRemoval of project engineer (MTL) fromm theiron other projects.for the DCP and the project.on other projects.for the resourcesas (DCPs 601 & 10 cold will delay the schedulefor the resourcesas per schedule.for the resourcesfor the installation would not be completedfor the resourcesfor the tot be resourcesfor the tot be resourcesfor the DCP and the project.for the tot be resourcesfor the tot be resourcesfor the tot be resourcesfor the tot be resourcesfor the tot be resourcefor	of MFC on Hydrogen System is new technology.	cost over run	Low	Different Alternatives were presented during the Preliminary COMS meeting. The Mass Flow Controllers was accepted as the preferred alternative. Recent OPEX has shown that a similar device was installed on Pickering 'A' without success. A review is being conducted by Design to confirm the Mass Flow Controlter is a viable option.	Lox
Octential for DelaysAny delays in the installation can impact age Installationage InstallationExtra Contractor costs. These delays were noted in the cost section and a contingency applied.age InstallationExtra Contractor costs. These delays were noted in the cost section and a contingency applied.the IOP ScheduleThe schedule for the installation of the ting T minusthe IOP ScheduleThe schedule for the installation of the done using the IOP process. Delays on the IOP schedule will mean that the modifications will have to remain open longer and potentially incur more costs.CP Revision.PRevision.CP Revision.Installation will be impacted if Design does not meet their agreed upon dates for the revisions of DCPs 406 and 601.T-26 milestones need to be met to ensure a timely installation and maintain the proposed budget.m their on other projectson other projectson other projects.on other projects.ation resourcesas per schedule.AsAs per schedule.AbAbAbAbAbAbAbAbAbAbAbAbAbAbAbAbAbAbAbAbAbAbAbAbAbAbAbAbAbAbAbAbAbAb </td <td></td> <td></td> <td></td> <td></td> <td></td>					
the IOP ScheduleThe schedule for the installation of the MFCs and the Duplex Strainers will all be done using the IOP process. Delays on the IOP schedule will mean that the done using the IOP process. Delays on the IOP schedule will mean that the modifications will have to remain open longer and potentially incur more costs. Installation will be impacted if Design does not meet their agreed upon dates for the revisions of DCPs 406 and 601. T-26 milestones need to be met to ensure a timely installation and maintain the proposed budget.Incers are motion their Removal of project engineer (MTL) from DCP 406 or 601 will delay the schedule on other projects.Inclored to be met to be and the project.Inclored to be and the project.<		ttallati re Our ts. Tr st sec	Medium	The installation of the Gas Chromatograph for P751 will be on the fourth and final Unit. All lessons learned from previous installations have been incorporated into Work Plans. A contract has been let out to the same vendor that performed the last two	Low
<ul> <li>A newision.</li> <li>Installation will be impacted if Design does not meet their agreed upon dates for the revisions of DCPs 406 and 601.</li> <li>T-26 milestones need to be met to ensure a timely installation and maintain the proposed budget.</li> <li>Indeers are Removal of project engineer (MTL) from m their</li> <li>S (DCPs 601 &amp; 01 will delay the schedule of the DCP and the project.</li> <li>On other projects.</li> <li>The Modification would not be completed ation resources as per schedule.</li> </ul>	hedule	The schedule for the installation of the MFCs and the Duplex Strainers will all be done using the IOP process. Delays on the IOP schedule will mean that the modifications will have to remain open onger and potentially incur more costs.	Medium	Project Engineers will attend T minus Project Engineers will attend T minus meetings to ensure project stays on the IOP schedule. A contingency of 2 months has been built into the schedule to allow for IOP delays.	۲ ۲
Ineers areRemoval of project engineer (MTL) fromm theirm theirm theirDCP 406 or 601 will delay the schedules (DCPs 601 &of the DCP and the project.on other projects.The Modification would not be completedation resourcesas per schedule.			Low	Design has provided TIS sheets for the two jobs. They have also provided a TCD date for DCP revisions that will be added to the target P3 file. A float of 2 weeks has been allocated to ensure no overrun in the Design Schedule	Low
Removal of project engineer (MTL) from DCP 406 or 601 will delay the schedule of the DCP and the project. rojects. The Modification would not be completed irces as per schedule.	a the state of the state of the state of the state of the state of the state of the state of the state of the st				
The Modification would not be completed irces as per schedule.	01 & rojects.	Removal of project engineer (MTL) from DCP 406 or 601 will delay the schedule of the DCP and the project.	Medium	Adequate project resources have been assigned for anticipated work load.	Low
	cces	would not	Low	Installation and commissioning tasks will be properly assessed and scheduled. All tasks will be "C" tasks, which means they have to	Low

GENERAL GENERAL	FION BUSINESS	Page CASE SUMMARY	Page: 11 of 19 ARY	
			Tbe completed in the week they are	
Vendor not available during commissioning of GC.	Delay would impact on Commissioning of Gas Chromatograph. If the vendor is not available during commissionig of the Gas Chromatograph, it will impact the return to service of the system, which could potentially affect the Outage End Date.	Medium	d. d. d on all remain the original mod ithe original mod nal unit install a ad. Stakehold in COMS review	Lok
Technical			i meetings. <u>1.882/P</u> PC/T-1885/2010 (CDD/12820) (CDD/12820)	
Modifications Do Not Meet the Design Intent and/or Design Requirements	Modification would require significant redesign or rework.	Medium	A rigorous COMS review has been conducted on all remaining modifications. Two of the remaining three modifications are rework to the original modification. The GC is the final unit install and no rework is anticipated. Stakeholders have been involved in COMS reviews and challenge meetings.	Low
		ı I		
Regulatory No Significant Risk				
<b>Environmental</b> No Significant Risk				
Health & Safety				
Workplace Injury of Serious MRPH Event	Unplanned intake/exposure to tritium and/or gamma. Potential for personal injury.	Low	The use of experienced trades personnel, the completion of the COMS process, as well the use of Event Free Tools (including procedural compliance) will help minimize and eliminate any such events. Work Plans have all been reviewed by Conventional Safety and Radiological Safety. Pre-job briefings are given every shift. JSAs will be	non la companya de la companya de la companya de la companya de la companya de la companya de la companya de la

		<b>OPG</b> Confidents		Page: 12 of 19	
GENERAI	VIION	BUSINES	BUSINESS CASE SUMMARY	ARY	
Personnel Contamination	Possible high MRPH, fire peronal injury.	MRPH, fire, explosion, or	Medium	One leg of the Hydrogen Addition System will be isolated at a time to perform the modification. This will ensure that hydrogen levels are not increased in the system which wil prevent an explosive mixture in the D2O Storage Tank. Blue Coveralls will be worn during the installation of the modification.	کے 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2
				work plans will be reviewed by Conventional Safety.	7 10 1
Modifications Do Not Meet	Higher Costs to Rectify D	to Rectify Drohlome			
Design Requirements	2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2		0 <b>%</b>	Modification details have been extensively reviewed and critiqued by all stakeholders. An in depth OPEX review and analysis has been done on all modifications and lessons learned incorporated. No new technologies are being installed. All modifications involve equipment previously used in the Nuclear	as ss ss ss ss ss ss ss ss ss ss ss ss s
			; ; ; ; ;	- Kaepon	

÷

BUSINESS CASE SUMMARY

and the second second second second second second second second second second second second second second second

# 11 POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Di	Final AFS	Targeted I	PIR Approva	I PIR Responsibility
Simplified	Dec	2008	Jun	2009	Manager, Chemistry

### Comments:

	Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it? (person / group)
1.	Performance Criteria and Reliability	Design Requirements	Modifications meet the performance and reliability criteria specified in the Design Requirements	Design acceptance of the Commissioning Report	Project Manager
2.	Stakeholder Acceptance of AFS	Installation and Commissioning of the modifications is as per DCN Packages	AFS Report	Signed Final AFS Declarations an acceptance of any Open Items	Project Manager
3.			•	· · · · · · · · · · · · · · · · · · ·	••••••••••••••••••••••••••••••••••••••
4.		·····	• • • • • • • • • • • • • • • • • • •		· · · · · · · · · · · · · · · · · · ·
5.		• • • • • • • • • • • • • • • • • • • •	, 		

**ONTARIO**POWER GENERATION

BUSINESS CASE SUMMARY

Appendix "A"

### Glossary (acronyms, codes, technical terms)

Abbreviations and Acronyms

AFS - Available For Service BCS - Business Case Summary **BTU** - Building Trade Unions CMO - Contract Management Office **CNSC** - Canadian Nuclear Safety Commission COMS - Constructability, Operability, Maintainability, and Safety CSA - Cost and Schedule Analyst CWP - Comprehensive Work Plan DA - Design Authority DCN - Design Change Notice DCP - Design Change Package DOM - Director, Operations and Maintenance DTL - Design Team Leader ECC - Engineering Change Control ECN - Engineering Change Notice ECR - Engineering Change Request EPSCA - Electrical Power Systems Construction Association FIPR - Fabrication and Installation Package Release FLM - First Line Manager FTL - Field Team Leader GC - Gas Chromatograph He - Helium HOR - Holder of Record ICP - Inductively Coupled Plasma IIP - Integrated Improvement Program IIPA - Independent Integrated Performance Assessment IX - Ion Exchange ITP - Inspection and Test Plan MA - Maintenance Authority MFC - Mass Flow Controller MR - Material Request MPSR - Major Project Summary Report NPMR - Nuclear Project Management Reporting OAR - Organizational Authority Register OM&A - Operating, Maintenance and Administration **OPEX** - Operating Experience OPG - Ontario Power Generation P3 - Primavera Scheduling Tool PCRAF - Project Change Request Authorization Form PDRI - Project Definition Rating Index PEP - Project Execution Plan PHTS - Primary Heat Transport System PLEP - Pickering 'B' Plant Life Extension Project **PIR** - Post-Implementation Review PMO - Project Management Office PO - Purchase Order PSM - Plan Start Milestone QA - Quality Assurance SCR - Station Condition Record SPOC - Single Point Of Contact SWC - System Window Coordinator TCU - Temperature Control Unit UV - Ultraviolet WBS - Work Breakdown Structure



		CALL & D. LE CO.
OPG Contidential	Pane	15

Page: 15 of 19

BUSINESS CASE SUMMARY

-----

Appendix "B"

and many services and and

# **Project Funding History**

telease Type	Month	Year	2002	2003	ulative Va 2004	2005	2006	2007	2008	Later Tota
Full	Feb	2001	3,996	1,222					2000	a salar and the salar salar and the
Superseding	Aug	2004	4,188	1,770	3,133	4.729	2.672	281		5,21 16,77
Adjustment	Apr	2005	4,188	1,770	1,568	4,500	4 700	1.684	- () (	18,41
Superseding	May	2007	4.188	1.770	1.568	3,591	3,702	2,082	1,509	18,41
· · · · · · · · · · ·								ļ		0
						· ··- <i>·</i> ···		1	!	0
	term and					1				0
		10.0				· · · · · · · · · · · · · · · · · · ·		· · · · ·		•••••••••••••••••••••••••••••••••••••••

### Comments:

In April 2005, funding was adjusted to \$18.4M to accommodate Head Office IIP costs relating to the development of a CEM Environmental Software Module that had been charged to the project.



<b>ONTARIO</b>	<b>POWER</b>
	GENERATION

BUSINESS CASE SUMMARY

Appendix "C"

### Financial Model – Assumptions

### Project Cost Assumptions:

Estimate includes specific contingencies for:

- Duplex Strainer Modification
- Mass Flow Controller
- Gas Chromatograph Total



Cost of Stopping the Project estimated to be \$400K (project management and design)

Cost of delaying the project for one year is estimated to cost \$500K for demobilization / remobilization and 5% for cost increases.

LTD Jan 2007 Spending = \$14,968 (including \$1.0M 2006 write off)

LTD Jan 2007 In Service Declarations = 14,340K

Write off for "Stop the Project" = \$14,968K less \$14,340K = \$628K (2007)

### Financial Assumptions:

WACC = 7%

### Project / Station End of Life Assumptions:

Units 5, 6, 7 Spring 2014 Unit 8 Spring 2016

### Energy Price / Production Assumptions:

N/A

### **Operating Cost Assumptions:**

Labour costs for Hydrogen Addition estimated at the per year Cost to repair metering valves estimated at the every 5 years

### **Other Assumptions:**

BUSINESS CASE SUMMARY

# Pickering 'B' Chemistry Standards 13 - 79147

# Superseding Business Case NK30-BCS-64510-00002-R000

#### Attachment "A"

### **Project Cost Summary**

5000's Capital	LTD Prior Yr 2008	This Release 2007	This Release 2008						Later	
Project Management (OPG)	938	249	132		149462513	ani. Xit.	a an an an an an an an an an an an an an	e se		1,319
Engineering & Drafting (OPG)	3,808	145	162		100					4,115
Material										4,115
Installation - PWU, BTU		and the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second sec			1	2.014	2.1			
Contract - Design				100.000		<b>State</b>	10-1-02		Post-10 m	
Contract - Installation										
Contract - Other					-				a second second	
Installation Support (FE)				The second second			1			
D ₂ 0 Upgrader write off				Carlos Colorado						
Interest (Capital Project Only)	and the second second			and the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second s		1.41.545				
Project Costs (exc) contingency)				******	CONTRACTOR OF	-				
General Contingency							-			
Specific Contingency		1.1.16		President and a second	and the second	- Contraction		1		
Project Costs ( incl contingency)	14,819	2,082	1,510					4.4.4.4.4.4.4.4.4.4.4.4.4.4.4.4.4.4.4.4.	100000	12
2007-2011 Business Plan	17,117	4,030	120	÷	. <u>.</u>	- <u>1</u>		<u></u>		18,410
Variance to Business Plan	(2,298)	(2,243)	1,095		Ø		- Tak su		s Verse and and a second second second second second second second second second second second second second second	21,267
Committed Cost	aliteration and a second and a second and a second and a second and a second and a second and a second and a s	<u> </u>	<u></u>		<u> </u>				<u>1996 - 19</u> 8	(3,447)
Inventory Write Off Required		• • • • • •		~~ ~~ ~~ ~	··· -··· -		<i>"</i> , <u> </u>	+	ļ	
Spare Parts / Inventory	· <del>- · · · · · · · · · · · · · · · · · ·</del>	······································		·· ;					<u>.</u>	• • • • •
Total Release (excl contingency)	14,819	1,787	1,215		ZU.	<u> </u>	- <u>11</u> 7883	LANG MELL	5-97-587***	-
Total Release (incl contingency)	14,819	2,082	1,510			• •	an an taon an t Taon an taon an t	1	al de la companya de la companya de la companya de la companya de la companya de la companya de la companya de La companya de la comp	17,820
Ongoing OM&A (non-project)					er en en en en en en en en en en en en en		403.722	in de locale RENEROIT	ereneren 1931 - Tap	
Removal Costa (Incl in above)					n E dit					

Design Complete		Up to - 40%	Stimate Quality of E		Release + 15% to - 10%		
3 rd Party Estimate	Yes	OPEX used	Yes	Lessons Le		Yes	
Reviewed by Sponsor	No	Budgetary Quote(s)	Yes	Phase 1 Ac		Yes	
Similar Projects	No	Contracts in place	Yes	Competitive		Yes	

The estimated variance(s) to the 2007-2011 Business Plan will be addressed through the portfolio management process. A PCRAF will be approved by May 2007.

Reviewed By:

March 28 Last un 7.2000

Approved By: Randy Ludlow

2007-3-29

Eng & Mods Manager (Strat IV)

Date:

ince Tzambazis

Date:

<b>ONTARIO</b>	riinen
	GENERATION

Page: 18 of 19

BUSINESS CASE SUMMARY

# Pickering 'B' Chemistry Standards 13 - 79147

# Superseding Business Case NK30-BCS-64510-00002-R000

<u>Attachment "B"</u>		Project Variance Analysis					
		Total Project					
Capital	LTD Dec 2006	Last BCS May 2004	This BCS Feb 2007	Verlance	Comments		
Project Management (OPG)	938	1.066	1.318	252	Additional project management required due to rework.		
Engineering & Drafting (OPG)	3.808	3,564	4,115	551	Cost overrun to resolve deficiencies identified during commissioning.		
Material							
Installation - PWU. BTU			Contraction of the local division of the loc				
Contract - Design	1	S LODBER C	COLUMN A	THE REAL PROPERTY	I DATES AND STREET STREET		
Contract - Installation							
Contract - Other							
Installation Support (FE)							
D ₂ 0 Upgrader Write Off				and the state of the factor			
Interest (Capital Project Only)	r						
pject Costs (excl contingency)					and the second second second second second second second second second second second second second second second		
the state and an and the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state					and the second of the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second sec		
General Contingency	-						
General Contingency							
Specific Contingency	14,819	17,410	18,410				
Specific Contingency Project Costs (incl contingency)	14,819	17,410	18,410	1,000			
Specific Contingency Project Costs ( Incl contingency) Committed Cost nventory Write Off Required	14,819	17,410	18,410	1,000			
Specific Contingency Trifect Costs ( Incl contingency) Committed Cost Inventory Write Off Required pare Parts / Inventory	14,819	17,410	18,410	t,000			
General Contingency Specific Contingency Protect Costs ( Incl contingency) Committed Cost nventory Write Off Required Spare Parts / Inventory Total Refease (Incl contingency)	14,819	17,410	······				
Specific Contingency Project Costs (Incl contingency) Committed Cost nventory Write Off Required Spare Parts / Inventory			18,410 18,410 17,820	1,000 1,000 2,678			
Specific Contingency Project Costs (Incl contingency) Committed Cost nventory Write Off Required Spare Parts / Inventory Total Refease (Incl contingency)	14,819	17,410	18,410	1,000			

Comments:

An underestimation in the cost of BTU trades. Numerous discovery issues such as degraded interfacing equipment 1. have been encountered. There have also been numerous delays such as late delivery of materials. Mitigating actions to perform more shop fabrication and testing has helped but these activities were not budgeted. Also support activities such as Holder of Record Duties. Maintenance Authority duties, material tracking, training, EPSCA travel, supervision, coordination, and reporting were all unfunded.

- Shortened outage schedules have required additional shift coverage which resulted in more work turnovers and 2. additional premium pay.
- An underestimation in the cost of Field Engineering support. Discovery issues have required additional oversight as 3. well as revisions to ITPs, FIPRs, and Comprehensive Work Packages (CWP). Also, changes to work processes including the Pressure Boundary process have increased the Field Engineering workload.



Design deficiencies, including the plugged strainers on the Boiler Steam and Sampling Panels and flow control problems on the Hydrogen Addition system, that were discovered during commissioning will require design rework as well as additional work to install and commission the revised design.

ONTARIO GENERATION

OPG Confidentiat

Page: 19 of 19

BUSINESS CASE SUMMARY

Attachment "C"

PROV

### Key Milestones

Co	mpletion I	Date	
Day	Mth	Yr	Description
03	Jul	2007	He Sampling Gas U5 AFS
01	Feb	2008	Hyrogen Addition U8 (MFC) AFS
25	Feb	2008	BS&W U8 Final AFS
01	Apr	2008	Hydrogen Addition U5 (MFC) AFS
09	Apr	2008	BS&W U5 Final AFS
01	May	2008	Hydrogen Addition U6 (MFC) AFS
05	May	2008	BS&W U6 Final AFS
02	Jun	2008	Hydrogen Addition U7 (MFC) AFS
16	Jun	2008	BS&W U7 Final AFS
15	Dec	2008	Chemistry Standards Project Complete
	ļ		
		<b>_</b>	
	L		

A Project Execution Plan (PEP) will be approved by May 2007

### Comments:





BUSINESS CASE SUMMARY

# Darlington Fire Protection Upgrade - Phase III 16 - 79148

# Superseding Business Case D-BCS-78000-10001- 005

Routing	Location	Antian		
T. Chong		Action	Signature	Date
Manager - Design Projects Darlington Projects & Modifications Division 703-3520	BW702	Review BCS	- Jung Chan	0
G. Brown/ R. Leavitt/ J. Beech Stan Nuclear Finance 400-7226	ТСН09	Review BCS	Palagist -	15 Sept 20
M. Arnone Director, Projects & Modifications 701-6063	P72-2	Review BCS	FR L	54720/05
S. Seedhouse Director, Engineering - Dartington 703-7584	D08-ES3	Review BCS	CC.	25 SEPT 200
G.O.D. Smith Senior Site VP - Darlington	D08-ES3	Submit BCS	2 Such	
P.R. Charlebois Executive Vice President and Chief Nuclear Officer	P82		Durg John	5 Or 260
D. Power Jirector, Investment & Business Planning	ТСН07	Review BCS		
J. Hankinson President & CEO		Approve BCS	Futures -	har 8/07
	TCH19	Approve BCS	Stir	tran \$/07
	·			
Ball		<b>D</b>		
ior Financial Analyst 4084	P82-386	Return For Distribution		

ONTARIO	<b>POWER</b> GENERATION
	DEMENATION

**BUSINESS CASE SUMMARY** 

# Darlington Fire Protection Upgrade - Phase III 16 - 79148

#### Superseding Business Case D-BCS-78000-10001-R005 **RECOMMENDATION:**

We recommend:

1/

- 1. The removal of Non REG C items from the scope of work (approximately \$800k).

2. The release of an additional \$6.2M, including contingency, for completion of the REG C scope of work.

The project met the Canadian Nuclear Safety Commission (CNSC) REG C commitment, A/R # 28030880, on December 30. 2005. Outstanding work to complete the project includes Available for Service actions, discovery work, and project close out activities. As of May 31, 2006 the project has spent \$26.1M which exceeds the released funding of \$23.5M. This unapproved expenditure of approximately \$2.6M has been documented by SCR D-2006-03180 and reviewed by the ensuing B2 (detailed

In order to complete the REG C work by December 31, 2005 all Non REG C work such as the Inaccessible Smoke Detectors and Fire Works was deferred. It is now recommended that this Non REG C work be examined under a new stand alone project where a thorough review of needs will be conducted and lower cost alternatives (including do nothing) assessed.

A Superseding Business Case was signed by the Site Vice President, Darlington in December 2005; however, it has been subsequently revised to correct OAR elements and incorporate the latest cost estimates to complete Available for Service actions, discovery work, close-out activities, and cost over runs.

The revised cost estimate of (excluding contingency) is more than the 2006 Budget. These variances will be addressed through the portfolio management process. more than the 2006-2010 Business Plan and



server and contingency)	Punding	LTD 2005		مرور بر محمد می مرور می مرور بر محمد مرور می مرور می مرور می مرور می مرور می مرور می مرور می مرور می مرور می م	، چېر <del>د</del> مېر <del>و د</del> مېرو کې د کې د	****			
Currently Released	- commissioners in the	anne marine in the	2006	2007	2004	2909	2010	Later	
Requested Now	Full	20,591	2,475	422					Total
requested NOW	Superseding	3.550	863	1,791					23,488
Future Funding Regid	Choose			1,791					6,204
Total Project Costs		04 144						t+	0,404
Ongoing Costs	******	24,141	3,338	2,213	•				
Other Costs								· · · · · ·	29,692
								]	
Grand Total		24.141							
Manufacture 1			3,338	2,213	-	-			
			トレージ発行	NPY OF	EN T		·····		29,692
ومغيرها والمتكليل وستأسف ومترسعه مراجعه	himmen in march			Het April			5 A.L. 4		Paylout,
Summer ou			· · · · · · · · · · · · · · · · · · ·	and the second second second second second second second second second second second second second second second	and a star and a star and a star and a star a star a star a star a star a star a star a star a star a star a st	Med App		Shie Card	State of the second

Summitted By:

G.O.D. Smith

Senior Sile VP - Darlington

Finance Approval:

D. Power

Director, Investment & Business Planning

5 000 2006 Date:

Date:

Line Approval (Per OAR Etement 1.4 Variance)

mar 9/07

J. Henidinson President & CEO

Date.

States a summer and





Page: 3 of 18

**BUSINESS CASE SUMMARY** 

# 2/ BACKGROUND & ISSUES

The Full Release Business Case Summary D-BCS-78000-10001 R004 for this project was approved on January 12, 2005 for \$23.5M, including contingency. The project scope included resolution of Code Compliance Review (CCR) and Fire Safety Analysis (FSA) deviations, which was a CNSC REG C commitment, as well as Non REG C work.

The drive to meet the REG C committed date, productivity issues, as well as an underestimation of scatfolding costs and labor rates resulted in higher than estimated costs for the CCR/FSA Fire Detection Work Package of approximately \$8.0M and for the Sprinkler & Standpipe Work Package of approximately \$1.3M. This includes contractor over expenditures and such as resolution of an engineering change breakthrough event associated with booster pump over pressure (SCR D-2006-00222) and Power House Annex issues and project close-out activities.

To limit the unapproved cost variance, all close-out activities have been placed on hold. Also, this variance has been partially offset by \$1.6M due to creative solutions (see below) for other REG C work packages, reducing the number of devices installed by 16% (approximately \$1.5M) and the drawing down of the project contingency of \$2.5M.

An alternate resolution has been successfully negotiated and implemented for the Public Address (PA) system resulting in a saving of approximately \$1.1M from the original estimate. The CNSC has been informed of the alternate resolution which consists of a system surveillance program where audibility and functionality of the PA system will be routinely monitored.

We have also successfully negotiated to retain the CO2 fire detection system "as is" and remove the CO2 extinguishing systems from the Darlington site except for the fuel storage tank rooms located inside the EPS-FM Bullding. CNSC has been informed of this alternate resolution. This has resulted in a saving of approximately \$0.5M.

In order to complete the REG C work by December 31, 2005 and limit cost variances the Non REG C work was deferred. It is now recommended that the Non REG C work be removed from this project so that it can be evaluated in more detail under a separate project. The Non REG C work primarily relates to the resolution of inaccessible smoke detectors for inspection and maintenance, removal of obsolete smoke detectors, tie-in of bypass switch panel for ease of maintenance, resolution of Works). The detailed scope of work for a significant portion of this Non REG C work is not yet defined. Cost estimates to objective is to reduce the current level of OPG staff effort required to perform periodic maintenance, a financial evaluation will be completed to assess lower cost alternatives.

See Attachment A, B and E for further detail.



Page: 4 of 18

**BUSINESS CASE SUMMARY** 

# 3/ ALTERNATIVES AND ECONOMIC ANALYSIS

GENERATION

\$ 0075	Stop the Project	Alt 1 (Rec Full	incremental	AN2 Deley	ARS	Alt+	ARS	Ans
Project Cost NPV (after tax)		29,692	6.204		24 100	in ji .		
Impact on Economic Value	Color 1 - 1 - 50				34,192			
IRR% Discounted Payback (Yrs)						······································		
Listedinos ( ayoack ( ( is)	·							

# Stop the Project - Not Recommended

**ONTARIOPOWER** 

Stopping the project is not recommended, since outstanding work associated with the REG C such as re-commissioning a part of the fire detection system, resolution of the booster pump over pressure issue, discovery work and project close out activities would remain incomplete. This would run counter to the CNSC's expectation to resolve and close out these items.

#### Alternative 1 -Do Less - Recommended

It is recommended that only the REG C work be completed under the scope of this project and that Non REG C items be

This allows for the completion of Available for Service actions, discovery work, and close-out activities associated with the REG C work. It also permits the re-evaluation of the needs versus wants and development of the detailed scope for the Non REG C work under a separate project so that an assessment of lower cost alternatives (including do nothing) is completed.

# Alternative 2 - Delay Project - Not Recommended

CNSC verbally agreed to the completion of the December 31, 2005 REG C on the condition that all outstanding items are completed on an urgent basis. Delay of the project is not recommended, as it shows lack of commitment to the regulator and would disrupt project efficiency the close-out stage (incurring additional stop/start costs).

# Alternative 3 - Complete Project within Original Plan - Not Recommended

The original plan was to complete the REG C and Non REG C work by December 31, 2005.

REG C committed work is to resolve deviations identified in the Darlington Code Compliance Review and the Darlington Fire

Non REG C work is associated with removal of obsolete smoke detectors, resolution of inaccessible smoke detectors for inspection and maintenance, tie-in of bypass switch panel for ease of maintenance, resolution of existing main control room fire alarm re-flash annunciation issues, and installation of a fire panel graphical user interface (Fire Works).

Completing the original plan is not recommended because the scope of the Non REG C work is not fully defined, the cost estimate of Non REG C work has escalated significantly and requires re-evaluation and review of the needs so that an assessment of lower cost alternatives (including do nothing) is concluded.

# Alternative 4 - Do More - Not Recommended

The scope is based on recommendations provided in the Fire Protection Code Compliance Review and Fire Safety Assessment Reports. There is no plan or justification to increase the scope of work. In the event that the CNSC challenges any of the CCR/FSA resolutions previously submitted, new projects are to be created by the stakeholders as required to

Alternative 5 -- Not Recommended



jntario	POWER
	GENERATION

**BUSINESS CASE SUMMARY** 

# 4/ THE PROPOSAL

The proposal is for the:

- 1. Removal of the following Non REG C items from the scope of this project so that they can be reviewed and approved on
  - a. Obsolete smoke detector removal.
  - b. Inaccessible smoke detector resolution.
  - c. Maintenance bypass panel.
  - d. Control room fire alarm re-flash resolution.
  - e. Fire Works installation.
- Approval of funding for completion of REG C related items, specifically to: 2.
  - a. Cover the cost variance to May 31, 2006 of \$2.6M (SCR D-2006-03180).
  - b. Complete the following Available for Service actions: ì.
    - Work Package #2: Fire Suppression
      - Standpipe close-out.
    - ii. Work Package #7: Fire Detection
      - Investigation of alarms in Local Unit Control Equipment Room (SCR D-2006-02283).
      - 3rd Party verification of duct detectors, pump annunciation, and door interlocks.
      - Removal of HVAC tie-in, pending CNSC approval.
      - Waste Handling Door spare parts review, drawing updates, Final AFS, and close-out. Update and issue detection drawings/documentation.
  - c. Complete the following discovery work:
  - Í.
    - Work Package #1. Fire Doors. Seals, and Exit Signs
    - Unit 2 stairwell grating replacement design, installation, and close-out (SCR D-2006-01082). Work Package #2: Fire Suppression ü.

    - Booster pump over pressure resolution, design, installation, and close-out (SCR D-2006-00222). Work Package #6: Fire Barriers, Power House Annex iiì, Insulation and door replacement.
  - Complete project close-out activities. d.

Refer to Attachment D for further detail.

Note that the REG C commitment has been met.

# 5/ QUALITATIVE FACTORS

This project will:

- 1. Increase safety to the public and to employees.
- 2. Improve the ability to prevent, contain, and minimize damage or loss of asset from fire.



ON. ARIOP GWER

OPG Confidential

Page: 6 of 18

BUSINESS CASE SUMMARY

# 6/ RISKS

	Detectiption of Consequence	Riak Before Mitigation		
Cost of Non REG C Items	) 1 <u>1</u> 지수			
exceeds the released funding. Project cost exceeds estimate	·····	Medium	Removal of Non REG C items from scope for re-evaluation and review of the needs under a separate unrelated project.	e s
Re-initiation of interest	····· - · ÷.	LOW	Majority of work is close-out/clean-up. For 2 items with outstanding design it is > 50% complete, installation estimates obtained, and estimates obtained for	
charges.	Additional funding required,	Low	Continued with Station Finance that Equipment In Service declaration is at	Fow
Undefined scope for Non REG	Additional function room		100%; hence, no further interest charges to the project.	, , , , ,
Duct detectors do not meet	Delinhar fairman	Medium	Removal of Non REG C items from scope for re-evaluation and review of the needs under separate unrelated project.	Pow
performance requirements. Standpipe hangers and fittings do not meet performance	detector relocation/re-adjustment. Increased cost due to standpipe hanger	Medium	contingency av k & HVAC tie-in	Low
reguirements. Schodune 1. Business case and	aru mung replacement.		replacement, contingency available for replacement,	Low
delayed.	Project completion date extended.	Medium	Project close-out activities out on Lite	
			remains MEDIUM until this business case is approved. Station (IPG) scheduling requirements to be followed upon project re- initiation.	Medium

<u> </u>	S
	Ē
	E
	NE.
	)
a	
0	Ĭ

OPG Confidential BUSINESS C4

Page: 7 of 18



	BUSINE	BUSINESS CASE SIMMARY	ABV	
Lack of CNSC confirmation				
duct detector & HVAC tie in		Madhum		
proposal.	detection design package.			Low
		<u></u>	CNSC stating that the proposal is assumed	
Redundant detection removal			tie-in will be deleted.	
Sector and current design.	detection design package.	Medium	include Action Tracking	Low
			defection	
Hesources not available to	Pod			
depending work.		Medium	from Design Eight	
			Station resources	<b>≩</b>
			$\sim$	
deside and a flow switch	Higher design			
Party: Party		Medium		
	the extended.			Mon
		~~~~	BCLON	
			design mor to accepted to	
Control Emiser 5	Increased operation cost due to		installation included in the extending treid	
1 I CED	municipal fire department mains	Medlum		
	Increased cost for mom close		····	Low
	repair of demanded continuent.		repairs to smoke/fire domains	
Door interfactors	associated with the project	A 1	cleaning of the room to room of	
	Increased cost for room and HVAC		particles is outside the some of this project	
Part of the second of the seco	repairs not associated with the project	Low	·	
				LOW
			Б Б	
			interlock operation. Room/HVAC renairs is	
CNSC does not accent the				
dispositions to the standning	Auditional work required to address	Marlum		
sprinkler, and other CCR/FSA	CIVEC CONCERNS.		and Party Reviews submitted to CNSC, Low	WC CONTRACTOR OF CONTRACTOR
nevtations.) . <u>-</u>	includes time to its requirement. Estimate	
			challences. Prohability of CNSC	
		0	challenges is low. Dismosition of and the	
			unresolved challenges is outside the month	* =
		0	of this project. New projects (approve set to	
	Name and the second second second second second second second second second second second second second second	9	to be initiated by stakeholders as required	÷
		-		





	Low	Low	Low		Low
АНҮ	specific contingency available for duct detector re-work & HVAC tio in	ind nuclear	Compliance to corporate and nuclear health		industry experts/3rd Parties used during design, installation, and commissioning to supplement OPG experience.
BUSINESS CASE SUMMARY	ector Medium		Low		
	Increased cost to complete duct detector & HVAC tie-in.	Release to environment.	ces. Personal injury.	ork as Higher costs.	
	CNSC requests duct detector & HVAC tie-in.	Poor installation and commissioning practices.	Unsafe labour practices.	Modifications do not work as planned	

BUSINESS CASE SUMMARY

7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:		Targeted PIR Approve	PIR Responsibility
Simplified	Jun 2007	Dete: Dec 2007	(Sponsor Title) Manager, Performance
Comments.			Engineering

Comments:

······

	Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it?
1.	Resolve/disposition all CCR and FSA deviations	No deviations resolved at start of project	3 Party concurrence of all resolutions and dispositions to CCR and	Written 3 Party acceptance	(person / group) Manager, Performance Engineering
2.	Completion of Available for Service (AFS) for CCR and FSA modifications	No modifications completed at start of project	FSA deviations AFS acceptance of modifications by December 31, 2005	AFS acceptance meetings	(Project Sponsor) Manager, Design Projects (Project Owner)
3.	Complete CNSC REG C Commitment A/R 28030880	REG C due date of December 31, 2005 at start of project	REG C commitment met by December 31, 2005	Completion letter submitted to CNSC	Manager, Regulatory Affairs
4. 5.					



GENERATION

Page: 10 of 18

BUSINESS CASE SUMMARY

Appendix "A"

Giossary (acronyms, codes, technical terms)

	AFS:	Available for Service
	A/R:	Action Request
	BCS:	Business Case Summary
	B&M:	Black & McDonald, installation contractor
	CCR:	Code Compliance Review
	CD:	Crossby Dewar, installation contractor
	CMO:	Contract Management Office
	CNO:	Chief Nuclear Officer
	CNSC:	Canadian Nuclear Safety Commission
	CO2:	Carbon Dioxide, inert gas based fire suppression system
	CSA:	Common Secondary Area
	DCP:	Design Change Package
	EC:	Engineering Change
	EPS:	Emergency Power Supply
	EPS-FM:	Emergency Power Supply - Evel Management
	EST:	Luwalus Systems Lechnology manufactures at C
	EST-3:	Fire Panel model supplied by Edwards Systems Technology
	FFAA:	Fueling Facility Auxiliary Area
	Fire Works	3: Graphical user interface to EST-3 fire papels by Edwards O
	FSA:	Fire Safety Analysis
2	HVAC: IRR:	Heating, Ventilation, and Air Conditioning
	LTD:	memai hate of Return
7	LUCER:	Life to Date
	MOCPER:	Local Unit Control Equipment Room
	N/A:	Main Output Control and Protection Equipment Room
	NPV:	
	OAR:	Net Present Value
	OM&A:	Organizational Approval Registry
	OPEX:	Operating, Maintenance, and Administration
	OPG:	Operating Experience
	PA	Ontario Power Generation Public Address
	PHA:	Power House Annex
	PHT:	Primary Heat Transport
	PIR:	Post Implementation Review
F	MOD:	Permanent Modification
F	REG C:	Type of CNSC regulatory commitment
S	SCA:	Secondary Control Area
	CH:	Station Condition Record
	MOD:	Temporary Modification
	ESDA:	Very Early Smoke Detection Apparatus air and the
Ν	/TP:	Very Early Smoke Detection Apparatus, air sampling based smoke detection system by Edwards Water Treatment Plant



ONTARIO	POWER GENERATION
---------	----------------------------

Page: 11 of 18

BUSINESS CASE SUMMARY

Appendix "B"

Project Funding History

S 000's Release Type	Month	Year	2001	Cum 2002	lative F	+ 1 1		· · · · ·	1		
Developmental	Nov	2000	100			2004	2905	2006	2007	Later	Total
Partial	Aug	2001	1,470	430			1	ļ			100
Interim	May	2002	1,470	930	1.000	ſ	+	1 ** ·			1,900
Interim	Feb	2004	1,470	930	1,000	3,800		ļ	ļ	 	3,400
Full	Jan	2005	1,470	930	1,000	3,945	10.010				7.200
Superseding	Aug	2006	1,470	930	1,000		13,246	2,475	422		23,488
			.,	- 300	,	3,945	16,796	3,338	2,213		29,692
			······								
		····	• <u>•••••••</u>		••••••••••••••••••••••••••••••••••••••						
LTD Spent	May	2006	1230	813	1412	3906	16700		r	·	
omments:						0300	16780	1933			26,074



ONTARIOPOWER GENERATION	OPG Confidential
GENERATION	BUSINESS CASE SUMMARY
Appendix "C"	Financial Model – Assumptions
Project Cost Assumptions:	
Not applicable.	
Financial Assumptions:	
Not applicable.	
Project / Station End of Life Assumpti	ons:

Not applicable.

Energy Price / Production Assumptions

Not applicable.

Operating Cost Assumptions

Not applicable.



Other Assumptions:

Page:

12 of 18

ONTARIOPOWER GENERATION

OPG Confidential

BUSINESS CASE SUMMARY

Darlington Fire Protection Upgrade - Phase III 16 - 79148

Superseding Business Case D-BCS-78000-10001-R005

Attachment "A"

Project Cost Summary

\$000's Capital	Work Package	LTD Prior Years 2005	2006	2007			LTD This Mth May	LTC
Project Management			2000	2007	2008	Total	2006	%
Detailed Eng							- 2610	- 00
Fire Doors, Seals, & Exit Signs								6
Tre Suppression								
tairweil Enclosures				-			in the second second second second second second second second second second second second second second second	
mergency Lights								
ublic Address Fire Alarm								
ire Barriers - Powerhouse Annex								
ire Barriers - PHT Pumps								
adiant Energy Fire Barriers	and the second s			-				
02 Fire Detection	Transformed and			-				
accessible Detectors/Removal							1900	
re Works				1000		Concession of		
CR/FSA Fire Detection							State of State	
rocedures						22/14/14		
lerest							TE .	
Ose-out								
verhead					1.1.1			
do lotal (REGC)			the second second second second second second second second second second second second second second second se					
meral Contingency								
ecific Contingency								
and Total				And the second s	C. Bed to start a low at			
going OM&A	-	24,141	3,338	2,213		29,692	26,074	N/A
entory Write Off Required								
re Parts / Inventory				T				
ind Total linci contingencyl					20.2000 (Contraction)		<u>}</u>	
6-2010 Business Plan		24,141	3,338	2,213	に対応的な	29,692	26.074	10.000
	Loss and the second	24.141	938	Charles and the second		95 0.70		and the second se
riance to Business Plan (excl conting)		1.00000	(2,400)	(1,363)	100 million (1997)	25,079	N/A	N/A

Specific Contingency:

-				State of the local division of the local div	
Design Complete		Basis of Estin	nate		
Party Estimate		PICKUD I	No	Competitive Bid	1
		OPEX used	Yes	Lessons Learned	<u>N/A</u>
eviewed by Sponsor	Yes	Sponsor Cost Estimate	N/A	Phase 1 Actual Used	Yes
			IN/A		Yes

Reviewed By:

Project Manager

. Typ R. Piggott

15/09/06 Date:

Approved By: 15 Sept 2006 T. Chong Eng & Mods Manager (Stratily) Date:



BUSINESS CASE SUMMARY

Darlington Fire Protection Upgrade - Phase III 16 - 79148

Superseding Business Case D-BCS-78000-10001-R005

Attachment "B"

\$000's

Project Variance Analysis

3000 \$		Last	This				
Capital	Work	Release 12-Jan-05	Release 31-Aug-06	Variance	LTD	Out Standing	Explanation
Project Management	Alf				May-06		
Detailed Engineering	All						4-9-2-
Fire Doors, Seals, & Exit Signs	1						and the second second second second second second second second second second second second second second second
Fire Suppression	2	7		য়েন্ডা আনাধ্য জা			
Stairwell Ericlosures	3					Section 14	Source (DAMN)
Emergency Lights	4		a strategio ana	A PROPERTY OF	ALC: NOT	California and	
PA Fire Alarm	5		RADING	an and the state	NUMBER OF	And the Distance of the second	All of the second
Fire Barriers - PHA	6		Street and		CAL NO.		
The Barriers - PHT Pumps	6		Constant of	REPORT N	Alley Track	のないのない	1. A marked and the second s
ladiant Energy Ine Barriers	7				1. S. P. B.	STANK GAR	
O2 Fire election	7		Suppose a			WHEN .	A STATE AND A STAT
accessible etectors	7	27 Hann	ersenadasse da anvernasi ada	CONNECTIVI MAR		Selectracia Angela Selectracia Conve Secolareus conves	And a start of the second start of the start of the second start o
re Works	7	1	2.4- R.(22) -			CPRIDE AL	
R/FSA Fire légtion	7			10000 1000 1000 1000 2000 1000			
	8					Congent	
	li Aji		Sales of		an Spiner and a	5 yes	and the second se
	431		120000	Charles and	THE PARTY	Purchase and a	This can be an an an an an an an an an an an an an
Charges)	WI T	1.1.18	微门部		1 Status	and the second	and a construction of the second seco
tingency	4L						and the second second second second second second second second second second second second second second second
nd Totel						a summer and a second	discould a

omments:



Page: 15 of 18

BUSINESS CASE SUMMARY

Attachment "C"

Key Milestones

Co	mpletion	Date	and the second design of the and the second design of the second de
Day	Mth	Yr	Dittoriation
08	June	2007	Unit 2 Grating Replacement - AFS
25	June	2007	
21	Dec.	2007	Booster Pump Over Pressure Resolution - AFS Project Complete
	<u> </u>	+	
		<u> </u>	
		L	
	···		
L			

Comments:



16 of 18

Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

Attachment "D" Scope of Work and Status

Mart D.	Scope of Work	Status/Outstanding Items
Work Package # Fire Doors, Seals and Exit Signs	 Inspect/repair fire rated barrier seals and penetrations in the exit stairwells. Install exit signs as per fire code requirements 	
Work Package # Fire Suppression	 <u>Sprinklers:</u> Install 5 additional sprinklers heads in the CSA Stores Restrict height of material in the storage racks. Sprinkler upgrades in the East and West FFAA. <u>Standpipe:</u> Complete hydraulic calculations of Standpipe System. Resolve deficiencies: low system pressure, additional fire hose connections, relocate fire hose cabinate, ato 	 Complete Complete, sprinklers kept "as is". <u>Standpipe</u>:
Nork Package #3 Stairwell Enclosures	Upgrade the eight Turbine Hall stainwell enclosures on the 115 m elevation to the required fire rating.	e Complete
Nork Package #4 Emergency Lights Vork Package #5	Pump Houses. Part B: Provide handheld portable lights for Operation sta Perform technical evaluation for the continued use of the	
ublic Address ire Alarm	system as an alternate disposition for fire alarm notification Seek concurrence from the 3 rd Party Reviewer and inform CNSC.	A Complete
/ork Package #6 re Barriers	PHA: Correct deficiencies in the powerhouse annex link to Unit 4. PHT Pumps: Install dikes at entrance to PHT pump rooms.	Discovery Work: Insulation/door replacement and close-out,
fork Package #7 re Detection	Part A: Install detection in LUCER/MOCPER/SCA. Install Bypass Switches (Non REG C) to facilitate maintenance on fire detection EST-3 system.	PHT Pumps: Complete Part A: Complete AFS follow up action: Investigation of VESDA alarms (Unit 1 & 4 LUCERs). Bypass Switches (Non REG C): To be removed from project.
	Part B: Install Rediant Energy fire barriers to protect affected cable pans identified in the FSA deviation report. Part C: T. Install fire detection and pull stations in various locations to resolve CCR and FSA deviations. 2 Inaccessible Detectors (Non REG C): Assess and seek alternate disposition to make approximately 340 smoke detectors accessible for routine maintenance and testing.	 Part B: Complete Part C: Complete AFS follow up actions: 3rd Party verification of duct detectors, pump annunclation, and door interlocks. Waste Handling Door spares review, drawing update, Final AFS, and close-out. Pending CNSC approval, remove HVAC tie-in. Issue documentation/drawings. Inaccessible Detectors (Non REG C): To be removed from project.
1	ine panels.	Part D: Fire Works (Non REG C): To be removed from project. Scope has grown to include resolution of an existing fire alarm re-flash annunciation issue.



ſ

NTARIO	POWER Generation
	arisriit, fi 101£

OPG Confidential

17 of 18

Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

	Scope of Work	Status/Outstanding
Work Package #7 Fire Detection (Continued)	the CCR deviations relating to inappropriate fire detector location, lack of pull stations, lack of pre-discharge and discharge alarms inside the CO2 protected areas. <u>Part F:</u> 1. Modify breaker interlock. 2. Re-route EVEN EPS bits related cables	Status/Outstanding items Part E: Complete Part F: 1. Complete, no modification required. 2. Complete, no modification required.
Work Package #8 Fire Protection Procedures	 CCA Deviation: Revise the identified fire protection inspection, testing and maintenance procedures to comply with the fire codes. FSA Deviation: Revise and issue Operating Procedure for Emergency Response Manual Fire Actions by Authorized Nuclear Operator. 	1. Complete 2. Complete







18 of 18

Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

Attachment "E"

Outstanding Scope/AFS Actions/Discovery Activities

Item	Forecast (\$000's)	Notes
Unit 2 Stairwell Grating Modification	87	
Booster Pump over pressure resolution	768	Discovery work – Design, implementation, and close-out outstanding. Discovery work – TMOD implemented. PMOD design, implementation, and close-out outstanding.
PHA Door AFS & close-out	20	Discovery work - Compustible insulation and the history
3 ^m Party verification & VESDA investigation	193	AFS Action - 3 th Party verification of detection and ing.
Waste Handling Doors	55	AFS Action - Spares review drawing update and Figure AFS
Duct Detection/HVAC tie-in deletion	182	AFS Action - Pending CNSC approval to
Standpipe close-out	309	
Detection close-out		" O HOUGH - COURACIDE AND ADDITION - ILLA
Project Management	552	Contractor and focumentation close and
Contingency	622	
		General Contingency: Specific Contingency:
		edesign of Booster Pump over pressure resolution installation of redesigned Booster Pump over pressure resolution or hanger and fitting replacement for duct detector relocation and HVAC tie-in

ONTARIOPOWER GENERATION

BUSINESS CASE SUMMARY

DNGS D2O Storage and Drum Handling Project 16 - 31555

Developmental Release Business Case Summary D-BCS-38000-10001- 001

Routing	Location	Action	Signature	Date
Shawn Bremner Modification Team Leader x 701-2070	P72-3	Prepare BCS	12 Jos Bran	~ Nov 8/0
Edmond Wong Project Leader x 701-3991	P72-3	Review BCS	51	Anofe 6
Stephanie Tham Project Manager x 701-4203	P72-3	Review BCS	UB.	Nev 8/06
Peter Floyd Manager, Design Projects, Pickering A x 701-4053	P72-1	Review BCS	1.4	Har Stoe
-Gord Brown Controller, NOSS x 702-5059	P82-3	Review BCS		BNacco
Aileen Sullivan Manager, TRF x 703-1361	D08-ES3	Review BCS	Dillive	Nov 21/0
Mark Arnone rector, Projects & Modifications 701-6063	P72-1	Review BCS	hills were to	rac s/d
Rumina Velshi Director, Commercial Activities x 702-5100	P82-4	Submit BCS	MI J-1	Aburch
Randy Leavitt Director, Investment Management x 702-5085	P82-3	Approve BCS	For .	Nos 25, 200
Larry Nichol Director, TRF x 703-7450	D08-ES	Approve BCS	Huy Mudol	NEV 4/02
Ball nior Financial Analyst 2-4084	P82-3B6	Return For Distribution		

ONTARIOPOWER GENERATION

Page: 2 of 19

BUSINESS CASE SUMMARY

DNGS D2O Storage and Drum Handling Project 16 - 31555

Developmental Release Business Case Summary D-BCS-38000-10001-R001 1/ RECOMMENDATION:

We recommend approval of a Developmental Release of \$3,600k (including \$840k contingency) to complete preliminary design, initiate detailed design, initiate Requests for Quotations for long-lead materials and develop a Partial Release for the DNGS D₂O Storage and Drum Handling Project by November, 2007. A Partial Release will be requested upon completion of preliminary engineering to facilitate a seamless transition to detailed design, long-lead material procurement, initiate Requests for Proposal for the construction contract and develop the Full Release. This funding strategy will minimize cost and schedule delays.

The business objectives of this project are as follows:

- Improve detritiation capability within OPG.
- Improve operational flexibility and ability to segregate different streams of D₂O to support various operation and outage scenarios in DND (ie: unit outages, SCO/VBO or upgrader outages)
- Improve the management of drum inventories in DND.
- Allow Isotope Sales Department to pursue new business opportunities.

Kinectrics was commissioned to study the Heavy Water storage and drum handling issues from an overall OPG perspective. The recommended modification for DNGS is to extend the existing HWMB to house additional 8 x 50Mg multi-purpose storage tanks and to provide additional drum handling/storage space, and install a drum testing facility. The recommendation is based on the understanding that DNGS's drums will be cleaned off site at PNGS's new drum cleaning facility, and the additional DNGS tanks will provide storage flexibility that benefits PNGS's detritiation program.

Choose One	Funding	LTD 2006	2007	2008	2009	2010	2011	Later	Total
Currently Released	N/A	-	. 	······	····				· · · · · · · · · · · · · · · · · · ·
Requested Now	Developmenta:	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	1.872	1.728			·		3,600
Future Funding Req'd		:		3,992	13.253	14,938	600		32,783
Total Project Costs		-	1,872	5,720	13,253	14,938	600		36,383
Other Costs		· · · · · · · · · · · · · · · · · · ·							-, -, <u>-</u> , -, -, -, -, -, -, -, -, -, -, -, -, -,
Ongoing Costs	1				/ /		· · · · · · · · · · · · · · · · · · ·	· ~ ~ 	••••
Grand Total		•	1,872	5,720	13,253	14,938	600	- 1	36,383
Investment Value Enhar	Type noing	Clas Capit		(IEV) Impact (13,6	on Ec Value 54	IRA 14.8		Discounted 9.8	Payback

Submitted By:

Rumina Velshi

al Jis /oc Date:

Now 22, 2006

Director, Commercial Activities

Finance Approval:

Randy Leave

Line Approval (Per-OAR/Element 1.1 Project in Budget):

Vort. Zille

Larry Nichol

Director, TRF

Date:

Director, Investment Management

ONTARIOPOWER	
GENERATION	

BUSINESS CASE SUMMARY

2/ BACKGROUND & ISSUES

OPG needs to improve its overall ability in managing its D₂O inventories to support continuous station operations in a safe and cost efficient manner. In December 2004, Kinectrics Inc. completed a study "Strategic Option Study for OPG Heavy Water Storage and Drum Handling", (Ref; K-011043-001-RA-0001-R00A). In April 2006, Kinectrics Inc. was contracted by this Project to further investigate the issues at Darlington and Pickering and to develop options which would address OPG's D₂O management needs.

The main objectives of this project are as follows:

- 1. Improve the detritiation process within OPG.
- 2. Improve operational flexibility and ability to segregate different streams of D₂O to support normal operation and outages.
- 3. Improve the management of drums in the station and to reduce to associated drum handling-related, radiological and conventional safety hazards.
- 4. Allow Isotope Sales Department to pursue new business opportunities.

Plant Life Extension and P2/P3 decommissioning are not part of the scope of this project. However, the impact of plant life extension on this project was considered in the choice of location (Reference Section 3).

With respect to DNGS, the Kinectrics study identified problems in three areas of the D₂O Management System with regard to the project objectives. They are reactor grade D₂O storage, downgraded D₂O storage, and drum storage and handling.

rea 1: Reactor Grade D₂O Storage

Storage & Inventory (S&I) Tanks are used for the storage of reactor grade D₂O such as TRF Feed, TRF Product, Moderator D₂O, PHT D₂O, and Station Upgrader Product (SUP).

PROBLEMS	ISSUES	CONSEQUENCES/IMPACTS		
 Lack of storage at DIOTS limits TRF flexibility to build up a large volume of Hi-Ci feed stock and/or Low Ci TRF product. 	 TRF's Hi-Curie (Ci) feed stock relies heavily on the ability from other stations to ship, and that their shipment may not align with the TRF availability or ability to receive. Inadequate volume of tankage for low Ci TRF product to fully support OPG's detritiation program or to support lsotope sales. 	 Inefficient use of TRF & OPG resources as less overall tritium is removed from the entire fleet of nuclear units for the same TRF operating costs. The inability to fully support PNGS's detritiation program endangers PNGS's OP&P limit. Inability to meet contractual obligation (estimated in loss of revenue through Isotope Sales, at the since 2001 from the same 2001 from pursuing new business with domestic customers of up to the same 2001 form the same 2001 fo		
2) Insufficient storage space to support moderator drain in a planned outage.	 All existing moderator grade D₂O must be emptied out (~ 100Mg) & relocated from S&I tanks to DIOTS or offsite to accommodate a moderator drain. 	 If DIOTS is used, then this interrupts TRF shipping & receiving (see item #1) May require offsite storage which can cost \$1.5M for each occurrence. Risk of delaying outage if offsite storage is unavailable. 		



BUSINESS CASE SUMMARY

PROBLEMS	ISSUES	CONSEQUENCES/MPACTS
4) Insufficient storage space to support SCO or VBO.	 More PHT grade D₂O must be accumulated prior to an SCO or VBO to accommodate 4 units shrinkage & loss make-ups 	 Failure to accumulate PHT D₂O could potentially cost OPG (140Mg) from an external source. Risk of delaying outage if external source is unavailable.
5) Insufficient storage space to support PHT Low Level Drain (LLDS) in SCO/VBO	• With the extra PHT grade D ₂ O accumulated prior to SCO/VBO there is insufficient storage space to accommodate the swell associated with re-starting 3 units while the 4 th unit remains in the LLD state	 If PHT grade D₂O is stored in the moderator S&I tanks to accommodate the swell & LLD it increases the risk of downgrading moderator grade D₂O, with a potential cost to OPG of \$1.5M to re-upgrade. If DIOTS is used to store PHT D₂O see item #1.

Area 2: Downgraded D₂O Storage

2.2

Downgraded D₂O storage tanks are used at the IXCU for the collection and process of downgraded recovery water

PROBLEMS	ISSUES	CONSEQUENCES/IMPACTS
6) Insufficient downgraded D ₂ O storage space to support acute recovery events or SUP outage.	• Alternate temporary storage methods such as using reactor grade D ₂ O tanks at DIOTS or drums to bridge the gap.	 Increased risk of downgrading reactor grade D₂O. This situation downgraded 60Mg of moderator D₂O in 2003, which cost DNGS approximately \$0.9M to upgrade.
		The use of drums increases housekeeping issues, and add drum purchasing cost of approx. \$30K / yr.
· · · · · · · · · · · · · · · · · · ·		Also see item #1
7) Insufficient downgraded storage to provide operational flexibility when	• When high TOC levels are present in the downgraded D ₂ O after being processed through the IXCU system	 The SUP is forced to go onto reflux due to lack of feed while the D₂O is being cleaned up, (SUP capacity factor reduced).
processing high TOC D ₂ O.	the TOC must be removed prior to processing through the SUP. After the TOC is removed, via the UV system, this D_2O must then be reprocessed	 The recycling of 'UV processed' D₂O through the IXCU further reduces the downgraded storage availability.
	through the IXCU to remove increased conductivity created by the UV system.	 It may also lead to storing downgraded water in DIOTS or in drums (see item 1).
8) Insufficient downgraded storage space and flexibility to support the efficient segregation and processing of high and low Ci recovery streams of	 During an extended TRF outage, the only source internal to DNGS to obtain more low Ci make-up PHT D₂O required to keep DNGS units within OP&P limits is by processing the high and low Ci recovery streams 	 The lack of downgraded storage space requires more switching between the 2 streams & thus requires more flushing which reduces the availability of low Ci products. If the amount of PHT makeup D₂O falls below 210Mg then DNGS would be required to:
D ₂ O during an extended TRF outage.	separately through the "single" clean- up and upgrading system. When switching from high Ci to low Ci	a) Lease low Ci D ₂ O from Control which had cost OPG Control ay.
	stream, low Ci D_2O is required to flush	b) Mix in available higher Ci D ₂ O with the
	to a system (creating a mid CL product) for a sufficient fime before the low Ci	aveilable bower Ci DiO this would excluse
المحتور والعارضة والمراجعة المرقع الرقعية ترجعهم والعرفين والمروم العارو والعار والمحافظ المواجر والمروم	product is produced at the SUP	the tritium levels in the PHT system) to maintain the level. This increases the risk



BUSINESS CASE SUMMARY

yang ng sang ng	fuel burn-up cost.
	 c) Use virgin D₂O as makeup to the PHT system. This will cost OPG \$300 /Kg.
	 The frequent switching of streams further stress the inadequacies of downgraded storage (see item 6 & 7).

Area 3: Drum Storage and Handling

This area is required to receive, ship and handle (ie: pressure testing and cleaning) drums used by the DNGS units to temporarily store recovered D₂O, store downgraded D₂O with high TOC for processing, or from external sources in support of lsotope Sales.

PROBLEMS	ISSUES	CONSEQUENCES/IMPACTS
9) Insufficient floor space available in the HWMB to store & handle D ₂ O drums.	 Drums are spread around in the HWMB and inside the station. Some of the locations that are storing these D₂O drums may not be designated normally for this purpose. Increase rework as drums need to be moved around or relocated more than once. Minimal space available for drums from external sources. 	 D₂O drums that are stored in re-designated areas can impede normal flow of operation & increase chance for human performance errors. Increased difficulties to maintain proper housekeeping within HWMB or the station. Increased workers' health and safety concerns with additional drum handling. An inefficient use of Operators. Restricts Isotope Sales from pursuing new business, (i.e. importing drums of D₂O from foreign customers). This contributes to a potential increase revenue up to \$4M/yr
10) Lack of on-site drum pressure testing facility, and or cleaning facility.	 Drums are sent off site to be pressure tested before they can be reused for D₂O shipment. Lack of available clean drums requires operators to re-using dirty drums that will contaminate relatively 'clean' D₂O. 	 Cost of external testing of drums is a second sec



Page: 6 of 19

BUSINESS CASE SUMMARY

3/ ALTERNATIVES AND ECONOMIC ANALYSIS

	A. States	Alt 1 (Recommended)		Alt 2	Alt 3	Alt 4	Alt 5
\$ 000's	Choose One	Full Cost	Incremental Cost	Delay			
Revenue		87,790	87,790	69,610			
Project Cost		(34,588)	(34,588)	36.639		······································	
NPV (after tax)	(9,206)	4,448	4,448	(3,905)	• • • • • • • •		
Impact on Economic Value (IEV)		13,654	13,654	5,301			/
IRR%	N/A	14.8%	14.8%	N/A			
Discounted Payback (Yrs)	N/A	9.8	9.8	N/A	· · · · · · · · · · · · · · · · · · ·		

Status Quo - Not Recommended

Maintaining the status quo is not recommended. Continuing to operate as is will result in DNGS experiencing the current issues identified in section 2 with associated costs and risks.

The lack of TRF Feed and Product storage limits HWMB's ability to receive and store D₂O. This restricts its ability to process more high Ci feed, which contributes to the inefficient operation of the TRF, and limits TRF from processing more D₂O from external customers (the customer contributes to the inefficient operation of the TRF, and limits TRF from processing more D₂O from its detribution program which causes continued increase in the tritium levels in OPG, particularly at Pickering. Increasing tritium levels result in increased tritium emission with environmental impacts, increased fuel burn-up costs, increased dose expenditure and regulatory impact due to potentially exceeding the OP&P limits.

The lack of D_2O storage limits DNGS's ability to plan and execute its maintenance outages for the station, SUP and TRF with the following potential costs and risks; \$1.5M to ship moderator D_2O off site, \$1.5M to upgrade D_2O , and/or to lease low Ci D_2O for PHT make-up.

The lack of recovery storage limits DNGS's ability to support acute events and high TOC recoveries. This causes backlog at the cleanup systems and increases the use of drums. As the station ages and more maintenance is performed on reactor systems, more acute events and recoveries with high TOC are anticipated. It also limits DNGS' ability to recover adequate low Ci products to support units' operation during an extensive TRF outage.

The lack of space to store drums results in poor housekeeping in the station & HWMB, and inefficient use of operator resources, which costs DNG approximately \$64K/year. Workers will continue be exposed to increased health and safety concerns related to drum handling. Also, the lack of drum storage restricts isotope Sales from pursuing new external customers, contributing to the potential to the potential to increased sales.

Without a drum testing facility, DNGS will have to incur an expense of approximately to continue to ship drums offsite for testing, which limits its flexibility to manage its shipments in a timely manner.

Alternative 1 - Build a 26m x 12m addition with 8x50Mg storage tanks and with drum storage and testing facilities - Recommended

Construct a 26m x 12m HWMB extension to house 8x50 Mg multi-purpose storage tanks, a 12m x 14m drum storage area, and drum testing facility.

Tank ID	Tank Spec	Proposed usage
1A/1B	2 x 50 Mg - class III	High Ci - Moderator/TRF Feed/SUP Product
2A/2B	2 x 50 Mg - class III	Low Ci - PHT / TRF Product
3A/3B	2 x 50 Mg - class III	Downgraded Dirty
4A/4B	2 x 50 Mg - class III	Downgraded Clean

be additional multi-purpose tanks can be used to store either reactor grade D_2O or downgraded D_2O . This addition will address all the problem areas, minimizing the risks and costs identified above.



Page: 7 of 19

BUSINESS CASE SUMMARY

It will also achieve the main objectives of this project

1. Improve the detritiation process within OPG:

The additional reactor grade D_2O storage at DNGS allows more schedule flexibility to ship or receive D_2O to/from the TRF to support OPG detritiation program. This additional flexibility can help to relieve some storage pressure at PNGS as their high Ci D_2O can be shipped for detritiation more readily. The additional space also allows TRF to accumulate a larger volume of high Ci D_2O to support continuous TRF detritiation operation and to accumulate a larger reservoir of TRF product to support OPG operations or detritiation efforts. This will improve TRF efficiency and the annual TRF's through-put as more tritium is removed for the same unit operating cost and will relieve some reliability pressure on TRF.

2. Improve operational flexibility to segregate different streams of D2O:

The additional reactor grade D_2O storage will allow storage of either high or low Ci products. This improves flexibility for D2O movement & planning and enhances shipping & receiving capability. It also provides additional reactor grade D_2O storage capacity to support moderator drains, SCO/VBO and extended TRF outages without having to ship D_2O off site or deal with the risk of downgrading reactor grade D_2O .

The additional downgraded D_2O storage will provide adequate storage capacity to support normal operations and outages even during acute recovery events or high TOC scenario. This will ensure 'clean' feed is always available to the SUP and reduces the amount of time it is forced to go into reflux mode and improve SUP capacity factor. It will also reduce recovery backlogs, operator work-arounds and amount of drumming required during acute events, which further improves housekeeping and associated worker health and safety issues. The additional downgraded storage also improves the flexibility to process the high or low Ci recovery streams separately with less switching of streams when processing through the SUP. This improvement allows more low Ci D_2O to be available during an extended TRF outage, thereby reducing the risk & cost of leasing low Ci D2O from other sources.

. Improve the management of drums :

A new 'designated' Drum Storage & Handling Facility (DS&HF) in HWMB that can store up to 350 drums will allow all D₂O drums to be stored in a central location. This capability will improve the management of drums & D₂O inventory. The facility will improve housekeeping, reduce rework and reduce drum handling-related radiological and conventional safety hazards

A new Drum Testing Facility (DTF) will eliminate the costs associated with having drums tested by a 3rd party including shipping and handling cost. It will allow HWMB to manage its drum QA requirements in house and provide the flexibility for operations to certify drums on a as needed basis to meet sales commitments.

A new Drum Cleaning Facility (DCF) will be proposed to be installed in PNGS. The new DCF will help in the overall management of drums within OPG.

4. Allow Isotope Sales Department to pursue new business opportunities

The operational improvements in the HWMB and the improved efficiency of the TRF will provide the flexibility and capacity for Isotope Sales Department to meet current contractual obligations and to pursue new business. The forecast for the increased business is estimated to be **definite the increased** business is estimated to be **definite the increase**.

Note: The recommended modification is less than what was originally proposed in the Charter. This recommendation was reviewed and subsequently agreed to by the stakeholders in the Project Challenge Meeting on August 18, 2006 that it can satisfy their needs and resolve the issues at DNGS.

ONTARIOPOWER GENERATION	OPG Confidential Page: 8 of 19				
	BUSINESS CASE SUMMARY				

Alternative 2 - Delay Project - Not Recommended

Delaying the project is not recommended. This would require DNGS to continue its dealing with current operational issues and the risks & costs similar to the "Status-Quo" option longer and reduce the number of years available to recover project costs through increased sales.

If OPG makes the final decision on Plant Life Extension (PLE) in the future, the proposed site location for this project will still have sufficient space to build a second addition to install more D₂O tanks. An alternative option is to include a basement area in the current proposed site to accommodate more D₂O tanks in the future when needed. However, this decision must be made now in order to be incorporated into the current design, and this will increase the current cost estimate and further impose project risks from any unknown discoveries when the geotechnical analysis of the soil is performed.

Alternative 3 -	- Not Recommended
Alternative 4 –	- Not Recommended
Alternative 5 -	- Not Recommended





ONTA	RIO	POi	NER	
		GENE	RATION	

BUSINESS CASE SUMMARY

4/ THE PROPOSAL

The following are the objectives and deliverables of this Developmental Release BCS:

- Prepare and award a Design contract for Preliminary Engineering & Detailed Design
- Complete Preliminary Engineering, (up to 40% Detailed Engineering).
- Issue Tech Spec for Long Lead Material
- Review/approve Preliminary Engineering
- Initiate Detailed Design
- Prepare Preliminary PEP
- Issue a Partial Release BCS

Refer to Appendix C for a list of the project milestones.

5/ QUALITATIVE FACTORS

The successful completion of this project will improve the following:

- Sovernment Relations
 - Reduce tritium emissions throughout OPG
 - Reduce risk of infringing on regulatory limits

Customer Relations

 Increasing OPG's capability and flexibility to process D₂O will improve customer relations by meeting contractual obligations with Bruce Power for detribution services and provide the ability to increase detribution services.

Technical/Operational Considerations

- Improve efficiency of TRF operation and increase the overall amount of tritium removed from the OPG D₂Q inventory.
- Improve availability of low Ci reactor grade D₂O for operational & outage needs
- Improve HWMB capability & flexibility to support any outage or acute events thus reducing the risks and cost to extend an outage.
- Improve management of detritiation programs particularly at Pickering by reducing the dependency on TRF availability

Health & Safety

- Reduced tritium levels will reduce worker dose.
- Additional drum storage will improve housekeeping and reduce drum handling requirements, thereby reducing the
 related health and safety concerns.
- Reduce operator work arounds and extra operator actions that are required to maneuver various grades of D2O into unconventional storage arrangements.



en andere van en de en de en de en de en de en de en de en de en de en de en de en de en de en de en de en de e

NTA AD Parts	OPG Confidential	0	Page: 10 of 19	
GENERATION		BUSINESS CASE SUMMARY	RY .	
el Risks				
Description of Risk	Description of Consequence	Risk Before Mitigation	Mitigating	Risk Atter Mitigation
	·			
Overal project cost exceeds current estimate	Unable to accomplish all project objectives without further release of funds	High	Detailed conceptual study completed by Kinectrics. Helyar review of project cost. Adopt optimal contracting strategy to mitigate cost excalation. Further fine tuning of overall project schedule and cost via partial BCS.	Medium
Changes to the funding release strategy and/or fine tuning of contracting stategy may impact overall cost and schedule	Could cause a delay to the schedule & increase costs	High	Review contracting stategy and design and installation requirements with Supply Chain, Procurement, Design & Legal	Medium
Second		1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1		
Preliminary/Detailed Design may result in an increase in scope.	Changes in scope will delay the schedule and add cost to the project.	Medium	Further scope identified during preliminary design will be challenged by projects & have to be agreed by all stakeholders & sponsor.	Low
Schedule				
Defay in the issuing of Design contract due to rigorous management, supply chain arti legal reviews of the RFP.	Schedule delay	ЧĜН	Early involvment of Supply Chain, Legal, Taxation etc to ensure that all the required information is included in the RFP	Medium
File turning of contracting stategy may impact overall cost and schedule	Require changes to funding release strategy which could cause a delay to the schedule & costs	hgh	Review contracting stategy and design and installation requirements with Supply Chain, Procurement, Design & Legal	Medium
determine accurately the	Delay to schedule	Medium	Fine tuning of final design deliverables timeline is available via partial BCS	Low

						Pow	Low	ملکنات سیاستیند ایران در ایران ایران میلید. ملکنات سیاستیند ایران در ایران در ایران میلید.	Low	Low	Medium	
	Page: 11 of 19	ARY		Select approved vendor, provide clear scope & deliverables. Review progress regularly & establish and monitor effective design performance metrics.		Design will be contracted out to external agency. OPG Projects Design have committed to provide DTL support for this project.	Obtain OPEX from other OPG projects of similar nature, early involvment with Supply Chain and various other deparments or potential vendors and the associated contracting strategies.		Seismic qualification considered as part of conceptual study. Seismic qualification requirements to be included in Preliminary Design	Test drill site to determine the soil composition prior to completing preliminary engineering to ensure the design takes this into account. Method & cost to implement corrective actions will be challenged & documented.	Site walkdowns have been completed. Complete drawing review on system impacted during Preliminary Engineering, and ensure there are open dialog with other projects.	Drawing rieview has been conducted to identify any possible underground services that may require relocation. Field survey to be completed during Preliminary Engineering
		CASE SUMMARY				High	Medium		High	Medium	Medium	
	OPG Confidential	FION BUSINESS		Delay to schedule		Delay project schedule & milestones.	Delay in issuing contract due to need to amass variuous interfacing risks and vendor qualification issues and contracting language.		Increase cost to the project due to unkown civil upgrade to meet the seismic requirement.	Delay and added cost to the project due to the prefered site not being suitable for building addition. Increase cost to the design and installation to meet the requirements identified	Re-eingineering may be required if there are legacy and interface issues with systems that the project is modifying. This would add scope to the project which may cause delays and will increase project costs	Changes in scope will delay the schedule and add cost to the project.
	DI FRIOPOWI	GENERAL	timeline of design deliverables	Design deliverables not on	Pisonos a survey a survey a survey a survey a survey a survey a survey a survey a survey a survey a survey a s	Insufficient OPG design resources available	Availability of qualified vendots to perform design and subsequent implementation		sting seismic requirements	Discoveries from geotechnical and the soil	Lebacy issues on Design, and intertate issue with other related D2O projects	Indreased scope of work due to tissavery work
17 Ke ADES		₩3 ₩+3 - ₩	tine		B		Sups Sups					

		Low			Low	Low	Low	
Page: 12 of 19	LRV	Identify required time allowance in project schedule. Incorporate approved time in contracting strategy. Review OPEX with other similar projects			Line management was involved in provoding the information based on historical perfomance of the system	The current NPV and IRR indicate a positive return on investment before stations' end of life. Impelement ongoing TRF improvement initiative to improve reliability	Using the current forecast of DNGS end of life date the current NPV and IRR indicate a positive return on investment before stations' end of life	
	L CASE SUMM/	Medium			Medium	Medium	мол	
OPG Confidential	10N BUSINESS	Delay in project & potential cost impact to contract			NPV and IRR results may be less optimistic than calculated	Insufficient time to recover capital investment before stations' end of life	Insufficient time to recover capital investment if end of life is earlier then currently forecast	
N FRIDPaus	GENERATI	Regulatory approvals (CNSC & ITSSA) requiring more time then anticipated	Eevimental	Health & Safety	obtained from stakeholders	Inability to recover investment such as TRF production is untellable	Early and of life of DNGS or THF	
) > ~~	the man	LI KI	H	ottan was r	Insbillty to such as T untellable		·ϪϷ;;;ϴͺ;;;ϴϳʹ;Ͼ;;ʹϼʹ;Ͽʹ;ʹʹ;ϲͻϳϸʹϪ;ͻϧͺϨ;ϒϧϲϫϲϒϲʹ;ϲʹ;ϲʹ; ϲϧͺϲ;;ϲ

7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Final AFS	Targeted PIR Approval	PIR Responsibility
	Date:	Date:	(Sponsor Title)
TBD in Next Release	TBD in Next Release Choose Year	TBD in Next Release Choose Year	Rumina Velshi

Comments:

	Measurable Parameter	Current Baseline		How will it be measured?	Who will measure it? (person / group)
1.					
2.					
3.		<u> </u>			· · · · · · · · · · · · · · · · · · ·
4.	····· •• •• •• •• •• •• •• •• •• •• •• •		******	· ···	·
5.		· · · · · · · · · · · · · · · · · · ·			

ander in the second of the second states and the second states of the second second second second second second



Appendix "A"

Glossary (acronyms, codes, technical terms)

AECL - Atomic Energy Canada Limited AFS - Available for Service **CNSC - Canadian Nuclear Safety Commission** DG - Downgraded D₂O - Heavy Water DIOTS - Darlington in/Out Transport System EC - Engineering Change EOL - End of Life HWMB - Heavy Water Management Building IXCU - Ion Exchange Clean Up LLD - Low Level Drain NPV - Net Present Value **OP&P** - Operating Policies and Principles PHT - Primary Heat Transport RFP - Request For Proposal RG - Reactor Grade SCO - Station Containment Outage S&I - Storage and Inventory SUP - Station Upgrader TDO - Tritiated Heavy Water TOC - Total Organic Carbon TRF - Tritlum Removal Facility TSSA - Technical Specification UV - Ultra Violet VBO - Vacuum Building Outage



Appendix "B"

Project Funding History

Choose			Previous Releases (incl contingency) Cumulative Values								
Release Type	Month	Year	2004	2005	2006					Later	Total
None	.,					1				1	0
						i				1	0
					,						0
<i>,,,</i>										í ľ	0
						i				-	0
											0
	_										0
										;	0
									··· · ·· · -		
LTD Spent											0

Comments:

The current estimate of \$36.4M (including contingency and interest) is a conceptual quality estimate (estimate band of +60% to -25%), and has an estimated available for service (AFS) date in Q4 of 2010. The estimate has been independently verified by Helyar (\$35.7M). The variance between the two project cost estimates is due to labour escalation each year and additional Project Management resources are required to complete close-out in 2011 which were not included in the Helyar estimate. Given that the estimate is performed based on conceptual information, there is a risk that this estimate may escalate (refer to section 6 Risk Table).

Project funding in the amount of (excluding contingency) is listed in the current approved Business Plan 2007 to 2011. The variance to the business plan will be addressed through the portfolio management process. There is \$0 capital spending released today to this project.

ONTA	RIOPOWER
	GENERATION

n de la completa de la completa de la completa de la destructura de la dedecidad de la completa de la devición de la definición de la d

BUSINESS CASE SUMMARY

Appendix "C" Financial Model – Assumptions

Project Cost Assumptions:

OPG staff will provide project management & support role during design and implementation Material cost assumptions based using class 3 tanks, hangers, piping and associated equipment Design and installation work will be contracted out

Financial Assumptions:

Escalation rate of 2% on revenues Escalation rate of 3% on employee wages See attached for assumptions regarding NPV calculations

Project / Station End of Life Assumptions:

Darlington end of life is 2019

Energy Price / Production Assumptions

N/A

Operating Cost Assumptions

New operating costs are negligible. Cost to upgrade D₂O

Other Assumptions:

OPG to provide unrestricted access to work area All work is within the secured area with incumbent restrictions All Nuclear grade materials purchased by OPG

OPG Confidential

Page: 17 of 19

BUSINESS CASE SUMMARY

Project Name 16 - 31555

Partial Release Business Case Summary D-BCS-38000-10001-R001

Attachment "A"

Project Cost Summary

\$000's	LTD Prior Yr	This Release	This Release	Future Release	Future Release	Future Release	Future Release		
Capital		2007	2008	2008	2009	2010	2011	Later	Total
Project Management (OPG)		546	390	454	1,020	948	152		3,510
Engineering & Drafting (OPG)	,	379	195	236	280	679	226		1,995
Material									
Installation - PWU, BTU									
Contract - Design			<u> </u>					_	
Contract - Installation									
Contract - Other									
		11.1							
Interest (Capital Project Only)									
Project Costs (excl contingency)									
General Contingency									
Specific Contingency									
Project Costs (incl contingency)		1,872	1,728	3,992	13,253	14,938	600	<u></u>	36,383
2006-2010 Business Plan		1,500	1,800	6,700	4,700	5,000			19,700
Variance to Business Plan		(59)	(481)	(3,605)	5,559	6,628	458		8,500
Committed Cost		~	-	•	-	-	-		-
Inventory Write Off Required	1	-		~	-	•	-		-
Spare Parts / Inventory	1	-	-	-	-	•	Į		+
Total Release (exci contingency)		1,441	1,319	3,095	10,259	11,628	458		28,200
Total Release (incl contingency)		1,872	1,728	3,992	13,253	14,938	600		36,383
Ongoing OM&A (non-project)							SP (P)		
Removal Costs (incl in above)	in the		الى يې الى يىلى	Contraction of the	3			200	

s states and set		Basis of E	stimate		1 m 1	
Design Complete		Zero to Minimal	Quality of E	Estimate	Conceptual +	- 60% to - 25%
3 rd Party Estimate	Yes	OPEX used	Yes	Lessons Le	arned	Yes
Reviewed by Sponsor	Yes	Budgetary Quote(s)	Yes	Phase 1 Act	tual Used	N/A
Similar Projects	Yes	Contracts in place	No	Competitive	Bid	N/A
	19. St. St. St. St. St. St. St. St. St. St	Variance to Ru	sinces Olan	1 3.7 1	······································	

Variance to Business Plan

The estimated variance(s) to the 2007-2011 Business Plan will be addressed through the portfolio management process. A PCRAF will be approved by Jan 2007.

Reviewed By: Stephanie Tham Project Manager Date:

and the state of the second state

Approved By:

Peter Floyd Eng & Mods Manager (Strat IV)

Date:



and a state of the

BUSINESS CASE SUMMARY

Project Name 16 - 31555

Partial Release Business Case Summary D-BCS-38000-10001-R001

Attachment "B"

Project Variance Analysis

		Choo	se One		F. S. S.			
Capital	LTD Nov 2006	Last BCS N/A N/A	This BCS Nov 2006	Variance		Comments		
Project Management (OPG)				0		<u> </u>		
Engineering & Drafting (OPG)				0				
Material								
Installation - PWU, BTU	1 -							
Contract - Design								
Contract - Installation	1 K							
Contract - Other	,					· · · · · · · · · · · · · · · · · · ·		
	1.							
Interest (Capital Project Only)								
Project Costs (excl contingency)								
General Contingency								
Specific Contingency	2							
Project Costs (Incl contingency)	0	0	0	0				
Committed Cost				0				
Inventory Write Off Required]			0				
Spare Parts / inventory		1		0				
Total Release (incl contingency)	0	0	0	0				
Total Release (excl contingency)	0	0	0	0				
e Junited					·····			
Ongoing OM&A (non-project)				0				

nen sen en la sen de la la de

COLORADOR FREE CONTRACTOR STATE

Comments:

Removal Costs (incl in above)



BUSINESS CASE SUMMARY

Attachment "C"

Key Milestones

Co	mpletion	Date	Description
Day	Mth	Yr	
30	NOV	2006	Developmental BCS Approved
01	FEB	2007	Project Start
10	May	2007	Major PO/Contract Award - Design Contract
19	SEP	2007	Long Lead Material Identified
01	NOV	2007	Partial BCS Approved
22	NOV	2007	Preliminary Design Complete (40%)

A Project Execution Plan (PEP) will be approved by May 2007

Comments:





Attachment to D-BCS-38000-10001-001 NPV Calculation Assumptions for Revenue & OM&A Costs

Category	Cost	Rational		
CAPITAL EXPENDITURES	\$36,388,000	Cost to build HWMB addition, inst 400Mg of new tanks, drum storage area & drum pressure testing equipment. (including testing contingency & the interest)		
OM&A Costs				
New Drum Purchases		Drums assumed drum -> 300 drums x over 5 years		
Cost to ship 100 Mg of Moderator D2O off site		Cost to ship 100 Mg of D2O and have it stored at the store at a moderator Drain accommodate a Moderator Drain estimated @ once every 2 years		
Cost to re-upgrade D2O in the event of downgrading reactor grade D2O.	\$1,500,000	20% chance of downgrading event of 100 Mg Eliminate the practice of using S&I or DIOTS tanks to store downgraded D20 during TRF & SUP outages		
Cost to borrow Low Cí D2O from AECL to provide PHT make-up duríng SCO/VBO.		 # Constant of the second		
Operator time lost due to moving drums to make space	\$64,000	800hrs @ 80/hr=64000		
Cost to pressure test drums off site		Contraction 200 drums/year =		
ADDITIONAL/NEW REVENUE		Detritiation services for new Units		
Bruce Power		starting @		
External Russinger (average conceits)		Excess capacity of TRF Carlor \$ Provide detritiation services to Carlo		
External Business (excess capacity)		Import more drums of D2O from external customers disclosure cleanup D2O and sell to the for loss makeup		
Additional sales				









DNGS Maintenance Facility 16 - 31717

Partial Release Business Case Summary D-BCS-28200-10003-R000

Routing	Location	Action	Signature	Date
Shawn Bremner				
MTL, Design Projects 701-2070	P72-3	Prepare BCS	SLA	31/30-1/2008
Mike Nairne			26-2	1.10
Project Leader, Design Projects 701-3571	P72-3	Review BCS		4/FEA/2008
Stephanie Tham			VY DEGAL 12 Mart	tour f
Project Manager, Design Projects	P72-3	Review BCS	I an Eng	
701-4203			for Stephanie Ham	1/Feb/2008
Dianne Gaine			The standard train	
Manager, Design Projects 701-4181	P72-1	Review BCS		
Mark Arnone			Juane Mine	FEG 4/08
Director, Projects & Modifications	072.4	D		1 1
701-6063	P72-1	Review BCS	12 le	4 FEB 2008
Dwight Zerkee				<u> </u>
Manager, Investment Management	P82-3A6	Review BCS	5	10,00
702-5058				1Feb 08
James Whyte				
Manager, Maintenance Production	D01-A2	Review BCS	tonesci Sinte	14 FES 08
au Seedhouse				
Director, Operations & Maintenance	D01-OSB2	Derive Doo		
703-7496	001-0382	Review BCS	Stort	15feboy
Randy Leavitt				13.090
Director, Nuclear Investment	P823-315	Deview DOD		
Management	rozo-010	Review BCS	tale water	Feb 20, 2008
702-6878 Wayne Robbins				
SVP - Darlington	D08-ES3	Davis DCO	ale all	
_	000-200	Review BCS	HuneRobby	208-02-25
Jim Beech		+	<i>pl</i>	
/P Nuclear Finance	TCH07-E19	Review BCS	17	As 25 205
			$ \lambda $	pro co, coos
Donald Power		1		
/P Corporate Investment Planning	TCH07-D06	Review BCS	1 The	VI I
Om Mitchell	2/08		Alterna 1	Hery 20/2000
NO Addad	P826A-1	Cubril DOO	00	31
executive autral lynd of 5	FOZDA-T	Submit BCS	Musilee	MAR 08
onn Hanbidge 0				08
SVP & CFO	TCH19-F27	Approve BCS		
			thear h	1 22/0 ·
Pierre Charlebois				J. J.
Chief Operating Officer	TCH19A21	Approve BCS	V V	
			C. C. C. C. C. C. C. C. C. C. C. C. C. C	Frang 2 6/08
m Hankinson	TCH19-A24	Return	Para	
resident & CEO	FULLO PLET	For Distribution	Man	May26/08
	···		<u> </u>	1-100



BUSINESS CASE SUMMARY

DNGS Maintenance Facility 16 - 31717

Partial Release Business Case Summary D-BCS-28200-10003-R000

1/ RECOMMENDATION:

Approval is requested for this Partial Release of \$6,935K capital (including contingency) to facilitate the demolition of the Power House Annex (PHA), FE Calibration Shop, Bldg 6 Security Change Room, & ERT Offices at Darlington as well as to complete the design for the relocation of buried services and to start the Preliminary Engineering portion only for the new Maintenance Facility. At this stage, present estimated total project cost is \$44.6M (\$57.7M including contingency) \$1,600K of which is required for building demolition. A Full Release BCS is scheduled for May 2009.

The objective of this project is to provide new permanent shops and office space for DNGS maintenance staff with a safe and effective work environment. Failure to implement this improvement would leave the station vulnerable to decreases in maintenance productivity and effectiveness, potential increase of industrial accidents, and potential outage extensions due to lack of facilities for rehearsal space for RM and IMS.

The (PHA), FE Calibration Shop, Bldg 6 Security Change Room, & ERT Offices are in the footprint of the proposed new site of the Maintenance Facility and must be removed as a pre-requisite. These buildings are vacant and life-expired and will require removal regardless of whether the new Maintenance Facility goes forward as a Project.

This Partial Release BCS strategy has been adopted to facilitate removal of the PHA in 2008 and to facilitate timely engagement of engineering activities to minimize cost and schedule risks of the overall Maintenance Facility Project by obtaining a clearly defined scope of work for the buried services relocation and building plant and service tie-ins prior to the issuance of the EPC contract

Specifically, this Partial Release will complete:



Decommissioning and removal of the existing DNGS PHA, Security Change Room, FE Calibration Shop & ERT Offices. Detailed Engineering of the Buried Services relocation and Tie-Ins required at the proposed site of the new Maintenance Facility.

- Issue Request for Proposal (RFP) and evaluate bids for a contract to install Tie-Ins and Buried Services relocations.
- Issue an RFP and complete bid evaluations for a Commercial Engineer, Procure, and Construct (EPC) contract for the new Maintenance Facility.
- Preparation of PO for the Preliminary Design portion for the Maintenance Facility to start design work for the new maintenance facility.
- Prepare a Full Release BCS.

Acres Sargent & Lundy (ASL) was commissioned to perform a study and develop several alternatives based on the priority of needs specified by the sponsor. The option selected by management is a new 2 story 60,000+ sq. ft building which meets all the needs identified except a welding shop.

This project will be executed between 2007 and 2011:

- 2007 Preliminary Design for the PHA removal. (complete)
- 2008 Removal of the PHA and associated buildings.
 - Complete Detailed Engineering for the Buried Services relocations and Tie-Ins at the proposed site.
 - Issue an RFP for a Commercial EPC contract for the proposed new Maintenance Facility, receive & evaluate bids.
- 2008/09 Preliminary and detailed design of the Maintenance Facility.
- 2010/11 Construction and turnover of the Maintenance facility to OPG Operations and Maintenance.
- 2012 Close-out

Note that this project estimate does not include costs for moving existing maintenance equipment, purchase of new maintenance equipment, purchase of radiation monitoring equipment.

Full project cost estimates are conceptual at this time (+60% / -25%) and include approximately the contingency. Before conceptual at this time (+60% / -25%) and include approximately the contingency. Before conceptual full funding release, detailed estimates will be completed and independently validated by a third party vendor.



Fi Executive Control limit of \$50 Million has been placed on the project as a whole; expenditure beyond this limit must receive formal approval by the Chief Nuclear Officer and the Chief Operating Officer prior to expenditure or cost commitment.

OPG Confidential

Page: 3 of 22

BUSINESS CASE SUMMARY

Ar [eci contrigency]	Funding	LTD 2007	2008	2009	2010	2011	2012	Later	Total
Currently Released	Developmental	1,369	234	- +	-!				1,603
Requested Now	Partial	(861)	3,960	3,836					6,935
Future Funding Regid	Full	/ 1/ -		15,096	19,985	13,599	521		49,201
Total Project Costs	ŧ	508	4,194	18,932	19,985	13,599	521		57,739
Other Costs	· · · · · · · · · · · · · · · · · · ·				'	1 4 -	ا ب		•
Ongoing Costs Grand Total	• • •	508	4,194	18,932	19,985	13,599	521	•	57,739
inerestanti Sentati		Ciao Capit	• · · ·	(IEV) Impact a S1.48	n Co Value	98 11.45	•		

Submitted By: 1 May 08, 2005 Date: ere. Tom Mitchell CNO

Finance Approval: Y Donn Hanbidge SVP & CFO Date:

Line Approval (Per OAR Element 1.1 Project in Budget):

May il/og Date: hork ikinson Fresident & CEO





BUSINESS CASE SUMMARY

BACKGROUND & ISSUES

DNGS needs to improve its overall maintenance capability to support continuous station operations in a safe and cost effective manner. Darlington initially commissioned a study of a Maintenance Facility under a partial release in 2002, that release was later cancelled due to changing station priorities. Subsequent studies by Wardrop (2005), Acres Sargent & Lundy (ASL) (2006), and most recently ASL to provide a revision to their 2006 study were commissioned; several iterations to the study were required due to changing maintenance strategies, changing management directives, station priorities, and budgetary constraints on the scope of the work.

The Maintenance Facility Conceptual Study rev 00 performed by ASL, which was issued November 13th, 2006, had four developed layouts and conceptual cost estimates, which significantly exceeded the portfolio budget. A new scope of work was provided by the Sponsor on December 13th, 2006 with scope ranked by priority and a cost ceiling for the new Maintenance Facility. ASL was re-engaged and an additional three new conceptual layouts, schedules, and cost estimates produced as a result of the iterations required to be developed to determine the optimal building layout while adhering to the stipulated scope priority and budget limitation.

The (PHA), FE Calibration Shop, Bldg 6 Security Change Room, & ERT Offices are in the footprint of the proposed new site of the Maintenance Facility and must be removed as a pre-requisite to the new build. These buildings are vacant and life-expired and will require removal regardless of whether the new Maintenance Facility goes forward as a Project. The removal & decommissioning cost is estimated at \$1.6M (+60/-30%) and was obtained from rev 00 of the ASL conceptual report. The current construction change room is also in the foot print of the proposed Maintenance Facility. The removal of this building is being completed under project 31718 "New Construction Change Room".

As a result of DNGS progressing through its life cycle, changes in technology, new maintenance strategies, and loss of expired temporary buildings, the current maintenance facilities at Darlington are no longer adequate. The issues that were evaluated to develop the recommended option include the following:

ncreased Maintenance Requirements/Original Facilities are Inadequate

- Increased maintenance staff Control Maintenance from 140 to 209, Mechanical Maintenance from 135 to 195, and Inspection Maintenance Services (IMS) personnel from 0 to 30. Maintenance staff has increased by > 160 personnel since plant was commissioned.
- 2. Maintenance strategy is now being focused on day crews as opposed to shift crews. Hence, the total accumulated crew size to be accommodated on days has increased from 40 to 188 maintenance personnel.
- 3. IMS was never originally provided space for permanent shops and offices. They had been housed in the PHA but this building has been since vacated and condemned.
- 4. Offices and shops had been built in the path of a potential secondary side pipe failure. These shops were removed and this has resulted in some work groups having inadequate offices and labs. Reference TOE 98-01234-20100-3981-01.
- Some of the existing shops and offices do not meet the National Building Code and/or ASHRAE 62.1 standards. These areas include MM M&TE lab, CM M&TE lab, MM/CM Valve shop, MM RV shop, MM Seal Lapping shop, and MM Supervisors offices.
- 6. CM/MM M&TE labs do not have adequate humidity and temperature control. This results in these labs being unavailable for certain critical calibration activities ~ 30% of the time.
- 7. Greater emphasis on safety resulting in the following requirements:
 - a. Pre-job briefing spaces.
 - b. Rehearsal and Mockup areas for both IMS and Reactor Maintenance work to maximize efficiency & minimize potential outage delays.
- 8. Computers now play an important role in delivering work instructions, providing additional information and documenting the work. Hence, offices facilities and computer work stations are required to house them.
- 9. Changing technologies resulting in the requirement for specialized crews' complete with customized shop space and required FLM/FLMAs such as Fix-It-Now crews and Predictive Maintenance crews.

ONT	ARIO	POW	ER
	G	ENERA	TION

Page: 5 of 23

BUSINESS CASE SUMMARY

- 10. As a result of DNGS progressing through its life cycle, the original plant facilities did not adequately accommodate or foresee current aging plant considerations or license requirements. These considerations include:
 - a. Maintenance strategy implementing transition from corrective to preventative/predictive maintenance requires as per industry benchmarking experience a 30% increase in required shop space. Overhaul/refurbishment programs for major breakers, pumps, and valves have or are being developed as part of this strategy.
 - b. Space for IMS Quality Control labs and personnel.
 - c. IMS Periodic Inspections Programs.
 - d. Reactor Maintenance specialized component repair programs for Pressure Tubes and End Fittings, Feeders, Horizontal and Vertical Flux Detectors, and Adjustor Rods.
- 11. No provision for adequate Breaker and Relay maintenance. This is currently being performed in the Sequence Event Monitoring computer rooms which were never designed for this purpose.
- 12. Reactor Maintenance (RM) shop was never provided. Currently RM is housed in a temporary building with inadequate space, no permanent services, and an underrated floor loading capacity.
- 13. As a result of IMS not having permanent facilities, it takes an extra 2 weeks with 6 people to set up their equipment every outage. IMS also incurred a 2 day outage delay while trying to remove the CIGAR (Channel Inspection and Gauging Apparatus) inspection head from the channel. SCR D-2005-03661 (B3 category). This can be attributed to the lack of proper facilities to do maintenance and rehearsal on CIGAR.

Refurbishment/Upgrade

As part of the 2006 ASL study, a review of the feasibility and cost of upgrading existing ships and offices was performed as a potential option for building a new facility. The following areas were not considered for upgrade as they do not currently exist or exist in an area that was not originally intended for its current use:

- Reactor Maintenance Shop
- CM Breaker and Relay Maintenance Shop
- IMS QA Group
- IMS Pressure Group Inspection Program
- Civil Maintenance FLM offices

The following areas were considered for upgrade at an estimated cost of \$33.5M:

- CM M&TE Lab \$4M
- MM M&TE Lab \$5.45M
- CM Valve Shop \$6.3M
- MM RV Shop \$6.46M
- MM Seal Lapping Shop \$6.65M
- MM FLM offices \$4M
- MM Welding Shop \$750K

Refurbishment of these areas was not recommended by ASL due to high costs as a result of a high level of contingency needed due to the risk of performing modifications in an operating plant. In addition existing plant configuration may place limitations on the level of improvements that can be achieved by upgrades. (i.e. existing Common Service Area (CSA) HVAC system may not support required ASHRAE 62.1 and M&TE clean requirements, precise humidity and temperature control specifications without major improvements)



BUSINESS CASE SUMMARY

Contracting Out Considerations

Contracting out of maintenance services has been briefly investigated by DNGS Maintenance management. However this strategy was never fully developed, documented, or costed out. The following issues are some of the contributing factors:

- 1. Damage may occur to sensitive equipment if shipping offsite is required.
- 2. Emergency type situations where 24/7 response is needed may not be available if a contractor is utilized.
- 3. Costs and delays associated with Unconditional Transfer Permits and security requirements when shipping offsite and outside the protected area.

The contracting out of major breaker maintenance as part of the OPEX and EPRI recommended developed overhaul program was quoted as \$10K per breaker in 2005 which equates to 980 breakers x \$10K = \$9.8M. This would be required for all 980 breakers on a 12 year cycle. This has not been implemented to date as pilot contracts (both onsite and offsite) were not successful due to quality and timeliness of contract work.

Combined Facilities

Wardrop as part of the 2005 conceptual study was commissioned to assess the viability of an OPG shared site facility. Due to the major decisions pertaining to Pickering A U2/U3 Safe Storage and the pending decision in 2009 for Pickering B refurbishment, this assessment could not be completed and ultimately it was decided by the CNO in 2006 that a combined site maintenance strategy was not viable at this time and the project mandate was changed to a Darlington only project.

DNGS Maintenance has recently investigated preliminarily a combined PNGS/DNGS offsite MM/CM M&TE lab option with OPG Real Estate Services Division and received a quote for \$1M for a "leased permanent" fully customized build to suit industrial unit plus \$400k per year on a lease agreement. Alternatively a quote of \$400k was received for a "leased portable" prefabricated relocatable M&TE lab structure that could be placed in an industrial unit which would then also require a ~ \$180k yearly lease cost. These estimates are only for the space and do not include any other costs such as equipment, utilities, IT, etc. or the costs in transporting the tools offsite from both sites on a daily basis under Radiological Transfer Permits. This simplistically works out to a cumulative cost of \$9M for the customized build or \$4M for the prefabricated relocatable lab assuming a 20 year lease. The proportional cost of the M&TE labs based on the estimated 2410 ft² net of new ~ 60,000 ft² Maintenance Facility is ~ \$1.8M. These costs have not been vetted through by the consultants and have been reflected here to facilitate option comparison.

Hybrid Solution

As part of the 2006 ASL study, a hybrid solution was considered. A hybrid solution consisting of refurbishment of existing lab/shops combined with a new facility was never developed as an option due to the estimated cost for refurbishment for existing areas of \$33.6M. This \$33.6M combined with the cost associated for a new ~ 25,000 sq. ft building for the remaining areas would have seen cost estimates easily exceeding \$55M - \$60M before contingency. As a result of these costs this option was deemed prohibitive from a cost perspective and not evaluated any further.

Additional Background and Issues

The ASL cost estimates are only for the construction of the new Maintenance Facility and required building services. The cost of computers, modular office furniture, and telephones are included but as these costs cannot be capitalized along with the building they will be accounted as minor fixed assets in subsequent BCS's. The cost estimates do not include any costs such as: moving existing maintenance equipment, purchase of new maintenance equipment, radiation monitoring equipment, signage, etc.



3/ ALTERNATIVES AND ECONOMIC ANALYSIS

\$ 000's		Alt 1 (Recommended)		At 2	AR 3	Alt4	AR 5
	Status Quo	Full	Cost	Delity	MF Option H	MF Option I	
Revenue	7	÷	· · · · · · · · · · · ·		· · · · · ·		
OM&A		(1,600)			(1,244)	(1,244)	
Capital	· · · · ·	(54,543)			(47,416)	(45,527)	
NPV (after tax)	(150,699)	(99,238)			(100,491)	(108,252)	
Impact on Economic Value (IEV)	N/A	51,461			50,208	42,447	
IRA%	N/A	13.4%					
Discounted Payback (Yrs)	N/A				· · · · · · · · · · · · · · · · · · ·	••• ••• • • •••• • • •••• • • •••• • • •	

Status Quo - Not Recommended

This option is not recommended since the need for upgraded maintenance facilities at Darlington was first identified in 2002, and has escalated since. The risks to employee health and safety, potential outage extension, and loss of productivity would continue to rise incrementally.

Option Compension	Option G	Option H	Option I
CM M&TE Lab	↓ ✓	Excluded	Excluded
MM M&TE Lab	×	Excluded	Excluded
MM Relief Valve Shop	✓ ✓	Excluded	Excluded
MM Seal Lapping Shop	✓		Excluded
Reactor Maintenance Shop	✓		✓
CM Breaker Maintenance Shop	✓	\checkmark	~
CM/MM Valve Shop	~	~	
IMS Pressure Tube Area	~	~	~
IMS QC Labs & Offices	✓	~	~
Civil FLM Offices	✓	~	~
MM FLM Offices	\checkmark	\checkmark	\checkmark
MM Welding Shop	Excluded	Excluded	Excluded

Alternative 1 - Maintenance Facility Layout G from Revised Conceptual Study - Recommended

Proceed with the scope defined in the revised Conceptual Study Option G by ASL with a space estimate of 57,300+ sq. ft at a cost estimate of excluding contingency. This alternative will address all the areas identified in the revised Charter except the welding shop. The new facility will increase maintenance productivity and effectiveness, mitigate the potential increase of industrial accidents, mitigate potential outage extensions, and otential future cost savings realized by not moving labs/shops permanently offsite into a leased industrial space. It is scope of this recommended option based on the priority specified by the sponsor will consist of the identified hops, labs and offices above under Option G. This alternative has a positive NPV of 54.4M\$. See Attachment E for a breakdown of this NPV.



Page: 8 of 23

BUSINESS CASE SUMMARY

Alternative 2 - Delay Project - Not Recommended

N/A

Alternative 3 – Maintenance Facility Layout H with "leased portable" M&TE lab - Not Recommended

This option provides a new facility similar to Layout G with the exclusion of the CM and MM M&TE labs, and MM Relief Valve shop. The space estimate for this option is 48,900+ sq. ft. and the cost estimate associated with this alternative is ~ \$39M excluding contingency. This option does not effectively meet all the current and identified future DNGS Maintenance needs and will result in further management intervention to mitigate the needs of these excluded areas in the future.

NPV was calculated including the purchase of a \$400K relocatable CM/MM M&TE lab plus an estimated industrial lease cost of \$180K per year. These estimates are preliminary and only for the space and do not include any costs such as equipment, utilities, IT, etc. or the accurate costs in transporting the tools offsite from both sites on a daily basis under Radiological Transfer Permits.

Alternative 4 - Maintenance Facility Layout I with "leased portable" M&TE lab - Not Recommended

This option provides a new facility similar to Layout H with the further exclusion of the MM Seal Lapping shop. The space estimate for this option is 45,500+ sq. ft. and the cost estimate associated with this alternative is ~ \$37.4M excluding contingency. This option does not effectively meet all the current and identified future DNGS Maintenance needs and will result in further management intervention to mitigate the needs of these excluded areas in the future.

NPV was calculated including the purchase of a \$400K relocatable CM/MM M&TE lab plus an estimated industrial lease cost of \$180K per year. These estimates are preliminary and only for the space and do not include any costs such as equipment, utilities, IT, etc. or the accurate costs in transporting the tools offsite from both sites on a laily basis under Radiological Transfer Permits.

Alternative 5 – N/A - Not Recommended

OPG Confidential

BUSINESS CASE SUMMARY

4/ THE PROPOSAL

The Following are the objectives and deliverables for this Partial BCS:

Building Removal & Decommissioning

- o Completion of Detailed Design.
- o Preparation of decommissioning workplans.
- o Issue PO for the decommissioning and removal of buildings.
- o Completion of contract for the decommissioning and removal of buildings
- o AFS for the building removal and decommissioning

Relocate Buried Services and Establish Tie-In Points

- o Issue PO for Detailed Design.
- o Complete Detailed Engineering of the Tie-Ins and Buried Services relocations
- o Issue Request for Proposal (RFP) and evaluate bids for an installation contract.
- o Preparation of workplans.

Maintenance Facility

- o Preparation of an EPC contract for the construction of the new Maintenance Facility.
- o Issue a RFP for a Commercial EPC contract for the new Maintenance Facility
- o Receive bids from proponents and complete bid evaluations
- o Issue a PO for the Preliminary Design of the Maintenance Facility
- o Issuance of a Full Release BCS.

In the Full Release BCS the following items will be included as per Nuclear Oversight Committee/Board of Directors specific request:

- 1. Analysis of existing space currently used by Maintenance staff for the various functions and an explanation of why each function must be moved to the new location (eg, tabulate: function/space currently used for this function/why the function must be moved to a new location).
- 2. Detailed benchmarking data for similar building construction on a cost-per-square foot basis.

5/ QUALITATIVE FACTORS

The successful completion of this project will improve the following:

Staff relations

• New maintenance facility shops and offices will relieve overcrowding and congestion and result in improved staff morale.

Health and Safety

• New maintenance facility shall be compliant with ASHRAE 62.1 air quality requirements, relieve overcrowding and congestion, and result in improved health and safety inefficiencies.





10 of 23

Page:

BUSINESS CASE SUMMARY

6/ RISKS

Risk After Mitigation	Medium	unipe W
	The conceptual study layouts have been independantly cost estimated by an external 3 rd party estimator Altus Helyar. Construction quote can be obtained after detailed design for the Full Release BCS. A second independent cost estimate will be commissioned when the scope is more defined before the Full Release BCS.	Review and finalize contracting stategy and impact to design and installation requirements with Supply Chain, Procurement, Design & Legal before Full Release BCS is issued. The estimates used for this BCS were conservatively assumed to be Owner/Constructor contracts. Early involvement of serior station management in investigating contracting strategy.
	ЧβН	E D e
Consequence Consequence	Potential adjustment required on scope and cost of the project.	Could cause a delay to the schedule & increase costs.
Description of Risk	Cont Overall project cost exceeds current estimate. Current cost estimates are conceptual. Cost estimate accuracy is +60%/-25%	Changes to the funding release strategy and/or fine tuning of contracting stategy may impact overall cost and schedule (owner only vs owner constructor) This is a 1 st time strategy for implementing an owner only contract inside the protected area. Lessons Learned can be utilized for future projects that may result in schedule and cost savings.

		Wedium	Low	Medium	Medlum
		Cost to remove the PHA was estimated by ASL in the 2006 conceptual study. Impact to other affected structures due to removal of the PHA has been identified and mitigation discussed with Sponsor. Sponsor has concurred that removal of adjacent trailers at this time is a cost effective solution. Waste removal and recycling plan being developed. The contingency added in 2008 cash flow to cover potential added cost of waste removal. Cost to complete the relocation of underground services and building tie-ins was estimated by ASL in the 2006 conceptual study. A drawing reivew was completed to identify underground services in the area during the conceptual study	A Detailed design will be performed to identify the detailed scope of buried services, and tie-ins before the scope is finalized for the Full Release BCS. A more accurate cost estimate will be available in the next release for management decision makino	Further scope identified during the design will be challenged by projects & have to be agreed by all stakeholders & sponsor.	Preliminary drawing review has been conducted to identify any possible services that may require relocation. Field survey to be completed during Technical Evaluation.
Page: 11 of 23	ARY	Cost to remove the PH/ ASL in the 2006 concept other affected structures the PHA has been iden discussed with Sponsor. Sponsor has concurren adjacent trailers at th effective solution. Waste removal and re developed. Cost to complete underground services was estimated by A conceptual study. A c completed to identify ur in the area during the co	A Detailed (identify the services, and finalized for th accurate cost the next rele	Further scop will be challe agreed by all	Preliminary conducted to that may rec be completed
	CASE SUMMARY	Medium	Н Н	High	ЧĞ
OPG Confidentis	BUSINESS	Potential increase in scope and cost of project.	Further changes in scope will delay the schedule and increase OPG project management costs.	Changes in scope will delay the schedule and add cost to the project.	Increase in cost and schedule or further reduction in shop space to ensure approved budget is maintained.
NARINPOWER	GENERATION	Cost for demolition of Power House Annex exceeds conceptual estimate of \$2.0M due to: - Impact on adjacent building - Waste removal and recycling requirements - Cost for the design and installation for the relocation of underground services and building service tie-ins exceeds conceptual estimate	Scope Final scope of the new F Maintenance Facility may s require further cuts due to π OPG budget constraints.	Preliminary/Detailed Design C may result in an increase in a scope.	Increase scope of work due to Ir discovery work (ie re-route buried services in building footprint).



Page: 12 of 23

BUSINESS CASE SUMMARY

Insufficient information to determine the scope and timeline of design deliverables accurately.	Increase in cost and schedule.	Medium	say a o e o	Medium
Fine tuning of contracting stategy may impact overall cost and schedule.	Require changes to funding release strategy which could cause a delay to the schedule & costs.	чвін	system tie-ins etc. These will be detailed in subsequent BCS's. Review and finalize contracting stategy and design and installation requirements with Supply Chain, Procurement, Design & Legal	Medium
Design deliverables not on time.	Delay to schedule.	Medium	Select approved vendor, provide clear scope & deliverables. Review progress regularly & establish and monitor effective design performance metrics.	Low
Resources Insufficient OPG design resources available.	Delay project schedule & milestones.	Hgh	Design will be contracted out to external agency. OPG Projects Design have committed to provide DTL and any additional design support for this project.	Low
Availablility of qualified vendors to perform design and subsequent implementation (procure, construct).	Delay in issuing contract due to need to assess various interfacing risks, vendor qualification issues, and contracting language.	Medium	Obtain OPEX from other OPG projects of similar nature. Early involvement with Supply Chain and various other departments or potential vendors and early review of the associated contracting strategies. Supply chain is currently in the process of qualifying more vendors for N286.1 "procurement".	Medium
Technical Legacy issues on Design.	Re-engineering may be required if there are legacy and interface issues with systems that the project is modifying. This would add scope to the project which may cause delays and increase	Medium	Preliminary site walkdowns have been completed. Complete drawing review on systems being impacted to be performed during Technical Evaluation and subsequent Engineering efforts.	Low



BUSINESS CASE SUMMARY

Page: 13 of 23



Low	N/A	Low	Pow	Low	Гом
Test drill site to determine the soil composition prior to completing Technical Evaluation to ensure the design takes this into account. Method & cost to implement corrective actions will be challenged & documented.		A Geotechnical Analysis and Radiological testing by Kinetrics will be performed during the Technical Evaluation. A Waste Disposal plan will also be developed and submitted to OPG for accentance	All building material to be scanned and tested for radiological, asbestos, mold and other contaimination prior to demolition of buildings	Adherence to OPG Policies and Procedures will be maniditory during the removal of buildings. Contractor's safety record wil be	All building material to be scanned and tested for asbestos, mold and other contaimination prior to demolition of buildings. Ensure personnel protect themselves with the apporpriate PPE per OPG Policies and Procedures
Medium	A/N	Low	۲0 ۲	Low	Low
project costs. Delay and added cost to the project due to the prefered site not being suitable for building addition which could then subsequently lead to Increased costs to the design and installation to meet the requirements identified.		Added cost to the project due to disposal costs associated with contaminated waste.	Added cost to the project due to disposal costs associated with contaminated waste.	Personnel injury or death Delay to project	Personnel injury or long term health concerns. Added costs and/or delay to project.
Discoveries from geotechnical analysis of soil.	Regulatory There are no regulatory risks.	Environmental Excavation and Construction waste may not be suitable for shipment to a clean landfill site due to radiological contamination.	Waste from demolition of buildings may not be suitable for recycling or for shipment to a clean landfill site due to radiological and/or conventional contamination.	Health & Safety Personnel injured during demolition of buildings.	Asbestos, mold or other conventional hazardos material present in the buildings to be removed.



Page: 14 of 23



BUSINESS CASE SUMMARY

Low	
End users have been interviewed to gather L critical data for calculation of the NPV. Investment Finance and Station Long Range Strategic group will further scrutinize validity of assumptions for the next release based on the final scope decision after the Technical Evaluation is complete	
Medium	
Return on investment cannot be realized.	
Investment Cost benefit information cannot justify proceding with the project. The final scope of the what that is to be included in the maintenance facility is not yet known.	

OPG Confidential

BUSINESS CASE SUMMARY

7/ POST IMPLEMENTATION REVIEW PLAN

	Type of PIR:	Targeted Final AFS Date:	Targeted PIR Approval Date:	PIR Responsibility (Sponsor Title)	
ĺ	TBD in Next Release	TBD in Next Release	TBD in Next Release		

Comments:

-	Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it? (person / group
1.	n des de la seconomie de la seconomie de la seconomie de la seconomie de la seconomie de la seconomie de la sec	a ga - Suberd - Fraktsteine comments - Rankt ist mindt in Stor Frank de Armend	ia ya wuxaanigu anga 200 - 2 ya katatatini nanununununun tatata a		
2.					
3.				<u>,</u>	
4.				······································	
5.					



OPG Confidential

BUSINESS CASE SUMMARY

Appendix "A"

Glossary (acronyms, codes, technical terms)

BCS PHA RFP EPC IMS TOE QC CIGAR SCR ASL NPV	Business Case Summary Power House Annex Request For Proposal Engineer, Procure, Construct Inspection Maintenance Services Technical Operability Evaluation Quality Control Channel Inspection and Gauging Apparatus Station Condition Report Acres Sargent & Lundy Net Present Value
	Net Present Value
СМ	Control Maintenance
PO	Purchase Order
DTL	Design Team Leader
OPEX	Operating Experience
TBD	To Be Determined
PIR	Project Implementation Report
PWU	Power Workers Union
BTU	Building Trades Union
PEP	Project Execution Plan
AFS	Available For Service
IEV IRR	Impact On Ec Value
RM	Internal Rate of Return
L/1A)	Reactor Maintenance





OPG Confidential

BUSINESS CASE SUMMARY



Appendix "B"

Project Funding History

\$ 000's	-	All	Existing a	nd Plann	ed Reise	ses (incl	continger	юу)			
		·.	*	Cum	ulative V	akaes		-			ć
Release Type	Month	Year	2007	2008	2009	2010	2011	2012	2013	Later	Total
Developmental	Jul	2007	1,369	234							1,603
Partial			(861)	3,960	3,836					1	6,935
Full			508	4,194	18,932	19,985	13,599	521			57,739
											0
						· · · · · · · · · · · · · · · · · · ·					0
]	0
											0
											0
		<u> </u>	<u></u>			L	<u>_</u>				·····
LTD Spent	Dec	2007		508							508

Comments:

Previous release of \$450k was obtained in 2002 to provide seed money for the first Acres Sargent & Lundy conceptual study of which \$116k was spent. \$34k in capital interest charges has accumulated against this amount to date.





BUSINESS CASE SUMMARY



Appendix "C"

ONTARIOPOV

Financial Model – Assumptions

Project Cost Assumptions:

- 0
- OPG staff will provide project management & support role during design and implementation Q
- Design and Installation work will be performed by contractors with oversight and support for OPG 0 Project Design
- Current P3 resource costs were used thru 2009. Escalation rate of 4% was used for 2010 & 2011 0
- DNGS Strategic Planning has prepared a Monte Carlo Crystal Ball risk model analysis of all \circ alternatives to develop the NPV figures. All assumptions used for this model were based on ASL submissions, OPG reliable sources, or from individual area stakeholders. Attachment D has the relevant information from this analysis for the recommended Option G with an overview of the NPV figures for Base and Options H and I. The appendix also includes the assumptions, Long Term Disability statistics. This model has been reviewed and accepted by OPGN Investment Management for the purpose of the Economic Analysis values used for this Developmental BCS.

Financial Assumptions:

- 0 7% discount rate
- PHA cost of removal will be expensed to accumulated depreciation monthly as incurred. 0
- Maintenance Facility Design and Construction_costs were estimated by ASL with the assistance of 0 an external constructor Ball Construction. A additional premium was added over equivalent commercial costs due to the fact that this work is inside the DNGS protected area and subject to OPG ECC processes and Safety Regulations. OPG Project Management and Support costs were developed between ASL & OPG Design Projects and substantiated via an independent 3rd Party estimator Altus Helyar.
- See Attachment "D" for BCS NPV Assumptions and Analysis. 0
- Note that this project estimate does not include costs for moving existing maintenance equipment, 0 purchase of new maintenance equipment, purchase of radiation monitoring equipment

Project / Station End of Life Assumptions:

- Darlington end of life ~ 2050 0
- Maintenance Facility nominal end of life 2050 0

Energy Price / Production Assumptions:

See Attachment "D" for BCS NPV Assumptions and Analysis Ó

Operating Cost Assumptions:

See Attachment "D" for BCS NPV Assumptions and Analysis 0

Other Assumptions:

- OPG to provide unrestricted access to work area 0
- All work is within the secured area with incumbent restrictions Ô





OPG Confidential

BUSINESS CASE SUMMARY

Project Name 16 - 31717

Partial Release Business Case Summary D-BCS-28200-10003-R000

Attachment "A"

Project Cost Summary

SORO's OM&A	LTD Prior Yr	This Rolease 2008	This Release 2009	Future Rolease 2009	Future Release 2010	Future Release 2011	Future Release 2012	Later	Total
Project Management (OPG)	164	570	356	357	f	484	184		2,990
Engineering & Drafting (OPG)	54	325	190	190	175	190	117		1,241
Material									
Installation - PWU, BTU									
Contract - Design	617	0.00	0.000						
Contract - Installation									
Contract - Other									
	1								1
Interest (Capital Project Only)									
Project Casts (and contingancy)									
General Contingency	1								
Specific Contingency									
Project Costs (Incl conlinguncy)	508	4,194	3,836	15,096	19,985	13,599	521	, and a substance of the substance of the substance of the substance of the substance of the substance of the s Substance of the substance of	57,739
2008-2012 Business Plan	1,170	2,140	2,951	11,418	15,154	11,556	-		44,389
Variance to Business Plan	(662)	1,105		194	219	(1,095)	401	•	162
Committed Cost	° +			nte c anta concernante e					
Inventory Write Off Required									
Spare Parts / Inventory									•
Total Release (and contingency)	506	3,245	2,951	11,612	15,373	10.461	401		44,551
Total Pleisume (Incl contingency)	508	4,194	3,836	15,096	19,985	13,599	521	*	57,739
Ongoing OM&A (non-project)	· · · · · · · · · · · · · · · · · · ·	··· - · · ··· · · · · ·	···· ··· · · · · · · · · · · · · · · ·			بر, , ,,, , به حمر		·····	
Removal Costs (incl in above)	137	1,453	******			**************************************		**************************************	1,600

		Basis of E	stimate			ande barr den ise ar operations is sender some i	
Design Complete Z		Zero to Minimal	Quality of E	stimate	Conceptual + 60% to - 25%		
3 rd Party Estimate	Yes	OPEX used	Yes	Yes Lessons Learned		N/A	
Reviewed by Sponsor	Yes	Budgetary Quote(s)	No	Phase 1 Actual Used		No	
Similar Projects	No	Contracts in place	No	No Competitive Bi		No	

Variance to Business Plan

The estimated variance(s) to the 2007-2011 Business Plan will be addressed through the portfolio management process. A PCRAF is not required

Reviewed By:

4 Feb sont 1 Cl Stephanie Tham Date: Project Manager

Approved By: F6.4/09 and Dianne Gaine

Eng & Mods Manager (Strat IV)

Date:

OPG Confidential

BUSINESS CASE SUMMARY

Project Name 16 - 31717

Partial Release Business Case Summary D-BCS-28200-10003-R000

Attachment "B"

Project Variance Analysis

	Choose One				
Capital	LTD Dec 2007	Last BCS Jul 2007	This BCS Jan 2008	Variance	Comments
Project Management (OPG)	164	2602	2990	388	Add resources for 2012 project closeout
Engineering & Drafting (OPG)	54	888	1141	253	Add resources for 2012 project closeout
Material					
Installation - PWU, BTU	4				
Contract - Design					
Contract - Installation					
Contract - Other					
					· · · · · · · · · · · · · · · · · · ·
Interest (Capital Project Only)					
Project Costs (end contingency)					
General Contingency	1 18				
Specific Contengency					
Project Costs (Incl contingency)	508	57701	57739	38	n - Brannan Managana a ang ang ang ang ang ang ang an
Committed Cost	nan on nin 2 oo d	dan - minitian - a	r (ir ATIAnar≩ I	0	and the second
Inventory Write Off Required		1		0	
Spare Parts / Inventory		1		0	
Total Release (act conlingency)	508	57701	57730	38	and a construction of the state burner and a construction of the subsystem of a construction of the second state
Total Palasas (aucl contingency)	508	44420	44551	131	
Ongoing OM&A (non-project)		·····			
Removal Costs (Inct in above)				·····	
HISTALE CORE (NET RI STOLE)				0	a An and a second s

Comments:



BUSINESS CASE SUMMARY



Attachment "C"

Key Milestones

Description nent complete - PHA Demo.
PO Issued
n Complete
sessment Complete
oved

A Project Execution Plan (PEP) will be approved by Jun 2009

Comments:







ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

ttachment "D"

DNGS Long Range Planning - Recommended Option NPV Calculation

- Result Summary
- Assumptions
- LTA source assumption
- Individual area results

NPV Option Result Summary

Up to Retube - 2021	NPV (k\$)
Base Case	(67,274)
Dption G	(67,430)
Option H (with leased Portable M&TE lab)	(64,482)
Option I (with leased Portable M&TE lab)	(67,250)

After Retube - 2050	NPV (k\$)
Base Case	(150,699)
Option G	(99,283)
Option H (with leased Portable M&TE lab)	(100,490)
Option I (with leased Portable M&TE lab)	(108.251)



Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

Attachment E

Briefing Note: 31717 DNGS Maintenance Facility Breakdown of the 54M\$ Preferred Alternative NPV

		<u>%</u>	NPV (M\$)
Backlog Improvement (1)		3.5	1.8
LTA Reduction (2)		0.1	0.1
Productivity Gain (3)		13.1	6.7
Planned Outage extension reduction (4)			28.8
- Reactor maintenance shops	27%		
- IMS Pressure Tube Insp prog	10%		
- MC Valve shop	10%		
- Other shops	9%		
subtotal	56%	56.0	
Forced Outage extension reduction (5)			11.6
- IMS Quality group	8%		
- MC Breaker & Relay shop	7%		
- Other shops	8%		
subtotal	23%	22.6	
Rebuilding, not buying, Seal parts (6)		2.0	1.0
Breaker overhaul inhouse (7) & various other		2.6	1.3
		100.0	51.4

(1) Online Elective Maintenance Backlog improvement will reduce Forced Loss Rate which will impact on generation and incremental Forced Outage Cost.

(2) Existing facilities are overcrowded and noisy with poor air quality which may cause potential Health and Safety incidents.

(3) Overcrowded locations, lack of Pre-Job Briefing areas, lack of crane equipment, extra equipment shuffling, lack of Mockup/Rehearsal area, and insufficient temperature/humidity control resulting in overtime to recover productivity losses.

(4) Improve response time on tool calibration, breaker preparation, valve work, Channel Inspection and Guaging Apparatus for Reactor work, Single Channel Fuel Replacement work, and minimize delays as the Mockup/Rehearsal facility and crane are always in place.

(5) Improve response time on tool calibration, Release Valve decontamination, Seal preparation, breaker preparation, Channel Inspection and Guaging Apparatus for Reactor work, and minimize delays as the Mockup/Rehearsal facility and crane are always in place.

(6) Facility to rebuild old Seal parts instead of buying new ones will result in significant savings.

(7) Performing major breaker maintenance in house instead of outsourcing.



ONTARIOPOWER GENERATION

BUSINESS CASE SUMMARY

DNGS SDS Aging Management 16 - 33955

Developmental Release Business Case Summary D-BCS-68000-10002-R000

Routing	Location	Action	Signature	Date
Perrik Le Dreff Design Engineer Safety Related Computers	P82-5F4	Prepare BCS	P.J. D.A.	Neille soft
Mike Viola Section Manager Safety Related Computers	P82-5F4	Review BCS	Mal	MU 16/200
Rick Hohendorf Manager Computers and Control Design	P82-5F6	Review BCS	ALM	N . 16/ 2006
Axel Kleer Senior Financial Analyst Investment Management	P82-3A5	Review BCS	Ma/Klar	21 Nov 06.
Bill Qualtrough Manager Performance Engineering, Darlington	D08-ESB2	Submit BCS	ADDAt	Nav 1/56
Randy Leavitt Director Investment Management	P82-3	Approve BCS	Falswit-	Now 22, 2006
Stu Seedhouse ector ation Engineering, Darlington	D08-ESB3	Approve BCS	SSedi-	28 Nov Zrob
Gregory Smith Senior Vice President Darlington	D08-ESB3	Approve BCS	Certhi	29 700 00-5
el Kleer for Financial Analyst estment Management	P82-3A5	Return For Distribution		

Page: 2 of 15

BUSINESS CASE SUMMARY

DNGS SDS Aging Management 16 - 33955

Developmental Release Business Case Summary D-BCS-68000-10002-R000

1/ RECOMMENDATION:

ONTARIO**POWER**

GENERATION

Approval is requested for this developmental release of \$1.55 million (excluding contingency) to perform preliminary engineering to address the aging and obsolescence issues of the Darlington NGS Shutdown System (SDS) computers. This includes funding of \$110K for hardware and software purchases for engineering evaluation to confirm the path forward in the detailed engineering phases.

The Business Objective is to manage the current threat to generation posed by the 57 aging SDS computers. It is currently deemed that the system in its current state is at risk of not operating to the 2018 end-of-life target. The operator workarounds imposed by the SDS computers as well as the hardware obsolescence issues are reflected in the SDS health reports by red performance indicators. This indicates a system at risk and, due to the critical nature of the SDS computers, their unavailability would directly result in unit unavailability. The hardware obsolescence issue cannot simply be addressed with spare parts procurement since most of the critical equipment is no longer available. As well, replacement components and/or computers must be qualified for use and/or designed.

During the preliminary engineering phase, detailed material condition assessments of the SDS computers will be carried out to determine their end-of-life. Due to the currently known operator and hardware obsolescence issues, the SDS1 and SDS2 Monitor computers will be replaced first. Preliminary engineering will re-evaluate the existing system requirements of the Monitor computers, and assess replacement software and hardware platforms. SDS2 Trip Computer components facing a critical shortage of parts will be evaluated for replacement.

The preliminary engineering phase will allow for a full plan to be established for a timeline of computer replacements to reach 2018 end-of-life target and will forecast the feasibility of maintaining the systems for approximately 20 years beyond 2018.

the preliminary engineering is targeted for completion in December 2008.

The project is included in the 2007-2011 Business Plan at a value of \$65 Million. A Project Execution Plan (PEP) for the preliminary engineering phase is scheduled for completion by December 15, 2006.

SOOR'S (loci contingency)	Funding	LTD 2006	2007	2008	2009	2010	2011	Later	Total
Currently Released	None	· · · · · · · · · · · · · · · · · · ·							-
Requested Now	Developmental	-	345	1,438	-				1,783
Future Funding Regid	Full	į		-	8,000	5.000	5,000	45,000	63,000
Total Project Costs		-	345	1,438	8,000	5,000	5,000	45,000	64,783
Other Costs		1							
Ongoing Costs					1				
Grand Total			345	1,438	8,000 1	5,000	5,000	45,000	64,783
investment Statisti		Cia Car		(IEY) Impact of IVA		iai NA		Cincounted W/	

Submitted By:

9.0

Nev 21/06 Date:

Bill Qualtrough Manager, Performance Englneering, Darlington

Finance Approval:

Line Approval (Per OAR Element 1.2 Project not in Budget):

130,2004

Nover, 2006 Date:

Randy Leavitt Director, Investment Management Gregory Smith Senior Vice President, Darlington Date:



Page: 3 of 15

BUSINESS CASE SUMMARY

And shares and the state

2/ BACKGROUND & ISSUES

The Darlington NGS SDS computers comprise a network of 14 computers per reactor unit connected to one Shutdown System Monitor Computer (SSMC) that is common to all four reactor units. The SDS computers are classified as part of a Special Safety System that Darlington NGS depends on to:

- a) Automatically initiate a reactor shutdown via the SDS1 and SDS2 Trip computers.
- b) Display SDS parameters at the main control panels (as well as the secondary control area in the case of SDS2) via the SDS1 and SDS2 Display/Test computers.
- c) Provide a facility whereby the trip measurements, logic and reactivity devices can be tested from the Main Control Room via the SDS1 and SDS2 Monitor computers and the SSMC.
- d) Monitor the SDS routinely to detect and notify the Operator of conditions which adversely affect production, reliability or SDS availability.

Currently, the SDS computers (totaling 57 computers for the entire station) use old technology that is increasingly difficult to maintain and for which there is no OEM support.

- The vendors of this equipment are no longer in business.
- Circuit board level repair, where possible, has been achieved though the use of existing parts; however, some critical parts are no longer available. For the SDS2 Trip Computer there is a major concern that, due to the technology employed, board level repair may not be possible.
- Failures of peripherals have caused an increased maintenance burden and spare parts for these are no longer available from the suppliers.

In addition to the hardware obsolescence issues, the SDS Monitor computers suffer from intermittent problems that are related to hardware limitations of the older technology.

There have been over 70 SCRs concerning SDS computers raised in the last several years.

86) N.



BUSINESS CASE SUMMARY

3/ ALTERNATIVES AND ECONOMIC ANALYSIS

and the angular and an and the second of the	· · · · · · · · · · · · · · · · · · ·	AR 1 (Recommended)		AL 2	ANJ	ALL4	AR5								
\$ 000%	Status Quo	Full incremental Delay Cost Cost			1 1				Delay Do More	Delay		De Mors	Do More Do Lesa		
Revenue															
OM&A															
Capital		1,550	· · · · · · · · · · · · · · · · · · ·	<u> </u>											
NPV (after tax)					· ·										
Impact on Economic Value (IEV)	N/A					 									
IRR%	N/A				Ļ										
Discounted Payback (Yrs)	N/A				2	<u>i</u> ł									

Do Nothing (Status Quo) - Not Recommended

There is a current need to address obsolescence issues with the SDS computers. The System Health Reports show a red status for Spare Parts/Obsolescence and Operator Workarounds. There is currently a critical shortage of components that are no longer repairable and have no OEM support; this situation will ultimately result in station outages when the components inventory is exhausted and no replacements are available. There are also no projections of failure rates established to determine when the stock of spare parts will be exhausted; due to the existing shortages in spare parts, it is not prudent to do nothing.

Iternative 1 - Proceed with Preliminary Engineering - Recommended

Perform a thorough material condition assessment of the SDS computers. Due to the currently known operator and the hardware obsolescence issues, as a minimum, proceed with the replacement of the SDS1 and SDS2 Monitor computers and the SDS1 and SDS2 Display/Test Computer CRT monitors. Also, as an interim solution to the development of a replacement Monitor Computer, initiate the replacement of the existing Monitor Computer hard disk whose stock is critically low and is at risk of being depleted. The SDS2 Trip Computer components facing a critical shortage of parts will also be evaluated for replacement. This approach would provide the best solution by addressing the most critical needs proactively and establishing an aging management strategy which would provide a clear path to 2018 and beyond.

Alternative 2 - Delay Project - Not Recommended

There is a clear need to begin the preliminary engineering immediately to perform thorough material condition assessments of the SDS computers. It is also important to initiate any replacements to mitigate a situation where a replacement component/computer is not available when the stock of parts runs out. Detailed failure rates of critical components are not known and, therefore, predicting when future failures of components will occur is very difficult. Also, staff with knowledge of the SDS computers is scarce and declining.

Delaying the project would increase the risk that equipment failures will exhaust any spare parts available before a replacement could be ready. Due to the current uncertainty of the future failure rates of the aging equipment, it is not prudent to delay the project.

Because the Trip computers comprise a safety-critical Category I software based system, qualification work will attract regulatory scrutiny and the prescribed processes and procedures that must be applied increase the elapsed time needed to put an acceptable replacement component/computer in place.

Alternative 3 - Do More - Not Recommended

full SDS computer replacement is not feasible within the current business plan cycle (2007-2011) due to the need to address the most pressing SDS computer issues in a shorter time frame than the time that would be required to accomplish a full computer replacement. No outage of sufficient duration for full replacement is scheduled during this period. Furthermore, the aging management strategy has not yet been developed to provide the optimum computer replacement path.



BUSINESS CASE SUMMARY

Alternative 4 - Do Less - Not Recommended

Perform the material condition assessments of the SDS computers but do not proceed with the replacement of the SDS1 and SDS2 Monitor computers, and the SDS1 and SDS2 Display/Test Computer CRT monitors. Doing less than the recommended alternative would introduce an unnecessary and likely consequential delay since the currently identified replacements are of high importance to continued plant operation. Because the critical replacements have been identified during the conceptual phase of this project, it would be best to initiate these initiatives in parallel with determining the material condition assessments to establish the SDS aging management strategy to mitigate operational risk for the station. Also, knowledgeable SDS computer staff is declining and the situation will only get worse with time.

4/ THE PROPOSAL

The developmental funds requested in this release will fund the preliminary engineering activities. They are:

- a) Determine the detailed material condition and component failure trends of the SDS1 and SDS2 Trip computers, the SDS1 and SDS2 Display/Test computers, and the SSMC.
- b) Initiate the replacement of the SDS1 and SDS2 Monitor computers, and the SDS1 and SDS2 Display/Test Computer CRT monitors. The Monitor Computer replacement will incorporate the existing functionality of the SSMC and, as a result, the SSMC shall be eliminated when all of the new Monitor computers have been installed. These activities include the qualification of the hardware and software for acceptability of use.

As an interim solution to the development of a replacement Monitor Computer, initiate the replacement of the existing Monitor Computer hard disk.

- d) Evaluate the replacement of SDS2 Trip Computer components facing a critical shortage of parts.
- e) Determine the replacement strategy for the SDS computers to ensure reliability is sustained at current levels or improved for the current station lifetime (2018) and ensure an upgrade path exists for plant life extension or for prior replacement, if necessary.
- f) Align resources for detailed engineering work including external resources.

The preliminary engineering will conclude by Q4, 2008. Prior to December of 2008, approval will be sought by subsequent BCS documents depending on the detailed plan that results.

For preliminary engineering milestones, see Attachment C.

5/ QUALITATIVE FACTORS

Qualitative benefits gained from implementing the recommended alternative are as follows:

- Reduced operator burden by eliminating or minimizing any operator workarounds.
- Derive a thorough understanding of the material condition of the SDS computers.
- Reduce regulatory risk by having a clear obsolescence plan for the most critical computers in the station.
- Improve the predictability of system reliability up to 2018 and beyond



6 of 15

Page:

BUSINESS CASE SUMMARY

6/ RISKS

Description of Risk				Risk After Miligation
Cost			automatical statement with a statement of the second statement of the second statement of the second of the second statement of the second statement of the second statement of the second statement of the second statement of the second statement of the second statement of the second statement of the second statement of the second statement of the second statement of the second statement of the second statement of the second statement of the second statement of the second statement of the second statement of the second statement of t	Statistics and the statistical second second
Underestimation of the preliminary engineering efforts.	Cost overtuns	Medium	A detailed breakdown of the complete preliminary engineering activities provides good assurance for the cost estimates. Include contingency on the overall estimate. Contingency to be released only if justified and approved.	Low
Scope		Barrow Andrew	יייייארא איז איז איז איז איז איז איז איז איז אי	
During preliminary engineening, scope of work expands.	Increase in costs and more personnel needed	Medium	Scope of preliminary engineering is well defined via good stakeholder involvement up front to assess the past/present and future issues of the system. Include to contingency on the overall estimate. Contingency to be released only if justified and approved.	٢٥
Schedule				
Scheduling	The risk to the schedule is related to the scope, resources and technical issues.	Medium	Control the scope and ensure resources are allocated as soon as a detailed schedule is produced. Identify up front of any constraints in resources and funds available in the target penod.	LOW

THE PART OF A DESCRIPTION OF A DESCRIPTI

ł



POWER Generation	
ON	

7 of 15 Page: OPG Confidential

ţ



BUSINESS CASE SUMMARY

knowledgeable internal or external staff.	Shortage of engineering personnel with expertise of the SDS computers. Less experienced persons will require more time to perform tasks.	Medium	Personnel resources shall be identified as early as possible in the preliminary design phase. Availability of resources already identified shall be confirmed in early 2007. Include time for personnel with little or no SDS knowledge to become familiarized with the systems to tackle their tasks. Contingency has been allocated for external resources.	No.
1 E 1	Obtaining resources from external agencies for early 2007 may be challenging.	Medium	Early discussions have been held with external agencies such as AECL and SWI to establish staffing availability.	Low
Material condition worse than initial estimates.	The material condition assessments reveal that there are more critical spares shortages and that failure rates are much higher than anticipated (operating on right of bathtub curve)	mibeM	Adverse findings will affect the Adverse findings will affect the scope/schedule/cost during the preliminary engineering but in the short and long term. getting a solid material condition assessment will lead to a better solution being implemented in the detailed engineering phase. The risk mitigation has been to obtain as much knowledge of the material condition, as is feasible, in the conceptual phase. Include contingency on the overall estimate. Contingency to be released only if justified and approved.	Wedium

ļ

ţ







R
N
N
u
CASE
$\tilde{\mathbf{o}}$
ŝ
ž
5
BUSH
ш

End of life of each SDS computer cannot be adequately defined	Lack of failure history, product information. or data for analysis may result in imprecise end-of-life estimates. This would force a more conservative end-of-life and would move forward in time more of the SDS computer replacements. It would have impact on resources, cost, scheduling.	Р В Н	The recommended alternative addresses the most challenged SDS components first as determined in the conceptual design phase of the project. This prioritization of the computer/component replacements reduces the nisk of not being able to assess the end-of-life for the remaining computers since they have already been assessed as being in less critical need of replacement.	Medium
Regulatory	CNSC may decide that a major SDS Computers overhaul will require the application of more strict hardware requirements and/or separation requirements which were not previously imposed on the legacy system.	Low	Consistent with past obsolescence projects. L during the preliminary engineering phase, the CNSC will be provided with an overview of our objectives and we can address any potential concerns they might have.	₹
Ervironmental N/A Health & Safety N/A Investment				

1 `_ · -.

ł

i ł



7/ POST IMPLEMENTATION REVIEW PLAN

Dete:	Date: (Sponsor Ti	ita) i
N/A	and a second and a second and a second and a second and a second and a second and a second a second as	e warden and

Comments:

PIR plan not required for a Developmental BCS.







Appendix "A"

Glossary (acronyms, codes, technical terms)

AECL	Atomic Energy of Canada Limited
CNSC	Canadian Nuclear Safety Commission
CRT	Cathode Ray Tube, a video display
OEM	Original Equipment Manufacturer
SDS	Shutdown System
S DS 1	Shutdown System 1 – A system which uses neutron absorbing "shutoff" rods to rapidly shutdown the reactor due to an abnormal condition.
SDS2	Shutdown System 2 – A system which uses neutron absorbing "poison" (gadolinium nitrate) to rapidly shutdown the reactor due to an abnormal condition.
SSMC	Shutdown System Monitoring Computer. Note that this Is not the SDS1 or the SDS2 Monitor Computer. The SSMC is a single computer which collects data from all of the 8 SDS1 and SDS2 Monitor computers.
SWI	Systemware Innovation





ONTARIO POWER GENERATION

OPG Confidential

Page: 11 of 15

0

BUSINESS CASE SUMMARY

Appendix "B"

Project Funding History

\$ 090's	-	Ali	Existing	and Plans	od Reion ulative V	eve (incl stuge	continger	ncy)	-		
Release Type	and a supervised of the second s	Year	2007	2008	2009	2010	2011	2012	2013	Later	Total
Developmental	Jan	2,007	345	1,438		3					1,783
Full					8,000	5,000	5,000			45,000	63,000
											0
			·		···						0
											Ŭ
							·		·····		0
	·										0
									1		0

Comments:

The only project funding to date has been Conceptual Seed money from the Projects and Modification organization to produce the Developmental BCS and the PEP. The funding was \$50K acquired in 2005 and spent in 2006. The spending to date (as of November 9, 2006) of the seed money has been \$26K.







Appendix "C"

Financial Model – Assumptions

Project Cost Assumptions:

To assess the cost of resources, it was assumed that 50% of the personnel would be internal and the other 50% external. An average internal rate is 70\$/hr and a conservative external rate is Therefore, a blended rate of 135\$/hr was used for the cost estimates of the preliminary engineering tasks.

Financial Assumptions:

N/A

Project / Station End of Life Assumptions:

The SDS computers are required for the life of the station (up to 2018) and for any plant life extensions until the end of decommissioning.

Energy Price / Production Assumptions:

N/A

Operating Cost Assumptions:

No changes in operating staff are expected to operate/maintain the SDS computers.

Other Assumptions:

N/A

ONTARIO POWER GENERATION

OPG Confidential

Page: 13 of 15

BUSINESS CASE SUMMARY

DNGS SDS Aging Management 16 - 33955

Developmental Release Business Case Summary D-BCS-68000-10002-R000

Attachment	"A"

Project Cost Summary

\$000's Capital	LTD Prior Yr 2006	This Release	This Rolass						
Project Management (OPG)		2007 50	2008	2009	2010	2011	I commune	Later	Total
Engineering & Drafting (OPG)		200	100 1 090						150
Material		200	1090		ļ	 +	+		1,290
Installation - PWU, BTU									
Contract - Design									-
Contract - Installation	1				without the same		-		
Contract - Other					_				
Future Project Costs					64-124	1			
(includes continengy and interest)									
Interest (Capital Project Only)									
Project Costs (and contingency)				-			-		
General Contingency									·
Specific Contingency	2	10000						-	Concernant of the
Toject Costs (Ind contingency)		345	1 438	8,000	5,000	2 000			
2007-2011 Business Plan		300	3.700	8,000	5.000	5,000		45,000	64,783
fariance to Business Plan			(2,450)	0,000	5,000	5,000	····»	43,000	65,000
Committed Cost		······································	1-1-1-1 ()	· · · · · · · · · · · · · · · · · · ·		· · · · · · · · · · · · · · · · · · ·		2,000	(450)
ventory Write Off Required									+
pare Parts / Inventory			——					·	-
otal Release (excl contingency)		300	1.250	8,000					-
otal Release (not contingency)	the second second second second second second second second second second second second second second second s	345	me - manuta	marine and the	5,000	3,000		45,000	64,550
			1,438	8,906	5,000	5,000	-	45,000	64,783
nyoing OM&A (non-project)			S. I.	T		T		r r	
ernoval Coeta (incl in above)				······································		-			

	- 20 - 20 - 20 - 20 - 20 - 20 - 20 - 20	Basis of E	stimate	······		*****
Design Complete		N/A	Quality of E	stimate	Conceptual -	- 60% to 254
3 rd Party Estimate	No	OPEX used	Yes	Lessons Lea		1
Reviewed by Sponsor	Yes	Budgetary Quote(s)	No	The second	where we are a second s	Yes
Similar Projects	Yes	Contracts in place		Phase 1 Act		N/A
and the second second second second second second second second second second second second second second second		1 conducto in place	No	Competitive	Bid	N/A

Variance to Business Plan

The estimated variance(s) to the 2007-2011 Business Plan will be addressed through the portfolio management process. A PCRAF will be approved by June of 2008.

Reviewed By: N. 16/200 6 ke Vida

Approved By V 16,24.6 **Rick Hohendorf**

roject Manager

Date:

Eng & Mods Manager (Strat IV)

Date:



DNGS SDS Aging Management 16 - 33955

Developmental Release Business Case Summary D-BCS-68000-10002-R000

Attachment "B"

Project Variance Analysis

	1	Choos	e One	Variance	na na serie na serie na serie na serie na serie na serie na serie na serie na serie na serie na serie na serie Na serie na s
Choose One	LTD NA NA	Lant BCS IVA IVA	This BCS N/A N/A		Convenents
Project Management (OPG)				0	
Engineering & Drafting (OPG)	1			0	
Material					
Installation - PWU, BTU					
Contract - Design					
Contract - Installation					
Contract - Other	3				
Interest (Capital Project Only) Project Costs (rast centingency) General Contingency					and a second and a second and a second and a second and a second and a second and a second a second a second a
Specific Contingency	. سري ملاقد				
mject Costs (Incl contingency)		0	0	<u>0</u>	the second second second second second second second second second second second second second second second s
Committed Cost				0	
nventory Write Off Required				0	· · · · · · · · · · · · · · · · · · ·
Spare Parts / Inventory	-			0	
Total Release (incl contingency)	. 0	0	0	Ø	
otal Release (excl contingency)	0	0	0	Ø	
Ongoing OM&A (pon-project)	فطرد رهي ادرايه اريادتها بميندر دراردطور م	T + ~~~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~	···· ·································	0	
HERICY Costs (incl in above)				<u></u>	анан алан алан алан алан алан алан алан
HORY THE LOUGH UNKLINE HUDS'N'		Same and the second second		Y	

Comments:

Not applicable since this BCS is not requesting a superseding release.

Page: 1 of 15

BUSINESS CASE SUMMARY

SG Controls Retrofit 16 - 33973

ONTARIO POWER GENERATION

Developmental Release Business Case Summary D-BCS-49100-10001-R000

Routing	Location		Signature	Date
E. Thomas Project Leader 703-3529	BW7-02	Prepare BCS	Attalian -	141) ac 200
T. Cvitkovic Section Manager, Design Projects 703-3571	BW7-02	Review BCS	AGA	14 Sa 200
J. Taras Section Manager, PMO 703-3528	BW7-02	Review BCS	Stin Taxos	- 14Dee06
J. Shemilt Manager, Projects Design 703-1963	ES3-L13-2	Review BCS	fur sweine	_
T. Chong Manager, Design Projects 703-3520	BW7-02	Review BCS	- 2 Jones	14 20020
W. Qualtrough Manager, Performance Engineering 703-7484	D08-ES2	Review BCS	ADDE	15 Dec/66
A. Kleer Sonior Financial Analyst 1110	P82-3B-6	Review BCS	Refer A.V.	13 De 2006
Director, Projects and Modifications 701-6063	P72-E4.4	Submit BCS	alle	15 2002006
R. Leavitt Director, Investment Management 702-6878	P82-F3-A6	Approve BCS	Tolonia	14 Dec 2006
3. Seedhouse Director, Station Engineering 103-7584	D08-ES3	Approve BCS	Serch	15 Dec 2006
Financial Analyst 084	P82-3B6	Return For Distribution		

Page: 2 of 15

GENERATION

ONTARIOPOW

BUSINESS CASE SUMMARY

SG Controls Retrofit 16 - 33973

Developmental Release Business Case Summary D-BCS-49100-10001-R000 1/ **RECOMMENDATION:**

Approval is requested for this Developmental Release of \$1536k (including approvaling contingency) Capital to complete the Definition Phase of the Standby Generators (SG) Controls Retrofit project. In this phase we will select and engage the supplier of the control systems from an evaluation of six (6) prospective vendors, complete the preliminary engineering, prepare detailed estimates and obtain approval of a Full Release Phase 1 BCS for the

The business objective of this project is to address the issue of unreliability and obsolescence such that the SG System Health can be maintained as white and generation risk avoided. This will be done by installing new control systems on all four SGs. The new control technology will also provide for remote monitoring and increased diagnostic capabilities to improve maintenance programs.

SG unavailability is a violation of OPG's Operating License that would require us to shut down all units if one SG could not be made available within twenty-four hours. SG Control System components are over 20 years old, are susceptible to unpredictable failure and are no longer supported by the original equipment manufacturer. Current trends indicate that our stock of critical spare parts will be depleted in an estimated 3 to 5 years, at which time the risk of concurrent SG failures will increase significantly.

Some effort has been focused on the search for alternate suppliers of spare parts, with no success to date. Similar projects performed at Darlington (Ref D-PIR-49200-10001) and Pickering B (Ref NK30-BCS-54600-00011-R000) were reviewed, and in both cases the control systems were completely replaced because no new sources pare parts could be identified. Project costs in both cases were also consistent with our current estimates, ever a better quality estimate for the overall project cost will be developed in this phase.

At least five SCRs have been raised to document problems with the existing SG control systems, and a continued decline in reliability will result in System Health degrading from white to yellow. Replacing the control systems will increase reliability and availability of spares, to maintain the System Health white.

autors (incl contingency)	Funding	1 TD GOOG		1	······································				
Currently Released	runong	LTD 2006	2007	2008	2009	2010	2011	Later	Total
Requested Now					and and a second second second second second second second second second second second second second second se	·····	<u> </u>	LOIDI	10tal
	Developmental		1,041	495					
Future Funding Req'd	Full			1,155	4.406	7.100			1,536
Total Project Costs		-	1.041	1.650		7,100	3,740		16,401
Ongoing Costs			1,041	000,1	4,406	7,100	3,740	-	17,937
Other Costs		······································		- · · · · · · · · · · · · · · · · · · ·	·	·- ·····			the second second second second second second second second second second second second second second second s
Grand Total	······································			····					
Investment	Vne		1,041	1,650	4,406	7,100	3,740		17 017
Sustainin		Class Capita		NPV or	IEV	IRA		Discounte	17,937 Ind Payback

Submitted By

M. Arnone

15 Dec 2006 Date:

Director, Projects and Modifications

Finance Approval

R. Leavitt

ector Investment Management

<u>Doe</u> N 200 / Date:

Line Approval (Per OAR Element 1.1 Project in Budget):

15 Declarob

S. Seedhouse Director, Station Engineering

Date:



BACKGROUND & ISSUES

Over the past few years, it has become evident that various control and monitoring components for the four Standby Generators (SGs) were obsolete. Manufacturers of the original components no longer provide replacement parts or service the equipment. In some cases these manufacturers no longer exist. At this time, there is a stock of critical spare parts but it is anticipated that within 3 to 5 years, this stock will also be depleted.

The known affected control and monitoring components are:

- Woodward Governor (some spares are available, calibrator parts are not available and neither technical nor parts support are available).
- Bentley Nevada Vibration Monitor (some parts are in stock and neither technical nor parts support are
- Rochester Annunciator (no spare parts in stock, neither technical nor parts support are available).
- Airpax Over Speed Unit (some spare parts in stock, manufacturer no longer in existence).
- Protection relays

The health status of the SGs is white (declining towards yellow). The system health reports have listed several SCRs which indicated that power supply circuit breakers have been found open, resulting in start failures or unavailability problems. The new control system would facilitate the early detection of these and other problems.

If the control system were to fail, the associated SG would be rendered unavailable. Repairs under such forced outage conditions could take several months to complete. If another SG were to fail during this time period or be unavailable due to scheduled maintenance or forced outage, the two remaining SGs must remain in the standby utdown state. If only two SGs are available, the SGs must be placed in their preferred SG line-up with respect reaker selections per NK38-OM-49100-4.12, ODD/EVEN SG selection.

Although the minimum requirement per OP&Ps is one SG, maintaining the effectiveness of Class III Transfer System requires a minimum of two SGs to be available. At least one must be selected to the ODD bus and at least one to the EVEN bus. The Class III Transfer System will first pick up the mandatory nuclear loads to ensure a safe shutdown state is maintained (one SG can carry these). The economic loads will then be picked up. The second SG is needed to pick up the significant economic loads. Failure to pick up economic loads such as the turning gear auxiliaries and the Irradiated Fuel Bay, which will then begin to heat up, could result in damage to

Several SCR's (D-2006-01672, D-2006-01413, D-2006-01821, D-2003-03331, D-2006-08173) document problems with the control system. The following significant issues were noted in the SCRs:-

- D-2006-01672 Numerous alarms were identified on SG1 in February 2006. At the time SG3 and SG4 were already unavailable, resulting in 3 SGs being unavailable.
- D-2006-01413 During a test run of SG3 in February 2006, the auto synchronization failed. The . synchronization was done manually. During the second run-up SG3 tripped on high vibrations and was
- D-2006-01821 In February 2006, A low vibration indication was found on SG4 vibration probe. A vibration probe was ordered for installation during the upcoming outage. This was not possible because the required parts were unavailable.
- D-2003-03331 In April 2003 the overspeed unit in SG2 was repaired by the manufacturer by obtaining a damaged board and replacing the burnt resistors, old capacitors and bad zener diode. This is a common problem for this board. The manufacturer questioned the wisdom of investing time and money in trying to extend the life of these units as opposed to replacing the whole system.



D-2006-08173 - In September 2006 SG3 tripped on generator protection. The 21B phase back-up relay, which has a history of spurious operation and the 64 ground fault relay were found to be tripped.



Page: 4 of 15

BUSINESS CASE SUMMARY

age: 4 of

3/ ALTERNATIVES AND ECONOMIC ANALYSIS

Carrier Carrier		Alt 1 (Rec	ommended)	Alt 2	AH 3	Alt 4	Aur	
	Do Nothing	Full Cost	Incremental Cost	Delay	2 SGs Only		Alt 5	Alt 5
Revenue	***** ********************************	••••••••••••••••••••••••••••••••••••••						
Project Cost	N/A	18,000	18,000	N/A	12,000		·····	······································
NPV (after tax)				·	12,000			
Impact on Economic Value								
IRR%						· · · · · · · · · · · · · · · · · · ·		
Discounted Payback (Yrs)					·······			
······································		· · · · · · · · · · · · · · · · · · ·						

Do Nothing (Not Recommended)

This alternative is not recommended because failure to improve reliability and maintainability of the SG Control System will not satisfy the requirements set out in the station OP&P and the Safety Report. SG Control System components are over 20 years old, are susceptible to unpredictable failure and are no longer supported by the original equipment manufacturer. Current trends indicate that our stock of critical spare parts will be depleted in an estimated 3 to 5 years, at which time the risk of concurrent SG failures will increase significantly. Continued partial or complete failure of stand by Class III power.

Alternative 1 – Replace All The Control Systems (Recommended)

We recommend the replacement of all the control systems, because complete replacement of the control systems would guarantee the reliability of the SGs for the remaining life of the station. This consideration and the need to maintain the reliability and availability of the SGs within the limits set by the reliability model for safe operation of the station, favour a complete replacement of the control systems for all SGs.

Replacing the existing SG control systems will improve reliability and eliminate obsolescence issues by providing the following:

- Reliable and proven control systems that are of more recent design, with readily available parts and technical support.
- Increased diagnostic capabilities and remote monitoring of generators by the system engineer to ensure that preventive maintenance and surveillance programs are effective.
 A reduction of the incidence
- A reduction of the incidence of start failures as per the reliability model for safe operation of the station, over the remaining life of the station.

This direction is consistent with similar projects performed at Darlington (Ref D-PIR-49200-10001) and Pickering B (Ref NK30-BCS-54600-00011-R000). Our current estimate for this alternative is also consistent with the project costs for both of these comparable cases. A better quality estimate for the overall project cost will be developed in this phase.

Alternative 2 - Delay Project - Not Recommended

recommended because all the SGs are of the same age and the anticipated problem of spare parts unavailability in 3 to 5 years could result in all four SGs being unavailable at the same time. Any further delays to the project schedule will result in an increased risk of concurrent SG failures.

OPG Confidential	

Page: 5 of 15

Alternative 3 - Replace The Control Systems On Only Two SGs (Not Recommended)

Replace the control systems in only two of the four SG's, and salvage the removed components to increase the inventory of spares for the remaining two SG's.

This alternative is not recommended because:

GENERATION

ONTARIOPO

- The reliability gains will be less than the recommended alternative. .
- The cost of this alternative is marginally less than the recommended alternative, with continued reliability and maintainability issues with the unmodified SGs.
- Operating and maintaining two pairs of SGs with dissimilar control and diagnostic systems will introduce new issues and challenges for configuration management, documentation, maintenance procedures and

Alternative 4 - Compile Substitute Parts From Alternate Suppliers (Not Recommended)

Search for available parts from any suppliers and continue to repair the control systems until the end of life of the station. This approach is not recommended because the Darlington Scope Review Team already investigated the possibility of purchasing substitute parts from any available vendors, whether or not they are already approved by OPG. The intention was to diligently explore the possibility of identifying available parts anywhere in the world and subsequently try to approve such vendors through the normal OPG process. There has been no success to date with this approach. While this approach may have been economically viable, assuming that all other problems associated with the age of any available parts and the age of the systems themselves, could be overcome, no parts have been located up to this point in time.

milar problems were encountered with the Darlington Emergency Power Generators (EPGs) and the Pickering B . In both cases the control systems were completely replaced (Ref D-PIR-49200-10001 and NK30-BCS-600-00011-R000 respectively).





4/ THE PROPOSAL

The developmental release will be used to select and engage the preferred supplier through competitive process, complete the preliminary engineering, prepare estimates and obtain Full Release Phase 1 BCS.

This release will deliver the following:

- The Modification Outline, Design Scoping Checklist, Design Plan and Modification Design Requirements. .
- **Technical Specifications**
- Issue RFP and evaluation of proposals from up to six prospective vendors ٠
- Retention of preferred supplier .
- Complete preliminary engineering ٠
- Preparation of quality estimates •
- Full Release (Phase 1) BCS •

5/ QUALITATIVE FACTORS

Increased diagnostic and remote monitoring capability will assist in establishing effective preventive ٠ maintenance programs and early detection of potential problems.



ONT IOP GWER

OPG Confidenti

Page: 7 of 15

BUSINESS CASE SUMMARY

6/ RISKS

The surger and the second

Cost	Description of Consequence	Risk Before Mitigation	Mitigating Activity	Risk After Mitigation
Expenditure may exceed released funds.	Cost overrun	Medium	Deliverables are clear; estimate is based on internal staff doing the work and good estimates are in hand; menor contingency has been allocated for this phase of the project to ensure expenditure does not exceed the release limit	Low
Scope Scope of this Phase may increase based on discussion with vendors	Schedule and cost overrun	Medium	The scope of this phase is defined and scope increase is unlikely, however,	Low
Schedule Schedule for completing the milestones may be delayed due to lack of resources	Schedule and cost overrun	Medium	Appropriate resources have been identified (eg. DNGD Projects Design, CCD - DNGD DCC) and will be used as soon as funding is released.	Low
Resources Lack of experienced engineering resources for this Phase of the project	Delay in completion of this Phase	Wedium		Mo
Technical		ALC: NOT ALC	contingency has also been allocated.	



Page: 8 of 15



OPG Confident

None	None	Environmental	Health & Safety	Investment

÷

l

11 POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Final AFS	Targeted PIR Approval	PIR Responsibility
	Date:	Date:	(Sponsor Title)
N/A	N/A	N/A	N/A

Comments:

N/A for this phase.

	Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it?
1.				meusureur	(person / group)
2.			 	·	
3.	· · · · · · · · · · · · · · · · · · ·				
4.	2/1 1- 0/1/2/2014				
5.					

Appendix "A"

Glossary (acronyms, codes, technical terms)

- SG - Standby Generator
- SCR Station Condition Record -

ONTARIOPOWER

- CCD - Computer Control Design
- Digital Control Computers DCC
- PEP PEP - Project Execution Plan PCRAF - Project Change Request
- Project Change Request Authorization Form

GENERATION

OP&P -Operating Policies and Principles



ONTARIOPOWER GENERATION

OPG Confidential

BUSINESS CASE SUMMARY

Appendix "B"

Project Funding History


000's Release Type	Month	Year	Timing of 2005	Funding 2006	Released 2007	2008	tingency) 2009	2010	2011	Later	Total
	{ 										0
											0
	· ·· [∲ 								0
	• • • • • • • •	,	<u>+</u>		·····	····	···				0
											0
		÷				·					0
											0
~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~		i					- «				0

# Comments:

Conceptual Funding of \$135k was approved by the Director of Projects and Modifications in November 21, 2005.



1977 - E. 198



# Financial Model - Assumptions

**Project Cost Assumptions:** 

Conceptual Estimate +60% to -25% See Basis of Estimate (Attachment A)

**Financial Assumptions:** 

Project / Station End of Life Assumptions:

2018

**Energy Price / Production Assumptions** 

**Operating Cost Assumptions** 

Other Assumptions:



**ONTARIOPO** 

**OPG** Confidential

**BUSINESS CASE SUMMARY** 

# SG Controls Retrofit 16 - 33973

# Developmental Release Business Case Summary D-BCS-49100-10001-R000

# Attachment "A"

# Project Cost Summary

\$000's Capital	LTD Prior Yr 2006	Dev Release 2007	Dev Release 2008	Future Release 2008	Future Release 2009	Future Release 2010	Future Release 2011	Later	2 . <u>2 . 2</u>
Project Management (OPG)	·	138	79	70	170	170	170	Later	Total
Engineering & Drafting (OPG)		315	162	400	420	360	100		79
Material							100		1,757
Installation - PWU, BTU	I	_				t provide		_	
Contract - Design									
Contract - Installation								_	_
Contract - Other									
Contract - Software & HFE								-	
									······
Interest (Capital Project Only)								Contraction of the	
Project Spending	10 H								
Committed Cost									
roject Costs (exci contingency)									- 4
eneral Contingency									
Specific Contingency									-
Project Costs (incl contingency)		1,041	495	1,155	4,406	7,100	2742		
Ongoing OM&A (non-project)				1,100	4,400	7,100	3,740		17,938
ventory Write Off Required			···					:	-
pare Parts / Inventory	· · · · · · · · · · · · · · · · · · ·		·····	· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · ·				•
irand Total (incl contingency)		1.041	495	1,155	4.400	-		; 	-
006-2010 Business Plan	1,500	3,500		3500	4,406	7,100	3,740	-	17,938
ariance to Business Plan	(1,500)	(667)	(3,104)	924	3,000	2,850			14,350
and a second second second second second second second second second second second second second second second		10011	5,1041	924	525	2,830	2,992		

Removal Costs (incl in above)

		Basis of Estimate	+60% / -25%		
Design Complete	No	Contracts in place	T	Compositive D' I	
3 rd Party Estimate	No	OPEX used	N.	Competitive Bid	No
Reviewed by Sponsor	No	Sponsor Cost Estimate		Lessons Learned	Yes
Other:		Popolisor Cost Estimate	<u>No</u>	Phase 1 Actual Used	No

Variances to 2006 Budget and 2006 -2010 BP will be addressed through the portfolio management process.

Reviewed By ed By - 30-208 n Cvitkovic Terry Chong Eng & Mods Manager (Strat IX) roject Manager Date:

Date:

-

ONTARIOPOWER GENERATION

OPG Confidential

BUSINESS CASE SUMMARY

# SG Controls Retrofit 16 - 33973

# Developmental Release Business Case Summary D-BCS-49100-10001-R000

# Attachment "B"

# Project Variance Analysis

	Choos	se One		
LTD Choose Choose	Last BCS N/A	This BCS N/A	Variance	Comments
1			0	and a second second second second second second second second second second second second second second second
	1		······································	
Provide State				
1			,	
T .				
P			4	······································
1				······································
882			2	
H.				
P			· 2	
0	0	0	0	
			· · · · · · · · · · · · · · · · · · ·	
			····· • ···-	
0	0	0	0	
	Choose Choose	LTD Last BCS N/A Choose N/A 0 0	Choose N/A N/A N/A N/A 0 0 0	LTD Last BCS M/A M/A Variance Choose N/A N/A 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0

No previous release. Not required

ONTARIOPOWER GENERATION

OPG Confidential

**BUSINESS CASE SUMMARY** 

# ttachment "C"

# Key Milestones

Completion Date		Date	
Day	Mth	Yr	Description
02	Sep	07	Major Contract Awarded (MCA)
14	Feb	08	Preliminary Engineering (DES)
30	May	08	Full Release (Phase 1) BCS
	<u> </u>		
		<u> </u>	

## Comments:

A Project Execution Plan (PEP) will be approved by September 2007

1.25

ONTARIO GENERATION

BUSINESS CASE SUMMARY

# PNGS-A D2O Storage and Drum Cleaning Facility 13 - 49251

# Developmental Release Business Case Summary NA44-BCS-38000-00001-R000

Routing	Location	Action	Signature	Date
Tracy Leung Modification Team Leader x2767	P72-3	Prepare BCS	to Deren for	Nav (7/06
Edmond Wong Project Leader x 3991	P72-3	Review BCS	P.S-	NN17/6
Stephanie Tham Project Manager x 4203	P72-3	Review BCS	ARD.	NEN 21/06
Peter Floyd Manager, Design Projects, Pickering A x 4053	P72-1	Review BCS	Carylow Car Royd	Nov 22 /06
Mark Arnone Director, Projects & Modifications × 6063	P72-1	Review BCS	Rhe	221002006
Dave Topolnisky Manager, Common Services x 3503	P05	Review BCS	Van Sand	1/122/2016
Dwight Zerkee Technical Advisor, Nuclear Analysis 02-4082	P82-3	Review BCS		211 Nacks
/ hina Velshi Oirector, Commercial Activities x 702-5100	P82-4	Submit BCS	Acrohu	27 Nov OL
Randy Leavitt Director, Investment Management x 702-5085	P82-3	Approve BCS	Alant	Nov. 27, 2006
Martin Tulett Director, Operation & Maintenance, Pickering A, x2099	P05-A2	Approve BCS	1002-05	No: 29/46.
		5 5		
R. Ball		Return		
Senior Financial Analyst /-4084	P82-3B6	For Distribution		

OPG	Confidential

H							СП А~	116745 20112 <b>111</b> 8		
		1	dina.	-	j,	Б	$\mathcal{A}$		JN	

# PNGS-A D2O Storage and Drum Cleaning Facility 13 - 49251

## Developmental Release Business Case Summary NA44-BCS-38000-00001-R000 1/ RECOMMENDATION:

We recommend approval of a Developmental Release of \$2,506k (including contingency) to complete preliminary design, initiate detailed design, initiate Requests for Quotations for long-lead materials and develop a Partial Release for the PNGS D₂O Storage and Drum Handling Project by November, 2007. A Partial Release will be requested upon completion of preliminary engineering to facilitate a seamless transition to detailed design, long-lead material procurement, initiate Requests for Proposal for the construction contract and develop the Full Release. This funding strategy will minimize cost and schedule delays.

There are three business objectives of this project as per Project Charter N-PCH-03800-10000:

- 1. Improve detritiation capability within OPG-N
- 2. Provide operational flexibility for the storage and segregation of different grades of  $D_2O$
- 3. Provide a drum cleaning facility to manage the backlog of D2O drums in the station

Note: Plant Life Extension and Decommissioning of P2 and P3 are not part of the mandate of this project.

Kinectrics was commissioned to study the Heavy Water Storage and Drum Handling issues from the overall OPG-N perspective. The recommended modification for Pickering is listed below:

- Install 1x 16 Mg downgraded, low curie, oily D₂O tank
- Install 1x 16 Mg downgraded, high curie, oily D₂O tank
- Install 1 x 46 Mg downgraded, low curie, non-oily  $D_2O$  tank
- Install 1 x 19 Mg downgraded, high curie, non-oily D₂O tank
- Install a Drum Cleaning Facility

Detritiation difficulties at PNGS cannot be solely tied to a lack of storage capacity at the Storage and Inventory (S&I) system and, therefore, it is not recommended any S&I tanks to be installed in PNGS. However, Pickering will be able to utilize Darlington's S&I pks, that are to be installed under Darlington Project 16-31555, as temporary storage as required or TRF product reservoirs to sure low curie D₂O is always available to Pickering for detritiation. Similarly, there is insufficient justification to install a drum cleaning facility at DNGS and that the Pickering's Drum Cleaning Facility will be used to clean dirty drums from Darlington.

Choose One	Funding	LTD 2005	2006	2007	2008	2009	2010	Later	Total
Currently Released	None		y hondrad en deul y sen voë y by Faush slavaladar i	a de alesta de la defenir de norma local esta sera de la  a de la constance de la constante de la constan	n randan antanahan antan karang anan 19 2 mm	n Corte de La MANTE de La constante de la const	, and a second second in the following of the first second second second second second second second second sec	Control Representation (Control Provided Street)	
Requested Now	Developmental			1,330	1,176				2,506
Future Funding Regid					2.837	7,720	4,319		14,876
Total Project Costs		•	*	1,330	4,013	7,720	4,319	-	17,382
Other Costs									•
Ongoing Costs									-
Grand Total		-	-	1,330	4,013	7,720	4,319	-	17,382
Investment	Туре	Cl	155	(IEV) Impac	t on Ec Value	l IF	IR	Discounte	ed Payback
Sustaini	ng	Caj	latic	6,4	173	14.	7%	7	.8

Submitted By

27 Nov 'OL Date:

Zook Date:

Nou. 27

Rumina Velshi Director, Commercial Activities Project Sponsor

Finance Approval

Randy Leavitt

Director. Investment Management, NOSS

Line Approval (Per OAR Element 1.1 Project in Budget)

XNNX Martin Tulett

Nov 29/06

Director, Operations & Maintenance, Pickering



# 2/ BACKGROUND & ISSUES

Both Pickering Nuclear Generating Station A and B need to improve their overall ability to manage D₂O inventories to support continuous station operations in a safe and cost efficient manner. In December 2004, Kinectrics Inc. was requested to perform a strategic study on OPGN's Heavy Water Storage and Drum Handling Strategy. (Ref; K-011043-001-RA-0001-R00A). In April 2006, Kinectrics Inc. was engaged by the Project to fine-tune the initial study with clear assumptions and verified information for the stakeholders

The three main objectives of this project are as follows:

- 1. Allow large volume bulk swap of heavy water for detritiation to keep units running below the OP&P limit for tritium concentration.
- 2. Improve operational flexibility to segregate different streams of D2O to support normal operation and outages.
- 3. Improve the management of drums in the station and to reduce associated drum handling-related radiological and conventional safety hazards.

Decommissioning of P2 and P3 and Plant Life Extension are not part of the mandate of this project.

#### 2.1 Large Volume Bulk Swap of Heavy Water for Detritiation

Pickering B units have exceeded their Administrative limits for tritium concentrations in both the Moderator and the Primary Heat Transport (PHT) system and are fast approaching the OP&P limits.

The current mode of detritiation is performed with the reactors online whereby high Curie Moderator D₂O is bled out from the unit and low Curie D₂O is fed from the Storage and Inventory System (S&I) into the unit simultaneously.

preferred mode of detritiation of the station is to perform bulk detriliation on a unit during outages when the Moderator intory is drained out and replaced by the same volume of low Curie  $D_2O$  which is often of a higher isotopic. As a result, the obiopic of the Moderator system is upgraded simultaneously. This mode of detritiation is opportunistic and requires more tanks for  $D_2O$  maneuvering; however, it is more effective since there will be no wastage of the low Curie  $D_2O$  being fed to the unit.

The following tables summarize the problems that are caused by the inability to perform large volume bulk swaps of D₂O for detritiation:

Problem	Issues	Impacts
There is inadequate Storage and Inventory (S&I) storage capacity to allow large volume bulk swap to be performed readily	<ul> <li>Reliance on online detritiation, as there is very limited capability to perform the more effective offline detritiation.</li> <li>Require extensive planning and coordination with TRF and rearranging D₂O in S&amp;I Tanks, even for on-line detritiation</li> <li>Inability to efficiently perform moderator upgrading</li> </ul>	<ul> <li>Less efficient reduction of tritium emissions to the environment</li> <li>Less efficient reduction of dose absorbed by workers</li> <li>Possibility of regulatory sanctions due to OP&amp;P violations as a result of a lower efficiency of detritiation</li> <li>Lower fuel-burnup efficiencies</li> </ul>

#### Table A. Problems caused by inability to perform large volume bulk swaps of D₂O for Detritiation

#### 2.2 Operational Flexibility to Segregate Different Streams of D20

The lack of storage capabilities for proper segregation of different streams of D₂O inventory is impairing operations. If off-site storage is required, or if operator work-arounds are warranted, then this increases costs and induces additional workload for operations

ONTARIO	ruwen
	GENERATION

Page: 4 of 21

BUSINESS CASE SUMMARY

#### 2.2.1 Reactor Grade D₂O Storage & Segregation

During normal or outage situations, the following inventories of D2O should be segregated:

- High Curie D₂O (including Sulzer-B Upgrader Product)
- Low Curie D₂O (including UPP-B Upgrader Product)
- Moderator D₂O (containing Gadolinium)
- Primary Heat Transport D₂O (contains Lithium)
- TRF Grade D₂O (Very Low Curie)

The following table summarizes the problems that are caused by not having enough Reactor Grade D₂O (S&I) Tanks for storage and segregation:

#### Table B. Problems caused by insufficient S&I tanks for Reactor Grade D2O Storage and Segregation

Problem	Issues	Impacts
Limited flexibility in reactor grade $D_2O$ segregation during outages	<ul> <li>During outages, when S&amp;I tanks are taken up by moderator drains or PHT drains, then the existing inventory does not have space for storage</li> </ul>	<ul> <li>Pickering Incoming/Outgoing D₂O Transfer System (PIOTS) is often used to store Reactor Grade D2O during outages, impeding TRF receiving and shipping activities</li> <li>When S&amp;I tanks are taken up by drains from the outage unit, there is limited capacity to hold upgrader products from Sulzer-B or UPP-B, causing these upgraders to go into reflux</li> <li>High probability of human performance errors when tanks that were specified to hold a certain grade of D₂O must be filled with another grade of D₂O due to lack of storage space</li> </ul>
Limited flexibility to store assigned TRF product's quota to meet PNGS's Detritiation Plan	<ul> <li>Shipment and receiving of TRF Product rely heavily on the availability of TRF and S&amp;I</li> <li>Requires planning and resources to rearrange contents in S&amp;I before shipping and receiving</li> </ul>	<ul> <li>Reduce capability to meet PNGS's detritiation plan</li> </ul>

2.2.2 Downgraded D₂O Storage & Segregation

The existing storage capacity at the Ion Exchange Clean-Up System (IXCU) is not adequate for segregating downgraded D₂O. The following grades of downgraded D₂O should be segregated for maximum IXCU operating efficiency:

- High Curie, Non-Oily D₂O
- Low Curie, Non-Oily D₂O
- High Curie, Oily D₂O
- Low Curie, Oily D₂O

0	TΑ	RI	0				
				GE	NE	RA	TION

Page: 5 of 21

**BUSINESS CASE SUMMARY** 

	ficient IXCU tanks for Downgraded D ₂ Issues	Impacts			
system is not adequate for the	System Degradation, causing high leakage rates and a high load on recovery and clean-up systems	<ul> <li>When the load cannot be efficiently processed by the IXCU system, a large amount of backlog is accumulated, requirin all recoveries to be drummed, increasing drum handling, dose hazards and housekeeping issues</li> </ul>			
designed for high volumes of oily	The Pickering fuelling machines leaks a hydraulic fluid which is collected in the Building Liquid Recovery system.	<ul> <li>Any backlogged oily D₂O is drummed, causing drums to become oily.</li> <li>Oily recoveries may overflow into non-oily tanks, causing these tanks to become oily as well, contaminating clean recoveries. This further increases the oily load.</li> <li>Additional expenses need to be incurred to clean the oil film off of the non-oily tanks every few years.</li> <li>Oily recoveries process at a slower rate than non-oily recoveries, lowering the efficiency of the IXCU system.</li> <li>Inadvertent leakage of oily recovery into the upgraders is a contributing factor to the degradation of upgrader's packing and to the reduction of heat transfer capability of the reboilers.</li> <li>External upgrading services will be expensive and repacking of upgraders will cost millions.</li> </ul>			
IXCU was not designed to treat or segregate High TOC D ₂ O.	<ul> <li>Use of organic solvents and chemicals in the Reactor Building for cleaning and reactor components inspections causes high Total Organic Carbon (TOC) levels in recoveries</li> <li>TOC is very difficult to remove and it requires sufficient time and segregation to be reduced to less than 1 ppm before they can be sent to the upgraders to prevent upgrader packing degradation and plugging of distributors.</li> </ul>	<ul> <li>The degradation of upgraders due to TOC may be exacerbated to a point where external upgrading services are required.</li> <li>Inadequate feed to the upgraders due to the inability to achieve specifications causes backlog at IXCU, while the upgraders to go into reflux, wasting operational resources</li> <li>If a significant inventory cannot be upgraded, then the D2O must be made up from D2O rentals from external companies</li> <li>Note: It is assumed that a UV-Oxidation Unit will be installed in Pickering, which is capable of reducing TOC from downgraded D₂O to the specified 1 ppm. The UV-Oxidation unit is designed to act as a polishing system to remove TOC after the majority of the contaminants are clean-up from the downgraded D₂O.</li> </ul>			

### Table C. Problems caused by insufficient IXCU tanks for Downgraded D₂O Storage and Segregation

\$



## **BUSINESS CASE SUMMARY**

### 2.3 Drum Cleaning Facility

## Table D. Problems caused by a lack of a Drum Cleaning Facility

Problems	Issues	Impacts
Inability to process or reduce drum inventory	<ul> <li>Pickering has an inventory of 3000 drums around the station.</li> <li>Oily drums being used to collect non-oily recoveries</li> </ul>	<ul> <li>Drums that contain sludge cannot be disposed of</li> <li>Housekeeping concern that has already instigated CNSC scrutiny</li> <li>Drum Handling Hazards</li> <li>Dose hazards</li> <li>Takes up valuable real estate in the station</li> <li>IXCU efficiency is reduced, causing a further backlog upstream, requiring the purchase of more drums to store the backlog @ \$700 to \$800/drum</li> <li>If the inventory of unprocessable D₂O becomes too large to handle, then external cleaning services needs to be purchased</li> </ul>

## 3/ ALTERNATIVES AND ECONOMIC ANALYSIS

\$000's	Do Nothing	Alt 1 (Rei	commended)	Alt 2	Alt 3	
		Full Incrementa Cost Cost		andra andra andra andra Geologica Maria Index and Providencia Maria Index and Providencia		
anevenue	0	0	0	0	3,573	
OM&A	(68,296)	(19,132)	(19,132)	(27,203)	(19,107)	
Capital	0	(17,384)	(17,384)	(18,442)	(36,000)	
NPV (after tax)	(26,817)	(20,344)	(20,344)	(22,985)	(32,390)	
Impact on Economic Value (IEV)	N/A	6,473	6,473	3,832	(5,573)	
IRR%	N/A	14.7%	14.7%	14.1%	N/A	
Discounted Payback (Yrs)	N/A	7,75	7.75	7.96	N/A	

#### Status Quo - Not Recommended

Status Quo is not a recommended option

Pickering units need to achieve better detritiation efficiency in order to prevent reaching the OP&P limits for tritium content.

During normal operation, online detritiation performed in a large volume requires careful planning, coordination with TRF and movement of Reactor Grade  $D_2O$  in S&I tanks. This is due to the limitation of S&I tank storage space, which sometimes prevents online detritiation to be executed.

During outages, the receiving and shipping of TRF product is often impeded by the available S&I tank space, causing the station to miss valuable opportunities to detritiate.

The downgraded  $D_2O$  storage capability is not sufficient to meet current recovery rates, causing excessive drum usage that induces radiological and conventional hazards for workers. The lack of sufficient segregation of downgraded  $D_2O$  has caused the IXCU system to run below optimal efficiency, limiting the input to the upgraders. Engineering – Common Services has indicated that if IXCU tanks were not provided to them by 2014, then upgrader packing replacement would be inevitable. Packing replacement is an extensive overhaul to the upgrader and can cost over \$10M. During the years where the flowrates

the upgraders can no longer meet its demand, external upgrading services will need to be purchased, costing over \$1.3M for every 10kg/h variance, per year.

The drum problem is further exacerbated by the fact that Pickering has no capability to clean dirty drums, causing a



nousekeeping and dose issues that has drawn scrutiny from the CNSC.

#### Alternative 1 -

### Install Additional Downgraded Storage Tanks and a Drum Cleaning Facility - Recommended

The recommended modification for Pickering is listed below:

Type of Tank	Size/Specifications	Location
Downgraded, low curie, oily D ₂ O tank	1 x 16 Mg	IXCU area, 274' el., RAB
Downgraded, high curie, oily D ₂ O tank	1 x 16 Mg	IXCU area, 274' el., RAB
Downgraded, low curie, non-oily D ₂ O tank	1 x 46 Mg	IXCU area, 274' el., FAB
Downgraded, high curie, non-oily D ₂ O tank	1 x 19 Mg	IXCU area, 274' el., RAB
Drum Cleaning Facility	Capable of cleaning a minimum of 10 drums/day	Between Solid Waste Handling Facility and PIOTS, 254' el., Service Wing

As a result of more rigorous review of the project needs vs. wants, the scope of the recommended option is leaner than that requested at the original project charter.

Installing additional downgraded storage tanks at IXCU and a drum cleaning facility will allow for the following (which are aligned with the project objectives):

- 1. Provide additional storage and segregation capability for downgraded D₂O to meet current recovery rates
  - Slow down degradation rates of upgraders to mitigate/delay costs to purchase external upgrading services
  - Mitigate costs to clean up oil-film build-up in non-oily tanks due to lack of proper segregation capability
  - Reduce the number of man-hours spent on tank maneuvering and backlog processing
- 2. Prevent the excessive use of drums
  - Reduce drum handling-related radiological and conventional hazards
  - Reduce the number of man-hours spent on drum handling
- 3. Allow Pickering and Darlington to clean oily drums
  - Prevents the use of oily drums to collect non-oily water.
  - Reduce the number of drums in the station that are taking up valuable real estate
  - Mitigate costs to purchase external downgraded D₂O cleaning services.

The final recommendation does not include S&I tanks for the following reasons:

Since 1997, it was evident that "feed and bleed" detritiation has not been consistently performed. This increase in PNGS-B tritium concentration can be partially attributed to the lack of sufficient storage capacity for reactor grade D₂O at the S&I system. In addition, there are other factors that had contributed to this issue:

- Extended Tritium Removal Facility (TRF) outages which limited the amount of TRF product available for detritiation
- One 150 Mg S&I tank occupied with Gadolinium-D₂O for two years as a result of a previous attempt to perform bulk detribution
- D₂O from Unit 4 Return-To-Service occupying S&I tanks
- Procedural issues associated with the safe execution of swaps that required 6-9 months to resolve
- Planning and resource coordination problems in shipments of D₂O to and from the TRF
- Detritiation can only be performed on weekends when the unit is in guiet mode

The additional S&I tanks installed at Darlington, as part of their D₂O Storage Project 16-31555 can alleviate Pickering's biance on the availability of the TRF and can improve Pickering's opportunity to perform large volume bulk swaps. These inks will act as temporary storage and TRF product storage tanks for Pickering when Darlington does not needs these tanks during outages. The utilization of Darlington's tanks in Pickering represents an additional investment mitigation of \$18.6M.



**BUSINESS CASE SUMMARY** 

#### Alternative 2 - Delay Project - Not Recommended

Delaying the project is **not** a recommended option. There is insufficient storage and segregation capability for downgraded  $D_2O$  since the recovery rates of downgraded  $D_2O$  have been increasing and the number of acute leakage events has been escalating. This causes backlog of recoveries that requires excessive drumming operations that may require more drum purchases. The number of drums in the station has already been causing housekeeping and dose issues that has drawn scrutiny from the CNSC. The backlog of drums maybe further aggravated when oily recoveries overflow to non-oily tanks causing clean recoveries to be contaminated with oil. Since oily D2O processes at a slower rate at the IXCU trains, this creates a vicious cycle of additional drum usage.

Furthermore, Engineering – Common Services has indicated that if IXCU tanks were not provided to them by 2014, then upgrader packing replacement would be inevitable. Packing replacement is an extensive overhaul to the upgrader and can cost over \$10M. During the years where the flowrates of the upgraders can no longer meet its demand, external upgrading services will need to be purchased, costing over \$1.3M for every 10kg/h variance, per year.

#### Alternative 3 -

# Install Pickering's own Storage and Inventory Tanks, Install Additional Downgraded Storage Tanks and a Drum Cleaning Facility - Not Recommended

Although installing additional S&I tanks will benefit Pickering station by increasing its flexibility in storing and segregating reactor grade D2O, this is not a recommended option. Kinectrics has suggested that the inability to detritiate or improve moderator isotopics effectively over the last 10 years at Pickering cannot be solely tied to a lack of storage capacity at S&I. Although installing Pickering's own S&I tanks improves Pickering ability to detritiate and increase moderator's isotopic, the savings from dose reduction and better fuel burn-up cannot recover the investment required to complete this modification here end-of-life of the Pickering A and B units.

the total cost to implement this option is \$36.0M, including contingency, with a +60%/-40% accuracy.

Alternative 4 – - Not Recommended

Alternative 5 - • Not Recommended



## 4/ THE PROPOSAL

This Developmental Release of \$2,505K (including contingency) will be used to complete the following deliverables:

- Provide project management support
- Provide OPG Design Support
- Prepare and award a Design Contract for Preliminary and Detailed Design
- Complete Preliminary Design (up to 40% Detailed Engineering)
- Issue Technical Specifications for Long-lead materials
- Review/Approve Preliminary Design
- Initiate Detailed Design
- Prepare Preliminary PEP
- Issue a Partial BCS

Refer to Appendix C for a list of the project milestones.

### 5/ QUALITATIVE FACTORS

#### Benefits to the Community/Regulator Relations

- Lower Tritium Emissions by using Darlington S&I tanks (Project 16-31555) to alleviate Pickering's reliance on the availability of the TRF, thereby ensuring a readily available supply of low curie product to detritiate Pickering's units.
- Eliminate scrutiny from CNSC of Pickering's tritium emissions

#### Health and Safety

- Effective utilization of the IXCU system will reduce the backlog of downgraded D2O in drums, reducing the
  occurrences of drum handling-related safety issues
- Clean drums can be re-used or disposed of to improve housekeeping in the stations

#### **Operational Considerations**

Fleduce operator workarounds, lowering the probability of human-performance errors

OPG Confident

BUSINESS CASE SUMMARY

-----

# 6/ RISKS

Description of Risk	Description of Consequence	Hisk Before Mitigation	Mrtgating Activity	Risk After Mitigation
Cost Overall project cost exceeds current estimate.	Unable to accomplish all project objectives without futher release of funds	15 FR	Detailed conceptual study completed by Kinectrics. Helyar review of project cost. Adopt optimal contracting strategy to mitigate cost escalation. Further fine tuning of overall project schedule and costs in a Partial BCS.	Medium
Fine tuning of contracting strategy & changes to funding release strategy may impact overall cost and schedule	Delay project schedule and increase costs.	dgi <del>H</del>	Obtained agreement with line management on present funding strategy. Contracting strategy and design/installation requirements will be reviewed with Supply Chain, Procurement, Design and Legal.	Medium
Scone				
Unknown cost justification information not submitted to Projects causing cost and schedule irrnoacts.	Rework will be required to evaluate impact of additional cost justification on preferred option. Additional costs and delavs will be incurred.	Medium	Rigrous communication with stakeholders prior to submission of BCS to ensure that all cost justification information have been submitted.	Low
Preliminary Design/Detailed Design may result in an increase in scope.	Changes in scope results in delays in schedule and additional cost to the project.	Medium	Scope has been clearly defined, communicated, and agree to by stakeholders. Design will be reviewed and challenged by OPG.	Low
Schedille				
Schedule for completing contractor selection may be delayed due to rigorous management, supply chain and lenal reviews of the RFP.	Schedule delay.	Hgh	Reviewed OPEX & had adjusted schedule to allow more time. Early Supply Chain involvement to ensure that the tendering process for the contract is completed as soon as possible.	Medium
Fine tuning of contracting strategy & changes to funding release strategy may impact	Delay project schedule and increase costs.	High	Obtained agreement with line management on present funding strategy. Contracting strategy and design/installation requirements	Medium

źį

	OPG Confiden		Page: 11 of 21		
	FION BUSINESS	S CASE SUMMARY	АПҮ		
overall cost and schedule			will be reviewed with Su Brownsond Doctor and Long	Supply Chain.	
Insufficient information to determine the timeline of design deliverables accurately, and design deliverables may not be on time	Delay to Schedule	Medium	Finetuning of final design deliverable timeline is available via partial BCS. Select approved vendor, provide clear scope and deliverables, review progress regularly. Establish and monitor effective design performance metrics.	regan, ssign deliverable tial BCS. rovide clear scope roogress regularly. effective design	Low
Resources					
Insufficient OPG design resources available.	Delay project schedule and milestones	4514	Design will be contracted out to an external agency. OPG Projects Design have committed to provide DTL support for this project.	to an external Design have upport for this	гом
Availability of qualified vendors to perform engineering	Delay in issuing contract due to the need to assess various interfacing risks and vendor qualification issues and contracting language	Medium	Obtain OPEX from other OPG projects of similar nature. Early involvement with Supply Chain and various other departments on potential vendors and the associated contracting strategies.	OPG projects of involvement with other departments id the associated	Low
Technical					
Commercial drum cleaning equipment being recommended may be more complicated than anticipated when installed in a nuclear system.	Costs and schedule delays if extensive testing and re-engineering is required.	461H	Potential design vendor will be informed that the equipment must be evaluated for suitability in the plant before equipment purchase and implementation.	e informed that evaluated for ore equipment	Medium
Meeting seismic requirements	Increase cost to the project due to unknown civil upgrades to meet the seismic requirements	НgН	Seismic qualification considered as part of the conceptual study. Seismic qualification requirements to be included in Preliminary Design.	onsidered as part of Seismic qualification Iluded in Preliminary	Low
Legacy issues on Design	Re-engineering may be required if there are legacy issues with the systems that the Project is modifying.	с Б Н	Completed preliminary system walkdown to identify potential legacy issues. Further detail reviews of documents and site scanning will be conducted to determine impacts at the Preliminary Engineering stage.	walkdown to es. Further s and site to determine Engineering	Medium
Regulatory					
Regulatory approvals (CNSC/TSSA) may require moer time than anticipated	Delay in project and potential cost impacts to the contract.	Medium	Identify required time allowance in project schedule. Incorporate approved time in contracting strategy. Review OPEX with	allowance in project approved time in Review OPEX with	Low

AND AND AND AND AND AND AND AND AND AND	2014 0.000 March 10.000			2 ⁰⁰⁰⁰
	OPG Confident		Page: 12 of 21	
	TON BUSINESS	S CASE SUMMARY	<u>ary</u>	
			similar projects.	
Environmental				
Drum cleaning procedures may impact of MOE requirements.	The drum cleaning method is yet to be finalized at the Design Stage. The solvent used may impact of MOE requirements, requiring special treatment before disposal.		The most appropriate method of drum cleaning will be evaluated during the Preliminary Engineering phase. Perform testing at vendor site if necessary.	
Health & Safety N/A				
Investment				
Some of the cost assumptions in the base case are worst case scenarios based on engineering judgment.	NPV and IRR results may be less optimistic than calculated.	Medium	Stakeholder line management was involved in obtaining information from historical performances of the systems.	Wedium
Inability to recover investment	Insufficient time to recover capital investment before stations' end of life.	Medium	The current NPV and IRR indicate a return of investment before stations' end of life.	Low
Early end of life of PNGS	Insufficient time to recover capital investment if end of life is earlier then currently forecast	Low	Using the current forecast of DNGS end of life date the current NPV and IRR indicate a positive return on investment before stations' end of life	T COM



### **BUSINESS CASE SUMMARY**

### 7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Final AFS	Targeted PIR Approval	PIR Responsibility
	Date:	Date:	(Sponsor Title)
TBD in Next Release	TBD in Next Release TBD in Next Release	TBD in Next Release TBD in Next Release	na matananis na se huren kuna na sa sa na na sa

### Comments:

Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it? (person / group)
1.				
2.		*	n an	1999 - The second second second second second second second second second second second second second second s
			a ser sta stilligen in som f i som et som att att förstadet att soger detangemen med men med oppgage oppraver i	
Ş.				
<b>4</b> ,	ar 1999 an 1999 an 1999 an 1999 an 1999 an 1999 anns an 1999 anns an 1999 anns an 1999 an 1999 an 1999 an 1999	1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 -		
		· · · · · · · · · · · · · · · · · · ·		
~d~				



BUSINESS CASE SUMMARY

Appendix "A"	Glossary (acronyms, codes, technical terms)
CNSC	Canadian Nuclear Safety Commission
D ₂ O	Heavy Water
Downgraded D2O	Heavy Water of an isotopic that is not suitable for use in the moderator or the primary heat transport system
ECs	Engineering Changes
EOL	End of Life
IXCU	Ion Exchange Clean Up
9&9O	Operating Policies and Principles
рнт	Primary Heat Transport
Reactor Grade D2O	Heavy Water of an isotopic that is suitable for use in the moderator or the primary heat transport system
S&I	Storage and Inventory
Sulzer-B Upgrader	High curie heavy water upgrader
TOC	Total Organic Carbon
(RF	Tritium Removal Facility
UPP-B Upgrader	Low curie heavy water upgrader

### ONTARIOP OWSER GENERATION

**OPG** Confidential

**BUSINESS CASE SUMMARY** 

### Appendix "B"

### **Project Funding History**

\$ 000's			Prev	ious Rele Cum	ases (inc ulative V	l continge alues	ency)				2010 2010 2010
Release Type	Month	Year								Later	Total
None											0
											0
											0
											0
											0
											0
·				t - en all Sel i filo en el tablet campion			an an an an an an an an an an an an an a			A to you o to to be been and a set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the se	0
		· · · · · · · · · · · · · · · · · · ·							W. d. debuilden i berindenbig		0
		*** **** ** ***********	•		• • • • •	•	•	di na 2000 ani na 1990 na 1990 na 1990 na 1990 na 1990 na 1990 na 1990 na 1990 na 1990 na 1990 na 1990 na 1990	&	,	
LTD Spent								·····			0

### Comments:

The current total project estimate of \$17.4M (including contingency) is a conceptual quality estimate of +60%/-25% and has an estimated Available for Service Date in Q2 of 2010. Altus Helyar has independently verified this estimate and includes a contingency of the set in Q2 of 2010. Altus Helyar has independently stimate is based on conceptual information, there is a risk that this estimate may escalate (refer to Section 6, Risk Table)

Project funding in the amount of \$5.0M **Construction and the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set o** 

### ONTARIOPOWER GENERATION

**OPG** Confidential

### **BUSINESS CASE SUMMARY**

Appendix "C"

### Financial Model – Assumptions

### Project Cost Assumptions:

OPG staff will provide project management and support role during design and implementation.

Material cost assumptions are based on using Class 3 tanks, hangers, piping and associated components and equipment. Design and installation work will be contracted out.

### **Financial Assumptions:**

Escalation rate on employee wages: 3%
 Escalation rate on other expenses: Canada IPPI

### Project / Station End of Life Assumptions:

As per memo J. Froats to D. Power, May 10, 2006, File No. NK30-01060 P, Pickering B Units 5,6 and 7 will have a End of Life of 2014 and 2016 for Unit 8.

See Attachment D for details of Expenses & Savings assumptions.

### Energy Price / Production Assumptions N/A

Derating Cost Assumptions New operating costs are negligible. External costs to upgrade D₂O is \$15/kg Cost to lease D₂O from AECL is \$0.055/kg/day

### Other Assumptions: All work is within the secured area with incumbent restrictions. OPG will procure all Nuclear Class and Pressure Boundary materials.

Page: 17 of 21

BUSINESS CASE SUMMARY

# PNGS-A D2O Storage and Drum Cleaning Facility Project 13 - 49251

# Developmental Release Business Case Summary NA44-BCS-38000-00001-R000

### Attachment "A"

### Project Cost Summary

	LTD	This	This	Future	Future	Future	Lange Street	97 (Å. 46 (* 14	
Choose One	Prior Yr	Release	Release	Release	Release	Release		5 6 49 49 59 7	n e segni komulet. An an
Choose One	2006	2007	2008	2008	2009	2010		Later	Total
Project Management (OPG)		435	-	671	748	538		Second Second Second Second Second Second Second Second Second Second Second Second Second Second Second Second	2,392
Engineering & Drafting (OPG)	1	304		558	425	447			1,734
Material									
Installation - PWU, BTU			e di Akastas	Sector in the	aline engla Aliana Alia				
Contract - Design								0.20.202	
Contract - Installation		a an ann an Anna Anna An Anna Anna Anna				an ann an Anna Anna Anna An Anna Anna An		elle Station State of 1997. State State of the State	nationili naterio in 19 Malanti - Ma
Contract - Other				Sevena e e e			707 W.Z		
¹¹ Observer and the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second s second second s second second sec second second sec									
			8 S 10 P - 1				norm Array		
Interest (Capital Project Only)									
Project Costs (exci contingency)									<b></b>
General Contingency						Maria 197.004		needen van de staat de staat de staat de staat de staat de staat de staat de staat de staat de staat de staat Needer van de staat de staat de staat de staat de staat de staat de staat de staat de staat de staat de staat d	1 <del></del>
Specific Contingency	<b>ORIGINA</b>							······································	
Project Costs (Incl contingency)	a seas	1,330	1,176	2,837	7,720	4,319		an an an air an ai	17,382
2006-2010 Business Plan	200	1,000	and a state of the second second second second second second second second second second second second second s	3,000	800	-	<u></u>		5,000
Variance to Business Plan	(200)	15	898	(834)		3,297			8,269
Committed Cost		********				e de Cincles		an ay maaring bag	
Inventory Write Off Required						·····	· · · · · · · · · · · · · · · · · · ·		-
Spare Parts / Inventory	· · · · · · · · · · · · · · · · · · ·	an an an an an an an an an an an an an a	analasi calari ne a ser ana ana ana dinggania a	100001-100-0010-0010-0010-001-0010-0010-0010-0010-0010-0010-0010-0010-0010-0010-0010-0010-0010-0010-0010-0010-		***		*******	
(excl contingency)	Contractory								
Total Release (incl contingency)		1,330	1,176	n 007	700	1			
	gundistandiska 			2,837	7,720	4,319	Salaya ya 👬 🔅	in containe station	17,382
Ongoing OM&A (non-project)					Circuit of the Andre				
Removal Costs (incl in above)	1.192.2017;143.6		$ \{ \substack{ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in \mathcal{N} \\ i \in$			Shires Congr			

Design Complete		Zero to Minimal	Quality of E	istimate	Conceptual -	+ 60% to - 25%
3 rd Party Estimate	Yes	OPEX used	Yes	Lessons Le	·····	Yes
Reviewed by Sponsor	Yes	Budgetary Quote(s)	No	Phase 1 Ac	tual Used	N/A
Similar Projects	N/A	Contracts in place	N/A	Competitive	e Bid	N/A

The estimated variance(s) to the 2006-2010 Business Plan will be addressed through the portfolio management process. A PCRAF will be approved by Jan 2007.

Reviewed By: NOV 21/0/-Stephanie Tham Date: Project Manager

loye Anni 2 Nov 06 150 Peter Floyd

Engl& Mods Manager (Strat IV)

Date:

ONTA	RIO	runtn
		GENERATION

# ProjectPNGS-A D2O Storage and Drum Cleaning Facility Pr Name 13 - 49251

### Developmental Release Business Case Summary NA44-BCS-38000-00001-R000

Attachment "B"

### **Project Variance Analysis**

		Choos	se One		
Capital	LTO Nov 2006	Last BCS N/A N/A	This BCS Nov 2006	Variance	Comments
Project Management (OPG)				0	
Erigineering & Drafting (OPG)				0	
Material	La constante	er of hus in the second state	ante contenencie:	adama niyeri	
Installation – PWU, BTU					
Contract - Design			n de State B	en an	
Contract · Installation				SECONDA IN	
Contract - Other					
				and a second second second second second second second second second second second second second second second	
			<u>69999</u> 0203		
Interest (Capilal Project Only)					
Project Costs (excl contingency)					
General Contingency			nerge and an and a start of the start of the start of the start of the start of the start of the start of the st		
Specific Contingency		1. 4. C. C. L. C.	engelse kanel provinsie de Carro an angelse kanel provinsie de Carro	Solo Alla Carlo Carlo	
Project Costs (incl contingency)	0	0	0	0	
Committed Cost				0	
Inventory Write Off Required				0	
Spare Parts / Inventory				0	
Total Release (incl contingency)	0	0	0	<b>0</b>	
Total Release (excl contingency)	0	0	0	0	
			والمحاد والمشار والمحافظ والمحافظ والمحافظ والمحافظ	kernessin in mensional manine and the second second second second second second second second second second se	
Ongoing OM&A (non-project)				0	
Removal Costs (incl in above)				0	

Comments:

N/A

ONTARIO POMER GENERATION

### OPG Confidential

Page: 19 of 21

**BUSINESS CASE SUMMARY** 

attachment "C"

### Key Milestones

Completion Date		)ate	
Day	Mth	Yr	Description
21	DEC	2006	Project Start Milestone (PSM)
23	DEC	2010	Project Complete Milestone (PCM)
02	JAN	2009	Budget Quality Estimate Approved (BEA)
04	JUN	2009	Full Release BCS Approved (FR1)
17	JUL	2009	Major Contract Awarded (MCA)
19	NOV	2007	Preliminary Design Complete (DES)
03	DEC	2007	Engineering Work Scope Identified (ESI)
05	NOV	2007	Regulatory Approval Obtained (RAO)
17	SEP	2008	DCP Approved - Drum Cleaning Facility (DCP)
16	OCT	2008	DCP Approved - IXCU (DCP)
17	SEP	2008	Final Design Complete Phase 1 (FD1)
11	AUG	2009	Start of Installation (SOI)
07	JAN	2010	AFS - Drum Cleaning Facility (AFS)

A Project Execution Plan (PEP) will be approved by Aug 2007

### Comments:

Other Key milestones:

e en en en	<u>?6</u>	APR	2010	AFS- IXCU (AFS)	-
	1	JUL	2010	In-Service Declaration (ISD)	-
	26	NOV	2007	Long Lead Materials Identified (LLT)	



BUSINESS CASE SUMMARY

### Attachement D: Incremental Costs & Expenses Assumptions

Category	Comments				
	Before PND-B End of Life (2007 to 2016)	After PND-B End of Life (2017 to 2026)			
	Expenses Without Drum Cleaning Faci	lity (DCF)			
New Drum Purchases	o drums/yr after AFS	15 drums/year after PB end of life; 0 drums/yr after AFS			
Additional Drum Handling Cost	2.7 drums/day @ 3 hours/drum >	2.0 drums/day after PB end of life; 0 drums/yr after AFS			
Costs to clean drum contents	per event once every 2 years; \$0 after	er AFS			
Costs on Drum Disposals	10 drums x 0.25 m3 x mm/m3 disposal; \$0 after AFS	7.5 drums after PB end of life ; \$0after AFS			
Leasing costs-D2O Makeup for unprocessable water	x (0.3 drums/day x 365d/yr x 230 L/drum x 30% isotopic x 1 kg/L) x 200 days of lease; \$0 after AFS	0.2 drums/day after PB end of life; \$0 after AFS			
	Expenses Without Additional IXCU	tanks			
Costs to cleaning IXCU Tanks	105K per event once every 2 years \$0k after AFS				
erator Work Around for 2 FTE; k Handling 0 FTE after AFS.					
Upgrader Degradation - External Mitigation Costs (with escalation)	External upgrading cost= when demand feedrate is less than upgrader's capability; Without IXCU, entire yearly load will be upgraded externally during repacking in 2014. Upgrader degradation rate: -8Kg/hr/yr :UV in service only in 2007, or -2kg/hr/yr: UV & IXCU in service in 2010; Demand feedrate reduces from 150kg/h to 105kg/h in 2015/2016 when 3 PB's units are out of service.	Same except the Demand upgrader feedrate reduces to after PB end of life.			
Packing Change Costs (with escalation)	delayed to 2042 if IXCU is installed.	; or			
	Expenses Without Additional S&I	tanks			
Offsite water storage - TDO Shipments Costs	0 trip after AFS	5 trips/year after PB end of life; 0 trip/year after AFS			
1920 - 111 - 111 - 111 - 111 - 111 - 111 - 111 - 111 - 111 - 111 - 111 - 111 - 111 - 111 - 111 - 111 - 111 - 11	Incremental Operating Expenses o	f DCF			
Operation Expense of DCF - Labour	1FTE				
Incremental Operational Expense - Utilities	drum x 10 drums/day x 365days				
aste Disposal Costs of DCF	100 drums with sludge of 3.5" in each (ONE	TIME COST of 0.0889m x (0.61m/2)^2*Pi >			



Page: 21 of 21

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

## Attachement D: Incremental Costs & Expenses Assumptions (Cont..)

Category	Com	iments
	Before PND-B End of Life (2007 to 2016)	After PND-B End of Life (2017 to 2026)
	Savings After Additional S&I Tanks In	stalled
Fuel Burn Up Savings	About 187Mg of the yrly TRF product shor moderator isotope after AFS (reference: K calculation & yearly distribution).	tfall can be received to detritiate & improve inectrics Report Appendix A for detailed
Dose (ALARA) Savings		tfall can be received to detritiate & improve eport Appendix A for detailed calculation &

ONTARIOPOWER GENERATION

OPG Confidential

Page: 1 of 17

**BUSINESS CASE SUMMARY** 

PNGS-A Switchyard Relay Building Replacement Project 13 - 49266

# Full Release Business Case Summary NA44-BCS-65130-00002-R000

Routing	Location	Action	Signature	
Leon Simeon Project Leader Design Projects, Pickering A	P72-2	Prepare BCS	Leon Simen	<u>Date</u> at 12/2
Craig Verwey Project Manager Design Projects , Pickering A	P72-3	Review BCS	atto beez	007 12/2
Peter Floyd Manager Design Projects, Pickering A	P72-1	Review BCS	RIG.	Cat 12/07
Mark Arnone Director Projects & Modifications	P72-1	Review BCS	Alle	12. Oct 200
Dwight Zerkee Manager Investment Manager	P82-386	Review BCS	Prul Mather (for)	(80120
George Boyd Manager Systems Performance Engineering, Pickering A	P42E3	Review BCS	Googe Bayes	Oct 15/07
Robert Black irector Station Engineering Pickering A	P42E1	Review BCS	Rech	150x+ 07
Mark Elliott Senior Vice President Pickering A	P42E3	Submit BCS	RKBer	
Randy Leavitt Director Investment Management	P82-3	Review BCS	Alent	1(set 0) Det 18, 2007
Jim Beech √ice President Nuclear Finance	TCH09F06	Review BCS	7(	Edite 2011
fom Mitchell Chief Nuclear Officer	P826A-1	Review BCS	Mitchell	1
Donald Power Director Investment & Business Planning	TCH07D06	Approve BCS		220072007
ierre R. Charlebois VP & Chief Operating Officer	P826A-1	Approve BCS		ON -
		5	Delaikhaup/	<u> </u>
Bail		Bet		
nior Financial Analyst 2-4084	P82-3B6	Return For Distribution		,



# PNGS-A Switchyard Relay Building Replacement Project 13 - 49266

#### NA44-BCS-65130-00002-R000 Full Release Business Case Summary

#### **RECOMMENDATION:** 1/

to complete the commissioning of a new We recommend a Full Release of \$7,452K (including contingency of Unit 012 Protection, Control & Telecom (PCT) interface with Hydro One and preparations for Unit 034. This BCS covers the OPG portion of this Joint Project; Hydro One is funding the work related to their property and equipment.

The business objective of this project is to improve the reliability of the station's Main Output system. Failure to properly interface OPG equipment with new Hydro One switchyard protection and control systems will leave the station vulnerable to forced outages and associated financial losses. This will be achieved by modifying OPG equipment and systems to interface with the new PCT system being installed by Hydro One in the PNGS-A switchyard. The new PCT system will utilize an independent dual redundant design philosophy to comply with current NPCC/IESO guidelines to provide full separation of A and B protection channels in the switchyard.

This project will be executed in several phases between 2007 and 2010. Initial installation of the new PCT system and interfaces for Unit 012 will be undertaken during P711 in Fall 2007 followed by similar modification for Unit 034 in P841 (2008). Remaining work, including DCC alarm update, Sequence of Event Recorder update and final update of associated design documents, will be staged and implemented online or during successive outages as required in 2009 & 2010.

The installation of the trench, duct bank, cabling and terminal boxes have been covered under the Partial Release of funding. Refer to section 2.0 "Background & Issues" for additional information.

Full release funding is required now to meet P841 milestones and to complete commissioning of U1/2 during P711. Refer to section 2.0 "Background & Issues" for additional information.

\$000's (inci contingency)	Funding	LTD 2005	2006	2007	2006	2009	2010	Later	Total
Currently Released	Partial	4	260	8,060					8,320
Requested Now	Fuli			1,125	3,350	1,867	841	269	7,452
Future Funding Req'd	None					1			-
Total Project Costs		-	260	9,185	3,350	1,867	841	26 <del>9</del>	15,772
Other Costs									
Ongoing Costs			260	9.185	3.350	1.867	841	269	15.772
Grand Total Investment T	Vite	Cla		(IEV) Impact of	·····	IRI		Discounted	Payback
Value Enhan		Cap		19,65		27.4	*	7.3	

Submitted By:

160CT

M Filiott Site VP, Pickering A 2007 Date:

Finance Approval:

0 \$29/07 Date:

Line Approval (Per OAR Element 1.1 Project in Budget).

Worker

**Director Investment Management** 

P.R. Charlebois EVP and COO

Oct 31/67

Date:





### **<u>Z</u> BACKGROUND & ISSUES**

As a result of a major fire in early 2006 (SCR-P-2006-05953/07053), the PCT equipment in PNGS-A switchyard relay building was damaged beyond repair. Further investigation revealed a significant number of fire-damaged cables inside cable trenches in the relay building. The extent of the damage forced Hydro One and OPG to bypass the damaged relay building equipment with a temporary protection & control solution in order to maintain connection of Pickering A units to the grid.

Additionally, OPG Engineering & Maintenance and Hydro One observed significant degradation of existing cables connecting the station with the switchyard as a result of aging and submersion in water for extended durations. This condition also influenced Hydro One's final decision to install a new PCT system compliant with current NPCC/IESO guidelines. This modification will enhance reliability of the switchyard as well as comply with current market rules for the Bulk Electricity System. OPG is also obligated to operate within these guidelines.

OPG will install new trenches, duct banks and cabling from the switchyard to the station and modify the wiring as required to support the Hydro One independent and fully separated dual protection channel initiative.

Hydro One is responsible for installation costs related to the upgrade/replacement of their equipment. OPG is responsible for the costs related to the upgrade/replacement of OPG-owned equipment.

The Unit 2/3 Safe Storage Project will be responsible for costs associated with Unit 2/3 specific work not covered under the scope of this project. This project will ensure the ring bus protection for the Unit 2 & 3 SST is restored.

To meet these objectives the project will undertake the following:



Design, install and commission a new interface for system interconnectivity between Hydro One and OPG station equipment.

- Implement revised Alarm and SOER signals from switchyard consistent with current standards.
- Update related design, operating and maintenance documents.

The scheduling of the project will be staged from 2007 thru 2010 outages with the initial primary focus to install and commission system interconnectivity between the station and the new PCT system on Units 012 during the P711 outage and Units 034 during the P841 outage.

# The following work has been completed under the Partial Release, NA44-BCS-65130-00001: \$6.3M

- Detailed design for all civil (U12/34) and U1/2 Electrical
- Installation of the East and West trench from the powerhouse to the security fence.
- Installation of cable duct from security fence to switchyard. Installation of a cable vault for the demarcation point.
- Installation of Marshalling boxes inside powerhouse and demarcation boxes in the switchyard.
- Installation of wall & floor penetrations in the powerhouse for new cable trays.
- Installation of new cable trays inside powerhouse and inside of the trenches.
- Pulling of new power cabling from the powerhouse to the new ATS building in the switchyard.
   Installation of two new circuit breakers for COOV
- Installation of two new circuit breakers for 600V power supply to the new ATS building. This work has completed a successful AFS.
- Pulling of new protection and control (P&C) cabling for U1/2 from Marshalling boxes in the powerhouse to demarcation boxes in the switchyard.
- Termination of P&C cabling for U1/2 in the Marshalling and demarcation boxes.

Outstanding work which will covered by the remaining amount of the Partial Release

- Pulling of U3/4 P&C cabling from the Marshalling boxes to demarcation boxes.
- Termination of U3/4 P&C cabling from the Marshalling boxes to demarcation boxes.
- Final grading, handrails and steps for the civil installation.





### BUSINESS CASE SUMMARY

Contingency Funding from the Partial Release was used to cover the cost of the following: \$1.9M

- Design and installation of the cable duct and vault in the switchyard. This risk was identified since the design was not
  available at the time of estimate and contingency funding was set aside to cover this risk.
- Cost of scaffolding for cable tray installation. The cable tray routing for power trays were not known at the time of estimate and contingency funding was set aside to cover this risk.
- Trench installation delays due to interferences and boulders during the boring under the security fence.
- · Delays and rework due to the main service water break in the switchyard. The break was not a result of this project.

### Full Release funding is required to complete the following work. \$7,452K

- Increase in Hydro One commissioning cost for P711. Note Hydro One is responsible for installation costs related to the upgrade/replacement of their equipment.
- Increase in installation cost due to the ISTB project (double shifts / premium time for electrical contractor).
- Design for U3/4 execution during P841. TCD for this package is 28 Feb. 2008.
- Increase scope to include the U2/3 Safe Storage Alarm reduction into the execution Engineering Change Package.
- Increase scope to remove On Line Wiring covered under U2/3 Safe Storage packages
- Complete the commissioning for U1/2 during P711
- Start the detailed design for U3/4 and to complete the commissioning for U3/4 during P841
- Alarm cleanup for U1/2 during P911
- Alarm cleanup for U3/4 during P1041
- Close out

### Explanation for increase (\$1.2M) from the Partial Release

- Increase in commissioning cost during P711 outage
- Scope increase as some of the U2/3 Safe Storage scope (switchyard related) had to be brought into this project to eliminate re-work and ensure configuration management was maintained.
- Inter-Station-Transfer-Bus impact as double shifts and premium time were needed to recover the time lost by the trades used to support this work.
- Increase in security cost. 24/7 coverage were required during the boring and work next to the security fence.
- Increase in design costs to start the U3/4 detailed design for P841.
- · Soil removal cost.





Page: 5 of 17

BUSINESS CASE SUMMARY

### 3/ ALTERNATIVES AND ECONOMIC ANALYSIS

GENERATION

		Alt 1 (Recomm	nended)	Alt 2	Ah3	Alt 4	Alts
\$000°s	Statua Cuo	Full Cost	Cost	Delay			
Revenue	(76,966)	(4,348)	(4,348)	(6,112)	(40,657)	<u>ىرىكى ئەرتىكە بىلىمە مەرەپلەر مۇلۇمە</u>	<u> </u>
OM8A	(22,052)	(1,115)	(1,115)	(3.724)	(22.052)		
Capital	*	(14,052)	(6,637)	(7,041)	(905)	,	
NPV (after tax)	(28,492)	(14,972)	(8,793)	(11,198)	(19.544)	·····	
Impact on Economic Value (IEV)	N/A	13,520	19,699	17,294	8.948		
IRR%	N/A	15.6%	27.4%	24.5%	41.2%		
Discounted Payback (Yrs)	N/A	11.20	7.33	9.25	4.00		

### Status Quo - Not Recommended

This option is not recommended since it would not be possible to complete U1/2 installation, and the investment to date would be lost. Also, the existing temporary arrangement to bypass the damaged relay building equipment was intended to be a short term solution. This and the degradation of the existing cabling in the cable ducts connecting the OPG units to the relay building will not ensure proper protection & control of the PNGS-A units' grid connection and is not in compliance with the NPCC/IESO guidelines for grid protection.



Base on the cable fault history input from Performance Engineering, Hydro One and other stakeholders, it is predicted that the probability of a similar failure in the future is significantly high. Any such failure in the switchyard equipment will isolate oth operating units (Units 1 and 4) from the transmission grid with substantial financial loss to OPG in the order of 500K\$ per unit per day.

Hydro One is spending considerable resources and funding to upgrade reliability of the switchyard. To ensure full advantage of these upgrades is obtained, OPG must improve the reliability of the connection to these systems.

The project will be unable to complete the U1/2 installation & commissioning and the investment to date would be lost.

#### Full Copper Technology with New Cable Duct - Recommended Alternative 1 -

OPG will continue to design, install and commission an improved interface system for interconnectivity between Hydro One and OPG systems with the following features:

- Like-for-like replacement of protection and control functions to the extent practicable. ٠
- Design, installation and commissioning of interface system based on all copper replacement.
- Replacement of existing copper cables which are degraded due to being submersed in water for long durations and end of life expectancy. ٠
- Design and install a new dual buried duct system for routing the cables from switchyard to the station. ٠
- Design and install the revised Alarm and SOER signals from the switchyard to the station. ٠
- Design and install new dual independent AC feed from plant to the switchyard as required for the new Hydro One relay buildings.

Hydro One will replace the existing relay building equipment with a dual independent PCT system incorporating full separation in compliance with NPCC/IESO guidelines and interfacing based on copper technology.

This option is recommended since it is based on existing copper technology and like-for-like replacement of the functionality of the protection and control scheme. The new duct system will allow cable replacement and other major tasks outside the utage schedule without any risk of damage to the operating units.

Reliability of the Class IV Power system is enhanced consistent with Safety Analysis requirements and reduction of probability of forced outages due to equipment failures in the switchyard.



Page: 6 of 17

### **BUSINESS CASE SUMMARY**

### Alternative 2 - Delay Project - Not Recommended

Delaying this modification is not recommended since this will keep the PNGS-A units and equipment at a high risk of grid protection related forced outages. If grid protection & control is not updated the OGCC may not allow the generating units to be connected to the grid. Either scenario would result in a subsequent financial impact of ~ 500K\$ per unit per day.

The rate of degradation of the existing cabling is unknown. Any cost savings to OPG by delaying would be offset by the increasing risk of forced outages. Additionally, OPG and Hydro One costs to defer due to remobilization and interest costs is estimated to be \$2.2 M.

### Alternative 3 - Complete U1/2 Work and Leave U3/4 As Is - Not Recommended

The old and the new switchyard relay buildings would need to be maintained and U3/4 reliability issues would still exist. In addition, if U3/4 work is not performed, OPG will not comply with the current market rules for the Bulk Electricity System, as set by the current NPCC/IESO guidelines.

### Alternative 4 - Do more - Not Recommended

The recommended option has considered all necessary actions to take full advantage of the upgrade in the switchyard protection scheme by Hydro One and achieving optimal reliability from the switchyard functions.

Alternative 5 – - Not Recommended







Page: 7 of 17

BUSINESS CASE SUMMARY

### 4/ THE PROPOSAL

The following are the objectives and deliverables for this Full Release BCS:

- To complete commissioning of U1/2 with increased scope and ISTB impacts (see Section 2.0, Background). .
- To complete the detailed engineering work including the On Line Wiring for the U3/4 cable cutting & termination and •
- To complete the installation of the Unit 3/4 cabling from the demarcation to the marshalling boxes. .
- To prepare detailed work plans, field installation packages and commissioning procedures for P841 work. ٠
- To complete all installation and commissioning work for Unit 034 portion of the project during P841 outage. .
- To complete the close out of U1/2 and U3/4 design packages
- Alarm cleanup for U1/2 during P911
- Alarm cleanup for U3/4 during P1041



### 5/ QUALITATIVE FACTORS

Replacement of switchyard PCT equipment and related interfacing equipment and cabling will increase reliability of the entire switchyard, enhance OPG unit and equipment protection in case of a grid failure and vice versa while complying NPCC/IESO guidelines for the protection scheme.

Class IV electrical power system reliability will be increased. The probability of unit trips and associated equipment stresses following unit trips will be reduced. Impairment of the protection systems' availability during fault situation due to cable failures would be minimized. This would result in avoiding potential catastrophic equipment failure causing extended outages and/or

This reduced probability of transmission failure and enhanced protection of OPG plant equipment will have a positive financial impact for the rest of the expected plant life for Pickering A Units.





**BUSINESS CASE SUMMARY** 


8 of 17



Description of Risk	Description of Consequence	Risk Before Migation	Mitigating	Riek Migation
<b>Cost</b> Since the U1/2 commissioning has not been completed there is limited Lessons Learned/OPEX information	This might lead to higher level of engineering installation and commissioning cost	ЧÔН	Rigorous planning and team work with stakeholders to identify any emergent abnormal situations that may arise. General contingency	Medium Medium
available for U3/4.				
Discovery - Increase in scope	Increased costs and schedule impact	Medium	As most of physical installation is complete, risk is now limited to commissioning, documentation, and configuration management. General Contingency	Low
Schadula				
Inability to meet design Outage milestones for P841 due to the same resources working on P711.	Non compliance with N-PROC-MA-0013 & N-PROC-MA-0022	Medium	Design has committed to delivering the P841 design EC on Feburary 28, 2008 (Refer to SCR P-2007-16725).	Low
H1 commissioning longer than outage window	Increased costs Lost revenue	High	P711 outage Lessons Learned will be used to take required actions for P841	Low
Resources				Low
Insufficient OPG Design resources to support project.	Schedule delays	Medium	Contract out Project Design work to external design agency. Obtain commitment from OPG Project Design to support project.	Low



Page: 9 of 17



Limited Hydro One resources to support commissioning work during outage	Delay in outage schedule	Medium	Set up contracts with Hydro One in advance to ensure availability of their resources as	Low
Limited OPG station support. Technical	Delay in schedule of pre-regs and outage.	Medium	Detain commitment for OPG station support as per schedule.	Low
Commission failure	Increase in outage schedule	Medium	Detailed commissioning work plan. Support on standby for outage troubleshooting	Low
Regulatory No regulatory approval required.		A/N		row
<b>Environmental</b> There are no environmental risks		NIA		NIA
Health & Safety Personal injury from working in vicinity of high voltage.	Potential serious personal injurtes,	Hgh	Proper pre job briefing, appropriate PPE and work protection.	Low
Investment No investment risk involved		N/A		A/N



# 71 POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Final AFS	Targeted PIR Approval	PIR Responsibility
	Date:	Date:	(Sponsor Title)
Simplified	Jun 2010	Jan 2011	George Boyd

### Comments:

	Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it? (person / group)
1.	600V power supply to new ATS building in the switchyard	Not in service	600V power supply to new ATS building n service U 1/2 new protection	Successful AFS	Performance Engineering
2.	Unit 1/2 new Switchyard protection and control cabling in service.	Unit 1/2 new Not in service Switchyard protection and control cabling in		Successful AFS	Performance Engineering
3.	Unit 3/4 new switchyard protection and control cabling in service	Not in service	U 3/4 new protection and control cabling in service		Performance Engineering
4.	Configuration documentation	Existing configuration	Revised Configuration	ECC Close Out	Project Design

ONTARIC	POWER
	GENERATION

Appendix "A"

OPG Confidential

Page: 11 of 17

## **BUSINESS CASE SUMMARY**

# Glossary (acronyms, codes, technical terms)

AFS	Available For Service
BCS	Business Case Summary
NPV	Net Present Value
PCRAF	Project Change Request Authorization Form
PEP	Project Execution Plan
MWH	Mega Watt Hour
NPCC	North-eastern Power Coordinating Council
IESO	Independent Electricity System Operator
OGCC	Ontario Grid Control Center
PIR	Post Implementation Review
PCT	Protection, Control & Telecom
PNGS	Pickering Nuclear Generating Station
OPG	Ontario Power Generation
СТ	Current Transformer
PT	Potential Transformer
SER	Sequence Event Recorder







### Appendix "B"

### **Project Funding History**

				Cum	lative Vi	lues					
Release Type	Month	Year	2006	2007	2008	2009	2010	2011	2012	Later	Total
Partial	N/A	N/A	260	8,060	0	0	0	0	0	0	8,320
Full		<u> </u>	<b>∤</b>	1,125	3,350	1,867	841	269			7,452
None	·				-						0
None	<b> </b>										0
N/A											0
N/A						<b></b>					0
N/A	• <u></u> • •										0
N/A							1			j 	0
	1						1	1	<u> </u>		7,415
LTD Spent	N/A	•	260	7,155		ì	i	l	h		-,410

### Comments:

2007 year to date values are up to the end of Fiscal week 093 in Scores.





Page: 13 of 17

**BUSINESS CASE SUMMARY** 

### Appendix "C"

## Financial Model - Assumptions

### **Project Cost Assumptions:**

2007-2011 labor rates are used.

Cost of material, support and vendor design are taken from the conceptual budgetary estimates received from vendors and other OPG groups.

### Financial Assumptions:

7% discount rate.

### Project / Station End of Life Assumptions:

End of life expectancy for Pickering A station assumed < 2024.

### Energy Price / Production Assumptions

Energy Price at \$49.5 / MWH Production assumed as 510 MW per unit for Pickering A units (1 & 4) Capacity factor 0.8 Revenue loss per unit for one year = 510x0.8x24 (hours)x365 (days)x\$49.5 = \$176,916,960

### **Operating Cost Assumptions**

N/A

### Other Assumptions:

Considering the previous cable fault records, inputs from Hydro One and Performance Engineering, the probability of similar fault reoccurring in future is considerable and is an increasing function with time.

For our calculation a simple exponential distribution of risk (Y= M e  $^{0.1659}$ t) is considered for the rest of plant life up to 2024 with a base risk (5%) at present as shown in figure 1. Y= Cumulative risk probability, M= Base risk factor, t= Plant life from now (0-18 Years)


In case of a severe failure due to current condition in the Pickering A switchyard both the units (U1 & U4) will be disconnected from the grid for a minimum 60 days period before it can be restored per input from Hydro One.

Revenue loss for any such failure is calculated with cumulative risk factor derived from the exponential distribution for that time period and generation and OM&A cost for 60 days forced outage for two units. Generation revenue loss for 60 days forced outage for 1 unit = \$177/365X60 = \$29M / unit Since two units (Unit1& 4) are connected to the grid via the PNGA switchyard the effective generation loss due to unavailability of the switchyard to be considered as two times the calculation = \$29MX2= \$58M OM & A manpower, material and engineering cost for 60days outage to restore 2 units back to the grid = Manpower( 60 X 200 K\$) + Approx. Engineering & Material cost ( 4000K\$) ~ \$16M

Total economic impact for 60 days outage = 58+ 16 ~ \$74M Estimated economic impact = (Total economic impact) X Risk Probability at that time.

Assumed 1 year delay for the delay option (Alternative-2) with project cost escalation @ 3% per year of delay

terest and remobilization costs are estimated at \$2.2M






Figure - 1

Page: 15 of 17

**ONTARIOPOWER** GENERATION

### BUSINESS CASE SUMMARY

# PNGS-A Switchyard Relay Building Replacement Project 13 - 49266

# Full Release Business Case Summary NA44-BCS-65130-00002-R000

### Attachment "A"

### **Project Cost Summary**

\$090's OM&A	LTD Prior Yr 2006	2007	This Release 2007	This Release 2008	This Release 2009	This Release 2010	This Release 2011	Later	Total
Project Management (OPG)	24	568		575	461	286	123	Laun	2,037
Engineering & Drafting (OPG)		583	231	426	340	259	49	······	1,888
Material		-			<u> </u>	200	43		1,000
Installation - PWU, BTU	F								
Contract - Design	-								
Contract - Installation									
Contract - Other						-			
							THE READ		
Interest (Capital Project Only)	7				10 30 1	_			-
Project Costs (excl contingency)									-
General Contingency								-	
Scific Contingency								tail Personal	
Project Costs ( Incl contingency)	124	8,198	1 125	3,350	1,867	1.11. <b></b>			
2007-2011 Business Plan		6,215	1,120	2,577	1,286	841	268		15,772
Variance to Business Plan	124	88	865	2,311		647	207		10,932
Committed Cost		00	002	· · · · · · · · · · · · · · · · · · ·	150				1,228
nventory Write Off Required									•
Spare Parts / Inventory	÷								
Total Release (excl contingency)	1.0					F			- 1
Total Release (Incl contingency)	124	0.400							
Total meloabe (the contempericy)	124	8,196	1,125	3,350	1,867	841	269		15,772
Ongoing OM&A (non-project)						( ar gall			
Removal Costs (Incl in above)					K. 1. 1. 1.				
			Basis	of Estima	te	5 5 5 5	<del>è. L</del>	<u></u>	
Design Complete		Up to - 40	the second second second second second second second second second second second second second second second s		luality of E	stimate	Re	lease + 1	5% to - 10
3 rd Party Estimate	N/A	OPEX u			Yes		ns Learner		Yes
Reviewed by Sponsor	Yes		ry Quote(s	5)	Yes	Phase	1 Actual L	Jsed	No
Similar Projects	N/A	Contract	a in mlana	1	Yes	1.0	etitive Bid		Yes

The estimated variance(s) to the 2007-2011 Business Plan will be addressed through the portfolio management process. A PCRAF will be approved by Oct 2007.

Reviewed B 00712/07 raig Verwey Project Manager

Approved By:

Peter Floyd

Eng & Mods Manager (Strat IV)



Page: 16 of 17

BUSINESS CASE SUMMARY

# PNGS-A Switchyard Relay Building Replacement Project 13 - 49266

# Full Release Business Case Summary NA44-BCS-65130-00002-R000

Attachment "B"

### **Project Variance Analysis**

		Full R	elesse		
Choose One	LTD Sep 2007	Last BCS N/A N/A	This BCS N/A N/A	Variance	Convisionas
Project Management (OPG)	594	2,109	2,109		No Change
Engineering & Drafting (OPG)	742	1,697	1,928	231	Additional amounts for On Line Wiring and scop
Material					increase for station initiative for Alarm reduction
Installation - PWU, BTU					
Contract - Design					
Contract - Installation					Sector and the sector and the sector and
Contract - Other		and the second	Alasanil wills	254661_3.00	Z
					responses to the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second s
			and the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of t	11110	
Project Costs (exci contingency)					
Project Costs (excl contingency) General Contingency					
Project Costs (excl contingency) General Contingency Recific Contingency					
Project Costs (excl contingency) General Contingency Project Costs (incl contingency)	7,415	14,452	15,772	1320	
Project Costs (excl contingency) Seneral Contingency Project Costs (incl contingency) Committed Cost	7,415	14,452	15,772	1,320	
Project Costs (excl contingency) General Contingency Project Costs (Incl contingency) Committed Cost Inventory Write Off Required	7,415	14,452	15,772	1,320	
Project Costs (excl contingency) General Contingency Project Costs (incl contingency) Committed Cost Inventory Write Off Required Spare Parts / Inventory	7,415	14,452	15,772	1,320	
Project Costs (excl contingency) General Contingency Project Costs (incl contingency) Committed Cost Inventory Write Off Required Spare Parts / Inventory Cotal Fielease (incl contingency)	7,415	14,452			
Project Costs (excl contingency) General Contingency Project Costs (incl contingency) Committed Cost Inventory Write Off Required Spare Parts / Inventory Cotal Release (incl contingency)			15,772 15,772 12,132	1,320 1,320 1,015	
Interest (Capital Project Only) Project Costs (excl contingency) General Contingency Project Costs (incl contingency) Committed Cost Inventory Write Off Required Spare Parts / Inventory Fotal Release (incl contingency) Fotal Release (excl contingency) Dingoing Oid&A (non-project)	7,415	14,452	15,772	- 1,320	

### Comments:

Life to Date for the project is based on 2006 and 2007 year to date values up to Fiscal Week 093 in SCORES.



\ttachment "C"

### Key Milestones

Co	mpletion I	Date	Description
Day	Mth	Yr	
30	Oct.	2007	Full Release BCS approved
16	Oct	2007	P711 outage pre req. complete.
28	Dec.	2007	U1/U2 PCT system commissioning complete and AFS'd.
28	Feb.	2008	P841 Detailed Design complete
12	Jun.	2008	Close out for U1/U2 PCT.
11	Aug.	2008	Pre req. work for P841 complete.
10	Dec.	2008	U3/U4 PCT commissioning complete and AFS'd.
10	Jun.	2009	Close out for U3/U4.
16	Nov.	2009	Alarm clean up for U1/U2 by P911 and AFS'd.
15	Jun.	2010	Alarm clean up for U3/U4 by P1041 and Final AFS.
15	Dec.	2010	Project close out complete.
L			1

A Project Execution Plan (PEP) will be approved by Jan 2008

Comments: Major installation and commissioning activities of this project are outage dependant and currently scheduled for P711 in 2007 and P841 in 2008.



.



ONTARIO POWER GENERATION

**BUSINESS CASE SUMMARY** 

# DNGD: EQ Closure and Component Replacement Project 16 - 38457

# Full Release Business Case Summary D-BCS-03651-10004-R000

Routing	Location	Action	Signature	Data
M. Arnone Director, Projects & Modifications	P72	Review BCS	plhe	2 Nou 2007
R. Leavitt Director, Nuclear Investment	P823-315	Review BCS	Falo-+	12. 2, 207
J. Lehman Director, Station Engineering Darlington (Acting)	D08ES3	Review BCS	Schlan	
J. Beech Vice-President, Nuclear Finance	TCH07E19	Review BCS	12.7	Nov 6/2
W. Robbins Senior Site Vice-President Darlington	D08ES3	Submit BCS	Shynikables	2007-11-12
T. Mitchell Chief Nuclear Officer	P826A-1	Review BCS	Muhlur.	2051112
P. Charlebois Executive Vice-President & Chief Derating Officer	TCH19A24	Review BCS		2007/12/14
Power Vice-President Corporate Investment Planning	TCH07D06 REC') DEC.20	Approve BCS	Adam	2008/01/03
J. Hankinson Pesident & Chief Executive Officer	TCH19A24	Approve BCS	Att	2000/01/03
			U.	
Nov 1 62007				
Refer to:				
. Ball Mior Financial Analyst 2-4084	P82-3B6	Return For Distribution		



### **BUSINESS CASE SUMMARY**

### DNGD: EQ Closure and Component Replacement Project 16 - 38457

### Full Release Business Case Summary D-BCS-03651-10004-R000

### I/ RECOMMENDATION:

ONTARIO**power** 

GENERATION

We recommend approval of the release of \$33.2M (including contingency), for a total release of \$63.1M. This will allow the Environment Qualification (EQ) Closure and Component Replacement Project to complete the remaining component replacements which have been committed to the Canadian Nuclear Safety Commission (CNSC) and environmental qualification completion assurance activities. It will also permit the project to determine the most efficient means for maintaining full compliance with the environmental qualification requirements of the Darlington Nuclear operating license; and allow for preliminary engineering activities to begin for new EQ issues identified during this process.

The business objective of this project is to align Darlington systems and components with the EQ requirements of its Power Reactor Operating License (PROL). Action Assignment # 28058364 has been raised to track the completion of a Regulatory Commitment (REG C) made to the CNSC for the replacement of non-qualified components with EQ-qualified components by December 31, 2010.

A total of \$29.9M was previously released in accordance with Organizational Authority Register (OAR) element 1.1. The funding was used to:

- Complete designs associated with regulatory committed component replacements.
- 2. Replace components in the field in 2005, 2006 and 2007 as per the regulatory committed schedule.
- 3. Complete EQ List Development Packages (to be completed in November 2007)
- 4. Complete an EQ Program Self Assessment.
- 5. Complete a scope optimization study (to be completed in October 2007).

This request is to:

- 1. Replace the remaining components in the field in 2008, 2009 and 2010 as per the current regulatory committed schedule.
- 2. Carry out completion assurance activities for the components which have been replaced during the project and for those not expected to be affected by the scope optimization study.
- Complete analysis to determine the most efficient means for Darlington Nuclear to meet the EQ requirement of its operating license. Develop the scope and business case for a new project to resolve new EQ issues arising from this analysis, if required.
- 4. Complete the transition the Project to the Station Sustaining EQ Program.

This release does not include any future detailed design, analysis or field work required to resolve anomalies outside of the scope currently committed to the CNSC, as shown in Attachment "D".

M find stallagency	Funding	LTD 2007	2198	2000	2/10	- 2011 -	******* **# -	Later	Tomi
Currently Released	Partial	26.7	3.2	1000-2000, do Carl (7, 1, 1, 1, 1, 1)	<b>≩رت</b> ~میتر،میر∎«فنعا ا				29.9
Requested Now	Full		11.3	10.7	10.4	0.8			33.2
Future Funding Reg'd							i		
Total Project Costs		26.7	14.5	10.7	10.4	0.8		•	63.1
Other Costs	 								
Ongoing Costs		1							
Grand Total		26.7	14.5	10.7	10.4	0.8	• •	 •	63.1
	Туре	Cie		(IEV) Impact	en Ex Yehre			Discounts	Particit
Regulato	Ω	Cill	M	Ø	<b>h</b> - 1	NA.	1	h	<b>4</b>

Submitted By:

207-11-12 W. Robbins Date:

Senior Site Vice-President Darlington

Fipance, Approval 2008-01-03 Powe Date: e-President Corporate Investment Planning

Line Approval (Per OAR Element 1.1 Project in Budget):

inson J. Hank ison

President & Chief Executive Officer

2008/01/27 Date:

### ONTARIOPOWER GENERATION

**OPG** Confidential

**BUSINESS CASE SUMMARY** 

### **BACKGROUND & ISSUES**

The Ontario Power Generation Nuclear (OPGN) Environmental Qualification (EQ) program establishes an integrated and comprehensive set of requirements that provide assurance that essential equipment can perform as required if exposed to harsh design basis accident conditions and that this capability is preserved over the life of the plants. Under License Condition 7.1, Darlington must implement a program that is traceable, auditable and meets the OPGN requirements for EQ.

Requirements for Environmental Qualification (EQ) at Darlington Nuclear Generating Station (DNGS) were first spelled out in the Construction License and then formalized in 1978 with the first issue of the Design Guide. The "science" of EQ was in its infancy and formal EQ requirements did not apply to other CANDU stations. In the absence of Corporate, or National standards for EQ, a Darlington specific program manual was developed to provide governance for implementation of EQ. The list of equipment required to be qualified, the EQ Safety Related Component List (EQSRCL), was developed in a non-procedural, non-auditable manner and EQ was implemented at DNGS over the period 1986 to 1992.

The EQ program was handed over from Design & Construction to Operations in 1992. Lack of focus on the EQ sustaining program and the resultant degradation in component condition prompted the IIP EQ Restoration Program (Project EN009) in 1997. In November 1999, the CNSC proposed an amendment that became a part of the Darlington Power Reactor Operating License (PROL) requiring that the station provide evidence that required systems, components, protective barriers and structures in the facility are environmentally qualified by June 30, 2004.

The IIP Project was closed in 2001, with some scope necessary to comply with the PROL Condition outstanding. The transition plan identified the work to be completed, with an expectation that the majority of the issues would be completed by the end of 2003.

In May 2003 the CNSC provided acceptance criteria to clarify what was required to satisfy the PROL condition. At the direction of the Chief Nuclear Engineer the remaining EQ work was divided into two projects: one to complete activities ecessary to satisfy the PROL condition due June 30, 2004 and a second to complete CNSC EQ commitments due after June 30, 2004 and establish a sustaining EQ Program.

The EQ Recovery Project (16-38411), which was completed June 30, 2004, involved completing the outstanding EQ assessments, completing gap analysis for components with a limited life and scheduling the resolution of issues remaining after June 30, 2004. Upon completion of project 16-38411, the current project, 16-38457 EQ Closure and Component Replacement was initiated to resolve the outstanding issues by December 31, 2010.

Under this project (16-38457), Darlington has followed the OPGN EQ list development process, as was done at the Pickering and Bruce sites, to update its EQSRCL; this process provides full traceability and compliance with the EQ design basis. During this exercise unqualified components that were not in the Darlington EQ program have been identified. As a result of these discoveries and other deficiencies the Senior Site Vice-President instructed the project to initiate a Darlington EQ Program Self-Assessment in 2006. One of the actions coming out of the self-assessment was the requirement for the EQ Project to perform a scope optimization study with the goal of identifying ways to reduce the scope and/or the cost of EQ.

The scope optimization study is scheduled to be completed in October 2007 at which time the recommendations will be used by the EQ Project and Darlington management to determine the most practical and economical path forward for EQ at Darlington.

Major deliverables achieved under previous releases of this project were:

- 1. Completion of EQ List Development Packages (TCD: November 30, 2007).
- 2. Completion of committed D541, D611, D631, D741, and D721 outage work (On track as per N-PROC-MA-0013).
- 3. Completion of committed 2007 online work (On track as per N-PROC-MA-0022).
- Completion of design packages for remaining committed outage and online work (including discovery items for Limitorque actuators and ITT Cannon connectors - U1 packages complete, TCD for remaining packages: March 20, 2008).
- 5. Completion of an EQ Program Self-Assessment (Complete).
- 6. Completion of a scope optimization study (TCD: October 26, 2007).

ONTARIO <b>power</b>	OPG Confidential	Page: 4 of 19
GENERATION	BUSINESS CASE	SUMMARY

The previous BCS (Ref. 7) was prepared prior to the current revision of the project charter (Ref. 6) which increased the scope of the project as described below:

- Additional components which need to be replaced in the field were identified as a result of additional EQLDP packages being completed. (Only components currently committed to the CNSC, as detailed in Attachment *D*, will be completed in this project)
- 2. It was identified that the transition to the EQ sustaining program will require a higher level of effort than originally anticipated from the project.
- 3. Requirement added to complete a scope optimization study.
- 4. Requirement to study fiber optical cables and determine a practical method to resolve the issues surrounding the requirement for them to be EQ. (This will not be addressed under this project.)
- 5. Requirement added to perform completion assurance activities for all EQ components. (In this project, completion assurance activities will only be completed for the components replaced under this project and those not expected to be affected by scope optimization.)

These changes have caused a small increase to the original cost estimate prepared under the previous BCS (Ref. 7), a new project is also expected to be required to address the deficiencies not covered by this project and new deficiencies which may be identified in the future.

In March 2007 the CNSC conducted an audit of Darlington's EQ program. The audit report (Ref. 5) has been sent to Darlington with several action notices and recommendations, the following are relevant to the EQ project:

- AN2 Based on the requirements of OPG Environmental Qualification Program, N-PROG-RA-0006 and OPG
  procedure, N-PROC-RA-0092, Environmental Qualification Implementation and Preservation DNGS is required to
  expeditiously complete the Technical Basis Documents (TBD), EQSRCL, EQLDPs, EQAs, EQ cables list and On-Line
  Wiring. DNGS is also required to prepare an auditable EQSRCL, with sufficient references to basis documents and
  guidance for, how to fill and read this list.
- AN3 CNSC inspectors observed lot of inconsistencies in the various documents as identified in Section 4.2 (of Ref. 5). DNGS need to revise these documents (EQ design guide, EQLDPs, EQA, EQSRCL, FIN procedure and EQLDP procedure).
- AN5 DNGS has not qualified the fiber optic cables. We require DNGS to provide a schedule for the completion of EQ of the fiber optic cables.
- R4 CNSC recommend DNGS that soon after the completion of all EQLDPs, the EQ RCM to be revised to provide conditions for all new rooms and areas, if needed.



### 3/ ALTERNATIVES AND ECONOMIC ANALYSIS

		All 1 (Ruce	manded	AR2	AR3	AR4	ARS
\$ Millione	Stop the Project	Pull Cont	incremental Cost	Delay	Do Lass	Do More	
Revenue	•		· · · ·			and the second second	•••••••
OM&A	(2.67)	(63.11)	(39.08)	N/A	N/A	N/A	· ·- ······
Capital		···· - 2			1		<u>-</u>
NPV (after tax)	(1.70)	(37.71)	(22.08)		• • - • • • • • • • • • • • • • • • • •		····· ··· ···
Impact on Economic Value (IEV)	N/A	(36.01)	(20.38)			+	
IRR%	N/A	N/A	N/A		1	· +·	
Discounted Payback (Yrs)	N/A	N/A	N/A				······

### Stop the Project - Not Recommended

Stopping the project is not recommended. This would result in the outstanding committed scope of work to remain incomplete; as a result the REG C commitment would not be met.

### Alternative 1 - Complete Committed Replacements & EQ Efficiency Analysis - Recommended

Completing committed component replacements (Including completion assurance) and determining the most efficient means for maintaining full compliance with the EQ requirements of the license is recommended. The work is required to bring Darlington in compliance with its PROL and the failure to do so would result in the CNSC REG C remaining incomplete.

In order for Darlington to be successful in meeting its regulatory commitments it is critical that the installation activities for the ommitted scope of work continue as scheduled in parallel with the scope optimization study and other activities required to letermine the most effective path forward for EQ at Darlington.

### Alternative 2 - Delay Project - Not Recommended

Delaying the project is not recommended. The component replacements which are being done under this project have been committed to the CNSC for completion by December 31, 2010 under Action Assignment # 28058364.

### Alternative 3 – Do Less - Not Recommended

Completing component replacements and not doing the EQ efficiency analysis is not recommended as it would jeopardize Darlington's ability to meet its regulatory commitment. The components which are being replaced in the field under this release are only those which have been previously committed to the CNSC (refer to Ref. 1 and Attachment "D"). The additional work being done is required to determine the best path forward for Darlington to comply with its PROL.

The project is making extensive use of Operating Experience (OPEX) from the Pickering and Bruce sites to ensure that the requirements of the Ontario Power Generation Nuclear (OPGN) EQ Program and Darlington's PROL are met at minimum cost.

### Alternative 4 – Do More - Not Recommended

Due to the number of unknowns associated with maintaining full compliance with EQ requirements of the license, it is recommended at this time to release an additional \$33.2M to allow the committed scope of work to be completed in accordance with the schedule. It will also allow the design basis documentation to be completed and an analysis to determine the most efficient method for maintaining full EQ compliance; if future work is found to be required for Darlington to meet its PROL it will be completed under a separate project.

Alternative 5 – • Not Recommended



### **BUSINESS CASE SUMMARY**

# 4/ THE PROPOSAL

The proposal is for the full release of \$33.2M to allow the Environmental Qualification (EQ) Closure and Component Replacement Project to:

- 1. Continue work on the following activities that are critical to the REG C committed schedule (Attachment "D"):
  - a. Replace components in the field during the D811, D931, D1041, and D1021 outages.
  - b. Replace components in the field in 2008 through 2010 via the Darlington online program.
- 2. Prepare completion assurance packages for the components replaced during the project and for those not expected to be affected by the scope optimization study (~ 4000 tags). Address completion assurance requirements for cables.
- 3. Determine the most cost effective and efficient method for Darlington Nuclear to comply with the EQ requirements in its operating license by December 31, 2010, through the following activities:
  - a. Preparation of draft EQ Technical Basis Documents and initiation of the station review of them.
  - b. Initiation of a gapping analysis to determine the components which, in order to comply with EQ governance, require:
    - i. Modifications.
    - ii. Replacement, due to them being beyond their qualified life span.
    - iii. Documentation updates.
    - iv. Qualification testing.
  - c. Use the scope optimization study as a cost benefit tool to determine the most efficient path forward for Darlington to comply with the EQ requirements of its PROL.
- 4. Initiate preliminary design / analysis / testing activities for deficiencies identified in the gap analysis and the selected scope optimization options (this may include procurement of long lead time materials). This includes, but is not limited to:



- a. Qualification of column line 11 as a steam barrier.
- b. Modification(s) required to address concerns with wet rooms.
- c. Qualification / replacement of BIW cables outside containment.

Detailed engineering activities, procurement of short lead time materials and installation activities for this new scope will not be completed under this project. If required, the business case for a new project to resolve the new EQ issues arising from this new scope will be developed.

5. Complete the transition to the Sustaining EQ Program, this will be done through mentoring, transfer of software tools to the sustaining staff and preparation of desktop guides to promote the consistent application of EQ.

### NOTE:

The correction of any configuration management issues identified during completion assurance walk-downs is not within the scope of this project.

The Project Execution Plan will be approved by December 2007.

### 5/ QUALITATIVE FACTORS

Environmental Qualification compliance and sustainability are licensing requirements. Qualitative benefits of the project are:

- 1. An improved ability to contain and minimize damage or loss of the asset due to a harsh design basis accident.
- 2. An increase in public and employee safety.



ONTARIOPOWER GENERATION

OPG Confidential

7 of 19

Page:

BUSINESS CASE SUMMARY

# 6/ RISKS

11	ts and actuals for Low the preparation of ingency has been cost increases. A een contracted to	this project is a Low whose purpose is overall scope and in This project will if work detailed in work required for its PROL will be project, the new	d in the estimate Low al contingency is ncreases.	It rework issues N/A e of this project for Darlington. A s under a "pilot d to establish a unt of rework that
Mitigating	TfS sheets, issued contracts and actuals for similar tasks were used in the preparation of the estimate, general contingency has been included to cover possible cost increases. A independent agency has been contracted to review the estimate for accuracy	Included in the scope of this project is a scope optimization study whose purpose is to find ways to reduce the overall scope and cost of EQ for Darlington. This project will only complete the scope of work detailed in section 4, any additional work required for Darlington to comply with its PROL will be managed through a new project, the new project will provide a detailed cost estimate	Funding has been included in the estimate for scaffolding and general contingency is available for possible cost increases.	Configuration management rework issues are not within the scope of this project however the risk remains for Darlington. A sample set of walk-downs under a "pilot project" will be completed to establish a better estimate for the amount of rework that Darlington should expected.
Risk Before Mitigation	Medium	мол	mibeM	NA
Description of Consequence	Higher cost.	A new project may be required for Darlington to comply with its PROL. Current conceptual estimates for this project are in the range of \$40M to \$140M.	Higher cost.	Challenge to schedule, increased station OM&A costs. Based on OPEX there is a risk that correction of these deficiencies could cost up to \$50M.
Description of Risk	Underestimation of cost.	Complete scope of activities for Darlington to comply with it's PROL not defined.	More scaffolding required than estimated.	Configuration management issues identified during completion assurance waik- downs.

1. 2.0 at 40



1

OPG Confidenti

**BUSINESS CASE SUMMARY** 

8 of 19 Page:




-	Darlington to comply with its PROL.		trictuded in the scope of this project is a scope optimization study whose purpose is to find ways to reduce the overall scope and cost of EQ for Darlington. This project will only complete the scope of work detailed in section 4, any additional work required for Darlington to comply with its PRO1 will he	Low
Uncertainty on the score of Lin			managed through a new project. This new project will provide a completion date for the new scope.	
walk downs.	nigitet cost.	Medium	Specific contingency has been included to reduce the risk associated with walk downs	Low
Delay in the schedule				
	Detay in the schedule, increased cost, and missed REG C commitments.	Medium	All work required to be completed under this project, as outlined in Attachment "D", has been scheduled in accordance with OPG governance. Adherance to this schedule is monitored regularly by the project and any threats will be communicated to Darlington	Low
o ۲	Inability to complete full scope of work by December 31, 2010. Until the full scope of work required for Darlington to comply with the EQ requirements of its PROL is defined and understood a completion date cannot be provided.	۲ ۵	Current committed scope of work (as shown in Attachment "D") has been planned and scheduled to ensure its completion by December 31, 2010. A scope optimization has been initiated in order to find ways to reduce the overall scope. Once the full scope of work required to EQ Darlington is understood a new project may be required. In order to prevent delays funding has been included in this release to initiate preliminary engineering / analysis / testing activities prior to the initiation of the new project	P
completion assurance walk- downs.	Increased scope of work for station resources. If this work is not completed prior to Dec. 31, 2010 there will be a list of open items turned over to the station.	AIN	Configuration management rework issues are not within the scope of this project however the risk remains for Darlington. Walk-downs will be scheduled as early as possible to maximize the time available to station resources for the correction of any	AIA



9 of 19 Page:

BUSINESS CASE SUMMARY



-F 13, 1 * 5- - 5

**∀**Z

ŔΝ

**V**N

N/A



Page: 10 of 19



# **BUSINESS CASE SUMMARY**

under Low saftey	Drk Low	ot ed A	
Installations will be executed under approved work practices, OPG saftey requirements, and OPG oversite	ALARA principles are applied during work planning / execution.	Work in this release incorporates OPEX and Low is required for compliance with the EQ requirements of Darlington's PROL. A scope optimization study is being completed to ensure that unnecessary work is not completed.	
unibeM Medium	Medium A		
<ol> <li>Injury to workers.</li> <li>Impact to the project schedule and cost.</li> </ol>	Field resources could reach their one and/or five year limits on radiation dose.	Higher cost.	
Workplace injury or MRPH 1. Injury to wo event. 2. Impact to the cost.	areas.	Risk of rework and/or the implementation of unnecessary modifications.	

## 7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Final AF8	Targeted PIR Approval	PIR Responsibility
	Date:	Date:	(Sponsor Title)
Simplified	Dec 2010	Dec 2011	Director of Engineering - Darlington Nuclear

## Comments:

	Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it? (person / group)
1.	Completion of CNSC REG C committed component replacements, Action Assignment #28058364.	As of Jan. 2007 the committed component replacements (as documented in Action assignment # 28058364) had a due date was December 31, 2010.	Completion of committed component replacements by December 31, 2010. See Attachment "D".	Completion letter submitted to the CNSC.	Regulatory Affairs Manager
2.	No EQ issues on the committed component replacements.	EQ Completion Assurance not completed on committed component replacements.	EQ Completion Assurance on committed component replacements.	EQ Completion Assurance documents in place for all replaced components.	Components & Equipment Manager
3.			······		
4.					-
5.					



Appendix "A"

## **BUSINESS CASE SUMMARY**

## Glossary (acronyms, codes, technical terms)

	AFS:	Available for Service
	BCS:	Business Case Summary
	BTU:	Building Trades Unions
	CNSC:	Canadian Nuclear Safety Commission
	EQ:	Environmental Qualification
	EQA:	Environmental Qualification Assessment
	EQLDP:	Environmental Qualification List Development Package
	EQSRCL:	Environmental Qualification Safety Related Components List
	IEV:	Impact on Economic Value
	IRR:	Internal Rate of Return
	LTD:	Life to Date
	MRPH:	Maximum Reasonable Potential for Harm
	N/A:	Not Applicable
	NPV:	Net Present Value
	OAR:	Organizational Authority Register
	OM&A:	Operating, Maintenance, and Administration
	OPEX:	Operating Experience
	OPG:	Ontario Power Generation
	OPGN:	Ontario Power Generation Nuclear
	PCRAF:	Project Change Request Authorization Form
	PEP:	Project Execution Plan
		Post Implementation Review
		Power Reactor Operating License *
		Power Workers Union
		CNSC Regulatory Commitment
		Station Condition Record
-		Technical Basis Document
	TIS:	Task Identification Sheet



ONTARIOPOWER GENERATION

**OPG Confidential** 

Page: 13 of 19

**BUSINESS CASE SUMMARY** 

Appendix "B"

## **Project Funding History**

\$ Millions		na Alb	Existing (		ved Relea wietive V		continge	ncy)			<u>- 36</u> - 6
Release Type	Month	Year	2004	2005	2005	2907	2008	2009	2010	Latine	Total
Developmental	Oct	2004	4.56	2.64					, <u></u> ,		7.20
Partial	Feb	2006	0.59	5.81	4.10						10.50
Partial	Apr	2006	0.59	5.81	11.52	6.95	1.25	1.25	2.50	∔	29.87
Full	Nov	2007	0.59	5.81	8.52	11.78	14.45	10.73	10.41	0.83	63.11
						1					0.00
										1	0.00
											0.00
											0.00

LTD Spent Aug 2007 0.59 5.81 8.52 7.61 22.5	
---------------------------------------------	--

•

## Comments:







#### **BUSINESS CASE SUMMARY**

## **Financial Model – Assumptions**

#### Project Cost Assumptions:

Appendix "C"

**ONTARIOPOWE** 

GENERATION

The project cost for the committed scope of work was developed using estimates from the supporting work groups combined with historical charges against this project. The quality for this portion of the estimate is in the +30% to -15% range.

The remaining portion of the funding released under this BCS will be used to:

- 1. Perform completion assurance activities for the components replaced during this project and for those not expected to be affected by scope optimization. This is expected to involve:
  - a. Walk-downs of ~4000 components and up to 9300 cables.
  - b. PASSPORT updates.
  - c. Documentation updates.
- 2. Determine the most cost effective and efficient method for Darlington Nuclear to comply with its operating license requirements for EQ by December 31, 2010.
- 3. Compete preliminary engineering / analysis / testing activities for newly identified scope. Money has been included for this activity only in 2008, it is expected that a new project will be initiated by Q4-2008 which will then be responsible for this scope of work.

There is greater uncertainty in this portion of the estimate which is mitigated by the inclusion of specific contingency for completion assurance walk downs and the overall value of the general contingency.

#### Financial Assumptions:

The PV_{Base} has been set to \$0 for this project since completing this project is a CNSC Regulatory commitment and not doing the project is not a viable alternative.

#### Project / Station End of Life Assumptions:

Darlington's end of life was assumed to be 2020.

#### **Energy Price / Production Assumptions:**

N/A.

#### **Operating Cost Assumptions:**

N/A.

#### Other Assumptions:

It was assumed that the EQ project will be split from Darlington Design Projects prior to 2008, as a result overhead costs for a Stratum IV manager, an Administrative Assistant and a new Stratum III manager have been included in the estimate.

A new project is expected to be initiated by Q4-2008 at which time it was assumed that overhead costs would be shared by the two projects.



## ONTARIOPOWER GENERATION

Page: 15 of 19

BUSINESS CASE SUMMARY

## DNGD: EQ Closure and Component Replacement Project 16 - 38457

## Full Release Business Case Summary D-BCS-03651-10004-R000

Attachment "A"

## **Project Cost Summary**

\$Willions	LTD Prior Yr	, , , , , , , , , , , , , , , , , , ,	This Release	This Release	This Release	This Release	a an an an an an an an an an an an an an		· · · · · · · · · · · · · · · · · · ·
	2006	2007	2008	2009	2010	2011	~	Later	Total
Project Management (OPG)	1.08	0.52	1.54	0.90	0.90	0.44			5.37
Engineering & Drafting (OPG)	0.81	0.57	1.30	0.48	0.35	0.14			3.65
Material									
Installation - PWU, BTU									
Contract - Design		2					Carlo Carlos		-
Contract - Installation						in the state of the second			۲. E
Contract - Other							nstart	the states	
Augmented Staff				東京の支持	1010 T	<b>展出推出</b> 。	13317 204	Contraction of the	7
								सुर्व करणहरू	1 Contraction
Interest (Capital Project Only)				<b>不能</b> 。					
Project Costs (exci conlingency)									
General Contingency									
Specific Contingency									
Project Costs ( Incl contingency)	14.92	11.78	14.45	10.73	10.41	0.83			63.11
2008-2012 Business Plan	14.93	11.78	5.40	5.20	5.50	6.90	• • • <b>••</b> • •••		49.71
Variance to Business Plan	(0.01)	· · · · · · · · · · · · · · · · · · ·	6.85	1.78	1.21	(6.32)	~		3.50
Committed Cost						··· ·· ·		 	•
Inventory Write Off Required						••••••		 	
Spare Parts / Inventory						·	**		•
Total Release (excl contingency)	14.92	11.78	12.25	6.98	6.71	0.58	·····		53.21
Total Release (incl contingency)	14.92	11.78	14.45	10.73	10.41	0.03	сын . 	1970	63.11
A A A A A A A A A A A A A A A A A A A		#*				··· ··· topodinana v			
Ongoing OM&A (non-project)	1226.7	135.00			***** * * *			0.852.553	••••••••••••••••••••••••••••••••••••••

	Bank of E	dinate			ale se de la se
	100%	Quality of E	stimate	Budget + 30	% to - 15%
No	OPEX used	Yes	Lessons Le	earned	Yes
Yes	Budgetary Quote(s)	Yes	Phase 1 A	ctual Used	Yes
Yes	Contracts in place	Yes	Competitiv	e Bid	Yes
	Yes	100%           No         OPEX used           Yes         Budgetary Quote(s)	No         OPEX used         Yes           Yes         Budgetary Quote(s)         Yes	100%         Quality of Estimate           No         OPEX used         Yes         Lessons Luistic           Yes         Budgetary Quote(s)         Yes         Phase 1 Au	100%         Quality of Estimate         Budget + 30           No         OPEX used         Yes         Lessons Learned           Yes         Budgetary Quote(s)         Yes         Phase 1 Actual Used

#### Variance to Business Plan

The estimated variance(s) to the 2008-2012 Business Plan will be addressed through the portfolio management process. A PCRAF is not required

Reviewed By: au

Approved B OINO T. Chong

B. Beaudette Project Manager

Date:

OLNOV200

Eng & Mods Manager (Strat IV)

Date:

## DNGD: EQ Closure and Component Replacement Project 16 - 38457

#### Full Release Business Case Summary D-BCS-03651-10004-R000

## Attachment "B"

## **Project Variance Analysis**

	Contraction of	Foll A	leiease		
CHARA	LTD Aug 2607	Lant BC3 Apr 2005	This BCS Nov 2967	Variance	Comments
Project Management (OPG)	1.38	1.39	5.37	3.98	See below
Engineering & Drafting (OPG)	1.19	0.60	3.65	3.05	See below
Material					
Installation – PWU, BTU		State of the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local division in the local div			
Contract - Design	-				
Contract - Installation					
	The second second second second second second second second second second second second second second second se				
Contract - Other		the second second second second second second second second second second second second second second second s			the man set in the manufacture of the set of the set of the
Contract - Other Augmented Staff	17-				
Augmented Staff Future Funding Req'd			No.		
Augmented Staff Future Funding Req'd					
Augmented Staff Future Funding Reg'd Interest (Capital Project Only)					
Augmented Staff Future Funding Req'd Interest (Capital Project Only) <b>Project Cools (und cardingency)</b> General Contingency					
Augmented Staff Future Funding Req'd Interest (Capital Project Only) Freject Cools (and earlingency) General Contingency Specific C					
Augmented Staff Future Funding Req'd Interest (Capital Project Only) Freject Cools (and earlingency) General Contingency Specific C	22.53	57.90	63.11	6.11	See below
Augmented Staff Future Funding Req'd Interest (Capital Project Only) <b>Project Cools (und cardingency)</b> General Contingency	22.53	57.00	63,11	6.11 0.00	See below
Augmented Staff Future Funding Req'd Interest (Capital Project Only) Enjust Courts (und courterent) General Contingency Specific C	22.53	57.00	63.11	به به رسوفت د ا	See below
Augmented Staff Future Funding Req'd Interest (Capital Project Only) Conjust Costs (und configurery) General Contingency Specific C	22.53	57.00	63.11	0.00	See below
Augmented Staff Future Funding Req'd Interest (Capital Project Only) Frainat Coults (und contingency) General Contingency Specific C Committed Cost	22.53	57.00	63.11	0.00	See below

#### Comments:

#### Explanation of Variance:

The previous Partial Release BCS had an overall estimate of \$27.1M for future release; it did not break down the estimate into the various categories. Hence, the high variances between the Last BCS and This BCS for the categories.

The project has achieved savings of approximately through scope reductions relating to the Limitorque Actuators and PAWCS heat Exchanger packages.

Additions in scope including the ITT Cannon work and the increased number of Deltrol / Norgren valves which required modifications added approximately to project costs. 60 addition EQLDP packages were also completed at a cost of the scope optimization study which was completed at the request of the Senior Site VP added to the project's cost. Given the uncertainty surrounding completion assurance activities a specific contingency of the the been included.

has been included to allow the project to initiate preliminary engineering activities to begin of newly identified scope of work prior to the establishment of the new project.

ditionally issues such as delays in obtaining vault access during outages, high radiation fields and legacy usues discovered during the project have caused challenges to the project team leading to increased costs.



Page: 17 of 19

**BUSINESS CASE SUMMARY** 



Attachment "C"

## Key Milestones

Co	Completion Date		
Day	Mth	Yr	Description
07	Jan	2008	PMM: Conceptual Design Input Complete (Scope Optimization)
19	Jan	2008	DCP: Design Pkgs App'd & issued – ITT Cannon Connectors (Online)
16	Feb	2008	LLA: Mat'l Contracts Awarded for D931S Outage
28	Mar	2008	SOI: Start of Installation for D811S Outage
15	Apr	2008	PTA: Passport Tasks set to Ready Limitorque Valves (Online)
16	Apr	2008	DCP: Design Packages Approved & Issued for D931S Outage
16	May	2008	ICA: Installation Contracts Awarded for D931S Outage
30	Jun	2008	AFS: D811S Outage
07	Jul	2008	SOI: Start of Installation – Limitorque Valves (Online)
07	Jul	2008	PMM: Preliminary Design Input Complete (Scope Optimization)
25	Jui	2008	SOI: Start of Installation - A/L Hoses (Online)
20	Aug	2008	SOI: Start of Installation – ITT Cannon Connectors (Online)
15	Sept	2008	ICA: Installation Contracts Awarded for 2008 Online Packages
18	Sept	2008	PTA: Work Package Assessments Complete for D931S Outage
28	Oct	2008	PTA: Work Package Assessments Complete for 2008 Online Packages
19	Dec	2008	AFS: 2008 Online Packages
26	Jan	2009	LLA: Mat'l Contracts Awarded for D1041S Outage
30	Jan	2009	SOI: Start of Installation – Gould Transmitters (Online)
05	Mar	2009	ICA: Installation Contracts Awarded for D1041S Outage
20	Mar	2009	DCP: Design Packages Approved & Issued for D1041S Outage
16	Apr	2009	SOI: Start of Installation for D931S Outage
11	Jul	2009	AFS: D931S Outage
01	Aug	2009	LLA: Mat'l Contracts Awarded for D1021F Outage
	Sep	2009	PTA: Work Package Assessments Complete for D1041S Outage
25	Sept	2009	DCP: Design Packages Approved & Issued for D1021F Outage
17	Oct	2009	ICA: Installation Contracts Awarded for D1021F Outage
28	Oct	2009	PTA: Work Package Assessments Complete for 2009 Online Packages
18	Dec	2009	AFS: 2009 Online Packages
26	Mar	2010	SOI: Start of Installation for D1041S Outage
26	Mar	2010	PTA: Work Package Assessments Complete for D1021F Outage
19	May	2010	AFS: D1041S Outage
01	Oct	2010	SOI: Start of Installation for D1021F Outage
24	Nov	2010	AFS: D1021F Outage
24	Jul	2011	PCM: Project Completion Milestone

A Project Execution Plan (PEP) will be approved by Dec 2007.



ONTARIOPOWER GENERATION

OPG Confidential

**BUSINESS CASE SUMMARY** 

attachment "D"

								CN	SC .	stal	latio	n Car	mple	tion D	ste				
			31-Dec-09	31-Dec-10	31-Dec-08	Complete	31-Dec-04		_	¥1¥	Contes	1		1	31-Dec-10	31-Dec-10	I	1	31-Dec-10
Outag <del>e</del>	Outag Туре	Unit	Norgren A/L Valves	Ion Chamber BIW Cable (RRS and SDS1)	er BIW Cable (SDS2)	States Ta cento Entra	Horic Faix Detector Tetzol	EDOIT AIR SECURIORIES		NUMBER LUCKASCH DERRY (AS JPC)	Berg Cart Value	Resyment Lints Souther	The State	A REAL PRIME AND	Airtock Hoses & Norgren	Limitorque Actuators	Street Classe Public Such	NEX MAN DE TON	ITT Cannon Connector 3 Replacement
D411 (Spring 2004)	Major	1			1	121		T		•••••			-			<u> </u>		-	<u> </u>
D431 (Fail 2004)	Minor	3				1000		1			-	10.1		1000				-	
D521 (Spring 2005) D541 (Fail 2005)	Major	2		-	L	100								10.1					
D631 (Spring2006)	Minor	4			_		_	1		_		2.18	210					trati	
D611 (Fall 2006)	Major Minor	3	100	-		in-	-	and one									22.2		
D741 (Spring 2007)	Major	4	100	-	-	in the second	_				-	-	-						
D721 (Fall 2007)	Major	2	UP	<u> </u>	X	120	X	ν/P		• • • •	re di	in t	in the second	Castler -			-	21.02	li
D811 (Spring 2008)	Major	1			x	and the second	- ĝ	WP			-6	ter d	100-	1.00			22		
D901 (Spring 2009)	VBO	1 0	1	t	<u> </u>			+	+		÷	ije d	in the	6 au	X	<u>×</u>	-		X
D911 (Spring 2009)	VBO	1	<u> </u>					ŧ	- <b>f</b> anna	-97	-	<u>*</u>	-	-				wete-	
D921 (Spring 2009)	VBO	2				22		t	+	- 2	eng:	*1	-				<b>1</b>	netperio	
D931 (Spring 2009)	Major	3	X	X			·····	X	+	- 2	-9	-7	-		X	x	à	-	X
D941 (Spring 2009)	VBO	4				1000		-	<b>†</b>	- 65	12	연사람	-	and a	+	<u> </u>	194		
D1041 (Spring 2010)	Major	4				1000			1		1		-	27	x	<u>x</u>	÷		-
D1021 (Fall 2010)	Major	2		X					T			101-P	-and-		X	X	-	110	X
Von-Outage			nsmitters 31-Dec-09	NV AD AL	31-Dec-07	ides Chamber 31-Dec-07	State	31-Dec-07	ses & Norgren 31-Dec-10	Actuators 11-Day 10		S MARY THE SHARE	日日二日の大日	Replacement 31-Dec-10					
Z		0 1 2 3 4	Gould Transmitters		X X X X Valves			X X X X Kopex Cor	X X X X Aurlock Ho	X X X X Limitorque	14		383 .	K X X X III Camon C					

Notes

Non-Outage items identified are non-unitized schedule. Date indicated is for completion of all station IPG work for the particular item

C' - Airlock 2 Complete

X¹ - Airlock 1 moved to D931 by Outage Management

 $\chi^2$  - Added by Charter Rev 2 to be committed to CNSC November 2007

C* - Removed from replacement program through exemption/QL extension

C** - Replacement is being completed every outage through regular PMs

I/P - In progress

Completion dates highlighted in yellow indicate schedule changes from CNSC submission

FERENCES

**ONTARIOPOWER** 

GENERATION

- NK38-CORR-00531-13472, CNSC Letter from Senior Vice-President W. Robbins to Mr. G.R. Schwarz, Darlington NGS 2006 Annual Update: Safety Significance of Remaining Environmental Qualification (EQ) Issues Post June 20, 2004
- NK38-CORR-00531-12540, CNSC Letter from Senior Vice-President Gregory OD Smith to Mr. G. Schwarz, Darlington NGS Safety Significance of Remaining Environmental Qualification (EQ) Issues Post June 30, 3004, dated November 30, 2004.
- 3. NK38-CORR-00531-12306, CNSC Letter from Senior Vice-President Gregory OD Smith to MS. B.A. Ecroyd, Safety Significance of Remaining Environmental Qualification (EQ) Issues Post June 30, 2004, dated May 31, 2004.
- NK38-CORR-00531-12132, CNSC Letter from Senior Vice-President Gregory OD Smith to Mr. E. Leader, Progress in Addressing CNSC Environmental Qualification (EQ) Acceptance Criteria, dated December 18, 2003.
- NK38-CORR-00531-13872, Action Item 20071314 CNSC Type I Inspection of Darlington NGS Environmental Qualification Program Conducted March 12 to March 30, 2007.
- 6. D-PCH-03651-10002-R002, EQ Closure and Component Replacements Project Charter.
- D-BCS-03651-10003-R000, DND: EQ Closure and Component Replacement (Phase II) 16-38457, Partial Release Business Case Summary.
- 8. D-BCS-03651-10002-R000, DND: EQ Closure and Component Replacement (Phase II) 16-38457, Partial Release Business Case Summary.
- 9. D-BCS-03651-10001-R000, DND: EQ Closure and Component Replacement (Phase II) 16-38457, Developmental Release Business Case Summary.



ONTARIOPOWER GENERATION

**BUSINESS CASE SUMMARY** 

Pickering B Steam Generator Locking Tab Replacement 13 - 40641

## Full Release Business Case Summary NK30-BCS-33115-00007-R000

Routing	Location	Action	Signature	Date
J. Xiao Project Leader (Acting), Boiler Projects 701-8649	P72-3	Prepare BCS	Trad	Jan 24, 07
P. Asgaripour Project Manager (Acting), Boller Project 701-4680	P72-3	Review BCS	1 Aspen	JAN 26/07
G. Kotwa Section Mgr. Process Scheduling 701 - 3755	P72-1	Review BCS	Awylowe	26 Jan /07
G. Keto Manager, Boiler Projects 701 - 2568	P72-3	Review BCS	Perry Vieto	Jan 26,07
D. Williams Manager, Projects Design Pickering 701 - 4956	P72-3	Review BCS	Charle Dull	A 27/07
B. Morrill Manager, Comp. & Equipment 701-4926	P41-E3	Review BCS	11.1. Shenche	20.7.01-31
R. Ball enior Financial Analyst 12 - 4084	P82-3B6	Review BCS	(P2	5F2607
· · · · · · · · · · · · · · · · · · ·				
			· · · · · · · · · · · · · · · · · · ·	
~ /	·			
R. Ball	·	·····		
Senior Financial Analyst 702-4084	P82-3B6	Return For Distribution		





## Pickering B Steam Generator Locking Tab Replacement 13 - 40641

## Full Release Business Case Summary NK30-BCS-33115-00007-R000

Rouling	Location	Action	Signature	Date
M. Arnone Director Projects & Mods 701-6063	P71-1	Review BCS	Flace	02.Fers200
R. Leavitt Director Investment Management 702-5085	P82-3	Review BCS	Falenit	Feb 19 2007
P. Tremblay Senior Vice President Pickering B 701-3501	P41-E3	Review BCS ⁴	RELlay	Fab 20/0
J. Beech VP Nuclear Finance 400-7276	H9 F26	Review BCS	pus	fan 23/07
T. Mitchell <del>EVP an</del> d CNO 702-5294	P82-6	Review BCS	Manhluce	28FES07
D. Power, VP - Corpurate Investment Director Investment & Business Planning 400-7172 Planning	H7 D06	Review BCS	A Sterren 1	March 8/0
P. Charlebois VP and COO 0-8470	H19 A21	Review BCS	f	marzolan
J. Hankinson President & CEO 400-2121	H19 A24	Approve BCS	н	Ma-20/0-
		; ; ; ;		
	······		· · · · · · · · · · · · · · · · · · ·	
		<u> </u>		
, Ball				
vor Financial Analyst 2-4084	P82-3B6	For Distribution		



Page: 3 of 18

**BUSINESS CASE SUMMARY** 

## Pickering B Steam Generator Locking Tab Replacement 13 - 40641

## Full Release Business Case Summary NK30-BCS-33115-00007-R000

#### **RECOMMENDATION:** 1/

We recommend a full release of \$20.5M (including contingency) to design, install, and commission new locking devices in all 12 Steam Generators (SGs) in Unit 7 during the 2008 outage and Unit 8 during the 2010 outage.

The business objective of this project is to remove the current requirement to shut down Unit 7 and Unit 8 after 6.3 Effective Full Power Years (EFPYs) because of the threat of fatigue failure of the cold leg locking tabs, by developing and installing a new design that will:  $\alpha$ 

- Allow Units 7 and 8 to run until End of Life (EOL) without concerns of locking tab failure Ö
- Reduce the overall project cost and dose uptake by ~\$4.3M and 40% respectively (compared to Units 5 and 6) 0
- Align with the Pickering B 85/5 initiative by allowing installation within a 40 day outage schedule 0
- Allow inspection/maintenance to be conducted with minimal interference with the new design O
- Allow for the removal and/or replacement of components of the new design with relative ease, if required

If a cold leg locking tab were to fail, it is speculated that it would cause significant damage to the Heat Transport System. More importantly, a broken cold leg locking tab could block Primary Heat Transport (PHT) water flow through feeder pipes and orifices. Lack of flow can cause overheating of fuel and result in fuel failure. In the worst case scenario, a broken cold leg locking tab could cause Pressure Tube failure leading to a Loss of Coolant Accident (LOCA). However, repairs to Units 7 and 8 can be postponed until March 2011 and October 2010 respectively since a Fitness for Service Evaluation of cracked hot leg locking tabs concluded that cold leg locking tabs will not fail prior to 6.3 Effective Full Power Years (EFPYs) and failure of hot leg locking tabs is not an operability issue. This analysis is based n a safety factor of 2. (see Glossary)

ocking tab design problems were first experienced when broken pieces of locking tabs and sealing skins were found on the hot leg (inlet) side of the Unit 5 SGs during the P551 outage. Similar problems were later found in Unit 6. The root causes were determined to be insufficient design analysis for the locking tabs and inadequate installation of the sealing skins. Repairs to both locking tabs and sealing skins were conducted on Units 5 and 6 because of the imminent threat posed by the sealing skin installation. Due to greater rigor applied during the installation of sealing skins in Units 7 and 8, there is no need to replace them prior to End of Life (EOL). Additionally, there is no need to replace the locking tabs on Units 5 and 6 as they are expected to operate without problems to EOL.

We have considerable experience in locking tab design and installation; however, a contingency has been included to address the risk associated with designing, qualifying and installing a new design or defaulting to the Unit 5/6 design in the remote chance that the new design is ineffective and/or cost prohibitive.

	Funding	LTD 2005	2006	2007	2008	2009	2010		
Currently Released	None						2010	Later	Total
<b>Requested Now</b>	Full			0.6		<u>ب</u>		· · · · · · · · · · · · · · · · · · ·	· •
Future Funding Reg'd		+			9.4	0.5	9.7	0.3	20.5
Total Project Costs	+	· · · · · · · · · · · · · · · · · · ·	·····		···- n 7				• •
Other Costs	+ 			0.6	<u>9.4</u>	0.5	9.7	0.3	20.5
Committed Cost	+	÷	+				; 		<u>.</u>
Grand Total Release	f==	f-		12.9	(6.4):	· - · · · · · · · · ·			-
Investment	Type	Clas	······································	13.5	3.0	(0.5)	4.2	0.3	20.5
Sustainin		ONS		(IEV) impact o 645.0				Discounted 3.5	Payback
Submitted By:								······································	
P. Tremblay	H Diskering B	<u> </u>	Date:	107					

President & CEO

Director Investment & Business Planning

Date.



Page: 4 of 18

**BUSINESS CASE SUMMARY** 

## 2/ BACKGROUND & ISSUES

#### **Adverse Condition**

The Steam Generator Divider Plate sealing skin modification was performed on Units 1, 4, 5-8 starting with Unit 4 in 2001 and finishing with Unit 7 in 2004. The primary purpose of this modification was to address Divider Plate bolt degradation as well as the steady increase in Reactor Inlet Header Temperature (RIHT) which was forcing some units to run derated. All modifications were completed successfully as measured by the decrease in RIHT for each unit. When the first unit (U5) SG inspections were conducted during the P551 (Spring of 2005) Outage following installation of the sealing skin/locking tab modification, it was discovered that numerous pieces of locking tabs and divider plate sealing skin had broken off in the hot leg (inlet) side of the steam generators (refer to SCR P-2005-03243) due to high cycle fatigue cracking. Further inspections revealed that all 10 affected steam generators experienced locking tab failures, and 4 of 10 steam generators experienced divider plate skin failures. The root causes of this event were deemed to be insufficient design analysis for the new locking tabs and inadequate sealing skin contact with the Primary Head seat bar.

## Repair Scope for Unit 7 and 8

During the original divider plate installations in P481 (Unit 8, 2004) and P471 (Unit 7, 2004), more rigor was applied for installation of sealing skins and design improvements to the skins were made. As a result there is a lower probability of sealing skin failure in these steam generators. This has been proven through subsequent inspections carried out during P681 (Spring of 2006) and P671 (Fall of 2006), as only 1 SG out of the 12 SGs inspected was found with minor, but acceptable skin failures. However, there were no changes made to the design of the locking tabs, so similar numbers of broken hot leg locking tabs have been in Unit 8 and 7. To date no broken locking tabs have been reported in cold leg (outlet) side of the any the inspected SGs.

A Fitness for Service Evaluation of cracked locking tabs for PNGS A and PNGS B (P-REP-33115-00001 R01) concluded that cold leg locking tabs will not fail prior to 6.3 EFPYs and failure of hot leg locking tabs is not an operability issue. This assessment allows the delay of the locking tab replacement until the 2010 Outages while development of an improved fastener design is underway to reduce the installation duration, dose and cost. Although it is acceptable from a Fitness for Service perspective to defer the locking tab replacement to 2010, performing this modification for all 24 SGs in 2010 is not aligned with the 85/5 initiatives. Thus, locking tab replacement will be completed in Unit 7 SGs in 2008 and Unit 8 SGs in 2010.

## Similar Previous Replacement Campaigns

As mentioned, hot leg locking tab failures were first found in Unit 5. Similar failures were found in Unit 6 Steam Generators during P561 Outage. Upon this discovery, all of the sealing skins, locking tabs, and associated components in all Unit 5 steam generators (except for two steam generators which were previously modified in 1999 with a different Divider Plate design) and in all Unit 6 steam generators were replaced. These repair campaigns were costly, lengthy, and dose intensive as shown below:

Project #13-40932, Unit 5 – approximately \$11M, 2 months, 33 Rem (10 steam generators) Project #13-40632, Unit 6 – approximately \$12M, 2 months, 65 Rem (12 steam generators)

This BCS covers the funding required for the development, qualification and testing of the new design along with field installation. This project will focus on locking tab replacement (currently installed sealing skins will be retained), and minimizing cost, time, and dose during execution. There are no plans to replace the locking tabs units 5 and 6 as they are evaluated to be operational to EOL.



## 3/ ALTERNATIVES AND ECONOMIC ANALYSIS

Based on the fact that cold leg locking tabs will not fail prior to 6.3 Effective Full Power Years (EFPYs), we have several options for scheduling the installation work. The following analysis examines the impact of various options based on 40 days outages and planned Water Lancing for Units 7 and 8.

<b>\$</b> Millions	Status Quo		ommended) in 2008 / 2010	Alt 2 Old Design	Alt 3 New Design	Alt 4 New Design	Alt 5 New Design
	CIBINO CION	Full Cost	Incremental Cost	in 2008 / 2010	in 2008	in 2010	in .
SG's / Outages / Critical Path					LONG	2010	2008/2010
P871	0	12	12	6	10		
P881	0		·	6	12		6
P1071	0				12		6
P1081	0	12	10	6		12	6
			12	6		12	6
Waterlancing in Outage	N/A	2008 (U8)	2008 (U8)	2010 (U8)	2010 (U8)	2010 (U8)	2010 (U8)
		2010 (U7)	2010 (U7)	2010 (U7)	2010 (U7)	2010 (U7)	2010 (U7)
Variance to Critical Path (1 outage)	N/A	-2-2	-2-2	+7+7+13+13	-2-2	+11+11	-2-2+4+4

Financials	11		T	T	1	T	·
Loss of Revenue	(1,532.2)	0.0	0.0	(22.5)	0.0	(10.0)	
roject Cost	0.0	(20.5)	(20.5)	(25.9)	(20.2)	(12.0)	(4.4)
, PV (after tax)	(656.9)	(11.9)	(11.9)	(26.8)	the second second second second second second second second second second second second second second second se	(20.2)	(20.5)
Financial Benefit (vs Status Quo)	N/A	645.0	645.0	630.1	(12.0) 644.9	(16.8)	(13.7)
IRR%	N/A	251.3	251.3	1.8		640.1	643.2
Discounted Payback (Yrs)	N/A	3.5	3.5	4.1	190.5	440.6	2.4
Ranking of Financial Benefits	6	t	1	4.1	3.7	3.4	3.6
ritaring of t indicial Deficitio	<u> </u>		1	4	2	5	

Business Objectives		T	1	1	1	1	·····
Fits Current Generation Plan	No	No	No	No	No		<u></u>
Allows operation beyond 6.3 EFPYs	No	Yes	Yes	Yes	Yes	No	Yes
Allows operation to EOL	No	Yes	Yes	Yes	Yes	Yes	Yes
Aligns with 85/5 initiative	No	Yes	Yes	No	Yes	Yes	Yes
40% dose reduction	No	Yes	Yes	No	Yes	No	No
Benefit of new design	No	Yes	Yes	No		Yes	Yes
Coo Alterration 4			100	INC	Yes	Yes	Yes

*See Alternative 1 description.

#### Status Quo - Not Recommended

Status Quo is **not** the recommended option. This alternative is unacceptable because we would have to shut down both units with revenue losses accruing to approximately \$1.5 Billion from the end of 6.3 EFPYs to EOL.

## Alternative 1 - Install 12 "New Design" Tabs in Unit 7 in 2008, 12 in Unit 8 in 2010 - Recommended

We recommend this alternative because it satisfies the Business Objectives and provides the greatest financial benefit (when measured against the Status Quo). This alternative minimizes the risk of an outage extension by roiding concurrent Water Lancing and Locking Tab repair in the same outage. The recommendation is to vance Unit 8 Water Lancing by 2 years to 2008, install all Unit 7 Locking Tabs in 2008 and all Unit 8 Locking into the Generation Plan. Moving Unit 8 Water Lancing to 2008 is also supported by EMD due to the poor condition of Unit 8 SGs in terms of sludge build-up.



Page: 6 of 18

**BUSINESS CASE SUMMARY** 

# Alternative 2 - Install Unit 5 and 6 Design Locking Tabs in Units 7 & 8- Not Recommended

We do **not** recommend this alternative because it doesn't satisfy the Business Objectives and provides the least financial benefit. This alternative is the contingency alternative should the new design not meet expectations.

## Alternative 3 - Install 12 "New Design" Locking Tabs in Units 7 & 8 in 2008 - Not Recommended

Although this alternative meets the Business Objectives, we do not recommend it because there are increased schedule risks in completing both units in 2008. Moreover, the financial benefit is marginally less than the Recommended alternative.

# Alternative 4 – Install 12 "New Design" Locking Tabs in Units 7 and 8 in 2010 - Not Recommended

We do **not** recommend this alternative because it doesn't align with the 85/5 initiative and provides only the 4th best financial benefit because of the outage extension. Moreover, leaving all Locking Tab installation until 2010 does not provide sufficient time to recover from unknown problems, without unfavourable financial impact.

# Alternative 5 - Install "New Design" in 6 SGs per U7 & U8 in 2008, remainder in 2010 - Not Recommended

his is the current Generation Plan. We do not recommend this alternative because it has higher risk of extending the Outages than Recommended Alternative and provides only the 3rd best financial benefit.



## 4/ THE PROPOSAL

We propose a full release (as opposed to a developmental) at this time because:

- There is little or no risk that this project will be cancelled and the investment subsequently lost 0
- Major contracts need to be awarded by October 2007 in preparation for the Unit 7 Fall Outage in 2008 0
- o Conceptual funding allowed us to determined the most technically viable and cost effective design from a number of locking tab replacement options 0
- An extensive risk profile with mitigating actions has been developed to reduce the overall risk to low
- We have considerable experience in locking tab design and installation; however, a been included to address the risk associated with designing, qualifying and installing a new design or defaulting to the Unit 5/6 design in the remote chance that the new design is ineffective and/or cost
- A Full Release will be used to:
  - Complete the Design 100%
  - Perform the Preliminary and Detailed Engineering
  - Award a labour contract (for both units)
  - Perform all pre-installation activities for Unit 7 (i.e. workplan preparation, work permits, space allocation,
  - Install, commission, and AFS the modification for Unit 7 (P871)
  - Revise Design Engineering documents as required (i.e. Design ECs, drawings, etc.) for Unit 8
  - Complete pre-installation activities for Unit 8
  - Install, Commission, and AFS the modification for Unit 8 (P1081)
  - Close-out the Project

Refer to Appendix C for a list of the project milestones.

## 5/ QUALITATIVE FACTORS

None other than outlined in the Business Objectives.



		Medium Medium Medium	Regular review of project expenditures. Regular review of project expenditures. Contingency available. If scope growth too large, design installed in Units 5 and 6 is ready and available to be installed in Units 7 and 8. And 8. And 8. And 10. A SGs contingency available.	Low Low
All SGs of Scope als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als let als l			Regular review of project expenditures. Contingency available. If scope growth too large, design installed in Units 5 and 6 is ready and available to be installed in Units 7 and 8. For contingency available.	Low
ted Sope			Regular review of project expenditures. contingency available. If scope growth too large, design installed in Units 5 and 6 is ready and available to be installed in Units 7 and 8. contingency available.	Low
ed S			Regular review of project expenditures. Contingency available. If scope growth too large, design installed in Units 5 and 6 is ready and available to be installed in Units 7 and 8. Contingency available.	Low
ted S be			If scope growth too large, design installed in Units 5 and 6 is ready and available to be installed in Units 7 and 8. Contingency available. pontingency available.	Tow .
ted s be			If scope growth too large, design installed in Units 5 and 6 is ready and available to be installed in Units 7 and 8. Contingency available. pontingency available.	Low
ted 20 solo			If scope growth too large, design installed in Units 5 and 6 is ready and available to be installed in Units 7 and 8. contingency available. Inspections have been conducted on 6.5Gs	Low
s p	 ! ד		inspections have been conducted on 6 SGs	
ted				
			each of Unit 7 and 8 in 2006 and have no i unexpected findings. Similar conditions are	2 2 1
	)     	- +	ected on the rema	
	· /.		SG internals will be protected during installation to preclude damage. Qualification testing as well as mock-up	Low
Schedule			basis	
Itaining required	and the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second			
materials for qualification testing.		Medium	Materials required for qualification testing have been identified. Some materials have	Low
Delay in completion of Design Schedule overnin		- + !	arready been obtained, and the remainder will be ordered promptly.	
	<b>2</b>	Medium	ces will be obtained idlines. There is project schedule to ays with no impact	LOW

ON R. RIO GENERATION

8 **of** 18

Page:

ON RINF WWW	DPG Confidentia			
	N	S CASE	`	}
Extensive amount of welding rework during execution.	Increase in Outage critical path.		Qualification testing will be conducted to ensure limited access welds can be completed to meet acceptance criteria.	row.
Resources Design Engineering resources re-allocated to higher priority projects.	÷	Medium	Design support has been committed to this project.	Low
Lack of qualifiedTrades to perform qualification testing due to conflict with P751 Outae.	Delay in qualification testing potentially leading to a delay in Design deliverables.	Medium	Trades will be acquired as soon as the qualification plan has been agreed upon.	Low
Technical				
option does not replacement option does not satisfy all contructability objectives	Constructability issues may impact design	чбін	Qualification testing will be done to ensure constructability issues are addressed and eliminated through completion of design	Low
		Low		Low
Regulatory				
regulator may not approve the re-start submissions of Unit 7 and 8.	Unable to restart Unit 7 and 8.	Medium	Re-start submissions have been approved for Units 5 and 6 for similar modifications.	Low
Environmental				
X,A				
Health & Safety				
events during qualification and site execution due to several conventional and radiological	Injuries to personnel involved in qualification testing and installation.	Medium	Pre-job briefings will be conducted prior to commencement of qualification testing and during installation. Boiler bowls will be surveyed and cleaned if required and cleaned if	Low

影響ができっていまし	OPG Confidential	ai	Page: 10 of 18	
UENEKA	I I UN BUSINE	BUSINESS CASE SUMMARY	ARY	
hazards,			shielding will be installed prior to personnel entries. All personnel involved will be required to wear appropriate PPE. Review Lessons Learned from previous campaigns	
Investment The current requirement to				
shut down Unit 7 and Unit 8 after 6.3 (EFPYs) is not adequately addressed	hinher cost		Locking Tab replacement option will be designed with a substantial amount of rigour.	and the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second se
The overall project cost and dose uptake largets are not achieved The installation is not aligned with the 85/5 principles. The new design inteferes with	higher dose uptake extended schedule outage extension	Medium	Qualification Program will be conducted to ensure that the new locking device can meet these project objectives.and ensure that the Locking Tab replacement option is robust and will not become Foreign Material.	· ·····
inspection / maintenance activities Future Locking Tab prohlams		[	Results of qualification testing will be used to alter the design of the new locking device as	Γοκ
prevent the operation of the	new project required to repair units		required.	
The new design does not allow for easy removal and or	possible forced outage higher costs	Medium	The Unit 5/6 design is available if this design proves to be too costly or not effective	_
Premature failure of condition			contingency is included	
locking tabs currently installed.	installation of the new design or	Low	Analysis has been completed for the current design with a safety factor of 2 and locking tabs are not expected to fail prior to 6.3 EFPYs.	Low
	Repair of Units 7 and 8 with old design (installed in Units 5 and 6).		Contingency Divider Plate sealing skin sets (12 in total) of the current design are on site	
	Both of these repairs would significantly impact schedule and costs.		and available to be used for an emergent repair campaign.	
			provide sufficient funding in the remote chance that the Unit 5/6 design is required	"



1-

-----

OPG Confidential

Page: 11 of 18

**BUSINESS CASE SUMMARY** 



1022

BUSINESS CASE SUMMARY

## 7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Final AFS	Targeted PIR Approval	PIR Responsibility
	Date:	Date:	(Sponsor Title)
Simplified	Jan 2011	Feb 2015	Components & Equipment

## Comments:

	Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it?
1.	Durability of Steam Generator divider plate fastener locking device	Unit 7 and 8 Boilers were found with several broken locking tabs	Divider plate locking device to remain intact until end of SG life.	Perform as-found inspections during the first and second planned outages subsequent to installation of the locking devices. Each steam generator must be inspected to confirm the Divider plate assembly is intact.	(person / group) Major Components Section, Components and Equipment Department
2.		÷			··· ··· ··· · <u>·</u> ·· · ·· ·
3.	··· " ·· · · · · · · · · · · · · · · ·		••••••••••••••	·····	
4.			···· ·· ··· ··· ··· ···		·····
5.		· ··- ·· ··- »·· •		· · · · · · · · · · · · · · · · · · ·	· ·· ··

Page: 13 of 18

#### **BUSINESS CASE SUMMARY**

## Appendix "A"

Glossary (acronyms, codes, technical terms)

- AFS: Available for Service
- CNE: Chief Nuclear Engineer
- CNSC: Canadian Nuclear Safety Commission
- EC: Engineering Change
- EFPY: Effective Full Power Year
- EOL: End of Life
- HTS: Heat Transport System
- NPV: Net Present Value
- RIHT: Reactor Inlet Header Temperature
- PNGS: Pickering Nuclear Generating Station
- PROL: Power Reactor Operating License
- SG: Steam Generator
- SMB: Site Management Board
- TOE: Technical Operability Evaluation
- Safety Factor of 2: In analyzing the operational life of the locking tabs, the largest crack size was used to account for the worst condition. This crack size was then multiplied by a safety factor of 2 in the model to predict the tab life.





Appendix "B"

## Project Funding History

\$ 000's				Releases	(incl cont ulative Va	tingency) dues					
Release Type	Month	Year	2006	2007	2008	2009	2010	2011	2012	Later	Total
Full	Nov	2006		13,326	3,148	0	3,990	61			20,525
			0								0
											0
			: 							- /、	0
								(			0
											0
											0
											0
LTD Spent	Nov	2,006	0		ì						0

#### Comments:

There have been no releases for this project to date as currently, conceptual funding is being used to perform preliminary work. A Full Release will be used to complete 100% design, installation, commissioning and AFS of the modification for Units 7 and 8 as well as the project close out. This approach will enable funding for early tender and award of installation contract.

<b>ONTARIO</b>	POWER
	GENERATION

Appendix "C"

## Financial Model – Assumptions

#### **Project Cost Assumptions:**

For the majority of engineering and design work, overtime has been assumed to be 10%. For field personnel, overtime has been assumed to be 25%. Installation estimate is based on Unit 5 and 6 experiences with assumed installation benefits for new design.

It is assumed that the Locking Tab replacement modification will be conducted over 2 outages as follows:

- Unit 7 during Fall 2008
- Unit 8 during Spring 2010

#### **Financial Assumptions:**

The rate of inflation estimated at 2% is consistent with Corporate guidelines.

## Project / Station End of Life Assumptions:

Based on a memo to D. Power from J.P. Froats, "Pickering Units 5, 6, 7, and 8 End of Service Life Predictions", May 10, 2006, we have assumed that End of Life for Units 7 and 8 will be 1st quarter 2014 and 1st quarter 2016 respectively.

#### Energy Price / Production Assumptions

The price of energy is estimated based on Corporate System Economic Values. Production from each Pickering B unit is assumed to be 516 MW at a capacity factor of 85%.

#### **Operating Cost Assumptions**

N/A

#### Other Assumptions:

The cold leg locking tabs are expected to fail after 6.3 EFPYs which is assumed to be:

- Unit 7: September 2011
- Unit 8: October 2010

Repairs to Units 7 and 8 can be postponed until September 2011 and October 2010 respectively because a Fitness for Service Evaluation of cracked hot leg locking tabs concluded that cold leg locking tabs will not fail prior to 6.3 Effective Full Power Years (EFPYs) and failure of hot leg locking tabs is not an operability issue. This analysis is based on a safety factor of 2.

## ONTARIO POWER GENERATION

Page: 16 of 18

**BUSINESS CASE SUMMARY** 

## Pickering B Steam Generator Locking Tab Replacement 13 - 40641

## Full Release Business Case Summary NK30-BCS-33115-00007-R000

## Attachment "A"

## Project Cost Summary

\$000's OM&A	LTD Prior Yr 2005	This Release 2007	This Release 2008	This Release 2009	This Release 2010	This Release 2011		Later	Total
Project Management (OPG)	**	241	223	280	318	163	2		1,225
Engineering & Drafting (OPG)	-	118	40	10	37	- 25			229
Material					-			1	1
Installation - PWU, BTU		1000	and the second	A COL					
Contract - Design		-					SET MESS		
Contract - Installation	1			SPATE PRO		State Date	STATISTICS.	ALC: NO	
Contract - Other		President Mart	an other star	-	THORNE A		-		
nstallation - IMS		er (hain) ag		N. 20	a say	22.53			
nterest (Capital Project Only)					নালন নালনালন			all a look and a	
Project Costs (excl contingency)					Contraction of the local division of the loc	Contraction of the	Contract of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local division of the local		
General Contingency		_							
Specific Contingency									
Project Costs ( incl contingency)		626	9,448	526	9.664	261	······	1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1	20,525
2007-2011 Business Plan		700	6,300	1,000	6,000				14,000
/ariance to Business Plan	Part Star								-
Committed Cost	1	12,700	(6,300)	(1,000)	(5,400)				
nventory Write Off Required	+	·····							
pare Parts / Inventory					· = /~~/~~~	<b></b>	, <u></u> ,		
otal Release (excl contingency)						í		·····	
otal Release (incl contingency)	j	13,326	3,148	(474)	4,264	261			20,525
Ingoing OM&A (non-project)									

Design Complete	100%		Quality of E	Estimate	Budget + 30% to - 15%	
3 rd Party Estimate	N/A	OPEX used	Yes	Lessons Le	arned	Yes
Reviewed by Sponsor	N/A	Budgetary Quote(s)	No	Phase 1 Ac	tual Used	N/A
Similar Projects	Yes	Contracts in place	No	Competitive		N/A

Variance to Business Plan

The estimated variance(s) to the 2007-2011 Business Plan will be addressed through the portfolio management process. A PCRAF will be approved by Jan 2007.

Reviewed By Jan 26/07

Approved B 26 Jan 07 J. Keto

P. Asganpour 'roject Manader

Date:

J. Keto Eng & Mods Manager (Strat :V)

Date:



## Pickering B Steam Generator Locking Tab Replacement 13 - 40641

## Full Release Business Case Summary NK30-BCS-33115-00007-R000

## Attachment "B"

## Project Variance Analysis

	Total P	roject		
Омба	Units 5 and 6	Units 788	Variance	Comments
Project Management (OPG)	824	1,225	401	Additional cost due to longer project duration - 4 years instead of 2 years for Units 5 and 6.
Engineering & Drafting (OPG)	529	229	(301)	Poplacement of forter or only Market in the
Material				skins is required.
Installation - OPG Support				an it successives we apply strangeners and we apply the
Contract - Design				
Contract - Installation				
linetrics				
Contract - Other		10.000	a ministry and	A SURVICE A SURVEY A CATOR AL CONCEPTION
Installation - IMS			1. AP 1949:	THE SEA IN A DRIVENING AND AND AND AND AND AND AND AND AND AND
Sub Total				
Foreign Material Unit 6				
BARC/Open/ Close			- State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State State Stat	
Init 7 & 8 contingency				
roject Costs (excl contingency)	- Contraction in the			
ieneral Contingency				
pecific Contingency			//	₩ ₩
roject Costs (incl contingency)	26,234	20,525	(5,709)	

This project was identified in March 2006. Currently, conceptual funding is being used to start the Design work and prepare the Full Release BCS.

**ONTARIO** GENERATION

**BUSINESS CASE SUMMARY** 

Attachment "C"

## Key Milestones

Co	mpletion	Date	
Day	Mth	Yr	
28	Feb	2007	FR1: Full Release BCS Approved
15	Mar	2007	IDR: Design Requirements Approved and Issued
13	Oct	2007	FD1: Final Design Complete (Unit 7)
01		+	DCP: Design Permanent Mods Documents Issued
01	Nov	2007	MCA: Major Contracts Awarded (2 Units)
20	Sep	2008	SOI: Start of Installation (Unit 7)
15	Dec	2008	AFS: Available for Service Meeting (Unit 7)
01	Feb	2009	FD2: Final Design Complete (Unit 8) DCP: Design Permanent Mods Documents Issued
15	Feb	2010	SOI: Start of Installation (Unit 8)
15	May	2010	AFS: Available for Service Meeting (Unit 8)
15	Feb	2011	PCS: Close-out Starts
31	Aug	2011	PCM: Plan Complete Milestone
	l	L	

A Project Execution Plan (PEP) will be approved by May 2007

## Comments:

Il outage milestones will comply with N-PROC-MA-0013 Revision 5B (Planned Outage Management).

ONTARIO GENERATION

BUSINESS CASE SUMMARY

# Pickering B Steam Generator Maintenance Waterlancing 13 - 40645

## Full Release Business Case Summary NK30-BCS-36340-00004-R000

Routing	Location	Action	Signature	Data
J. Xiao Project Leader (Acting), Boiler Projects 701-8649	P72-3	Prepare BCS	TAU	Date April, 2, 2a
P. Asgaripour Project Manager (Acting), Boiler Project 701-4680	P72-3	Review BCS	1 Aspa	APR 3/200
G. Kotwa Section Mgr. Process Scheduling 701 - 3755	P72-1	Review BCS	Jary apro-	April 10/20
G. Keto Manager, Boiler Projects 701 - 2568	P72-3	Review BCS	Carry / Sete	10 Apr 07
B: Morrill M. W. SHAMAHAW Manager, Comp. & Equipment 701-4926	P41-E3	Review BCS	M.U.Shancha_	
M. Arnone Director Projects & Mods 701-6063	P71-1	Review BCS	22 - e	2017 06-1, HAPRIL 2007
R. Ball Senior Financial Analyst 2 - 4084	P82-3	Review BCS	$\int$	12 Cepro
			- 9 /	Theyno
			ECEIVE by P. R. Charleboas	3
			VA1 2-2 (200)	
			27-25	
			an an an an an an an an an an an an an a	
		V - A - N - MARINE - M		
Ball níor Financial Analyst -4084	P82-3B6	Return For Distribution		

ONTARIO GENERATION

Page: 2 of 16

BUSINESS CASE SUMMARY

## Pickering B Steam Generator Maintenance Waterlancing 13 - 40645

## Full Business Case Summary NK30-BCS-36340-00004-R000

Routing	Location	Action	Signature	
R. Leavitt			Signature	Date
Director Investment Management 702-5085	P82-3	Review BCS	Real	April 12, 2017
P. Tremblay Senior Vice President Pickering B 701-3501	P41-E3	Review BCS	Pr Julay	Aportis
J. Beech VP Nuclear Finance 400-7276	H9-F26	Review BCS	DICS	1 1 1
T. Mitchell EVP and CNO 702-5294	P82-6	Submit BCS	La Da.	A. 16/07
D. Power O Director Investment & Business Planning 400-7172	H7-D06	Approve BCS	Der	Ouiled
P. Charlebois EVP & Chief Operating Officer	H19-A21	Review BCS	5	m 12/07
D. Hanbidge S.V.P & C.F.O.	H19-F27	Review BCS	DAthof	No yoy
Hankinson President & CEO 400-2121	H19-A24	Approve BCS	Attana m-	21/5
Ball nior Financial Analyst -4084	P82-3B6	Return For Distribution		

Page: 3 of 16

GENERATION

BUSINESS CASE SUMMARY

## Pickering B Steam Generator Maintenance Waterlancing 13 - 40645

#### Full Release Business Case Summary NK30-BCS-36340-00004-R000 **RECOMMENDATION:** 1/

We recommend a Full Release of \$25M (including contingency) to complete Water Lancing on all four Pickering B units from 2008 to 2010 as recommended in the Steam Generators Life Cycle Management Plan (LCMP) (NK30-PLAN-33110-10008), and the Steam Generator Investment Review (30 May 2006) (N-REP-33110-10018)

The business objectives of this project is to:

ONTARIOPOWER

- Reduce / eliminate the risk of forced outages due to tube leaks caused by sludge build up.
- Reduce/eliminate the need for future Chemical Cleaning campaigns •
- Maintain critical assets until units end-of-life

Under-deposit pitting due to sludge build-up is one of the main failure mechanisms causing tube leaks in the steam generators. A multifunctional Steam Generator Review team recently completed a study of this type of failure and came to

- A Fitness for Service strategy of inspecting and plugging of tubes will allow us to operate all units until their current End of ٠ Life dates; however, this strategy will lead to a deteriorating and perhaps irreversible SG performance that will result in a large financial penalty and likely loss of regulatory credibility.
- The current Life Cycle Plan involving Water Lancing every four years will substantially reduce the likelihood of forced outages (under a Fitness for Service strategy) and will therefore provide a significant financial benefit.
- Other variations of the current LCP such as targeted and enhanced Water Lancing may provide marginally greater value but cost more and involve greater risk.

Changes in this strategy should be considered if End of Life, Forced Loss Rate, and Planned Outage projections change

Based on the recommendations of this study we are therefore requesting approval of a Full Release of \$25M to conduct Water Lancing on each PB unit from 2008 to 2010. Should further analysis or more definitive refurbishment / EOL dates suggest there is more value in an alternative strategy, we will submit a superseding BCS outlining the opportunities and risks.

\$000's (Incl contingency)	Funding	LTD 2006	2007	2000	·				
Currently Released	N/A	<u></u>		2000	2009	2010	2011	Later	Total
Requested Now	Full								· · · · · · · · · · ·
Future Funding Reg'd	1 Gh		486	6,318	11,487	6,287	395	+	24,973
Total Project Costs					i				
Other Costs			486	6,318	11,487	6,287	395	•	24,973
Ongoing Costs									•
Grand Total		······································	486	010		·			
Investment T	ype	Cla	400	6,318	11,487	6,287	395	-	24,973
Sustaining		OM	8A	(IEV) Impact 38.9		IRF		Discounter	I Payback
Submitted By:	5				and the second second	N/A		N.	A

Submitted By

P. Tremblay Date: Senior Vice President Pickering B

Finance Approval:

Power Date:

Line Approval (Per OAR Element 1.1 Project in Budget):

Wintersul 2116 J. Hankins Date: President & CEO

Director Investment & Business Planning

ONTA	RIO	PO	Ŵ	ĒR
h.		GENI	ERAT	TION

Page: 4 of 16

BUSINESS CASE SUMMARY

## 2/ BACKGROUND & ISSUES

The historic operating trends for Pickering B SGs have shown a correlation between the tube leak and intervals between chemical cleaning and Water Lancing. The historical data illustrate absence of tube leaks for several operating years after completion of effective cleaning campaigns followed by escalation in the frequency of tube leaks in the hot leg tube sheet region. The chief mechanism for this phenomenon is known to be under-deposit pitting corrosion. Effective Water Lancing is a cost effective method (as opposed to chemical clean) to remove accumulated sludge during operating intervals to mitigate under deposit pitting.

According to studies, the sludge piles that form in the SGs are generally "kidney shaped" piles with the peak located near the center of the hot leg bundle. Over time the peak heights increase and the pile spreads outwards the periphery and the No Tube Lane (NTL) of the SGs. In a short time, the central tubes are covered with sludge and are at higher risk. The current LCMP calls for Water Lancing every four years at a minimum to reduce the corrosive environment created by sludge piles.

New improvements made to Water Lancing system and inspection equipment have produced favorable results in recent campaigns (2005-2006). This was achieved through the development of Inter tube flushing lance for the removal of sludge in the shadow areas and improved inspection strips for cleaning assessment respectively. Implementation of different strategies and better understanding of sludge profile has provided valuable information to produce enhanced results as the process will be customized to the unit conditions. The expected window for Water Lancing during a 40 day outage is expected to be approximately 17 days. In the bidding process vendors will be requested to demonstrate their ability to produce maximum results during this fixed period. Assessment of endors cleaning capabilities along with cost will be used as selection criteria.

A multidisciplinary team comprised of engineers, operating, maintenance, and financial expertise was asked to review the Steam Generator (SG) Life Cycle Management (LCM) strategy for Pickering B (PB) in order to produce a report that summarized investment options, costs, and risks to OPG. The objective was to provide sufficient information as input to the 2006 Business Plan and to unit refurbishment decisions.

ONTARIC	POWER
2	GENERATION

Page: 5 of 16

BUSINESS CASE SUMMARY

## 3/ ALTERNATIVES AND ECONOMIC ANALYSIS

S Millions Revenue	Base Case FFS Inspect/Plug All SGs every 2.5 yrs	Alt 1 Recommend Std. W / L All SGs every 4 yrs	Alt 2 Targeted Enhanced W/L only Bad SGs every 2 yrs	Alt 3 Enhanced W/L All SGs every 2 yrs	Alt 4 FFS Inspect/Plug All SGs every yr
OM&A				······································	j
Capital					
NPV (after tax)	-52.8	-13.9	-18.7	05.0	
Impact on Economic Value (IEV)	N/A	38.9	34.1	-35.2 17.6	-156.6

## Note: All NPV calculations are based on executing the strategy being measured to EOL

# Base Case: Fitness for Service (Minimum Inspection/Plugging every 2.5 years) - Not Recommended

The Base Case involves:

- minimum inspection / plugging to satisfy Fitness for Service requirements for a 2.5 year operating interval.
- No water lancing

We do not recommend the Base Case because, the multidisciplinary team concluded, in July 2006, that this strategy will allow us to operate all units until their current End of Life dates; however, it will lead to a deteriorating and perhaps irreversible SG performance that will result in a large financial penalty and likely loss of regulatory credibility.

## Alternative 1 – Water Lancing ever four years (Current LCMP - Recommended

The recommendation involves:

- Standard inspection/plugging every 2 years
- Standard water lancing on all 12 SGs every 4 years

The conclusion of the team (July 2006) was that the current LCMP involving Water Lancing every four years is a sound strategy and should be followed. Although their analysis indicates that other strategies (namely targeted and enhanced Water Lancing) would generate marginally greater value, they cost more and involve greater risk. They also recommended that this strategy be reviewed should there be any change in End of Life, Forced Loss Rates or Planned Outage projections

## Alternative 2 - Specific (Targeted) S.G. Life Cycle Management Plan - Not Recommended

This option involves:

- enhanced inspection/plugging (every 2 years) on "bad" steam generators
- enhanced water lancing on only "bad". SGs every two years

We do not recommend this strategy as it creates less value, the cost is higher and the risks are greater than the LCMP

## Alternative 3 – Enhanced S.G. Life Cycle Management Plan - Not Recommended

This option involves:

- enhanced inspection/plugging every 2 years (per LCMP)
- enhanced water lancing on all 12 SGs every two years

e do not recommend this strategy as it creates less value, the cost is higher and the risks are greater than the LCMP

This strategy involves:

- minimum inspection / plugging to satisfy Fitness for Service requirements for a 1 year operating interval.
- No water lancing

This strategy is not recommended because it adds about 40 planned outage days per year (2 more outages per year). There is a risk regarding our capability to plan and resource 4 outages per year







## BUSINESS CASE SUMMARY

## 4/ THE PROPOSAL

- Initiate a competitive bidding process in preparation of Water Lancing in planned outages in 2008-2010 for . all Pickering B units. This may include but not limited to development of mock-up, on boiler equipment, sludge removal tool, qualification testing, new lancing flow diagram and registration.
- Assess vendor's proposal based on meeting acceptance criteria as outlined in the LCMP and award •
- Ensure all required materials/equipment and procedures are available for execution per outage milestones ٠
- Ensure contractor is adequately trained for working at OPG nuclear sites •
- Achieve Water Lancing cleaning results per EMD proposed scope ٠ •
- Complete Water Lancing within the allotted budget and the Outage schedule

The requested amount of \$25M is based on the estimated contracted cost and staffing levels required during preparation, execution and restoration phases of the previous Water Lancing campaigns. The validity of assumptions used for this estimate are confirmed using most recent Water Lancing campaigns (P681 and P671)



## 5/ QUALITATIVE FACTORS

None other than stated in the Business Objectives.



ONTA...OROWIER GENERATION

OPG Confidential

8 of 16

Page:

BUSINESS CASE SUMMARY

# 6/ RISKS

Description of Risk	Description of Consequence	Risk Before Mitigation	Mitigating Activity	Risk After Mitigation
Unexpected difficulties in equipment/flow diagram development and registration	Cost overrun	HgiH	Monitoring and tracking contractor's preparation activities by OPG Projects	Wedium
Scope Unable to complete scope during a fixed outage window	Inadequate tubesheet cleaning and increased risk of under deposit pitting as a result,during the operation	High	Water lancing strategy will be customized to unit condition to maximize the effectiveness. Lessons learned from previous campaigns will be reviewed for improvements	Medium
Schedule Contract not awarded per				
P881 Outage Milestone due to the 2 year advancement of Unit 8 campaign and lack of funding	for P881 and delay in vendor's deliverables.	łĝ	Boiler Projects staff will work closely with finance to ensure adequate funding is available to initiate a RFP for competitive bidding and award the contract in a timely	Low
Station caused delays	Delay in Waterlancing onsite activities	66 1H	manner for P881 execution. Delays in Waterlancing schedule due to unforeseen station issues will be documented and communicated to outage management and recovery plans will be jointly developed. Review lessons learned from previous campaigns and improve alignment and awareness from station	Гом
Defay in registration of Waterlancing process system (if new)	Unable to register and accept the new Waterlancing system	ЧĜН	vill revie vendor's rea n, and if necessary t unit execution (usi and competitively t its	Low

<b>CWLR</b> ENERATION	
ONTARIOF	

OPG Confidential Page: 9 of 16



GENERATION		BUSINESS CASE SUMMARY	ßY	
Resources				فيانيك الروقيا والمتداولين الأمراني والمناري
Lack of skilled trades and technicians	Unfamiliarity with Waterlancing process and working at nuclear sites, compromising quality and schedule.	Medium	Contract will be awarded to allow sufficient time for staff training	Low
Failure of qualification testing (if new system)	Insufficient cleaning due to modification of process parameters	Medium	qualification to ensure	Low
Site execution issues	Contractor work practices impacting equipment condition and outage duration	ųĝi	Process is qualified and effective Management expectations will be rolled out 1 to contractor prior to site execution to ensure event free tools are effectively practiced	Low
Regulatory No significant regulatory risks are expected.				
Environmental Spill due to hose rupture or fitting failure	Unplanned release of radionuclide through lancing waste water or breach of containment	Medium	These concerns will be considered during L design phase of the system and accepted by OPG prior to site execution	Low
High pressure water jets and spread of contamination	Personnel injury. Unplanned dose uptake	Medium	Use of mock up for training and L implementing procedural barriers	
Investment No significant risk is expected				



**BUSINESS CASE SUMMARY** 

## 7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Final AFS Date:	Targeted PIR Approval Date:	PIR Responsibility (Sponsor Title)
Simplified	Dec 2010	Jun 2011	Manager Pickering B Components and
		······································	Equipment Department

## Comments:

Tre al	Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it?
1.	Cleaning effectiveness	Post water lancing results form previous campaigns	Removal of soft sludge snd returning SGs to post Waterlancing conditions of previous campaigns between 2005 and 2006	Visual inspection of pre and post Waterlancing of the same SG	(person / group) Engineering Mechanics Department and IMS
2.	Tube pitting indications	Results from previous inspection	Comparable to recent histotrical data	Eddy Current inspection per the SG LCMP	Engineering Mechanics Department and
3.				······································	IMS
<b>i.</b>	·		· ···· · · · · · · · · · · · · · · · ·		
		/ / /			



Page: 11 of 16

BUSINESS CASE SUMMARY

## Appendix "A"

Glossary (acronyms, codes, technical terms)

EOL: End of Life LCMP: (Pickering B Steam Generator) Life Cycle Management Plan NTL: No Tube Lane SG: Steam Generator SMB: Site Management Board



Page: 12 of 16

BUSINESS CASE SUMMARY

Appendix "B"

## **Project Funding History**

\$ 000's				ind Plann Cum	ed Releas ulative Va	ses (incl ) ilues	continger	icy)			
Release Type	Month	Year	2006	2007	2008	2009	2010	2011	2012	Later	Total
Full		·•·	· · · · -	486	6.318	11,487	6.287	395			24,973
			" - ·· · ·				4		,		0
		• • • •	· · · · · · · · · · ·							1	0
		· · · · ·			· · · ·		·· ···· - · ·		",		0
			÷								0
					ļ						0
	I				~~						0
	···					]					0
LTD Spent	·		· · · · · · · · · · · ·	····· · · · · · · · · · · · · · · · ·	ſ	ľ					
cro opent		···· · · · ·	· · · · · · · · · · · · · · · · · · ·								0

#### Comments:



Page: 13 of 16

BUSINESS CASE SUMMARY

## Appendix "C"

## Financial Model – Assumptions

See the Pickering B Steam Generator Investment Review N-REP-33110-10018 (Sections 5)

Page: 14 of 16

BUSINESS CASE SUMMARY

# Pickering B Steam Generator Maintenance Waterlancing 13 - 40645

# Full Release Business Case Summary NK30-BCS-36340-00004-R000

## Attachment "A"

ONTARIOPOWER GENERATION

## Project Cost Summary

\$000's OM&A	LTD Prior Yr	This Release 2007	This Release 2008	This Release 2009	This Release 2010	This Release 2011	Future Release	Later	
Project Management (OPG)		314	314	392	314	235	· · · · · · · · · · · · · · · · · · ·	Later	Total
Engineering & Drafting (OPG)		20	40	20	10	8			1,569
Material	1				C. Second	·		· · · · · · · · · · · · · · · · · · ·	98
Installation - PWU, BTU	a construction		and the						
Contract - Design			15 Second		NURALIN	distant.			
Contract - Installation			- Applications						
Contract - Other			in an	age og vere Sindersøre dag				ALL ST ST	
Interest (Capital Project Only)			0.335		1.40				
Project Costs (and contingency)	-							Non-	
General Contingency									
Specific Contingency	-			Constanting de	distant -				-
Project Costs ( Incl contingency)		486	6.040						
200-2010 Business Plan	1764	400	6,318	11,487	6,287	395	<u></u>		24,973
ariance to Business Plan	0.001		1.000	11,000	12,000				24,000
Committed Cost	<u></u>	10.107							
ventory Write Off Required		18,197	(4,677)	(8,843)	(4,677)				+
pare Parts / Inventory									
otal Release (excl contingency)									
otal Release (incl contingency)					_			,	
oral melease (mci conungency)	, A	18,683	1,641	2,644	1,610	395		100	24,973
ingoing OM&A (non-project)				1					-4,313
emoval Costs (incl in above)				2-2-2-4 1 4-1 2-2-2-4	1. 1. 1. 1. E.	Sterio (	Scotland H	1.5.72	
a and a second of the second second second second second second second second second second second second second	A Star .			2291212		· · · · · ·	1224	12257	

Design Complete		N/A Basis of E	Quality of E	The Alignet Hard State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the State of the S		
3 rd Party Estimate	No	OPEX used			Release + 1	5% to - 10%
Reviewed by Sponsor	Yes	Budgetary Quote(s)	Yes	Lessons Lea		Yes
imilar Projects	Yes	· · · · · · · · · · · · · · · · · · ·	No	Phase 1 Acto	ual Used	Yes
and the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second sec	103	Contracts in place Variance to But	No	Competitive	Bid	Yes

The estimated variance(s) to the 2006-2010 Business Plan will be addressed through the portfolio management process. A PCRAF will be approved by Apr 2007.

Reviewed By: 10 APR / 2007 P. Asgaripour

Approved By J. Keto

Eng & Mods Manager (Strat IV)

16 <u>Apr 6 7</u> Date:

Project Manager

Date.



Page: 15 of 16

BUSINESS CASE SUMMARY

## Pickering B Steam Generator Maintenance Waterlancing 13 - 40645

# Full Release Business Case Summary NK30-BCS-36340-00004-R000

## Attachment "B"

## **Project Variance Analysis**

	Sector St.	Total Project					
	LTD N/A N/A	Last BCS N/A N/A	This BCS N/A N/A	Variance	Comments		
Project Management (OPG)	1	······································	- 172	0			
Engineering & Drafting (OPG)				0			
Material					· · · · · · · · · · · · · · · · · · ·		
Installation - PWU, BTU		Manis and Solar		Primber State			
Contract - Design			10000	50			
Contract - Installation	(C			1	······································		
Contract - Other			Enternance.	-			
		Meeting					
		COLUMN THE					
Interest (Capital Project Only)	1	COLORIZATION OF	Carlon and a line				
Project Costs (exci contingency)					Anna and an and an and an an an an an an an an an an an an an		
General Contingency		and a second second second second		100000 A			
Specific Contingency				~			
Project Costs ( incl contingency)	0	0	0	0			
Committed Cost				0			
nventory Write Off Required				0			
Spare Parts / Inventory				0	Nr.		
Total Release (incl contingency)	0	0	0	0			
Total Release (excl contingency)	0	0	0	0			
				<u> </u>			
Ongoing OM&A (non-project)			100000		the second second second second second second second second second second second second second second second s		
Removal Costs (incl in above)	a. 3	EX STATE	-	0			
to the second second second second second second second second second second second second second second second	·····			0			

Comments:



Page: 16 of 16

BUSINESS CASE SUMMARY

-----

Attachment "C"

## Key Milestones

Co	mpletion	Date	
Day	Mth	Yr	Description
15	05	2007	Full Release BCS approved
30	06	2007	Waterlancing contract awarded
18	02	2008	Unit 8 Waterlancing start
27	03	2008	Unit 8 Waterlancing complete
15	04	2008	Unit 8 Available for Service
09	03	2009	Unit 5 Waterlancing start
05	04	2009	Unit 5 Waterlancing complete
11	04	2009	Unit 5 Available for Service
02	11	2009	Unit 6 Waterlancing start
29	11	2009	Unit 6 Waterlancing complete
10	12	2009	Unit 6 Available for Service
01	11	2010	Unit 7 Waterlancing start
28	11	2010	Unit 7 Waterlancing complete
02	12	2010	Unit 7 Available for Service
31	05	2011	Project close-out complete
			a characterization out complete
		····	

Project Execution Plan (PEP) will be approved by Sep 2007

Comments:

ONTARIO POWER GENERATION

Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

## PNGS-A Unit 4 Boiler Chemical Clean 13 - 49201

Routing	Location	Action	Signature	Date
L. Yu MTL Design Projects	P24 AN	Prepare BCS	Comen M.	March 4/ sous
S. Von Svoboda Project Leader II Design Projects	P24 AN	Review BCS	p.m. hope	Mar 7,200
G. Kotwa Section Manager Process Scheduling, PMO	P24 AB	Review BCS	Mary alwa	Ma 7/200
J. Marczak Project Manager Design Projects	P24 AN	Review BCS	He Margan	2005 Mar 0
P. Floyd Manager Design Projects	P24 AB	Review BCS	RV Hoyl.	1 in 8/05
R. Ball Senior Financial Analysts	P82-3	Review BCS	5.B	SMaros
troller - Engineering & Modifications	P82-3	Review BCS	Alla *	8 MARIUS
+ Signal infrast	to recent /	neme) 11		5. m C J
assessment, nor	- mother on	and g /	tick ok-	
Ť		rog lig is	AS	
	~			
	<u> </u>	//		
<u> </u>		· · ·		

ONTARIOPOWER Generation

## ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

# PNGS-A Unit 4 Boiler Chemical Clean 13 - 49201

Routing	Location	Action	Signature	Date
M. Arnone				Date
Director Projects & Modifications	P72-2	Review BCS	Date	OSMAROS
G. Paterson				
Manager. Components & Equipment PNGS-A	P42 E3	Review BCS	Mars - A	09Macho5
M. Reid			XIVEXIV	
Director, Station Engineering PNGS-A	P42 E3	Review BCS	Ma Mala	2005 Mar IC
J. Coleby				
Site Vice President PNGS-A	P05 A2	Submit BCS	SEE ATTACHED	
D. Power		· · · · · · · · · · · · · · · · · · ·		
Director, Investment & Business Planning	H07 D06	Review BCS	SEE ATTACHED	
D. Hanbidge				
Vice President - Controller	H19 F27	Review BCS	SEE ATTACHED	
Charlebois				 
of Nuclear Officer (Acting)	P82-6	Review BCS	SEE ATTACHED	
R. Dicerni		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		
Acting President & CEO	H19 E27	Approve BCS	SEE ATTACHED	
				1 
			; 	1
		*****		· · · · · · · · · · · · · · · · · · ·
· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·			
	1		· · · · · · · · · · · · · · · · · · ·	
1		(		
Bail	<u> </u>			
enior Financial Analyst	P72-2	Return For Distribution	3	· · · · · · · · · · · · · · · · · · ·



ONTARIOPOWER GENERATION

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

## PNGS-A Unit 4 Boiler Chemical Clean 13 - 49201

Routing	Location	Action	Signature	Date
M. Arnone Director Projects & Modifications	P72-2	Review BCS	SEE ATTACHED	oure
G. Paterson Manager, Components & Equipment	P42 E3	Baulan BOO		
PNGS-A M. Reid	F42 E3	Review BCS	SEE ATTACHED	
Director, Station Engineering PNGS-A	P42 E3	Review BCS	SEE ATTACHED	
J. Coleby Site Vice President PNGS-A	P05 A2	Submit BCS	SEE ATTACHED John Gueroy.	Man 8d
D. Power Director, Investment & Business Planning	H07 D06	Review BCS	Robien	
D. Hanbidge Vice President - Controller	H19 F27	Review BCS	Down	Mal 10/0
P. Charlebois Chief Nuclear Officer (Acting)	<b>P8</b> 2-6	Review BCS		manaho
Dicerni Acting President & CEO	H19 E27	Approve BCS	SEE ATTACHED	
				·····
. Bali				·····
enior Financial Analyst 01-8241	P72-2	Return For Distribution		



Page:

#### ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

## PNGS-A Unit 4 Boiler Chemical Clean 13 - 49201

Routing	Location	Action	Signature	Date
M. Arnone Director Projects & Modifications	P72-2	Review BCS		
G. Paterson			SEE ATTACHED	
Manager, Components & Equipment PNGS-A	P42 E3	Review BCS	SEE ATTACHED	
M. Reid Director, Station Engineering PNGS-A	P42 E3	Review BCS	SEE ATTACHED	
J. Coleby Site Vice President PNGS-A	P05 A2	Submit BCS	John Carerbay	Man 8t. i
D. Power Director, Investment & Business Planning	H07 D06	Review BCS	SEE ATTACHED	1
D. Hanbidge Vice President - Controller	H19 F27	Review BCS	SEC ATTACHED	
harlebois Nuclear Officer (Acting)	P82-6	Review BCS		margh -
R. Dicerni Acting President & CEO	H19 E27	Approve BCS	been	Marshos- Mar 11/05-
	;             			
· · · · · · · · · · · · · · · · ·	\$			
3. Ball Senior Financial Analyst 01-8241	P72-2	Return For Distribution		

3 of 15

Page:



#### ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

## PNGS-A Unit 4 Boiler Chemical Clean 13 - 49201

## Full Release Business Case Summary NA44-BCS-36330-00003-R000

#### 1/ RECOMMENDATION:

We recommend the completion of all detailed engineering work and pre-requisites required to support the PNGS-A Unit 4 Boiler Chemical Clean Project (13-49201), and the execution of the Boller Chemical Clean process during the 2007 Unit 4 outage (with the option to advance execution to 2006). At this time, we require a full release of \$47.4M for the project.

A successful Boiler Chemical Cleaning must be completed at Unit 4 to ensure generation revenues are protected by eliminating the requirement for boiler tube plugging and potential unit shutdown due to boiler tube denting. A target period of eight years of operation without tube denting can be expected after completion of boiler cleaning at Unit 4. A regulatory commitment to the CNSC has also been made for chemical cleaning the boilers in Unit 4 (REGC AR# 28026033).

In order to prepare for the planned execution of Unit 4 boiler chemical clean in 2007 (with the option to advance execution to 2006), design deliverables must be expedited to allow all installation and execution documentation and prerequisite modifications to be completed in time to allow the option of performing the 2006 Unit 4 boiler chemical clean. Favourable P541 boiler inspection results will defer Unit 4 boiler chemical clean to 2007 – P741 outage; however, planning must be in place now for the execution option in 2006.

In August 2004, a superseding developmental release (NA44-BCS-36330-00002) was approved to provide funding to complete preliminary engineering and initial detailed engineering work. The superseding developmental release brought the project cumulative release amount to \$7.9M (\$7.2M excluding contingency). With the initiation of detailed engineering, the project is in a position to request this full funding release.

The Unit 4 Boiler Chemical Clean Project is listed in the proposed 2005-2009 Business Plan at \$44.3M. Variances will be managed via the Portfolio Management process in 2005.

SM(0)		and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated and indicated an	Excluding		Excluding	
Released to Date:	Developmental	7.9	7.2	Jan-05 Spent Life to Dute:		
Requested Now:	Full	47.4	38.9	2005-2009 Appr'd Busines: Plan (Tot Proj)	4.2	
Cumulative Release:	Total to Date	56.3	46.1			
Total Project Estimate:	+30% to -15%	55.3	46.1		1.8	
Current Year Estimate:	2005	17.4	14.5		10.2	
Type of Investment:	Regulatory	NA		2005 Budget Varianca (Current Yr)	4.3	
NPV: Recommendation	ut Dobudoo		N/A	Cumulative Release Remaining:	41.9	
DD: Decommendation	va uranay##U	116.0	N/A	Contingency on Remaining Release:	9.2	
RR: Recommendation	vs Detaying	NA	NA	Contingency % on Remaining Release:	22.0%	

Submitted By: Am lill

XL 65 rhil

Date:

Nos

Date:

J. Coleby Site Vice President, PNGS-A

Pence Approval Hanbidge ice President - Controller

ine Aporov L Protect in Budget): lerhent

R. Dicerni V Acting President & CEO

Date:



Page:

#### ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

#### 2/ BACKGROUND & ISSUES

#### **Boiler Operations & Maintenance**

During normal, steady state operation of nuclear power plants, small amounts of metallic impurities, principally iron, nickel, zinc and copper, are transported via the feedwater to the secondary side of the boilers where they slowly accumulate. Although their concentrations are low, typically a total of ~2 ppb, over 20 years of operation the amount transported may be as high as several hundred kilograms. In addition, normal start-up evolutions contribute an estimated 10 – 50 kg per start-up.

PNGS has adopted a boiler chemical cleaning (BCC) practice as part of its Boiler Life Cycle Management Plan to remove these deposits to stop or slow the boiler tube degradation mechanisms, particularly tube denting and under-deposit pitting corrosion. Unit 4 boilers are showing early indications of pitting and tube denting (latest inspections results showed 19 dents / 362 pits in all 12 boilers (31000 tubes) inspected). The degradation is not as advanced as compared to other PNGS-A unit boilers, and the chemical controls in place since the Return to Service of this unit have been excellent. However, empirical data from other units has shown that the phenomenon can advance rapidly once initiated. Data on the rate and exact onset is somewhat limited. It is therefore important to address the boiler tube denting on Unit 4 in a timely fashion.

Prevention of boiler tube denting will minimize boiler tube failure due to stress corrosion cracking and also ensure continued unrestricted access of inspection probes to the boiler tube interiors to demonstrate tube fitness-for-service, and will reduce the requirements for tube plugging due to inaccessibility issues. Minimizing the number of plugged boiler tubes will sustain boiler life and protect station against generation revenue losses. Completion of boiler chemical clean can alleviate the Unit 4 boilers of tube degradation conditions for a target beriod of eight years.

## Regulatory and Life Cycle Management Plan

OPG has a regulatory commitment (CNSC) to complete boiler cleaning at Unit 4 (REGC AR # 28026033). The Pickering 1-4 Steam Generator Life Cycle Management Plan (NA44-PLAN-33110-10003) specifies the requirement for a Boiler Chemical Clean to be conducted on Unit 4 to ensure sustained life of the asset.

#### Process Selection & Estimate Development

Two process options are available for Boiler Chemical Cleaning: the Hot Boiler Cleaning (HBC) process or the Electric Power Research Institute/Steam Generator Owners Group (EPRI/SGOG) process. The HBC process is too corrosive to apply to Pickering-A boilers due to the large quantity of deposits to be removed, and the boiler material corrosion limits. Therefore, the EPRI/SGOG process was selected for Unit 4 BCC.

The original \$31.5M estimate (2004 Business Plan) was based on a cost-sharing scenario with Unit 3 BCC for common design, prerequisite elements, and materials. With Unit 3 BCC project put on hold, the cost-sharing assumption is no longer valid, and the Unit 4 BCC project will have to fund all current BCC work. Additional analysis/reviews of cost assumptions have also been incorporated into the project estimates since this change.

The subsequent estimate of \$54.3M (previously listed under the superceding developmental BCS) was based on the assumption that additional dedicated station resources will be available to the project. Further refinement of the project estimate led to two scenarios (detailed in table below): 2006 execution scenario at total project cost of \$43.1M; and 2007 execution scenario with 2006 execution option at total project cost of \$46.1M. This BCS submission is based on the 2007 Execution (with 2006 option) scenario, as this is expected to be the actual scenario realized. It must be noted that (towards the end of 2005) should a 2006 execution be deemed necessary, the project budget and Business Plan cashflows must be promptly increased to permit such execution.



#### **ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY**

## Execution Scenarios Cost Estimates

UNTARIO**pûw**i

Alt SM (excluding contingency)		·····		·····			
(or conditing contingency)	2003	2004	2005	2006	2007	2008	Total
1A 2006 Spring Execution	0.3	3.4	14.5	23.8	1.0	2000	
	Actuals	Actuals	14.5	20.0	1.0	0	43.1
1 2007 Spring Execution	0.3	3.4	14.5	5.7	22.2	0	46.1
(with 2006 Execution Option)	Actuals	Actuals				v	40.1

#### Past Experience

PNGS-A Unit 1 and Unit 2 boilers were previously cleaned using the EPRI/SGOG process. However, the change control environment in early 1990's was not as stringent as today's standards. The equipment and design registration requirements for Unit 4 BCC is much more rigourous than before, and the new engineering change control environment and pressure boundary program requirements are leading to higher overall project costs than previous EPRI/SGOG boiler chemical cleans.

The equipment used and process time for the HBC method is significantly different from the EPRI/SGOG process that will be used for cleaning Unit 4 boilers. These differences prevented the use of common equipment and processes previously developed, and added on to the cost of designing new equipment and processes that is required for EPRI/SGOG.

#### Project Cost & Schedule

A peer review performed by Helyar & Associates on the cost estimate based on the single-unit execution cenario resulted in a project total of **the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second se** beer review was obtained by using OPG's cost estimate, scrutinizing and supplementing it with additional Helvar's conservatisms to yield their value; there was no original estimate performed independently using field data. Through detailed planning and monitoring by the project team, and oversight by line management (Management Steering Committee), and through experience from previous boiler chemical cleaning campaigns, the presented is deemed to be reasonable for completion of Unit 4 BCC. estimate

Pickering Unit 4 currently has planned outages scheduled for 2005 (Fall) and 2007 (Spring). This is based on the standard two year outage interval. Given prerequisite requirements, the project will not be ready for Boiler Chemical Clean execution in the 2005 outage. The earliest readiness date for execution would be 2006 (Spring). Pickering A operational requirements preclude delaying the planned 2005 (Fall) outage to 2006 (Spring). As a result, the current project schedule is aligned for a planned Unit 4 outage in 2005 (P541) for prerequisite activities, and is targeting for the execution outage in 2007 for boiler chemical cleaning with a 2006 execution option. The option would be invoked if boiler tube inspection results in 2005 indicate a requirement to advance the clean. Design deliverables must be expedited to allow all installation and execution documentation and pre-requisite modifications to be completed in time to allow the option of performing the 2006 Unit 4 boiler chemical clean. Pre-requisite activities include installation of access nozzles to boilers, installation of waste transport piping, modifications to boiler blowdown line, installation of containment penetrations, fabrication and testing of boiler cleaning equipment, transportation and staging of equipment, routing and connection of power supplies, development of procedures, and, training and mobilization of personnel.

It should be noted that pre-BCC and post-BCC flushing work will be completed as part of the separate Unit 4 Boiler Flushing Project.





Page:



#### ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

## 3/ ALTERNATIVES AND ECONOMIC ANALYSIS

## Stop the Project (NPV -\$700M) (Not Recommended)

## Fitness for service issue - Stop Project

This alternative is **not** recommended. The regulatory commitment (AR# 28026033) to the CNSC requires the completion of boiler cleaning at Unit 4. Potential boiler degradation/denting caused by crevice deposits will also limit unit operation and affect station assets, forcing a unit shutdown and negatively affecting generation revenues if boiler cleaning is not performed. (Reference Pickering 1-4 Steam Generator Life Cycle Management Plan – NA44-PLAN-33110-10003). A premature unit shutdown scenario causing loss of generation revenues could result. For the purposes of calculating a limiting NPV in this scenario: A premature unit shutdown from 2007 (extremely low probability) until its projected end-of-life of boilers (2017) with no mitigating work to restore/replace boilers would lead to an estimated NPV of approximately -\$700M (after tax).

## Alternative 1 – Prepare for 2006 Clean but Plan for 2007 Clean (NPV -\$29M) (Recommended)

Complete all design & prerequisites, Support 2006 Execution Option & Perform Boiler Clean in 2007 Complete all design packages, documentation, prerequisite modifications, and perform boiler chemical cleaning at Unit 4 during the 2007 outage (P741) with the option to execute in 2006. Boiler chemical cleaning operations have successfully been completed on all PNGS-B units and on PNGS-A Units 1 and 2. Costs have been minimized to permit advancing execution to P641 if P541 inspection results are unfavourable (low probability, but contingency to be maintained), and internal and external resources have been optimized. This scenario also maximizes opportunities for execution readiness. The project cost estimate for this alternative is \$55.3M (including contingency). Estimated NPV = - \$28.7M (after tax).

## ternative 1A – Execute Boiler Chemical Clean in 2006 (NPV -\$33M) (Not Recommended) ove 2007 and all subsequent outages forward by one year.

This alternative is **not** recommended. From a Business Planning perspective, project cost deferral to future years will permit better station cost management since more nuclear generation revenues are expected to be available with more nuclear units online in the near future. Executing BCC (and other major planned U4 outage work) in 2006 will impose a heavy cost load on the station, and subsequent advancing of future planned outages will also shift the cost load towards years with less generation revenues. The project cost estimate for this alternative is \$51.7M (including contingency). This alternative should only be selected in the situation where boiler inspection results in 2005 strictly require the earliest execution of U4 BCC.

## Alternative 2 - Delay the Recommendation (NPV -\$144M) (Not Recommended)

## No 2006 Preparation - 2005 inspection indicates Fitness for Service issue - Shutdown Nov 05 to Mar 07

This alternative is **not** recommended. Risk due to denting uncertainty makes this a less prudent option. Upcoming inspection results from P541 may indicate requirement for an earlier boiler chemical cleaning in 2006. If P541 inspection results indicate so, not having the 2006 execution option available will require unit shutdown post-P541 outage due to fitness for service consideration until after completion of U4 BCC in 2007 (though all efforts would be applied to further advance execution readiness should this scenario arise). Loss of generation revenues associated with this forced unit shutdown justifies maintaining the provision for the 2006 execution option.

## Alternative 3 - Do Less (Not Recommended)

This alternative is **not** recommended. Chemical Cleaning all twelve Unit 4 boilers is required to satisfy CNSC REGC commitment and to maintain station assets and generation revenues. Costs have been minimized for the current project scope of Unit 4 boiler chemical clean.

## Alternative 4 - Do More (Not Recommended)

This alternative is **not** recommended. The selected EPRI/SGOG process has been proven to effectively clean the NGS-A boiler internals, while maintaining the corrosion levels within acceptable limits. This process has been timized to provide the degree of boiler cleaning required.



#### **ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY**

## 4/ THE PROPOSAL

This full release BCS will allow the completion of the following deliverables.

- Project Execution Plan (R1)
- Detailed Engineering for site modifications and process design packages. . Packages include:
  - Station Tie-ins
  - **RAB/TAB Utilities** 0
  - Ó **RB** Utilities
  - Containment Inserts  $\odot$
  - 0 BCC System
- Purchase of materials for site modifications and vendor processes .
- Development of all vendor and station documentation to support BCC .
- Installation of site modifications to support BCC ٠
- Testing and commissioning of process systems ٠
- Execution of Unit 4 BCC •
- Demobilization and waste disposal .

Milestones Finish Date (D/M/Y)	Description
28-Feb-05	Preliminary Engineering Complete
25-Mar-05	Project Execution Plan (R1) Issued
25-Mar-05	Full Release BCS Approved
29-Mar-05	P541 Workplans Issued
31-May-05	Detailed Engineering Complete
1-Dec-05	P541 BCC Prerequisite Outage Activities Complete
31-Jan-06	P641/P741 BCC Go/No-Go Decision (Tentative)
15-Jun-06	P641 BCC Execution Complete (if 2006 execution option is selected)
15-May-07	P741 BCC Execution Complete
31-Dec-07	Project Close-out
15-May-07 31-Dec-07	P741 BCC Execution Complete

## 5/ QUALITATIVE FACTORS

Boiler cleaning can result in the following benefits for the station: ٠

- Prevention of further boiler tube denting which will
  - allow more comprehensive and efficient boiler inspections and hence shorter outage time 0
  - reduce boiler tube plugging requirements and hence lower probability of reactor derating and O. generation revenue loss or full shutdown
- stop potential for tube cracking and hence prevent forced outages
- Prevention of corrosion-induced boiler tube leaks which will
  - reduce potential for forced outages
  - reduce potential for environmental releases  $\bigcirc$



OPG Confidentia BUSINESS CASE SUMMARY



# 6/ RISKS

Risk After Mitigation	Low	Гом	Low	Low
Mitigating Activity	Clearly define scope of work and introduce incentive / penalty clauses into contract. Detailed monitoring of field activities progress during execution. Allocation of a method contingency to project for unforeseen developments.	Plan in detail execution tasks and logics with Outage Department. Integrate with station Outage Operations and Maintenance departments for optimization of execution. Allocation of a contingency to project for unforeseen developments. Using Framatome with their extensive world wide experience in the BCC area and OPG internal OPEX. Project managed to meet Outage Milestones (Materials(Plane(Att))	May require access to project contingency, CNO contingency, or re-balance of portfolio to support 2006 Boiler Chemical Clean execution.	Continue review with vendor design group and station stakeholders to define design and execution scope. Strict scope control processes implemented. Management Steering Committee oversight in place.
Risk Before Mitigation	Medium	Medium	Гом	Medium
Description of Consequence	Unlike a fixed-price contract, time and materials contract may result in cost escalations. Project could require additional funding.	Staging of equipment and mobilization of execution resources will have to be extended. Delays may result in outage extension (day-for- day cost increase) and associated generation loss.	Unit may require to be shut down following P541 or have a short operating period in 2006 prior to Boiler Chemical Clean. Late changes to Project Budget and Business Plan cashflows would be required, and large business plan variances may result.	Increased scope affects project cost and schedule.
Description of Risk Cost	Vendor contract to be time and materials type	Delays during outage execution (Also affects negatively execution schedule)	soller Chemical Clean may be id based on P541 boiler tions (advanced rate of g).	Design and execution scope increase







Risk After Mitigation	Low	Low	Low	Med to Low	Med to Low
Mitigating Activity	Current project direction is for a 2006 boiler chemical clean execution, with prerequisite work to be performed during P541 or before start of P641. (Business Plan is indicating 2007 execution, with 2006 execution as option). Management Steering Committee oversicht in place	Involve station Operations early during work planning stages/workplan preparations. Secure stakeholder support on schedule via Task Identification Sheets (TIS) and/or Interface Agreements.	See "Cost" category above.	Continue to arrange for contract resources to augment regular staff, and seek knowledgable contractors with previous boiler cleaning experience. May result in delay in project development, but will not result in execution failure. Potential cost impacts/outage extensions are covered by the contingency (see	Secure stakeholder resource support (Operations, Maintenance, Radiation Protection, etc.) via detailed planning and use of Task Identification Sheets and/or Interface Agreements. Reduce station resource reliance by optimizing station interface designs and by extending scope of contract execution support. Ensure continued oversight by Management Steering Committee (PNGS-A Site VP and vendor management as members). May result in delay in project development, but will not result in execution failure. Potential cost impacts/outage extensions are covered by the contingency (see "Cost" above).
Risk Before Mitigation	Low	Medium	Medium	Medium	Medium
Description of Consequence	Insufficient time and resources to accommodate late changes to project plan.	Delays to execution window. Need for re-application of permits. This may result in outage extension and associated generation loss.	See "Cost" category above.	Backlog of project-related deliverables.	Insufficient resources to support BCC execution. This may result in outage extension and associated generation loss.
Description of Risk (this release only!!!!) Schedule	schedule changes to p	BCC	Ing outage execution	Engineering ort BCC. st through	



10 of 15 ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY Page: OPG Confident



Insufficient         Information         Medium         Arrange for boiler nozzle inspections during P541 and completence to linaize design         Deckages.         Deckages. <thdeckages.< th="">         Deckages.         Deck</thdeckages.<>	Description of Risk ( <i>this release only!!!!!</i> ) Technical	Description of Consequence	Risk Before Mitigation	Mitigating Activity	Risk After Miligation
Incorrect         Low         Qualification tests to be completed for EPRI/SGOG           internals         tremals during BCC.         Development         Event         Ev	Insufficient information on boiler nozzle interference to finalize design	1	Medium	Arrange for boiler nozzle inspections during P541 and complete design packages based on inspection results.	LOW
Description       CMS to be returbished to support BCC with required for functionality and reliability.         CMS functionally inadequate       Low       CMS to be returbished to support BCC with required level of functionality and reliability.         Revel of BCC.       Need to after plan to execute       Low       Sought and received initial CNSC concurrence on deferred execution of BCC. Actual BCC execution deferred execution deterred execution of BCC matter deferred execution of BCC matter and fiquid tartical clean with reterionment         Unplanned release to the       Low       Continued monitoring of air emissions and liquid tartient of Approval permitted levels.         Liquid waste remains in waste       Low       BCC waste handling is an integral part of the project, and is being reviewed in detail during engineering design, and will be managed with continued project tarm oversight during BCC execution.         Event-Free       Day resets       Low       Oversight by Contract Administrators, Contract Monitors, and Contract Management Team to be management and the project team oversight by Contract Management and the project team oversight by Contract Management and the project team oversight by Contract Management and the project team oversight by Contract Management and the project team oversight by Contract Management and the project team oversight by Contract Management and the project team oversight by Contract Management and the project team oversight by Contract Management and the project team oversight by Contract Management and the project team oversight by contract Managemen	Chemical addition strategy	Incorrect concentration of chemicals may affect boiler internals during BCC.	Low	Qualification tests to be completed for EPRI/SGOG process prior to execution of BCC.	Low
<ul> <li>Need to after plan to execute</li> <li>Low</li> <li>Sought and received initial CNSC concurrence on deferred execution of BCC. Actual BCC execution boiler chemical clean</li> <li>Unplanned release to the Low</li> <li>Unplanned release to the Low</li> <li>Continued monitoring of air emissions and liquid waste remains in waste</li> <li>Low</li> <li>Event-Free Day resets</li> <li>Low</li> <li>Oversight during BCC execution</li> <li>Recention</li> <li>Recention</li> <li>Event-Free Day resets</li> <li>Low</li> <li>Oversight by Contract Administrators, Contract Management Team to be furthed project transities</li> <li>Revent-Free Day resets</li> <li>Low</li> </ul>	Corrosion Monitoring System (CMS)	CMS functionally inadequate for BCC.	Low	CMS to be refurbished to support BCC with required level of functionality and reliability.	Low
bolier chemical clean       Sought and received initial CNSC concurrence on deferred execution of BCC. Actual BCC execution date to be determined by 2005 inspection results.         Unplanned release to the release to the Low       Continued monitoring of air emissions and liquid wastes generated during boiler chemical clean with reference to Centificate of Approval permitted levels.         Liquid waste remains in waste       Low       Continued monitoring of air emissions and liquid wastes generated during boiler chemical clean with reference to Centificate of Approval permitted levels.         Liquid waste remains in waste       Low       BCC waste handling is an integral part of the project, and is being reviewed in detail during engineering design, and will be managed with continued project learn oversight during BCC execution.         Event-Free       Day resets /       Low       Oversight by Contract Administrators, Contract Management Team to be emphasized during execution.         Injuries       Event-Free       Day resets /       Low       Oversight by Contract Administrators, Contract Management Team to be emphasized during execution.	Regulatory CNSC may not formally approve		me		
Unplanned release to the environmentLowContinued monitoring of air emissions and liquid wastes generated during boiler chemical clean with reference to Certificate of Approval permitted levels.Liquid waste remains in waste tankers during execution.LowBCC waste handling is an integral part of the project, and is being reviewed in detail during engineering design, and will be managed with continued project team oversight during BCC execution.Event-Free Day resets /LowOversight by Contract Management Team to be emphasized during execution.Event-Free Day resets /LowNorriscs, and Contract Management Team to be emphasized during execution.	olan for deferred execution of BCC ollowing 2005 Inspection results.	1	R D	bought and received initial CNSC concurrence on deferred execution of BCC. Actual BCC execution date to be determined by 2005 inspection results.	Low
Unplanned release to the environmentLowContinued monitoring of air emissions and liquid wastes generated during boiler chemical clean with reference to Certificate of Approval permitted levels.Liquid waste remains in waste tankers during execution.LowBCC waste handling is an integral part of the project and is being reviewed in detail during engineering design, and will be managed with continued project team oversight during BCC execution.Event-FreeDay resets /LowNonitors, and Contract Management Team to be emphasized during execution.Event-FreeDay resets /LowNonitors, and Contract Management Team to be emphasized during execution.Nonitors, and contract Management Team to be involved early in process emplemented. JHSC to be involved early in process development.	invironmental				
Liquid waste remains in waste Low BCC waste handling is an integral part of the project, tankers during execution. BCC waste handling is an integral part of the project and is being reviewed in detail during engineering design, and will be managed with continued project team oversight during BCC execution. Contract hijuries bay resets / Low Oversight by Contract Management Team to be emphasized during execution. OPG Contract Management processes implemented. JHSC to be involved early in process development.	Air and/or liquid emissions during boiler chemical clean beyond Dertificate of Approval limits.	release to	Low	Continued monitoring of air emissions and liquid wastes generated during boiler chemical clean with reference to Continue of According to the second second second second second second second second second second	Low
Event-Free Day resets / Low Oversight by Contract Administrators, Contract Injuries Monitors, and Contract Management Team to be emphasized during execution. OPG Contract Management processes implemented. JHSC to be involved early in process development.	victatile deposits removed (in solution form) cannot be disposed of.	Liquid waste remains in waste tankers during execution.	Low	BCC waste handling is an integral part of the project, and is being reviewed in detail during engineering design, and will be managed with continued project team oversight during BCC execution.	Low
Event-Free Day resets / Low Oversight by Contract Administrators, Contract Injuries Monitors, and Contract Management Team to be emphasized during execution. OPG Contract Management processes implemented. JHSC to be involved early in process development.	lealth & Safety				
	Insate work practices during endor execution of BCC. Potential hemical hazards associated with iCC solvents.	Day	Low	Oversight by Contract Administrators, Contract Monitors, and Contract Management Team to be emphasized during execution. OPG Contract Management processes implemented. JHSC to be involved early in process development.	Low



11 of 15 Page: OPG Confiden



ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

negatively

As part of the ongoing cost-saving measures, three options as part of detailed design have been identified for review. These options include continuing with detailed design with new BCC equipment (current design direction), relaxing the ECC rigour for detailed design, and pursuing detailed design using existing vendor equipment.

In order to allow the risks listed in the above table to remain comprehensive for the project, the details and specific risks associated with the costsaving options are listed only in the reference documents below to maintain the clarity of this BCS document.

<u>Beferences:</u> 1. Correspondence, G. MacDonald to J. Marczak, "FANP Assessment of Options for P4BCC", February 24, 2005. 2. Memorandum to File, "PNGS-A Unit 4 Boiler Chemical Clean Project – Risks Associated with Project Cost Savings Options", February 28, 2005.



#### ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

## 7/ POST IMPLEMENTATION REVIEW PLAN

The Post Implementation Review (PIR) will be performed in accordance with the PIR Procedure (FIN-PROC-PA-012) and the Simplified PIR Template (FIN-TMP-PA-002). Design Projects, in cooperation with Finance, Engineering Mechanics & Codes Department; Chemistry, Metallurgy & Welding Department, will perform the PIR with a target completion date of December 2007. The results of the project will be documented and compared against the following baseline criteria (in development). Major lessons-learned from the project will be documented in a report. In addition, the boiler performance will continue to be monitored under the Pickering Unit 1-4 Steam Generator Life Cycle Management Plan.

Type of PIR:	Targeted Final AFS Date:	Jeree , in the prove			
Simplified	May 2007	Dec 2007	(Sponsor Title) Manager, Components & Equipment, PNGS-A		

	Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it? (person / group)
1.	BCC		Within corrosion limits (limits to be finalized in NA44- REP-36330-00001: EPRI/SGOG Chemical Cleaning Process for Pickering-A)	Via Corrosion Monitoring System (CMS) and corrosion probes & coupons.	CM&W Dept. & Engineering Mechanics Dept.
2.	Deposit removal	N/A	6500 - 8500 kg	Via Waste Solvent calculations,	CM&W Dept.
3.	REGC AR 28026033	N/A	Fulfillment of commitment	Via successful completion of BCC during outage.	Components & Equipment, PNGS-A.
4.	[Qualitative] Removal of Crevice Deposits	N/A	Crevices cleaned	Post BCC inspection results to be reviewed	CM&W Dept.
5.	[Qualitative] Reduction in Boiler Tube denting	N/A	Based on crevice deposit removal	Post BCC inspection results to be extrapolated	Engineering Mechanics Dept.
6.	[Qualitative] Reduction in corrosion induced boiler tube leaks	N/A	Consistent with Life Cycle Management Plan expected performance	Post BCC inspection results to be extrapolated	Engineering Mechanics Dept.

Page: 13 of 15

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

## PNGS-A Unit 4 Boiler Chemical Clean 13 - 49201

ONTARIOPOWER GENERATION

## Full Release Business Case Summary NA44-BCS-36330-00003-R000

Attachment "A"		<u>P</u>	roject Co	ost Sum	mary				
\$000's OM&A	LTD Prior Years 2003	LTD Prior Years 2004	2005	2006	2007	2008	Tetel	LTD This Mth Jan	LTD
Project Management (OPG)	106	411	1,880	1,400	1,870	2008	Total 5,667	2005	%
Engineering & Drafting (OPG)	169	649	1,380	620	660		3,478	635	11.2
Material			1,000	020	000		3,478	863	24.8
Installation – PWU, BTU		-							
Contract - Project Mgmt	17								
Contract - Design	2								
Contract - Installation			-15 - 11	class-			10		
Contract - Other									
					and the second	SEX PHAN		a starting	
			a unter.	ALCO DE LO	N DEPOSIT		all the second second	-	
				the states in	A				
					And a state of the				
1									
	Concession in which the				A STATEMENT				_
nterest (Capital Project Only)									
Sub Total									
excl Contingency)									-
Contingency									
Grand Total	275	3,391	17.050	0.000					
005-2009 Business Plan			17,350	6,860	27,430	-	55,306	NA	NA
arlance to Business Plan	275	4,672	10,180	5,400	22,750	976	44,253	N/A	N/A
excl Contingency)				1					
able A: Cashflows and Br									

able A: Cashflows and Breakdowns for Alternative 1 (Execution of U4 BCC in 2007 with 2006 Option).

Removal Costs included in above	0
Definition Costs included in above	0
Estimate Name, Quality, etc	Budget Estimate +30% to -15%
Design Complete:	Up to ~ 40%
Reviewed By: J. Marczak oject Manager	Approved By: P. Floyd Eng & Mods Manager (Strat IV)



Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

## PNGS-A Unit 4 Boiler Chemical Clean 13 - 49201

## Full Release Business Case Summary NA44 -BCS-36330-00003-R000

Attachment "I	<u>B</u> "
---------------	------------

**Project Cost Summary** 

\$000's OM&A	LTD Prior Years	LTD Prior Years						LTD This Mth Jan	LTD
	2003	2004	2005	2006	2007	2008	Total	2005	%
Project Management (OPG)	106	411	1,880	1,880	650		4,927	635	12.9
Engineering & Drafting (OPG)	169	649	1,400	700	140		3,058	863	28.2
Material						-	0,000	000	Z
Installation – PWU, BTU		the second second second second second second second second second second second second second second second s							
Contract – Project Mgmt									
Contract - Design				a beautiest and a state	CONTRACTOR OF	State State			-
Contract - Installation	1						the mappy		-
Contract - Other			S Sol Party	1011	C1-1-2-2-2-2-		Chine Constants		
Interest (Capital Project Only)									
Sub Total									
exci Contingency)				_					
Contingency									_
Grand Total	275	3,391	17,430	29,310	1 005				
2005-2009 Business Plan					1,285		51,691	N/A	N/A
	275	4,672	10,180	5,400	22,750	976	44,253	N/A	N/A
/arlance to Business Plan excl Contingency)									

Table B: Cashflows and Breakdowns for Alternative 1A (Execution of U4 BCC in 2006).

Comparing against cost details of Alternative 1 (Attachment A), the following can be noted.

- Overall higher cost (mainly in Project Engineering and Installation) for Alternative 1 is associated with the need for:
  - Re-work of documentation (execution workplans, process procedures, etc.),
  - Re-training of execution crews & Re-mobilization,
     Re-scheduling of execution activities for Output
  - Re-scheduling of execution activities for Outage schedule alignment.
  - Maintenance of resource readiness.

Removal Costs included in above	0
Definition Costs included in above	0
Estimate Name, Quality, etc	Budget Estimate +30% to -15%
Design Complete:	Up to ~ 40%

**Reviewed By** Margol 205.1 la: 08 Marczak Date: oject Manager

Approved By: March lor.

P. Floyd / Eng & Mods Manager (Strat IV)

15 **of** 15

Page:

ONTARIOPOWER GENERATION

## ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

## PNGS-A Unit 4 Boiler Chemical Clean 13 - 49201

## Full Release Business Case Summary NA44-BCS-36330-00003-R000

Attac	hment	"Ç"

## **Project Cost Summary**

S000's OM&A	LTD Prior Years 2003	LTD Prior Years 2004	2005	2006	2007	2008	Total	LTD This Mth Jan 2005	LTD
Project Management (OPG)	106	411	1,320	1,960	1,870	-	5,667	635	11.2%
Engineering & Drafting (OPG)	169	649	970	1,030	660	-	3,478	863	24.8%
Material		-	200 C			100 miles (100	A Distance of the		I no A
Installation – PWU, BTU		L	5-18-37-18-1						
Contract – Project Mgmt		1	- 4-1	2162538		TANK!			
Contract - Design			Some in VAL	AND DE LA	DER LI TO	DETASIC	ANT CONT	1201-2	
Contract - Installation		1	14.5 × 16	Martin N	AN ALL DES	ELSANGAR.	Contract - La		-
Contract - Other		1 -			ARE REAL	19 STERE AND			-
		1	-i-mainten	8			wishi izi		
			CURRENTS!	Mitterstat	1000014-012-015		al references to be of	Sed states	
			- Statutes	ANTERSTON	Constitution of the local division of the lo	Contract of the	10.000		
				Statesant.	and the second	cicilitermer	L'UNITES LOU	SECTION -	-
· · · · · · · · · · · · · · · · · · ·			THE PARTY	A CONTRACTOR A CONTRACTOR	SCIENCE HERE			PERMINANCE -	
		-		TRUMPIC SHEEK	THE PERSON SHE	REMARKING (S)	-MARGACZERS		
······				mark-white papers	and a second second second second second second second second second second second second second second second	ner af angel angel angel der den Annender Angel 1 Constraint Angel angel			
nterest (Capital Project Only)				正式的時間的	And the Parallelist		WARE N		
Sub Total					311533 J - 6-		Carlos and	ALC: NOT	
excl Contingency)	275				Contraction of the	Second D	No.	-	
Contingency									
Grand Total						1			
	275	3,391	12,155	12,085	27,420	-	55,326	N/A	N/A
005-2009 Business Plan	275	4,672	10,180	5,400	22,750	976	44,253	N/A	-
ariance to Business Plan						370	++,203	IVA	N/A
excl Contingency)	- 1				the state to spill the	制建立的	Constant of the		and the second second

ble C: Alt # 2 (Execution of U4 BCC in 2007 with Unit Shutdown from November 05 to March 2007).

Removal Costs included in above	0
Definition Costs included in above	0
Estimate Name, Quality, etc	Budget Estimate +30% to -15%
Design Complete:	Up to ~ 40%

**Reviewed By:** - Marijele 205-Mar-08 Date: J. Marczak Project Manager,

Approved By Mard &

P. Floyd Eng & Mods Manager (Strat IV)

ONTARIO POINER GENERATION

**OPG** Confidential

Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

## U4 Boiler Flushing - Project# 13 - 49204

Routing	Location	<u>Action</u>	<u>Signature</u>	Date
A. Maxim Mod. Team Leader, Design Projects 701 - 3579	P24 AN	Prepare BCS	Alpan.	2005/02/17
C. Verwey Project Leader, Design Projects 701 - 4327	P24 AN	Review BCS	Yhis Eduel/	2005/02/17
G. Kotwa Section Manager, Process Scheduling 701 - 3755	P24 AB	Review BCS	P.Y. Flort for.	\$ 1
E. H. Wong Project Manager, Design Projects 701 - 4173	P24 AN	Review BCS		2005/2/17
P, Floyd Manager, Design Projects 701 - 4053	P24 AB	Review BCS	Potr J. Floyd	Feb 17/05
R. Ball Senior Financial Advisor, Engineering and Modifications )1 - 8241	P72-2	Review BCS	A-Go_	
G. Brown Controller, Engineering and Modifications 400 - 5991	H7 F20	Review BCS	Alan	17-FES '05
M. Arnone Director, Projects and Modifications 701 - 6063	P72-2	Review BCS	Place	18 FEB 2005
G. Paterson Manager, Components and Equipment 701 - 4141	P42 E2	Review BCS	Marstatur	23Feb,205
-D:-Power- Director, Investment-& Bus-Plan-OPG 4007172	H7-D06	Review-BCS-		
J. Coleby Vice-President, PNGS-A 701 - 3260	P05 A2	Submit BCS	John Celeby	26 Feb'05.
D. Hanbidge D. PowER for Vice-President, Controller, OPG 400 - 2395	H7 Dab H7 626	Approve BCS	Adam	02 Mar 05
P. Charlebois Chief Nuclear Officer 701 - 8221	982-6 - <del>P72-</del> 1	Approve BCS		mar 7/05
R. Ball Senior Financial Analyst 701-8241	Рвг-3 <del>Р72-2</del>	Return For Distribution		

Page: 2 of 12

**OPG** Confidential

ENGINEERING & MODIFICATIONS

BUSINESS CASE SUMMARY

## U4 Boiler Flushing - Project# 13 - 49204

## Full Release Business Case Summary NA44-BCS-36340-00002-R000

## 1/ RECOMMENDATION:

GENERATI

We recommend additional release of \$13.1M plus contingency) for a project total of \$14.7M (\$12.8M plus contingency) to secure the funding required to 1) complete development of the Boiler Flushing process, 2) execute the field pre-requisites (i.e. boiler nozzle installations, shroud hole repairs, and mechanical and electrical modifications) in P541 to support and equip for the Flushing and Boiler Chemical Clean (BCC) programs, and 3) execute the pre-BCC and post-BCC flushing in the P741 outage.

There is a possibility, as a result of the P541 boiler inspections, that the BCC and Flushing activities may be required prior to P741; therefore, the Flushing program must be planned and ready for execution in 2006 (P641).

The business objective of this project is: 1) to prevent the boiler tube degradation by removing the unhardened sludge deposits collected on top of the tube-sheet, and 2) support the BCC project (13-49201), which is to ensure generation revenues are protected by eliminating the requirement for boiler tube plugging and potential unit shutdown due to boiler tube denting. There is a regulatory commitment to the CNSC for chemical cleaning of the 12 boilers in Unit 4 (REGC AR # 28026033).

A previous developmental release of \$1.6M was made under NA44-PLAN-36340-00001, of which \$660k has already been spent to complete the preliminary engineering and start the detailed engineering on both the site modifications and the flushing process. More specifically, the preliminary design and the detailed engineering for the site modifications have been completed, while preliminary engineering has been completed and the development of the flushing process is being started. Consequently after the change in requirement to execute Flushing in the same outage as BCC, as evident through eliminary engineering (as per the scope in NA44-PLAN-33110-00004), the Flushing related activities were deferred from ne 2004 schedule; this resulted in considerably less funds spent in 2004 than was budgeted.

This project is listed in the 2005-2009 approved business plan with a project total of \$14.5M (\$1340k was budgeted for 2004). See attachment "A" for details. Any cash flow variances to this Plan will be addressed through the Portfolio Management Process. Currently the BCC is under review, and will be presented to the Board of Directors in March 2005. If the BCC is not approved, a superceding release will be processed to reduce the amount of this project accordingly.

Choose One		Including Contingency	Excluding Contingency	e a provinsi orași de la construire 1960 - Angel Angel Angel 1960 - Angel Angel Angel	an an an taon an ann an taon an Taon ann ann an taon ann an taon	Excluding Contingency
Released to Date:	Developmental	1,600		Jan-05	Spent Life to Date:	660
Requested Now:	Full	13,100		2005-2009	Appr'd Business Plan (Tot Proj):	
Cumulative Release:	Total to Date	14,700	And Andread	2005-2009	Business Plan Variance:	
Total Project Estimate:	+30% to -15%	14,700	BERNEY PRICES	2005	Budget (Current Year)	
Current Year Estimate:	2005	5,765		2005	Budget Variance (Current Yr)	
Type of Investment:	Regulatory	N/A	N/A		ease Remaining:	
NPV:		-	N/A	Contingency on	Remaining Release:	
IRR:			N/A	Contingency %	on Remaining Release:	

Submitted By:

26 kb 2005

J. Coleby Vice-President, PNGS-

Date:

Date/

Finance Approval:

Pra- 7/05

P. Charlebois Chief Nuclear Officer

Line Approval (Per OAR Element 1.1 Project in Budget):

Date:

D. Hanbidge Vice-President, Controller, OPG

Page:



**OPG** Confidential

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

#### 2/ BACKGROUND & ISSUES

#### **Boiler Operations & Maintenance**

During normal, steady state operation of nuclear power plants, small amounts of metallic impurities, principally • iron, nickel, zinc and copper, are transported via the feedwater to the secondary side of the boilers where they slowly accumulate. Although their concentrations are low, typically a total of ~2 ppb, over 20 years of operation the amount transported may be as much as several hundred kilograms. In addition, normal start-up evolutions contribute an estimated 10 - 50 kg per start-up.

PNGS has adopted a boiler chemical cleaning (BCC) practice, as part of its Boiler Life Cycle Management Plan, to remove these deposits and stop or delay the boiler tube degradation mechanisms, particularly tube denting and under-deposit pitting corrosion. The Unit 4 boilers are showing early indications of pitting and tube denting (recent inspections showed 19 dents / 362 pits in all of the 12 boilers (31000 tubes) inspected). In comparison to the other PNGS-A unit boiler, the degradation is not as advanced, as the chemical controls in place since the Return to Service of this unit have been excellent. However, empirical data from other units have also shown that degradation can advance rapidly once initiated (data on the rate and exact onset is somewhat limited). It is therefore important to address the boiler tube denting on Unit 4 in a timely fashion.

Prevention of boiler tube denting will minimize boiler tube failure due to stress corrosion cracking, and ensure continued unrestricted access of inspection probes to the boiler tube interiors for tube fitness-for-service evaluations. It will also reduce the requirements for tube plugging due to inaccessibility issues. Furthermore, minimizing the number of plugged boiler tubes will sustain boiler life and protect the station against generation evenue losses. The completion of boiler chemical clean can alleviate the tube degradation conditions of the Unit 4 boilers for a period of eight years.

#### Regulatory and Life Cycle Management Plan

Flushing activities are required as on going "maintenance" activities as per the Steam Generator Life Cycle Management Plan (NA44-PLAN-33110-10003) to control the secondary side deposits.

OPG also has a regulatory commitment to the CNSC to complete boiler cleaning of Unit 4 (REGC AR # 28026033). The Pickering Unit 1-4 Steam Generator Life Cycle Management Plan (NA44-PLAN-33110-10003) and the Pickering Unit 4 - 2005 Steam Generator Outage Scope Plan (NA44-PLAN-33110-00004) specify the requirement for a Boiler Chemical Clean to be conducted on Unit 4 to ensure sustained life of the asset. To fulfill this requirement, boiler flushing must be performed prior to and after BCC. The Pre-Flush will remove the build up of "soft" deposits to expose the "hard" pile to the BCC process, while the Post-Flush will remove the deposits dislodged or "softened" by the BCC process.

Page:

4 of 12



ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

## 3/ ALTERNATIVES AND ECONOMIC ANALYSIS

#### Do Nothing (Not Recommended)

This is not recommended. OPG has a regulatory commitment to the CNSC to complete boiler cleaning of the Unit 4 boilers (REGC AR # 28026033). Pickering Unit 1-4 Steam Generator Life Cycle Management Plan (NA44-PLAN-33110-10003 R0) outlines the need for the boiler flushing process in relation with BCC operations as well as to control the secondary side deposits. The nozzles installed under this project are required for BCC execution. Boiler tube fouling/denting will limit unit operation if BCC and Flushing operations are not performed.

#### Alternative 1 – Execute Boiler Pre-req's in P541 and perform Flushing in P741 (Recommended)

Execute the BCC and Flushing prerequisites (i.e. install boiler nozzles, repair shroud holes, and complete electrical and mechanical modifications) during the P541 outage in parallel with other boiler work. Develop a flushing process and execute the pre- and post- BCC flushing during the P741 outage. This approach is recommended. There is a possibility that execution of Flushing and BCC may be required prior to the scheduled P741 outage; thus, flushing developments need to be done early to accommodate a P641 outage.

## Alternative 2 - Delay the Recommendation (Not Recommended)

2.1. Delay the prerequisites execution.

This is not recommended. The execution of prerequisites (i.e. nozzle installation, shroud repair and electrical and mechanical modifications) can be done during P541 in parallel with the Feedwater Nozzle Thermal Sleeve Replacement (TSR), and should have no impact on the P541 outage duration. If the boiler prerequisites are not executed in the P541 outage, and delayed until the next outage (P741), this activity will become a "series" activity with the Flushing and BCC activities and will increase the length of the outage by approximately 25 days.

## 2.2. Delay the Flushing development closer to the P741 outage.

This is not recommended, as there is the possibility that BCC and Flushing activities may be advanced to a P641 outage.

## Alternative 3 - Do Less (Not Recommended)

3.1. Execute a pre-BCC Flush only or a post-BCC only.

This is not recommended. A post-BCC flush is required to remove the solid deposits from the boiler dislodged by the BCC process. If Flushing is not done prior to BCC to remove the build up of "soft" deposits to expose the "hard" pile, the BCC process will not be effective.

## 3.2 Execute Flushing activities only. (If BCC is not approved)

Although this will help address the secondary deposit issue, this will not fully address the requirements set out in the Life Cycle Management Plan - nor fulfill the REGC shown above.

## Alternative 4 - Do More (Not Recommended)

4.1. Progress the development of the Flushing process and execute the Flush during P541 prior to P741. This is not recommended. Flushing must be performed in the same outage as BCC to remove "soft" deposits and expose the "hard" deposits for maximum benefits of BCC.

#### 4.2. Execute a Flush in both P541 and P741

This is not required by the Boiler Life Cycle Management Plan and would significantly increase the duration of the P541 outage.

N/A Alternative 5 - Other -

Page:

**ENGINEERING & MODIFICATIONS** BUSINESS CASE SUMMARY

#### 4/ THE PROPOSAL

IMARIE

The additional release of \$13.1M Flushing process, award contracts with Vendor(s) to prepare and execute the boiler pre-requisites, and execute the pre- and post- BCC flushing activities. The project cost estimate is based on estimates received from vendors, and past and current flushing activities being performed on Pickering B boilers. The total project cost was also evaluated by a third party (Helyar); their estimate including contingency is approximately hiaher. The difference is largely due to the third party's use of "conceptual quality" information and a higher amount for contingency.

The scope of work addressed with this release:

- project management support ą
- complete engineering activities Ģ
- finalize contracts with vendor(s) ø
- pre-mobilization activities (i.e. tooling, mock-ups, training, materials) 緻
- develop an enhanced flushing process for PNGS-A boilers and sludge pile specific configuration ŵ
- work plans and ITP's preparation
- assessing activities ø
- QA and QS activities
- station support (i.e. maintenance, operation, radiation protection) ۲
- contract management support
- permanent power supply installation (for Flushing equipment)
- prerequisites execution P541 nozzle installation, shroud repair, and electrical & mechanical modifications
- flushing equipment maintenance, testing, preparation for storage ۵
- scaffolding execution (for both the pre-req outage and the Flush/BCC outage) φ
- execution coordination support (for both the pre-req outage and the Flush/BCC outage) ۵
- pre-BCC and post-BCC Flushing execution (for Flush/BCC outage)
- project / ECC closeout activities

<u>Milestones</u> Finish Date	Description
(D/M/Y)	
25-Feb-05	Approve Full Release BCS
29-Jan-05	Complete Detailed Engineering for P541 Pre-req Scope
31-May-05	Complete Detailed Engineering for P741 Flushing Scope (alming to be ready for P641)
29-Mar-05	Einalize Contracts with Vendor(s) for P541 Pre-reg Scope
30-Sep-05	Finalize Contracts with Vendor(s) for P741 (aiming to be ready for P641)
29-Mar-05	Issue P541 Workplans
30-Sep-05	Complete enhanced Flushing Development
30-Sep-05	Issue P741 Workplans (aiming to be ready for P641)
1-Dec-05	Complete P541 Flushing Prerequisite activities
3-Jul-07	Complete Pre and Post BCC Flushing activities
30-Dec-07	Complete Project Close-out activities



Page:



**OPG** Confidential

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

### 5/ QUALITATIVE FACTORS

Performing boiler flushing activities result in a more effective BCC. The combination of Flushing and BCC operations can result in the following benefits for the station:

- Prevention of further boiler tube denting which will
  - o allow more comprehensive and efficient boiler inspections, and hence decrease outage time
  - reduce boiler tube plugging and hence lower the probability of reactor derating, generation revenue loss or full shutdown
  - minimize the potential of tube cracking and hence prevent forced outages
  - Prevention of corrosion-induced boiler tube leaks which will
    - o reduce the chances of forced outages
    - o reduce the potential of environmental releases

ĺ			1015A
and the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second se	1.2		
1		× -	-
			1000
1	<b>1</b>	<u> </u>	
	C C	37	
	62	с 1 1 1 1 1 1	
(	Contract		
-		27/27	
1			
	20 000	1	
S	1 second		
	See.	1000	
	e and a second		

OPG Confidential Page: 7 of 12 ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY - - -

- -

----

# 6/ RISKS

Description of Risk	Description of Consequence	Risk Before Mitigation	Mitigating Activity	Risk After Mitigation
Cost Higher than estimated vendor(s) cost for the preparation and execution of the P541 outage work.	Overall cost of the project may be greater than estimated.	Medium	<ul> <li>Project management has entered into negotiations with vendor and has received proposals from vendor for this work.</li> <li>Fixed price contract where appropriate to minimize unexpected price increase.</li> <li>Contract administration and monitors are to be assigned to ensure efficient use of resources.</li> <li>A portion of the contingency is allocated for this.</li> </ul>	Low
Enhanced flushing execution may take longer than previous Pickering B flushing job, thereby increasing vendor(s) cost for the preparations and execution of the P741 outage work.	Overall cost of the project may be greater than estimated.	Medium	<ul> <li>Project management has entered into negotations with vendor. The vendor will be requested to follow the outage schedule.</li> <li>Extensive testing and qualification of the enhanced flushing lance in progress to meet OPG technical specification requirements.</li> <li>Contract administration and monitors are to be assigned to ensure efficient use of resources.</li> </ul>	\$ ) ]
Scaffold cost greater than estimated.	Overall cost of the project may exceed the estimate detailed in this BCS.	Medium	-Project management to work closely with scaffolding vendor to outline requirements and scope. Preliminary estimate from vendor has been received. -Work with other groups to review work plans to mitigate and avoid re-work. -Contract administration and monitors are to be assigned to ensure efficient use of resources. -a portion of the contingency is allocated for this.	Low
Scope Changes in BCC requirements to increase the scope of boiler pre- requisite work.	Increase in cost and schedule.	Low	-Great efforts in the design phase of the BCC project has been made to minimize this threat.	Low

C B	
$(\Box)$	
	1
A CONTRACTOR OF THE OWNER	
A1000000000	
Station of the second	
CONTRACTOR OF THE OWNER	and and a second
Continued	

OPG Confidentian ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

No Lo ≷ Low Lov Low Low Low -Workplans, Job Safety Analysis and pre-job briefings -Oversight from contract administrators and monitors. proceed on more than one boiler at a time. Proposals -Flushing activities previously executed in other units -Project Management to involve vendor with schedule unable to provide required support, Projects will staff are to include tooling, training, and vendor execution -Prepare workplans and develop enhanced flushing development and outage logic, to allow for work to process early to accommodate for a P641 outage. -P541 outage scope was frozen on Dec. 15, 2004. -Maintain close communication between Outage, -Projects is seeking pre-commitments. If CMO is -Maintain close communication between Outage, arrange for an alternate flushing waste handling -a portion of the contingency is allocated for this. -Implementation of OPG Contract Management have produced similar effluents and anticipated -Projects to identify the system capabilities and -Contract administration and monitors are to be assigned to ensure efficient use of resources. shall address adherence to procedures. process if necessary. Projects and Vendor. Projects and Vendor up as required. processes. resources. volumes. Medium Medium Medium Low Low Hígh Execution schedule advanced to P641. Increase in project execution Increase cost for handling duration leading to greater Delay in project execution duration leading to greater Potential for personnel injuries. Delay in schedule. waste. costs. costs. and BCC work if P541 inspections Active Liquid Waste Management Vendor unable to finish execution Advancement in Boilier Flushing Outage schedule may impact on execution of Boiler Flushing and Unsafe work practices during System unable to handle the work along outage schedule. volume of flushing waste. Administration support. pre-requiste activities. Insufficient Contract vendor execution. Health & Safety deem necessary. Environmental Resources Schedule

计结构 的复数人名英格兰人 网络教育教育教师 化乙酰甲基基乙酰乙酰基

CNLABO CENERATION GENERATION

OPG Confidential ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

Low	Low
-Vendors to apply past experience, as similar work was done previously on other units. -Tooling design reviews and mock-up training to be conducted. -Contract administrators and monitors are to ensure that proper procedures are followed. -OS validation to be conducted by Field Engineering.	-Flushing tool design and development to be reviewed and accepted by OPG. Testing as well as mock-up training to be conducted. Enhanced lance provided with video camera. -Contract administrators and monitors are to ensure that proper procedures are followed, and qualified trades are performing the work.
Low	Medium
Re-work required.	Repair work required leading to a schedule delay.
Investment Improper installation of nozzles.	Damage to boiler tubes during flushing activities.



ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

## 7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted	Final AFS	Targeted P	IR Approval	PIR Responsibility (Sponsor Title)	
		<u></u>		0000	Components and	1
Simplified	Jun	2007	Jun	2008	Equipment Manager	l

at second	Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it? (person / group)
1.	Installation of 12 Boiler Nozzles.	12 boiler nozzles are required to be installed in U4.	12 nozzles installed in U4 during P541.	Available for Service (AFS) declaration signed and accepted.	Project Sponsor (Components and Equipment Manager)
2.	Execution of pre and post BCC boiler flushes.	Pre and post BCC Flushing required.	Pre and post BCC flushes executed in support of BCC during P741 (or P641 if schedule is advanced).	Boiler Inspection Report.	Project Sponsor (Components and Equipment Manager)

ONTARIOPOINER GENERATION

OPG Confidential

Page: 11 of 12

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

## U4 Boiler Flushing 13 - 49204

# Full Release Business Case Summary NA44-BCS-36340-00002-R000

Attachment "A"

### Project Cost Summary

\$000's	LTD Prior							LTD This Mth	
SUUU S OM&A	Years							Jan	LTD
an an an an an an an an an an an an an a	2004	2005	2006	2007	2008		Total	2005	%
Project Management (OPG)	440	530	410	510	-	, in the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second s	1,890	440	23.3%
Engineering & Drafting (OPG)	140	165	130	170	-		605	140	23.1%
Material						A PS-Alteria Despera Alteria (Statistica)	ternski proje u Survey († 1997) 1976 - Denos Standard Standard († 1997)		
Installation – PWU, BTU					59000000000		100500157+M49716		
Contract - Project Mgmt									
Contract - Design									
Contract - Installation				anstan 2017					
Contract - Other					ana ana ang ika kata da Ng ika kata ng ika kata	nen orrest (T			
		16000	000000	16 18 States I.C.					
			<u>(746,3)</u> 274-0015	and and a star and a star and a star and a star and a star and a star and a star and a star and a star and a st		and a second second			
· · · · · · · · · · · · · · · · · · ·		<u>a na na na na</u>					<u> </u>		
Interest (Capital Project Only)	1040-00 F								
SubTotal		Reality of the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second		a de se en la serie de la serie de la serie de la serie de la serie de la serie de la serie de la serie de la s	Level with a second second second second second second second second second second second second second second				
(excl Contingency)	en den den ersongen en	recolligation	0.848/8/10	6.2052-2029		1997 (1996) 1997 - 1996 1997 - 1996			
Contingency									
Grand Total	615	5,765	2,160	6,160			14,700	M/A	N/A
2005-2009 Business Plan	1,340	5,000	2,500	4,480	2,500		15,820	N/A	N/A
Variance to Business Plan (excl Contingency)									

Removal Costs included in above	0
Definition Costs included in above	0
Estimate Name, Quality, etc	Release Quality Est +15% to -10%
Design Complete:	40% to 90%

Reviewed By: E.H. Wong Project Manager

Approved By Date:

P. Floyd Eng & Mods Manager (Strat IV)



ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

## U4 Boiler Flushing 13 - 49204

## Full Release Business Case Summary NA44-BCS-36340-00002-R000

ATTACHMENT "B"

SUPERSEDING COST VARIANCE TABLE

Not Applicable.

ONTARIO DIVERSION

#### BUSINESS CASE SUMMARY

#### Pickering A Steam Generator Locking Tab Replacement 13 - 49248

#### Developmental Release Business Case Summary NA44-BCS-33115-00001-R000

Routing	Location	Action	<u>Signature</u>	Date
T. D'Angela Modification Team Leader 701 - 7768	P72-3	Prepare BCS	Staten Daugila	section and
G. Kotwa Section Mgr. Process Scheduling 701 - 3755	P72-1	Review BCS	Manylowa	300012006
G. Keto Manager, Boiler Projects 701 - 2568	P72-3	Review BCS	Sen / Test	3. A. U.
D. Williams Manager, Projects Design Pickering 701 - 4956	P72-3	Review BCS	\$2 pr	16 Mar 07
R. Ball Senior Financial Analyst 702 - 4084	P82-3B6	Review BCS	ROJ.	25 Jun 57
G, Brown Controller Eng & Mods 702 - 5059	P82-3A6	Review BCS	NR	
M. Arnone Director, Projects & Modifications	P72-1	Submit BCS	234e_	25 JUE 207
Leavitt Director Investment Management 701 - 6878	P42-E3	Approve BCS	Pal.	Jame 54, 2007
M. Reid Director Station Engineering, Pickering A 701 - 3645	P42-E1	Approve BCS	mleid	June 27,2007
۰.				
		generalen er en en en en en en en en en en en en en		for an annual second second second second second second second second second second second second second second
R. Ball Senior Financial Analyst 2-4084	P82-3B6	Return For Distribution		

#### Pickering A Steam Generator Locking Tab Replacement 13 - 49248

#### NA44-BCS-33115-00001-R000 Developmental Release Business Case Summary

#### 1/ RECOMMENDATION:

We recommend a release of \$1.2M (including contingency) to complete Preliminary Design of the preferred Steam Generator Locking Tab replacement option, develop a Full Release BCS, and generate a contract strategy for the Pickering A (Units 1 and 4) Locking Tab Replacement project by March 2008.

The business objective of this project is to avoid a significant forced outage due to a locking tab failure on the cold leg of the Heat Transport System. A Fitness for Service evaluation has indicated that the cold leg locking tabs have a minimum lifespan of 6.3 EFPYs. If a cold leg locking tab were to fail, it is speculated that it would cause significant damage to the Heat Transport System, potentially including some components of the reactor core (i.e. fuel bundles). A forced outage would then be required to repair the damage at a projected cost of \$100M and duration of 90 days. More importantly, a locking tab failure could potentially affect OPG's standing with the CNSC and our Power Reactor Operating License (PROL). Beyond 6.3 EFPYs in service, justification for continued operation would be required for Units 1 and 4.

The deliverables of this project are:

- Complete a mini-field campaign to remove and re-install the SG Clamping Dogs in support of inspection by IMS during the P711 Outage
- Develop a new locking tab replacement option which will minimize/eliminate interference with routine Q. maintenance activities as well as meet or exceed SG life expectancy
- Develop a new locking tab replacement option which will minimize project cost, schedule, and dose uptake ø
- Replace the locking tabs currently installed in Unit 1 and 4 steam generators (SG) with a new design prior to the calculated 6.3 year expected lifespan of the locking tabs (2010 and 2011)

Currently, preliminary work has been conducted to acquaint the project team with the project objectives and current field conditions. In addition, a number of locking tab replacement options are being reviewed to determine the most technically viable and cost effective.

As this project is related to Pickering A, there are no issues/opportunities with respect to the ongoing life extension assessment.

\$000's (incl contingency)	Funding	LTD 2006	2007	2008	2009	2010	2011	Later	Total
Currently Released	None	an	narhainte ( ) nates e dan anntañ an bander i bander e et brada	e Andres Arendomieniek alteratuel () examine dan et eine —		a daga yaliyo dag gali yani yeye menindirang menindu an oran.		ngi ayayyang ay palanga yang dinan paninanaka na	•
Requested Now	Developmental	*	850	385					1,235
Future Funding Req'd	Full	-	*		520	7,675	7,905	400	16,500
Total Project Costs		-	850	385	520	7,675	7,905	» 400	17,735
Other Costs									+
Ongoing Costs								an ferrar gebruiter i gebruiter i gebruiter andere andere i Anne de	-
Grand Total		•	850	385	520	7,675	7,905	400	17,735
Investment Sustaini	Type Na	CI: ON	188 184		t on Ec Value 48M	<ul> <li>Interpretation (Control of the Control /li></ul>	}R 2%	に対応についたち ビル・めつん やき	ed Payback .9

M Reid

Submitted B

M. Amone

25 June 207 Date:

Director Projects & Modifications

Finance Approval:

R Loavit

Director Investment Management

Line Approval (Per OAR Element 1.1 Project in Budget):

June 25, 2007 Date:

Director Station Engineering Pickering A



**BUSINESS CASE SUMMARY** 

#### 2/ BACKGROUND & ISSUES

#### Adverse Condition

The Steam Generator Divider Plate sealing skin modification was performed on Units 1, 4, 5-8 starting with Unit 4 in 2001 and finishing with Unit 7 in 2004. The primary purposes of this modification were to address Divider Plate bolt degradation as well as the steady increase in Reactor Inlet Header Temperature (RIHT) which was forcing several units to run derated. All the modifications were completed successfully as measured by the decrease in RIHT for each unit. The steam generator inspections conducted in Unit 5 during the P551 (Spring of 2005) Outage were the first to be done for the PNGS B units following installation of the sealing skin/locking tab modification. These inspections revealed that numerous pieces of locking tabs and divider plate sealing skin had broken off in the hot leg (inlet) side of the steam generators (refer to SCR P-2005-03243) due to high cycle fatigue cracking. Further inspections revealed that all 10 affected steam generators experienced locking tab failures, and 4 of 10 steam generators experienced divider plate skin failures. The root causes of this event were deemed to be insufficient design analysis for the new locking tabs and inadequate installation of the sealing skins to ensure proper seal. Subsequent steam generator inspections in Units 6 and 8 uncovered more broken locking tabs and sealing skins. It is expected that Unit 7 steam generators will exhibit the same adverse condition. There have been no locking tab failures observed in the cold leg (outlet) side of any steam generator inspected. [Note that Pickering A Units 1 and 4 have had no locking tab or skin failures to date but are considered vulnerable to similar failures found in Pickering B SGs.]

#### **Required Repair**

The sealing skin modification installed in the PNGS A units was similar to that of PNGS B, but not identical. Due to the Unit 5 event, PNGS A was obligated to review locking tab design installed in Units 1 and 4 in order to allow for continued operation of the units (refer to SCR P-2005-03370). An Engineering Assessment (NA44-33110) of the locking tabs installed in the PNGS A SGs was performed. In addition, steam generator inspections were conducted and showed that there had been no locking tab failures in the SGs. These two activities allowed for both PNGS A units to run for a period of 1.8 EFPYs since the sealing skin modification. The rationale for continued operation was due to the determination that hot leg tab failures can be tolerated from a reactor safety point of view. Cold leg tab failures were deemed unacceptable as they could produce debris of broken tabs flowing downstream and blocking tabs for PNGS A and PNGS B (P-REP-33115-00001 R01) was conducted. This evaluation proved that cold leg locking tabs will not fail prior to 6.3 EFPY. Thus, replacement of the locking tabs must be completed prior to 6.3 EFPY or 2010 (U4) and 2011 (U1).

#### Similar Previous Replacement Campaigns

As mentioned, hot leg locking tab failures were first found in Unit 5. Upon this discovery, all of the sealing skins, locking tabs, and associated components in all Unit 5 steam generators (except for two steam generators which were previously modified in 1999 with a different design) and all Unit 6 steam generators in the following outage (Units 7 and 8 were delayed in order to re-evaluate the repair strategy) were replaced. These repair campaigns were costly, lengthy, and dose intensive:

Unit 5 – approximately \$11M, 2 months, 33 Rem (10 steam generators) Unit 6 – approximately \$12M, 2 months, 65 Rem (12 steam generators)

The replacement strategy for PNGS A will focus on locking tab replacement (currently installed sealing skins will be retained), and minimizing cost, time, and dose.



**BUSINESS CASE SUMMARY** 

#### 3/ ALTERNATIVES AND ECONOMIC ANALYSIS

		Cost	Cost				
an a sea da na canada da	(164.5)	-	-	(6.5)	-		
OM&A	(336.5)	(17.7)	(18.0)	(33.5)			
Capital	*	*	-	-		an ana amin'ny ana amin'ny fisiana amin'ny fisiana amin'ny fisiana amin'ny fisiana amin'ny fisiana amin'ny fisi	
NPV (after tax)	(157.2)	(9.1)	(9.2)	(18.3)		-	
Impact on Economic Value (IEV)	N/A	148.1	148.0	139.0			
IRR*/-	N/A	79.2%	79.2%	117.2%			
Discounted Payback (Yrs)	N/A	5.9	5.9	6.8			

#### Status Quo - Not Recommended

Status Quo is not a recommended option. The Fitness for Service evaluation conducted on the Locking Tabs proved that cold leg locking tabs have a minimum lifespan of 6.3 EFPYs. After 6.3 EFPYs in service, the risk of cold leg locking tab failure increases, thereby increasing the risk to reactor safety. If a cold leg locking tab were to fail, it is speculated that it would cause significant damage to the Heat Transport System, potentially including some components of the reactor core (i.e. fuel bundles). A forced outage would then be required to repair the damage at a projected cost of \$100M and duration of 90 days. More importantly, a locking tab failure could potentially affect OPG's good standing with the CNSC and in turn OPG's Power Reactor Operating License (PROL). In addition, beyond 6.3 EFPYs in service, justification for continued operation would be required for Units Fand 4.

#### Alternative 1 - Replace Locking Tabs with new design - Recommended

Replacing the current locking tabs installed in Units 1 and 4 with a new design will allow for the following (which are aligned with the project objectives):

- » SGs to run until End of Life (EOL) without the possibility of locking tab failure
- Ability for maintenance to be conducted with minimal interference from the new design which will replace the current locking tabs
- * Ability to remove and/or replace components of the new design with relative ease, if required
- Installation to be less complex, optimizing cost, schedule, and dose

The Locking Tab replacement option will be designed with a substantial amount of rigour as per CNE Directive 05-01. As this modification cannot be commissioned, qualification testing along with required analysis will be performed to ensure that the Locking Tab replacement option is robust and will not become Foreign Material.

This is the only alternative which achieves all of the project objectives and in doing so, is this least expensive and has the greatest Net Present Value (NPV).

#### Alternative 2 - Delay Project - Not Recommended

Delaying the Project is **not** a recommended option. When the Technical Operability Evaluation (TOE) was first generated, it was determined that all affected units (Units 1, 4, 5, 6, 7, 8) would only be able to operate for 1.8 EFPYs since installation of the locking tabs and sealing skins. OPG Projects pursued locking tab life extension ind successfully increased the minimum tab life from 1.8 EFPYs to 6.3 EFPYs. If the project is delayed past 6.3 EFPYs, there is a risk of cold leg locking tab failure which increases over time. As in the Status Quo option, this risk of cold leg locking tab failure is very costly, and has very severe Reactor Safety consequences. There is a slight chance that locking tab failure can be tolerated from a reactor safety point of view beyond 6.3 EFPYs in

ONTARIOPOWER	OPG Confidential	Page: 5 of 15			
GENERATION	BUSINESS CASE SUMMARY				

service, however justification for continued operation of Units 1 and 4 would be required.

Based on the current outage schedules for Units 1 and 4, the Locking Tab replacement will be conducted several months before the end of the minimum tab life (6.3 EFPYs). Thus, there is no benefit to having a separate outage specifically for the Locking Tab replacement, only a few months after the planned outage.

#### Alternative 3 - Replace Locking Tabs with Pickering B design - Not Recommended

Replacing the current locking tabs installed in Units 1 and 4 with a design similar to that of Pickering B (Units 5 and 6) is not a recommended option. Although this option allows the SGs to run until EOL without the possibility of locking tab failure, it does not meet all of the other project objectives previously outlined as is shown below:

- The locking tabs installed in Pickering B are welded on the Hot Leg side of the SG Primary Head and thus are not conducive to removal and/or replacement if required during maintenance activities.
- Due to the bolt configuration in the Pickering A SGs (i.e. uneven bolt spacing), installation of locking tabs similar to those in Units 5 and 6 would be quite difficult.
- Replacement of the Units 5 and 6 locking tabs during 2005 involved a tremendous amount of inspections and rework, and hence was costly, time consuming, and dose intensive.

In addition to the above, this option is more costly than Alternative 1. Therefore, replacing the locking tabs with a design similar to Pickering B is not recommended.

Alternative 4 - - Not Recommended

Alternative 5 – - Not Recommended

ONTARI	0ř	ÛN	
	GE	NER/	ATION

**BUSINESS CASE SUMMARY** 

#### 4/ THE PROPOSAL

A Developmental Release will be used for a mini-campaign (to remove and re-install Clamping Dogs) in support of P711 SG inspections, Preliminary Engineering, to create a contract strategy and complete a Phase 1 BCS.

A Full release will then be requested to:

- Perform the Detailed Engineering
- Award a labour contract (for both units)
- Perform all pre-installation activities for Unit 4 (i.e. workplan preparation, work permits, space allocation, etc.)
- Install, commission, and AFS the modification for Unit 4
- Revise Design Engineering documents as required (i.e. Design ECs, drawings, etc.) for Unit 1
- Start pre-installation activities for Unit 1
- Complete pre-installation activities for Unit 1
- Install, Commission, and AFS the modification for Unit 1
- Close-out the Project

Refer to Appendix C for a list of the project milestones.

#### **UNALITATIVE FACTORS**

Successful implementation of the locking tab replacement project will eliminate the reactor safety risk inherent to the design of the current cold leg locking tabs. Ease of maintainability will be a consideration during the development of the design.

GENERATON

7 of 15 page: OPG Confidentia

BUSINESS CASE SUMMARY

# 6/ RISKS

Description of Risk	Description of Consequence	Risk Betore Mitigation	Mitigating Activity	Risk After Mitigation
Cost Objectives stated in the Developmental BCS will cost more	Unable to accomplish objectives or will require futher release of funds	Low	Clearly defined scope. Regular review of project expenditures. Contingency available.	Low
Scope Preliminary design results in an increase in scope	Change in scope resulting in changes in cost and schedule	High	Scope has clearly been identified through several meetings and a preliminary evaluation of design options.	Medium
Schedule Conflict between Boller activities (Inspection and Locking Tab replacement)	Increase in Outage duration	Medium	Schedule will be optimized to ensure that work is conducted in parallel as much as possible. Divider Plate work has already been moved to 2010 and 2011 to mitigate interference with the Boiler Chemical Clean.	Low
Resources Lack of Design Engineering resources	Delay in Design deliverables	Medium	Design support has been committed to this project	-Low
Technical Locking Tab replacement option does not satisfy all project objectives	Constructability and maintenance issues with design	High	OPG Design and Components and Equipment are actively working together to ensure that an acceptable option is selected. Qualification testing will be done to ensure constructability and maintability issues are addressed and eliminated if possible.	Wedium

		Low				Medium
Page: S of 15	RV	Locking Tab replacement option will be Lo designed with a substantial amount of rigour as per CNE Directive 05-01. Qualification testing along with required analysis will be performed to ensure that the Locking Tab replacement option is robust and will not become Foreign Material.				OPG Design will determine the most viable M locking tab replacement option taking into consideration the requirement for access to low row tubes when performing inspections or maintenance.
	BUSINESS CASE SUMMARY	Wedlum				High
a give of Confidentio						Removal of locking tab replacement components for low row tube plugging may require significant time and resources
		Locking Tab replacement option fails prior to end of SG life.	Regulatory This modification does not require regulatory involvement	or approval Environmental N/A	Health & Safety N/A	Investment Locking Tab replacement option interference with low row tube plugging

**BUSINESS CASE SUMMARY** 

#### 7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Final AFS Date:	Targeted PIR Approval Date:	PIR Responsibility (Sponsor Title)
Simplified	Jun 2011	Jul 2015	Components & Equipment

#### Comments:

	Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it? (person / group)
	Installation of replacement component(s) during P1041 and P1111 outages	N/A	Components installed during respective outages	Schedule review	PNGS A Components & Equipment
2.	Reliable performance (100% non-failure) of components to end of SG/plant life.	6.3 EFPYs	Non-failure of components during life of SGs	<ol> <li>Inspection of components during first and second SG inspection outages following replacement.</li> <li>Confirmed non-failure at subsequent outages to end of SG life.</li> </ol>	PNGS A Components & Equipment
3.		· · · · · · · · · · · · · · · · · · ·	, , , , , , , , , , , , , , , , , , ,		
5.					

#### ONTARIOPOWER GENERATION

#### **BUSINESS CASE SUMMARY**

#### Appendix "A"

#### Glossary (acronyms, codes, technical terms)

- AFS: Available for Service
- CNSC: Canadian Nuclear Safety Commission
- EC: Engineering Change
- EFPY: Effective Full Power Year
- EOL: End of Life
- HTS: Heat Transport System
- NPV: Net Present Value
- RIHT: Reactor Inlet Header Temperature
- PNGS: Pickering Nuclear Generating Station
- PROL: Power Reactor Operating License
- * SG: Steam Generator
- TOE: Technical Operability Evaluation

ONTARIO	GENERATION
---------	------------

Page: 11 of 15

BUSINESS CASE SUMMARY

#### Appendix "B"

#### **Project Funding History**

\$ 000's			Previ	ous Relea Cum	ases (incl ulative Va		ency)				
Release Type	Month	Year	2006	2007	2008	2009	2010	2011	2012	Later	Total
Developmental	in a second second second second second second second second second second second second second second second s	and the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second s	التصليف للملكر ورسيست	850	385	520	7,675	7,905	400		17,735
the state birround		¢				- al					0
							1000 ² 1 1 1				0
		1									0
····									•		0
			an and an in a second second second second second second second second second second second second second second			· · · · · · · · · · · · · · · · · · ·					0
······									,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		0
								an <b>1</b> , an <b>1</b> , an attach ¹ ,, 1 <b>1</b> , <b>1</b> , <b>1</b> , <b>1</b> , <b>1</b> , <b>1</b> , <b>1</b> , <b></b>			0
				1	L	.t	£		å <u>.</u>		
LTD Spent			<b>3</b>		n			]	l		0

#### Comments:

The Developmental Release will be used to cover the cost of a mini-campaign to support P711 SG inspections and complete ~40% of the design. The Full Release will be used to complete 100% of the design, install, commission, AFS the modification in Unit 4. Additionally, it will be used to prepare for Unit 1, install, commission, and AFS the modification in Unit 1, as well as complete Project Close-out.



BUSINESS CASE SUMMARY

Appendix "C"

**Financial Model – Assumptions** 

Project Cost Assumptions:

For the majority of engineering and design work, overtime has been assumed to be 10%. For field personnel, overtime has been assumed to be 25%.

**Financial Assumptions:** 

The rate of inflation estimated at 2% is consistent with Corporate guidelines.

Project / Station End of Life Assumptions:

Based on a memo to D. Power from P.R. Charlebois, "Pickering Units 1 & 4 End of Service Life Predictions for Establishing Book Value", January 12, 2006, we have assumed that Station End of Life for Units 1 and 4 will be in 2021, thus requiring replacement of the Locking Tabs during 2011 and 2010 respectively.

It is assumed that the Locking Tab replacement modification will be conducted during Fall 2010 for Unit 4 and Fall 2011 for Unit 1.

It is assumed that the majority of design work will be completed well before the 2009 outage milestone.

Energy Price / Production Assumptions

The price of energy is estimated based on Corporate System Economic Values. Production from each Pickering A unit is assumed to be 516 MW at a capacity factor of 80%.

**Operating Cost Assumptions** 

M/A

Other Assumptions:

It is assumed that if a Cold Leg locking tab were to fail, it would cause damage to the Heat Transport System (HTS). The forced outage required to repair the HTS is assumed to cost \$100M and be 90 days in duration.

The risk of Cold Leg locking tab failure is assumed to be 5% starting in 2011 (U4) and 2012 (U1) and increasing at a rate of 5% per year.

The probability of Cold Leg locking tab failure in Units 1 and 4 simultaneously is too low to be considered. If a failure were to occur in one unit, the 2nd unit would be shut down immediately.

BUSINESS CASE SUMMARY

#### Pickering A Steam Generator Locking Tab Replacement 13 - 49248

#### Developmental Release Business Case Summary NA44-BCS-33115-00001-R000

#### Attachment "A"

#### Project Cost Summary

	LTD	This	s a This 4	Future	Future	Future	Future		
\$000's	Prior Yr	Release	Release	Release	Release	Release	Release		
OM&A	2006	2007	2008	2009	2010	2011	2012	Later	Total
Project Management (OPG)		221	175	137	395	434	177		1,539
Engineering & Drafting (OPG)	_		160	86	157	168	96		666
Material		an an an an an an an an an an an an an a	ter (in the second second second second second second second second second second second second second second s					ing a fair of a set of a transition of a set of a set of a set of a set of a set of a set of a set of a set of	
Installation - PWU, BTU							10.000.001		
Contract - Design					1.				
Contract Installation			0.000		115 S G G				
Contract - Other									
Installation - IMS					00000000000	60			
Kinectrics									
Interest (Capital Project Only)									· ·
Project Costs (excl contingency)					日本 生物 う	感感で引き			
General Contingency			50	200	500	201	100		
Specific Contingency									
Project Costs (Incl contingency)	121210-021	850	385		7,675	7,905	400		17,735
2007-2011 Business Plan		300	100	500	7,100	7,100	300		15,400
Variance to Business Plan	1000 at 200	400	235	(180)	75	105			635
Committed Cost		Promotion Control of Particle Westerland and a straightform			a for summed processing of a classic constitution for the processing	an gan dina mangkan malalak nyengalipen pakan palam dina dina ma ² ka			-
Inventory Write Oil Required		j · . ·							+
Spare Parts / inventory		B. A. Constrained and a second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second sec				- for			NA (1.17) (1.17) (1.17) (1.17) (1.17) (1.17) (1.17)
Total Release (excl contingency)						agangan pengerangan kana pengerangan Tanggan pengerangan kana pengerangan pengerangan pengerangan pengerangan pengerangan pengerangan pengerangan pe			
Total Release (incl contingency)		850	385	520	7,675	7,905	400		17,735
Ongoing OM&A (non-project)									-
Removal Costs (Incl in above)									

Design Complete		Up to - 40%	Quality of E	Istimate	Conceptual +	60% to - 25%
3 rd Party Estimate	N/A	OPEX used	Yes	Lessons Lea	arned	Yes
Reviewed by Sponsor	Yes	Budgetary Quote(s)	No	Phase 1 Act	ual Used	N/A
Similar Projects	Yes	Contracts in place	N/A	Competitive	Bid	N/A

The estimated variance(s) to the 2006-2010 Business Plan will be addressed through the portfolio management process. A PCRAF will be approved by May 2007.

Reviewed By:

APR/35/2207

Approved By Jerry Keto

Eng & Mods Manager (Strat IV)

Date:

Péjman Asganpour Project Manager

Date:

ONTARIOPOWER GENERATION OPG Confidential

Page: 14 of 15

BUSINESS CASE SUMMARY

## Pickering A Steam Generator Locking Tab Replacement 13 - 49248

## Developmental Release Business Case Summary NA44-BCS-33115-00001-R000

#### Attachment "B"

#### **Project Variance Analysis**

		Choos	e One		
OM&A	ltd - NVA NVA	Last BCS N/A N/A	This BCS Sep N/A	Variance	Comments
Project Management (OPG)				0	والمحافظ المراجع والمراجع والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحافظ والمحا
Engineering & Drafting (OPG)				0	
Material				<u></u>	
Installation - PWU, BTU					
Contract - Design					
Contract - Installation				indiadent.	
Contract - Other		a second and a second			
Kinectrics	1				
Interest (Capital Project Only)	b				
Project Costs (excl contingency)		0.000	lever () ever		
General Contingency	7				
Specific Contingency					
Project Costs (Incl contingency)	0	0	0	1 (in 1	1000 sectors of the sector and readers and the
mitted Cost				0	
Untory Write Off Required				0	
Spare Parts / Inventory	e entre autopologie - 1679 (n. 1000) Million (n. 1000) - 1000			0	
Total Release (incl contingency)	0	0	0	0	
Total Release (exci contingency)	0	0	0	0	
in an ing in a Spin Allin with a Manufacture and an and a Spin in a Spin in a Spin Andrew Market with a spin s					
Ongoing OM&A (non-project)				0	
Removal Costs (Incl in above)	お客心作品			0	

#### Comments:

This project was identified in June 2005. Currently, conceptual funding is being used to perform minimal design work and to generate the Developmental BCS.

ONTARIOFORER GENERATION

**OPG** Confidential

Page: 15 of 15

BUSINESS CASE SUMMARY

#### Attachment "C"

#### Key Milestones

Cor	npletion i	Jate	Description
Day	Mth	Yr	
30	Apr	2007	BCS: Developmental Release Approved
30	Jun	2007	PSM: Plan Start Milestone
16	Oct	2007	SOI: Start of mini Field Campgain (P711 Clamping Dog Removal/Re-install)
30	Apr	2008	FR1: Full Release BCS Approved
15	Apr	2009	FD1: Final Design Complete (Unit 1 and Unit 4)
15	May	2009	MCA: Major Contracts Awarded
15	Apr	2010	SOI: Start of Installation (Unit 4)
30	Jun	2010	AFS: Available for Service Meeting (Unit 4)
31	Dec	2010	ECC: EC Close-out (Unit 4)
31	Mar	2011	SOI: Start of Installation (Unit 1)
15	Jun	2011	AFS: Available for Service Meeting (Unit 1)
27	Jun	2011	PCS: Close-out Starts
21	Dec	2011	PCM: Plan Complete Milestone

A Project Execution Plan (PEP) will be approved by Jul 2008

#### Comments:

All applicable milestones will be in accordance with N-PROC-MA-0013 (Planned Outage Management) as the ocking tab replacement will be conducted during the 2010 and 2011 outages.

## ONTARIO GENERATION

New requests for project funding (including incremental funding for approved projects) must be documented in a Business Case Summary. This form must be completed for submission of all new funding requests to the Assat Investment Screening Committee.

Guidelines for	Evaluation	of New.	Funding	Requests at	Asset Investme	nt Screening.

Part A - Issue Characterization (normally completed in conjunction with Project Charter)

		19 M 19		
		(2) 3 71	20.2	17
100				
	한 날 수요 것		1	\$C.
10.00	5 1 M 19 49 49 49 19 19			

والإيطوي في الى المان

#### Project Number: 49248 Project Title: Pickering A Steam Generator Locking Tab Replacement

Sponsoring Organization: Pickering A	Classification: OM8A
Most Recently Approved: Cnatter	Funding Release to Date: \$ 0.00 Million
Invostment Type: Sustaining	Estimate Quality: Conceptual

Base Case Analysis ("No Project" option)

The following section must be completed for the "No Project" option. The probability, consequences and urgency for the status que situation are documented, with an estimation of the costs of the "no project" option for use as a benchmark for other alternatives.

#### Missed Opportunity or Risk/Adverse Condition to be Managed for "No Project" Option

The Steam Generator (SG) Divider Plate scaling skin modification was installed in Units 1& 4 to address Divider Plate belt degradation as well as the sloady increase in Reactor Intel Header Temperature (RIHT) which was forcing units to run derated. All the modifications were completed successfully as measured by the decrease in RIHT for each unit. SG inspections conducted in Unit 5 during the P551 Outage revealed that numerous pleces of locking tabs and divider plate scaling skin had troken at the hot leg (inlet) side of the steam generators due to high cycle fatigue cracking. The root causes of this event were doemed to be insufficient design enalysis for the new locking tabs and inadequate installation of the scaling skins to ensure preper seal. Subsequent SG inspections in Units 6 and 8 uncovered more broken locking tabs and scaling skins. There have been no tocking tab failures observed in the celd leg (cutlet) side of any SG inspected. Pickering A Units 1 and 4 have had no locking tab or skin failures to date but are considered vulnerable to similar failures found in Pickering B SGs.

A Fitness for Service evaluation has indicated that the cold teg locking tabs have a minimum tifespan of 6,3 Effective Full Power Years (EFPY). If a cold teg locking tab were to fail, it would cause significant damage to the Heat Transport System: potentially including some components of the reactor core. A forced outage would then be required to repair the damage at a projected cost of \$100M and duration of 90 days. Beyond 6,3 EFPY since the modification's in service, justification for continued operation would be required for Units 1 and 4.

Priority Coding	Probability (P)	Consequence (C)	Urgency (U)	Priority (P×C×U)
a Lunuch Monuch	4	4	4	64

Probability Coding	Urgency Coding		
1. Improbable (< 10%)	1. Long Term (telérable delay > 4 years)	Example 1	
2. Unlikely (10% - 30%)	2. Flexible (tolerable delay 2 - 4 years)		 ******
3. Possible (30% - 70%)	3. Some Flexibility (toterable delay 1 - 2 years)		 
4. Likely (70% - 90%)	4. Little or No Flexibility (tolerable delay 6 month	is 1 year)	
5. Probable (> 90%)	5. Existing or Imminent Condition (tolerable dela	iy < 6 months)	

 Consequence Coding
 (measured over remaining life of station)

 1.
 Low (< \$1M; small release; minor injury; regulatory non-compliance with few implications; minimal impact on employee engagement)</td>

 2.
 Marginal (\$1M - \$10M; small release; minor injury; regulatory non-compliance with few implications; some employee dissatisfaction)

Medium (\$10M - \$30M; moderate release; serious injury; regulatory non-compliance with implications; measurable impact on employee engagement)
 High (\$50M - \$200M; moderate release; serious injury; regulatory non-compliance with implications; potential for tabour conflicts)
 Significant (> \$200M; large release; potential employee/public fatality; significant regulatory non-compliance; major impact on

employee engagement)

#### Issue Screening - Significance of the "No Project" Base Case on Business Drivers

3-1 y	A	Firm regulatory commitment with established due date; significant employee/public safety issue.	
	8	Potential plant shut down if not miligated.	
	C	Potential unit shutdown if not miligated,	Issue Screen
And the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second se	0	Supporting or critical to the achievement of unit Business Plan objectives.	G
3:	ise (	Case Net Present Value	

The NPV for the Base Case is the impact on shareholder's value of not implementing the project. It consists of all custs (expense and loss of revenue) that will take place in the tuture to operate in normal fashion or work around the condition if the project is not implemented: Because these costs are an outflow of cash, the value is negative (or zero); this serves as a benchmark against which to measure the NPVs of other alternatives.

NPV_{Base}: - \$ 156.9

Part B - Option Characterization (normally completed in conjunction with Developmental Business Case Summary)

Option Analy	~ra	agains	at the NPV of	the Base Ca	ise, and spec	cific screenin	g gales are e	valuated for	the provided a	ilternativos.
		g the curré the followi		ibs installed i	n Units † and	4 with a new	v design will	I	ΝΡΫΑΠ	- \$ 9.1
1	1		*	3 (EOL) with	nut the possil	oility of tockin	g tab failure	NPV,	un - NPV9444	+ \$ 147.B
bebnommoson) oplioni			nteriance to t will replace ti			d interference	s from the ne	W Lega	il Regulatory	8
	🐟 Adili	- ty to remo	we and/or ro			new design v	with relative	Safety/	Environmenta	8
		a, if requir- altation to		olex, apiimizi	na cost, scin	idide, and do	160	Peo	ele Postazi	8
	The Lock	ing Tab re	eplacement o	ption will be	designed wit	h a substanti	al amount of	flaso	urse:Financial	8
*- 9 ⁴	qualificati	an testing	along with r	equired anal	ysis will be p	annot be con enformed to c	insure that th	G Assol	Preservation	10
	Locking T	fab replac	ement option	n is robust ar	id will not be	came Foreigi	ı Malerial.	Do-a	bility Total	42
Required Cash	Flow (S.N	blions)	< 2006	2007	2008	2009	2010	2011	> 2011	Total
	no construction and the second	Request	0	0.8	0.4	0.5	77	7.9	0.4	17.
nam and an annual amount of the state of a state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the s		set Total	0	Q.9	0.4	0.5	7.7	7.9	0.4	17.
sa anna an tao an tao an tao an tao an tao an tao an tao an tao an tao an tao an tao an tao an tao an tao an ta	Delaying	the Proia	tis na a ne	and the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set of the set		<b>*****</b> *******************************				99999 (******* ****); (**********************
	Dellaying	the Froiet	CT IS FROM O FRA							
0	risk of co	ld leg lock	ing tab failur	a la varv cos	tiv, and has	verv severe P	teactor Safet	v	NPVail	- \$ 18.5
2	risk of co conseque a reactor	ld leg lock inces. Th salely poi	iing tab failur iere is a sliph int of view be	e is very cos it chance the syond 6.3 EF	by, and has a t locking tab PYs in servic	in the Status very seivere F failure can bi te, however j	teactor Safet e tolerated fro	y 2m NPV	NPV _{All} M - NPV _{Base}	+ \$ 138.4
2	risk of co conseque a reactor continued	ld leg lock ences. Th salely poi t operation	ing tab failur iere is a sliph int of view be n of Units 1 a	e is very cos it chance the ayond 6.3 EF and 4 would t	tly, and has a t locking tab PYs in servic be required.	very seivere F failure can b te, however j	leactor Safet e tolerated fro ustification fo	y 2m NPV,		+ 5 138.4 4
2	risk of co consequi a reactor continuer Based on replacem	ld leg lock ences. Th safely poi d operation the curre ent will be	ling tab failur bare is a sliph Int of view be n of Units 1 a int outage sc a conducted e	e is vary cos it chance tha ayond 6.3 EF and 4 would t hedules for t soveral mont	ty, and has a t locking tab PYs in servic as required. Joits 1 and 4 hs before the	very severe F failure can be to, however j . The Locking a end of the n	teactor Safet a tolerated fro ustification fo Teb	y om <u>NPV</u> Ir Logr	w - NPV _{llasa}	+ <b>5 138.</b> 4 4 8
2	risk of co conseque a reactor continuet Based on replacem (6.3 EFP	ld leg lock ences. Th safely poi d operation the curre ent will be Y). Thus;	ting tab failtur tere is a stiph Int of view be in of Units 1 a int outage sc a conducted a there is no b	e is very cos it chance tha zyond 6,3 EF and 4 would t hiedules for t soveral mont benefit to hav	ty, and has a t locking tab PYs in servit be required. Joits 1 and 4 hs before the ing a separa	very severe F failure can b te, flowever j , the Locking	teactor Safet a tolerated fro ustification fo Tab alnimum tob acilicatly for t	y 2m NPV, If Lagr	na - NPV _{Basa} Willegulatory	+ \$ 138.4 4 8 5
2	risk of co conseque a reactor continuet Based on replacem (6.3 EFP	ld leg lock ences. Th safely poi d operation the curre ent will be Y). Thus;	ting tab failtur tere is a stiph Int of view be in of Units 1 a int outage sc a conducted a there is no b	e is very cos it chance tha zyond 6,3 EF and 4 would t hiedules for t soveral mont benefit to hav	ty, and has a t locking tab PYs in servit be required. Joits 1 and 4 hs before the ing a separa	very severe F failure can be to, however j , the Locking a end of the n te outage spi	teactor Safet a tolerated fro ustification fo Tab alnimum tob acilicatly for t	y 2m NPV, ir Laga life Saleny he Pac	ka - NPV _{Basa} a/Regulatory Environmenta)	+ <b>5 138.</b> 4 4 8
2	risk of co conseque a reactor continuer Based or replacem (6.3 EFP Locking T	Id leg lock ences. Th safety poi J operation I the curre ent will be Y). Thus, Fab replac	ing tab failur ere is a sligh Int of view be n of Units 1 a nt outage sc a conducted i there is no b coment, only-	e is vary cos It chance the syond 6.3 EP and 4 would 1 hedules, for t several mon benefit to hav a few month	By, and has t I locking tab PYs in servit as required. Joits 1 and 4 Joits 1 and 4 Joits 1 and 4 Joits 1 and 4 Joits 2 and 1 Joits 1 and 4 Joits 2 and 1 Joits 2 and 1 Joi	very severe F failure can b te, however j , the Locking a end of the n te outage sp anned outage	teactor Safet a tolerated fro ustification fo Tab alnimum tob acilicatly for t	y NPV, rr Lagi life Sulety, he Pec	na - NPV(Jana anRegulationy Environmenta) opto/Political	+ \$ 138.4 4 8 5
	risk of co conseque a reactor continuer Based or replacem (6.3 EFP Locking T	Id leg lock ences. Th safety poi J operation I the curre ent will be Y). Thus, Fab replac	ing tab failur ere is a sligh Int of view be n of Units 1 a nt outage sc a conducted i there is no b coment, only-	e is vary cos It chance the syond 6.3 EP and 4 would 1 hedules, for t several mon benefit to hav a few month	ty, and has a t locking tab PYs in servit be required. Joits 1 and 4 hs before the ing a separa	very severe F failure can b te, however j , the Locking a end of the n te outage sp anned outage	teactor Safet a tolerated fro ustification fo Tab alnimum tob acilicatly for t	y NPV, ir Logi life Sulery he Pec Frator	na - NPV _{IIa} a:Regulatory Environmenta) Ipta/Political urce/FinaAciat	+ 5 138.4 4 8 5 8
2 Required Cash	risk of co conseque a reactor continuer Based or replacem (6.3 EFP Locking 1 Locking 1 Flaw (5 M	Id leg lock noces. Th safety poi J operation the curre ent will be Y). Taus, Fab replac mative is illions)	ing tab failur ere is a sligh Int of view be n of Units 1 e n of Units 1 e conducted 2 there is no b sement, only clearly distin	e is vary cos it chance tha ayond 6.3 EF and 4 would 1 hedulos, for t soveral mont benefit to hav a few month: ctive from the 2007	ty, and has t I locking tab PYs in servit be required. Joits 1 and 4 ha before the ing a separa s after the pla a recommence 2008	very severe F failure can b te, however j , the Locking a end of the n te outage spe anned outage ted option.	toactor Safet a tolerated fr ustification fo Tab alphimum tob actifically for t actifically for t actifically for t actifically for t	y NPV, Ir Lagi life Sulen, hio Pec Reso Reso Do-a 2011	An - NPV _{Base} a Regulatory Environmental pla/Political unceFinancial Preservation billity Total > 2011	+ 5 138.4 4 8 5 8
2011/11884/1011-04110-1-0211-02110-0210-021-021-021-021-02	risk of co conseque a reactor continuet Based or replacem (6.3 EFP Locking T Locking T Locking T Flow (5 M This I	Id leg lock noces. Th safety poi 1 operation 1 the curre 1 operation 1 the curre 1 operation 1 operati	ing tab failur ere is a stigh Int of view be no of Units 1 a ant outage sc s conducted of there is no b comant, only clearly diating < 2006	e is vary cos t chance the ayond 6.3 EF and 4 would 1 hedules, for t soveral monther a few monther ctive from the 2007 6.1	ty, and has t t locking tab PYs in servit a required. Joits 1 and 4 ha before the ing a separa s after the pla a recommend 2008 0.7	very severe F failure can be te, however j , the Locking a end of the n te outage spi anned outage ped option.	loactor Safet a lolarated fr ustification fo Tab ninimum tab scifically for t s. 2010 0.7	y Ir If Sulen, Ne Pec Flatch Assist Do-a 2011 7.9	ka - NPVussa skitegulatory Environmental splexbolitical urcoFinancial I Preservation billity Total > 2011 - 8.5	+ \$ 138.4 4 8 5 8 4 4 Total 18.
	risk of co conseque a reactor continuet Based or replacem (6.3 EFP Locking 1 Locking 1 Locking 1 Flaw (5 M This I Proje	Id leg lock moses. Th safety poi o operation of the curre ent will be Y). Thus, Fab replac mative (s illions) Request act Total	ing tab failur lere is a stip! Int of view be not Units 1 a mit outlage sc a conducted o there is no b comont, only clearly diatin < 2006 0	a is vary cos t chance the syond 6.3 EF and 4 would 1 hedutes for t soveral month a few months ctive from the 2007 0.1 0.1	tly, and has t t locking tab PYs in servit Joits 1 and 4 hs before the ing a separa s after the pla a recommence 2008 0.7 0.7	very severe F failure can br te, however j . the Locking a ond of the n te outage spe anned outage ted option. 2009 0.3 0.3	leactor Safet e Iolerated fr ustification fo Tab ninimum tab scifically for t s. 2010 0.7	y NPV, Ir Lagr Ilife Sulery, Ne Poc Resco Resco Do-a 2011 7.9	An - NPV(IIIIA Alteritation Environmental meta/Political uncerFinancial Preservation billity Total > 2011 3.5 8.5	+ \$ 138.4 4 8 5 8 4 4 Total 18,
NA 1998 PARTO ARTINO PROVINSI ANTINO	risk of co conseque a reactor confleuer Based or replacem (6.3 EFP) Locking T Locking T Locking T Flow (5 M This I Proje Replacing Bat of Pi allows the	Id leg lock noces. Th safety poi J operation I he curre ent will be Y). Taus, Fab replac mative is itilions) Request act Total g the curre ckering B p Scs tor Scs tor	ing tab failur ere is a stigh Int of view be n of Units 1 e ant outage sc conducted a there is no b coment, only- clearly diatine < 2006 0 0 0 ant locking ta (Units 5 and EOL	e is vary cos it chance the ayond 6.3 EF hedulos for t several mont benefit to hav a few months ctive from the 2007 0.1 0.1 b) is not a re without the r	ty, and has it locking tab PYs in servic a required. Joits 1 and 4 the before the ing a separa s after the pla a recommended 2008 0.7 0.7 n Units 1 and commended	very severe F failure can be be, however j , the Locking a end of the n te outage spe anned outage need outage ded option. 2009 0.3 0.3 1.4 with a det option. Alth coking ten fa	toactor Safet a tolerated fr ustification fo Teb hinimum teb actifically for t b. 2010 0.7 0.7 algn similar to use this cot	y NPV, If Logi Sulery Reform Reform 2011 7.9 7.9 100	ka - NPVussa skitegulatory Environmental splexbolitical urcoFinancial I Preservation billity Total > 2011 - 8.5	+ \$ 138.4 4 8 5 8 4 4 Total 18.
Required Cash	risk of co conseque a reactor continuet Based or replacem (6.3 EFP) Locking T Locking T Locking T Flow (5 M This I Proje Replacing Bat of Pi allows the meet all c ♦ The	Id leg lock noces. Th safety poi J operation I the curre ent will be Y). Tous, Fab replac mative is itilizons) Request ict Total g the curre ckering B p SGs to p SGS	ing tab failur ere is a stigh Int of view be n of Units 1 e ant outage sc conducted a there is no b coment, only- clearly diatine < 2006 0 0 ant locking ta (Units 5 and 0 0 ant locking ta (Units 5 diata) 0 0 ant locking ta (Units 5 diata)	e is vary cos It chance the syond 6.3 EF and 4 would 1 hedulos for 1 soveral month crive from the 2007 0.1 0.1 b) is not a re without the p ectives due to in Pickering 5	ty, and has it tocking tab PYs in servic a required. Joits 1 and 4 the before the ing a separa s after the pla a recommended 2008 0.7 0.7 0.7 n Units 1 and cossibility of o the followin 3 are welded	very severe F failure can be be, however j , the Locking a end of the n te outage sp anned outage need outage outage 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3	teactor Safet a tolerated fr ustification fo Tab Infimum tob crifically for t b 2010 0.7 0.7 0.7 0.7 sign similar to ough this opt illure, it does on side of the	y NPV, taga life Sulen, h6 Pec Pation 2011 7.9 7.9 100 not NPV, a Lega	A - NPV(IIIIA A Regulatory Environmental pterbolitical uncerFinancial IPreservation billity Total > 2011 8.5 8,6 NPV as	+ \$ 138.4 4 8 5 8 4 7 7 0 7 8 4 18 18 5 5 8 4 18 5 18 5 18 5 18 5 5 18 5 18
Required Cash	risk of co conseque a reactor continuet Based or replacem (6.3 EFP Locking 1 Locking 1 Locking 1 Proje Replacing that of Ph allows the most all c SG 1 requ	Id leg lock moses. Th safety poi operation operation operation operation operation operation (the curre charling B operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation operation o	ing tab failur iere is a stiph lot of view be not Units 1 a mt outage so a conducted of there is no b content, only clearly diatine < 2006 0 ant locking ta (Units 5 and un unit EOL, rr project obje bis installed i bis installed i bis installed a	a is vary cos t chance the syond 6.3 EF and 4 would 1 hedules for t soveral month crive from the crive from the 2007 0.1 be installed i b) is not a re- without the j ectives due to in Pickering fi s are not con- ce activities.	tly, and has t t locking tab PYs in servit as required. Joits 1 and 4 hs before the ing a separa s after the pla a recommende 0.7 n Units 1 and commended possibility of o the followin B are wilded ducive to rem	very severe F failure can be te, however j . the Locking and of the n te outage spe anned outage ded option. 2009 0.3 0.3 d.4 with a der option. Alth locking tab fa g: on the Hol L noval and/or	teactor Safet e Iolerated fr ustification fo Tab ninimum tab actifically for t actifically for t actif	y m r Logi Sulery hi Pec Pec Pec Asiet Do-a 2011 7.9 7.9 0 fon fiot NPV, Logi Logi f Safety	An - NPV Intervention Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipological Antipologica	+ \$ 138.4 4 8 5 8 4 7 7 0 7 8 4 18 18 5 5 8 4 18 5 18 5 18 5 18 5 5 18 5 18
Required Cash	risk of co conseque a reactor continuet Based or replacem (6.3 EFP Locking T Locking T Locking T Locking T Proje Replacing that of Pil allows the most all c \$ The SG I requ \$ Pop skin;	Id leg lock no.es, Th safety poil 1 operation 1 the curre (the curre (the curre) (the cure	ing tab failur ere is a stight int of view be not Units 1 a ent outage sc s conducted a there is no b coment, only clearly disting 2006 0 ent locking ta (Units 5 and un until EOL er project obje ibs installed i bad and thus g maintenan mping otate	e is vary cos t chance the ayond 6.3 EF and 4 would 1 hedules, for t several monther crive from the 2007 0.1 0.1 0.1 0.1 105 installed ti 5) is not a re- without the p ectives due to in Pickering 5 s are not con- ce activities. FEX, the cost in Unit 5 a	ty, and has t t locking tab PYs in servit be required. Joits 1 and 4 hs before the ing a separa s after the pla a recommende 2008 0.7 0.7 n Units 1 and commended iossibility of o the followin 3 are wolded ducive to rem	very severe F failure can be te, however j , the Locking a end of the n te outage spe anned outage anned outage 0.3 0.3 d.4 with a des option. Alth tocking tab fa g: on the Hol L toval and/or weided lock as \$12Mon	teactor Safet a tolerated fr ustification fo Tab hinimum tab actifically for t b 2010 0.7 0.7 0.7 sign similar to ough this opt dure, it does og side of the replacement	y NPV, F Logi Sulery, NB Pec Sulery, Pec Pec Pec Pec Pec Pec Pec Pec	ka - NPV(Java a) Regulatory Environmenta) opto/bolitical uncorFinancial Preservation billity Total > 2011 3.5 8.6 NPV as siRegulatory	+ \$ 138.4 4 8 5 8 4 7 7 0 7 8 4 18 18 5 5 8 4 18 5 18 5 18 5 18 5 5 18 5 18
Required Cash	risk of co conseque a reactor continuer Based or replacem (6.3 EFP Locking T Locking T Locking T Flow (5 M This I Proje Replacing that of Plu allows the meet all c \$ G Pop SGI reque \$ Pop skin: weld	Id leg lock moses. Th safety poil operation the curre- ent will be Y). Thus, Tab replac mative is r (Y). Thus, Tab replac the curre charter of the curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre curre cure cu	ing tab failur ere is a stight int of view be n of Units 1 a ent outage sc s conducted of there is no b coment, only clearly disting < 2006 0 ent locking ta (Units 5 and un until EOL er project obje ibs installed i g maintenan nd Unit 6 OP mpping plate g tabs alone	e is vary cos t chance the ayond 6.3 EF and 4 would 1 hedules, for t several monther crive from the 2007 0.1 0.1 0.1 0.1 0.1 0.1 0.1 0.1	ty, and has t t locking tab PYs in servit be required. Joits 1 and 4 hs before the ing a separa s after the pla a recommend 2008 0.7 0.7 n Units 1 any commended iossibility of o the followin 3 are wilded ducive to ren t of installing nd Unit 6 w 80% of total	very severe F failure can be te, flowever j , the Locking a end of the n te outage spe anned outage anned outage 0.3 0.3 d.4 with a des option. Alth tooking tab fa ig: on the Hot L noval and/or weided lock ras \$12M/uni cost.	teactor Safet a tolerated fr ustification fo Tab infimum tab actifically for t actifically for t actif	y NPV, NPV, Logi sulen, Sulen, NPV, Logi Reich 2011 7.9 7.9 7.9 160 NPV, Logi 16 3stely 16 3stely 100 8	An - NPV Interview of the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second sec	+ \$ 138.4 4 8 5 8 4 7 7 0 7 8 4 18.1 18.1 19.1 5 11.2
Required Cash	risk of co conseque a reactor continuet Based or replacem (6.3 EFP Locking T Locking T Locking T Locking T Proje Replacing that of Pil allows the meet all c SG I requ SG U requ SG Due skin: weld	Id leg lock no.es, Th safety poi 1 doperation 1 the started Y). Thus, Tab replac (Y). Th	ing tab failur ere is a stight int of view be not Units 1 a ent outage sc a conducted a there is no b centry distinct a conducted a there is no b centry distinct a conducted a conducted a there is no b centry distinct a configuration of Units 6 OP mping plate g tabs alone it configuration of Units 6 or mping plate	e is vary cos t chance the ayond 6.3 EF and 4 would 1 hedules for t several monther crive from the 2007 0.1 0.1 0.1 0.1 0.1 0.1 105 installed i 6) is not a re- without the p ectives due to in Pickering for ce activities. PEX, the cost in Unit 5 a accounts for on in the Pick	ty, and has t t locking tab PYs in servit be required. Joits 1 and 4 hs before the ing a separa s after the pla a recommence 2008 0.7 0.7 0.7 0.7 0.7 0.7 0.7 0.7 0.7 0.7	very severe F failure can be te, however j , the Locking a end of the n te outage spe anned outage anned outage 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3	teactor Safet a tolerated fr ustification fo Teb Infimum teb ecifically for t ecifically for t ecifical for the replacement ing tobs, sea t, installation of locking fab	y NPV, If Legi Sulery, Legi Sulery, Pec Pec Pec Pec Pec Pec Pec Pec	ka - NPViissa skilogulaidry Environmental sple/Political uncerFinancial Preservation billity Total > 2011 3.5 8.5 NPV as skilogulatory Environmental scie/Political	+ \$ 138.4 4 8 5 8 4 7 7 0 7 0 7 18 18 - \$ 11.2
Required Cash	risk of co conseque a reactor conflueet Based or replacem (6.3 EFP Locking T Locking T Locking T Locking T Proje Replacing that of Pil allows the moet all c ⇒ The SG I requ ⇒ Poy skin weld ⇒ Repl	Id leg lock no.es, Th safety poi 1 (b operation 1 (b operation 1 (b operation 1 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (b operation 2 (	ing tab failur ere is a stigh int of view be n of Units 1 a int outage sc s conducted a there is no b sement, only- clearly diatine < 2006 0 ant locking ta (Units 5 and un until EOL r project obje ibs installed i lead and thus g maintenan nd Unit 6 OP mping plate g tabs alone it configuratio e in Units 5 c	e is vary cos t chance the ayond 6.3 EF hedulos for t several mont benefit to hav a few month: ctive from the 2007 0.1 0.1 ibs installed i b) is not a re- without the p ectives due to in Pickering for a accounts for an in the Pick and 6 would 1 5 and 6 lockit	ty, and has it tocking tab PYs in servit be required. Joits 1 and 4 the before the ing a separa s after the pla a recommended possibility of a the followin 3 are wolded ducive to rem t of installing md Unit 6 w 80% of total learing A SGs be quite diffic no tabs inveit	very severe F failure can be be, however j , the Locking a end of the n te outage spe anned outage need outage 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3 0.3	teactor Safet a tolerated from ustification for Tab Infimum tab actifically for t be 2010 0.7 0.7 0.7 0.7 0.7 0.7 0.7 0.7 0.7 0.	y NPV, If Legi Sulery, Legi Sulery, Pec Pec Pec Pec Pec Pec Pec Pec	An - NPVulain autopulation autopulation pleufoulleau unceFinancial Preservation billity Total > 2011 3.5 8.5 NPV au sun - NPV game sun - NPV game	+ \$ 138.4 4 8 5 8 4 7 7 0 7 0 7 18 18 - \$ 11.2
Required Cash	risk of co conseque a reactor continuet Based or replacem (6.3 EFP Locking T Locking T Locking T Locking T Proje Replacing that of Pil allows the meet all c SG I requ SG I requ SG Due skin: weld S Due skin:	Id leg lock no.es. Th safety poil 1 doperation 1 the stare 1 doperation 1 the stare 1 doperation 1 the stare 1 doperation 1 the stare 1 the stare 1 doperation 1 the stare 1 doperation 1 d	ing tab failur ere is a stight int of view be not Units 1 a ent outage sc s conducted a there is no b centry distinct a conducted a there is no b centry distinct a conducted a conducted a there is no b centry distinct a conducted a g maintenan of Units 6 OP mping plate g tabs alone at configuratic o in Units 6 of the Units 6 of the Units 6 of the Units 6 of the Units 6 of the Units 6	e is vary cos ti chance the ayond 6.3 EF and 4 would 1 hedules, for t several monther crive from the 2007 0.1 0.1 0.1 0.1 0.1 0.1 0.1 0.1	ty, and has it locking tab PYs in servit be required. Joits 1 and 4 ha before the ing a separa s after the pla a recommended possibility of o the followin 3 are welded ducive to rem t of installing md Unit 6 we 80% of total learing A SGs be quite diffic no tabs inveit	very severe F failure can be te, however j , the Locking a end of the n te outage spe anned outage anned outage 0.3 0.3 d.4 with a des option. Alth tocking tab fa g: on the HoL L noval and/or weided lock as \$12M/oni cost. , Installation o tout.	teactor Safet a tolerated from ustification for Tab Infimum tab actifically for t be 2010 0.7 0.7 0.7 0.7 0.7 0.7 0.7 0.7 0.7 0.	y m m subset m m m m m m m m m m m m m m m m m m m	An - NPVulain autopulation autopulation pleufoulleau unceFinancial Preservation billity Total > 2011 3.5 8.5 NPV au sun - NPV game sun - NPV game	+ \$ 138.4 4 8 5 8 4 7 7 0 7 0 7 18 18 - \$ 11.2
Required Cash	risk of co conseque a reactor continuet Based or replacem (6.3 EFP Locking T Locking T Locking T Proje Replacing that of Ph allows the most all c \$ The SG I requ \$ Poy skin: weld \$ Due simit \$ Replacing that of Ph allows the most all c \$ Replacing that of Ph allows the simit \$ Replacing that all the simit	Id leg lock moses. Th safety poi operation operation operation operation operation operation operation (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Construction) (Constru	ing tab failur ere is a stight int of view be not Units 1 a ent outage sc s conducted a there is no b centry distinct a conducted a there is no b centry distinct a conducted a conducted a there is no b centry distinct a conducted a g maintenan of Units 6 OP mping plate g tabs alone at configuratic o in Units 6 of the Units 6 of the Units 6 of the Units 6 of the Units 6 of the Units 6	e is vary cos ti chance the ayond 6.3 EF and 4 would 1 hedules, for t several monther crive from the 2007 0.1 0.1 0.1 0.1 0.1 0.1 0.1 0.1	ty, and has t t locking tab PYs in servit be required. Joits 1 and 4 hs before the ing a separa s after the pla a recommende a second near 2008 0.7 0.7 0.7 0.7 0.7 0.7 0.7 0.7 0.7 0.7	very severe F failure can be te, however j , the Locking a end of the n te outage spe anned outage anned outage 0.3 0.3 d.4 with a des option. Alth tocking tab fa g: on the HoL L noval and/or weided lock as \$12M/oni cost. , Installation o tout.	teactor Safet a tolerated from ustification for Tab Infimum tab actifically for t be 2010 0.7 0.7 0.7 0.7 0.7 0.7 0.7 0.7 0.7 0.	y m m subset m m m m m m m m m m m m m m m m m m m	Aa - NPVussa autopulationy Environmental pterbolitical pterbolitical Preservation billity Total > 2011 3.5 8.5 8.5 NPV au wRegulatory Environmental pterbolical Preservation Preservation	+ \$ 138.4 4 8 5 8 4 7 7 0 7 8 4 18 18 5 5 8 4 18 5 18 5 18 5 18 5 5 18 5 18

#### Part B - Option Characterization (continued)

 $\epsilon_{\rm c}$ 

									NPVAIL	\$
4								NPV,	ati - NPV _{iliana}	\$
								Leg:	si Regulatory	
								Galdy	Envirorental	
								Per	ople/Politica/	
								Reso	urco:Finerxial	
						unaanalisa aykee diranggaa ara meriya - 120		Asse	Printervation	
		Alternative is i	clearly distinc	tive from the	e recontiment	led option	ina a panan menangki kemenini rebut dalam	Do-a	ibility Total	
Required Cash	Flow	(S Millions)	< 2006	2007	2008	2009	2010	2011	> 2011	Total
	1	This Request								
		Project Total							1	

Impact Category	High Potential (score 8 - 10)	Medium Potential (score 5 – 7)	Low Potential (score 1 – 4)	Showstopper (score 0)
Logal or Regulatory issues	Few and easily contained items.	Defined and manageable issues.	Complicated and changing situation.	Overwheiming complications or changing situation.
Salety or Environmental Impact	No issues.	Defined and manageable fastics	Evaluation not complete; possible issues.	Major controversy or resistance.
Paople/Political Support	Strong support or no political element.	Support required and being sought.	Unpopular project; low visibility.	Strong resistance or unstable situation.
Resource/Financial Feasibility	Attractive financial conditions; resources available.	Not resourced or financed, but displaceable work identified.	Not resourced or linanced; no displaceable work identified.	Questionable financial back-up or high risk.
Accot Proservation	Enhanced esset preservation; extended life of plant or system.	Implementation has no Impact on life of asset	Evaluation not complete; possible issues.	Implementation results in potential to reduce useful life of plant or system.

Propared by:	Name Joney Jet	Date 24 Apr. 07
Approved for Submission to Asset Investment Screening Committee:	Name	Date 26 ARAL 2007

AISC Disposition:	Approved     Approved     Cancelled     Deferred	
	Deferred     Returned for Rework	Craig Sellers Vice President Engineering and Modifications and Chief Nuclear Engineer

1 of 15

**ENGINEERING & MODIFICATIONS** 

Page:

**BUSINESS CASE SUMMARY** 

## DCC Aging Management - Project- 10 - 62553

## Full Release Business Case Summary N-BCS-66400-10001-R000

Routing	Location	Action	<b>Signature</b>	Date
R. Hohendorf Manager - Computers and Control Design (CCD) Department 702 5077	P82-5	Prepare BCS	loft fill	July 27, 2006.
R. Ball Senior Financial Analyst 702 4084	P82-3	Review BCS		
G. Brown Controller Eng & Mods 702 5059	P82-3	Review BCS	Abon	July 27,20
F.Dermarkar Director - Engineering Services Division 702 5066	P82-6	Submit BCS	Flah	July 27,20 28 July 200
J. Froats C. Selfers Vice President - Engineering & Modifications 702 5044	P82-6	Review BCS	foll-	-31 July 2014
Power Director - Investment and Business Planning	H7 D06	Approve BCS	Dollover	deg 17/02
P. Charlebois Executive Vice President & CNO	P82-6	Approve BCS <	57	Augzste
			BECEN by P. R. Charl	
			AU0 1 3 .0	
			Refer to:	
Ball Senior Financial Analyst 702-4084	P82-3B6	Return For Distribution		

ONTARIOPO

**GENERATION** 

Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

## DCC Aging Management Project- 10 - 62553

#### Full Release Business Case Summary N-BCS-66400-10001-R000

#### 1/ RECOMMENDATION:

ONTARIO

GENERA

We recommend a full release of (\$14.5M total project including contingency) for the DCC (Digital Control Computer) Aging Management Project. The two objectives of this project:

- Manage Pickering A and B DCC aging issues that challenge Unit operators and Control Maintenance staff and threaten reliable station operation and planned capacity targets.
- Participate in the joint CANDU DCC Replacement project COG JP4048 (CANDU Owners' Group Joint Project 4048) so that we will be in a position of readiness to replace the Pickering B DCCs for arising reliability reasons

The CANDU DCC Replacement joint project provides a unique opportunity to share resources with six other CANDU utilities. A \$2.0M developmental release was approved in March 2004 to undertake sufficient preliminary engineering to confirm the technical and licensing viability of the DCC replacement, to validate system design, plans and processes and to produce a quality estimate and schedule. These objectives were achieved at a cost of only \$0.6M when the chosen replacement platform eliminated the necessity to design, verify and validate a vertical slice of the DCC logic.

The following are the major elements of this DCC Aging Management Project:

- Joint CANDU DCC Replacement Project COG JP4048
- · Replacement of Pickering A Main Control Room Operator Interface Computer System (PACE)
- DCC training for Darlington, and Pickering A and B
- Strategic spare parts for Pickering A and B (PA and PB)
- PA test facility upgrade, PB field cable replacement, PA breakjack panel refurbishment, and PB scanner fix
- Contingency :
- Total Project Estimate

Approval of this request is in line with the approved Project Charter N-PCH-64000-00001, the 2006-2010 Business Plan and the 2006 Budget. A Project Execution Plan (PEP) already exists for the COG Joint Project and an overall PEP for this DCC Aging Management Project will be issued by December, 2006.

\$000's OM&A		Including Contingency	Excluding Contingency			Excluding Contingency
Released to Date:	Partial	2,000		Jan-06	Spent Life to Date:	1 0
Requested Now:	Full	12,492		2006-2010	Appr'd Business Plan (Tot Proj):	7
Cumulative Release:	Total to Date	14,492		2006-2010	Business Plan Variance:	7 5
Total Project Estimate:	+30% to -15%	14,492	1 5	2006	Budget (Current Year)	1 5
Current Year Estimate:	2006	1,600		2006	Budget Variance (Current Yr)	7 5
Type of Investment:	Sustaining	N/A	N/A	Cumulative Rel	ease Remaining:	1
NPV:		N/A	N/A	Contingency on	Remaining Release:	2
IRR:	1776-0 - 0	N/A	N/A	Contingency %	on Remaining Release:	

Submitted E

F. Dermarkar Date:

Director - Engineering Services Division

Finance Approval

4 aug de Power Date: rector - Investment and Business Planning

Line Approval (Per OAR Element 1.1 Project in Budget):

23/06

P.R. Charlebois Executive Vice Presiedent & Chief Nuclear Officer



ONTARIO	POWER
	GENERATION

3 of 15

Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

#### 2/ BACKGROUND & ISSUES

The Pickering B WANO review (SCR P-2003-21245) and Obsolescence audit (SCR P-2003-20608) both indicated that obsolescence issues were being dealt with in a reactive manner, increasing risks to the forced loss rate. Engineers are not anticipating aging and practicing obsolescence management sufficiently to resolve these issues before system performance is affected; most obsolescence issues require years to resolve.

The need for the work covered by this BCS is consistent with the approved Project Charter, is focused on both the near-term and long-term viability of the DCCs, and pertains to the following:

- uncertain availability of DCC spare parts and excessive maintenance, and operational challenges
- old technology approaching the start of the upward edge of "bathtub curve" lifetime reliability
- operating experience (OPEX) on DCC field input cable degradation and an incipient problem at Pickering B
- impending loss of knowledgeable internal staff who are currently able to trouble-shoot and repair Varian DCC faults
- long lead time to engineer, qualify and license a DCC replacement.

Within OPG, work has been underway to improve the weakest aspects of the existing DCCs to try to keep them operational for the current station planned lifetimes. For Pickering B, Project 40505 (DCC Obsolescence and Operability) is in progress and is expected to be able to keep the existing Pickering B DCCs operating reliably in he near-term. For Darlington, Projects 33509 and 33977 are expected to keep the Darlington DCCs operating eliably to the current end-of-station life there. The DCCs on Units 1 and 4 at Pickering A have been replaced by emulators of the original IBM 1800 digital control computers. Since life extension has already occurred at Pickering A, further DCC replacement is not necessary there, except for its main control room (MCR) operator interface (PACE). PACE replacement is included in the release of this project.

The Varian DCCs, which are used at Pickering B for reactor/process control, are obsolete, not supported, becoming unreliable and unmaintainable, and there is no qualified replacement. Other CANDU stations also need to proceed with qualifying a replacement DCC system which is supported in the long-term.

#### 2.1 COG Joint Project

OPG participation in the CANDU DCC Replacement JP4048 is viewed as:

1. insurance should an increasing trend of failures occur on DCCs at Pickering B

2. a DCC replacement path if station life extension decisions are made in the future for Pickering B The scope of the Joint Project is to undertake sufficient preliminary engineering so as to be able to confirm the technical and licensing viability of the DCC replacement, to have a validated replacement product and processes and procedures in readiness for project implementation, and to have sufficient information to produce high quality project estimates and schedules. If OPG did not participate in the Joint Project, OPG would have to incur all the costs and risks by itself at a later date in the event of plant life extension. Not participating in the Joint Project would eliminate the availability of the low risk, low cost DCC emulator replacement alternative for Pickering B.

In Phase 1 of the Joint Project, the objectives have been achieved at lower than expected costs because selection of the particular replacement platform eliminated the need to design, verify and validate a vertical slice of DCC software-based control logic.

ecently, additional CANDU utilities (off-shore) joined the Joint Project. This has reduced OPG's share of Joint Project costs by an additional \$650K. This is partly why 2006 and 2007 costs are below Business Plan estimates. (A PCRAF was approved on September 28, 2005 to lower the costs of project 62533 in line with the excluding contingency costs listed in Attachment A.)



Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

#### 3/ ALTERNATIVES AND ECONOMIC ANALYSIS

#### Stop the Project (Not Recommended)

This is not the recommended alternative since reliable DCCs are essential for CANDU plant operation.

- existing DCC technology is at least a quarter century old; if the Joint Project was not to proceed, the
  option to use a hardware emulator to replace the Pickering B DCCs would not be preserved. (The
  hardware, software, system and field cabling costs of replacing the DCCs using modern hardware in a
  necessarily different configuration would increase costs several times over, near to an order of
  magnitude in cost difference and with considerably greater technical risks.)
- DCCs at CANDU plants no longer have OEM (original equipment manufactuer) support. (DEC, Varian and SSCI are all out of business.)
- questionable ability to maintain trouble-shooting and repair expertise is a concern; for reasons of maintenance burden and DCC reliability (SCRs P-2004-01089, -02863, -15054), Pickering B Engineering management wants to acquire additional DCC spares to obviate the need to repair failed circuit boards and eliminate the risk in returning them into service
- the cables connecting field devices to the Pickering B DCCs have recently exhibited degradation (SCR P-2005-16456) with similarities to that seen at Pt. Lepreau where it was necessary to completely change out the degraded cables there
- the DCCs have been replaced on Pickering units 1 and 4, but the computers (PACE) which drive the
  operator interface in the Main Control Room (MCR) are a major reliability and maintainability burden
  and contain key circuit boards which are obsolete, in short supply and cannot be replaced
- the company which supplied the replacement DCC hardware at Pickering A is exiting the business. Purchase of the strategic spares needed for the remaining Pickering A lifetime needs to before this occurs would be prudent.
- training courses do not exist to train new engineering staff to support the DCCs at Pickering A and B and Darlington. New staff are displacing experienced contractors and many experienced staff are expected to retire soon; graduate hires need DCC training courses to acquire the necessary core qualifications.

If a Pickering B DCC were to fail and become irreparable (as the unreplaced Pickering A DCCs are currently threatening to do on Units 2 and 3), there would be no readily available replacement. The affected generating Unit would have to be shut down until either a replacement Varian DCC was built up from scrounged parts or a new DCC was designed, tested and installed. The latter approach would take upwards of three years and it is this potential Unit downtime that would be avoided by having a hardware emulator ready for use. Each of the seven utilities participating in the COG Joint Project recognize the inherent risk and the value of proactive action to mitigate this. The PACE system represents an analogous, but less time-critical situation at Pickering A.

#### Alternative 1 - Undertake the Necessary Sustaining Work (Recommended)

This is the recommended alternative. It enables Pickering B DCC performance and functionality to be sustained and improved with minimum cost and technical risk. It also addresses, for all OPGN stations, the residual DCC aging management issues which are not already covered by existing projects (see Section 4 – The Proposal)

#### Alternative 2 - Delay the Recommendation (Not Recommended)

This is not the recommended alternative. In May 2001, Hydro-Quebec undertook a pre-project study for the replacement of their digital control computers (DCCs). NB Power initiated similar work for life extension of Pt. Lepreau. OPG and Bruce Power recognized that, although their need is not as immediate, they also do not have



<b>ONTARIOPOWER</b>	OPG Confidential Page: 5 of 15
GENERATION	ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

a DCC replacement solution available now or for the time when life extension of the Pickering and Bruce plants will be considered. Design expertise on these DCCs is fading. Replacement by hardware emulators has been successful (e.g. at Pickering A), but there was major concern about the support from the vendor of the emulator (SSCI-890) successfully used to replace Varian DCC hardware in off-shore CANDU plants. The company, Second Source Computers (SSCI), gave notice that they were exiting the business. The most economical alternative was to purchase the intellectual property rights to the SSCI-890 emulator and arrange for a capable company to manufacture this product and guarantee the long-term product support needed by all the CANDU utilities. This is the essence of JP4048.

If this Joint Project was delayed by 2 or 3 years, the critical mass of knowledgeable staff would no longer be available to make it workable. (The JP4048 initiator from Hydro Quebec recently retired.) For only the next few years, we will still have access to disappearing DCC design expertise either at each Utility. Also, other utilities would not be interested in a delayed joint project because it would miss their need date.

The software within each DCC contains many functions important to the control of key station processes, including the reactor. Within each of these DCC functions, there are several modes of operation corresponding to different plant conditions and to the health of plant equipment. Once it is decided to proceed with a station life extension, there is no time to produce a prototype DCC product and then test the DCC software in all of these modes. All the life extension project time must go into implementation planning, preparing the engineering change packages and the field work plans, etc.

This overall DCC Aging Management Project 62553 has been structured to defer those elements which can be belayed without incurring excessive risk. For example, the Pickering A DCC System Health Report had identified operator interface system (PACE) obsolescence issues as a primary impediment to improving DCC health. However, the safe store of Units 2 and 3 will free up some otherwise unavailable spare parts for use in maintaining these computers. As a result, it has been possible to defer and stretch out this work. (This is reflected in lower near-term project costs relative to previous Business Plan estimates.) However, scarce knowledge of PACE design details limits the extent to which further deferral is prudent. The PACE replacement was originally to be done under Pickering A project 2004-PA-45. However, during the 2005 Business Planning process, it was decided to integrate this work into project 62553.

#### Alternative 3 - Do Less (Not Recommended)

Doing less would leave known problems unaddressed with corresponding risk to reliable station operation:

- core qualifications are already at risk due to the unavailability of DCC training courses
- there are only one or two staff knowledgeable enough to maintain the PACE systems operational and key circuit boards (such as the X.25 communications board) cannot be repaired or replaced
- the cable degradation on Pickering B poses a potential risk of DCC mal-operation
- recent SCRs have identified problems with DCC power supplier reliability (SCR P-2006-09680) and annunciation scanner operation (P-2005-11865) which cause operational and maintenance challenges and threaten reliable station operation.

Project elements have been critically reviewed in order to reduce project scope. For example, although Pt. Lepreau has decided to replace all their DCC field input cables, condition assessment of Pickering B cables has resulted in a more limited work scope of repairing or replacing them on an as-needed basis.

System health colour of "White") not to be achieved. For example, adequate test facilities are necessary to thoroughly test DCC software and hardware changes prior to installation. Otherwise, breakthrough events will occur which cause Unit reactivity management events reportable to the regulator. Similarly, continued use of old DCC parts can challenge Unit operators and cause Unit output reductions, such as the 10% power reduction that

ONTARIOPOWER	OPG Confidential	Page: 6 of 15
GENERATION	ENGINEERING & MODIFIC BUSINESS CASE SUMM	

occurred on Pickering Unit 7 on June 7, 2006 (SCR P-2006-09557).

#### Alternative 4 - Do More (Not Recommended)

This is not the recommended alternative since the actual replacement of the Pickering B DCCs would occur in concert with a positive decision on life extension. It is likely that G2, Lepreau and one of the Bruce stations will need to implement their DCC replacement first. OPG can benefit from the lessons learned from these prior implementation projects to further reduce all types of risks during the actual implementation of DCC Replacement at Pickering B. Similarly, it is not recommended to replace the DCC field cables in bulk at this time. If necessary, this would also be determined as part of the life extension decision. Based on a review of DCC System Health Reports at all OPGN stations, it is believed that all known risk-critical DCC aging management issues are covered by the scope of this BCS in conjunction with the other in-progress DCC projects.

#### Alternative 5 – Other - Use of a Modern Hardware System (Not Recommended)

The COG Joint Project in Phase 1 initially looked at DCC replacement using modern commercially-available distributed control systems. However, in-depth assessment confirmed that such a replacement was infeasible without a complete re-design of the system configuration and the DCC software. The Canadian Utilities applied a comprehensive set of assessment factors. Based on this evaluation, the Utilities unanimously concluded that use of a hardware emulator was the overwhelmingly superior alternative, both from economic and technical risk perspectives. In particular, if a Pickering B DCC failed irreparably prior to life extension, use of a modern replacement system would require the affected Unit to remain out-of-service for several times the duration required ar replacement by a hardware emulator. Such a long and costly outage would be unjustifiable from either a mancial or society point of view.





Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

#### 4/ THE PROPOSAL

The release will fund the OPG contribution to the COG DCC Replacement Joint Project 4048 which will:

- Apply the combined CANDU utility experience of knowledgeable DCC staff resources to minimize the technical risk
- Update proven in-house software engineering standards to conform to new IEC standards to minimize regulatory risks
- Share costs and combine staff resources to enable sufficient pre-project engineering to be done so that major technical concerns can be resolved and costs and schedules can be accurately estimated prior to launching the DCC replacement projects at each station
- Confirm that the replacement DCC will meet operability, functionality, reliability and performance needs and will be maintainable in the long-term
- The scope of the Joint Project will produce and validate replacement hardware that will then be available to realize a Pickering B DCC Replacement project at low risk and with a firm cost and schedule as part of life extension, or earlier, if necessary.

A major result of the Joint Project is the provision of a product which will be sustainable for use over a long time.

Joint Project Phase 2 Deliverables (for Pickering B)

- Proof of concept including production and testing of hardware prototype
- Proven QA program, with updated industry-compliant standards and procedures and established licensing framework (a letter received from the CNSC says the Joint Project as planned is "a very good approach for minimizing the implementation risk").
- Qualified platform, using a proven system architecture
- Confirmed detailed production and verification processes including an efficient test facility
- Confirmed long-term vendor support (contractually)
- Firm basis for estimating DCC replacement project costs and schedules

The cost of Phase 2 of JP 4048 is \$5.85M. OPG, Bruce Power, NB Power, Hydro Quebec, SNN (Cernavoda), NASA (Embalse) and KHNP (Wolsong) comprise Joint Project participants. OPG is allocated two of nine shares of the direct project cost, or \$1.3M.

This release will also fund the following necessary work:

- replacement of the obsolete, unreliable and difficult to maintain main control room (MCR) operator interface (PACE) on Pickering Units 1 and 4
- provision of DCC training courses to enable qualified core staff
- replacement of Pickering B DCC field cables, as needed (ref. SCR P-2005-19193)
- refurbishment of the Pickering A breakjack panels and Pickering B annunciation scanners, as needed
- strategic bulk spare parts purchase for Pickering A and B DCCs (including power supplies)
- upgrade Pickering A DCC test facilities for maintainability (ref. SCR P-2005-04754) and effectiveness reasons

Milestones Finish Date (D/M/Y)	Description
16-Dec-05	Prepare JP 4048 Phase 2 Project Execution Plan (complete)
19-Mar-06	System Design for prototype DCCZ (PDCCZ) (complete)

ONTARIOPOWER	OPG Confidential	Page: 8 of 15
GENERATION	ENGINEERING & MOD BUSINESS CASE S	

10-Dec-06	PACE Replacement Charter
22-Dec-06	System Documentation for PDCCZ
30-Apr-07	Acceptance Test of PDCCZ
30-Jun-08	Qualified Replacement DCC Available for Pickering B
15-Dec-09	Qualification of Pickering B software on PDCCZ
15-Dec-10	First Unit installation of PACE replacement
15-Dec-11	Second Unit installation of PACE replacement

#### 5/ QUALITATIVE FACTORS

The qualitative benefits that would be realized by implementing the recommended Alternative (#2) are as follows:



- Reduced risks in the development of a common DCC replacement platform:
   1. Operating experience (OPEX) from existing stations already using the SSCI 890 is being fed back into the prototype production;
  - 2. the replacement DCC will be used first at other non-OPG sites
- The best solution will result by sharing the best scarce expertise contributions from each organization (OPG, NB Power, Bruce Power, Hydro-Quebec, and others)
- A common solution with other CANDU stations will enable future sharing of spare parts and of solutions to emergent problems, if encountered
- The Joint Project agreement includes sustained obsolescence avoidance as part of the longterm support agreement reached with the vendor. COG owns the Intellectual Property rights on behalf of the CANDU utilities
- It will no longer be necessary to retain internal maintenance expertise to repair failed parts; parts can be shipped to the long-term service provider for off-site repair; this will reduce workload burdens on Control Maintenance staff such that more focus can be applied to preventative maintenance



OPG Confidential Page: 9 of 15 ENCINEEPING & MODIEL ATIONS

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

# 6/ RISKS

			11 International Physics and the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second se	
Description of Risk (this release only!!!!!)	Description of Consequence	Risk Before Mitigation	Mitigating	Risk After Mitigation
Cost				
<ol> <li>Underestimation of the engineering effort.</li> </ol>	Work scope not able to be completed within approved funding.	HgH	Given the difficulty in accurately predicting the effort required, input from all CANDU utiliites was sought. A major goal of the preliminary engineering to be done as part of the joint CANDU DCC Replacement project was to be able to prepare a high quality estimate for the actual replacement projects. Use of a DCC hardware emulator in lieu of a system redesign substantially reduces the project risk. A separate detailed estimate was prepared for the PACE replacement, the other major project element	LOE
2. One of the utilities withdraws from the CANDU Joint Project	Increased costs to OPG.	Medium	All Canadian CANDU utilities have confirmed funding to the Joint Project. In addition, off-shore utilities have indued	Low
<ol> <li>The scope of some project elements may change as additional operational performance emerges</li> </ol>	Work priorities may need to be adjusted in response to operational needs.	Medium	Costs will be captured against the differentiated project elements. Approval to allocate contingency funds will be sought if necessary.	Low
4 Analization and blick and a series				
DCC requirements	Delivered product would not meet OPG needs without redesign of DCC software.	Hgh	Preliminary engineering was done as part of JP 4048 Phase 1 to produce a detailed specification. Technical reviews are taking place periodically.	Low
<ul> <li>Accurate establishment of PACE requirements</li> </ul>	Installed product would not meet operational needs	Medium	The original PACE requirements document has been located. A Human Factors Engineering Program Plan (HFEPP) and construcatability, operability, maintainability, and safety (COMS) reviews will also ensure operability.	Low
Schedule				
1 Shortage of chilled in hard a	-			
	Schedule slippage	ч₿Н	Identify needs and plan for the skills required early on. Hire contractors, if necessary, and make use of recent graduate hires as a learning experience.	Гож
2. It is necessary that the CANDU	Latent deficiencies in the	High	gineering done	Low
				ł

FIRITING PARIS (Reneared N = 19207 BCS)

	oe z
	55 Base
	$\bigcirc$
	6
	F
-	=
	2

10 of 15

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY



utilities band together to achieve the critical mass of knowledge needed to enable the emulator implementation with an acceptable level of risk.	replacement DCC		as part of the Joint Project, DCC Replacement implementation risks will be substantially reduced. OPG implementation risks will be further reduced as the result of lessons learned from antecedent CANDU utility projects.	
3. Work pressures at their own stations could prevent CANDU utilities from participating as actively in the joint project as planned.	Schedule slippage	Hgh	A manager has been appointed for the Joint Project. Knowledgeable non-utility resources have been added to the Joint Project team. L3-MAPPS has been contracted to undertake most of the Phase 2 work.	Low
Resources				
1. Over time, staff knowledgeable about the design details of the DCC functionality and its interaction with station process systems and equipment have moved on.	Inability to maintain core DCC expertise.	нġн	Production of DCC training courses will preserve the core knowledge. New staff will gain exposure to the DCCs via participation in this project.	Low
<ol> <li>Training Division does not have internal resources needed to prepare DCC training courses.</li> </ol>	Inability to produce needed DCC training material.	Hgh	Training Division has agreed to the use of external resources. Knowledgeable external companies have expressed interest and one has submitted a draft syllabus.	Low
Technical				
1. Unforeseen SQA issues	Schedule delays/increased costs	Чġн	Proven internal SQA processes will be reviewed and upgraded where necessary to meet the intent of IEC standards.	Low
2. Unforeseen technical issues	Schedule delays/increased costs	Medium	Solution approach has been identified and is an incremental change only to systems already in use in off-shore CANDU stations.	Low
3. Unforeseen HFE issues	Schedule delays/increased costs	Medium	Minimal observable changes are planned to the MCR operator interface.	Mo
Regulatory				
<ol> <li>CNSC staff have already indicated interest in the standards to be adopted for the work and in human factors engineering aspects.</li> </ol>	Schedule delays/increased costs	Medium	atory risks. CNSC letter has already stated anned approach is low risk.	Low
			ine same group that implemented PACE will implement the PACE replacement.	

FILET OF PARTING AND AND REPORTED BY A DEPARTMENT RECEIPTING TO A DEPARTMENT RECEIPTING TO A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENT OF A DEPARTMENTA OF A DEPARTMENT OF A DEPARTMENTA OF A DEPARTMENTA OF A DEPARTA OF

Theory and a state of the state of the state

RATION	A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL PROPERTY AND A REAL
<b>IOPO</b> GENE	and the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second se
ONIAT	The same and the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second s

Page: **OPG Confidential** 

11 of 15

i

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

Environmental None				
Health & Safety 1 "Normal" health and outst				
concerns	medically-treated accidents or lost-time accidents	Low	All work on the project will be conducted in accordance with all legal, OPG corporate, OPG Nuclear and site safety programs.	Low
Investment				
<ol> <li>Life extension for Pickering B may not proceed, obvitating some benefits to OPG from the Joint Project.</li> </ol>	OPG would not receive the maximum benefit from the Joint Project	Medium	Even if extending the life of Pickering B does not proceed, the project output would still have value as defense against an expected trend of increasing failure rates for existing DCCs. OPEX benefits have already accrued to OPG based on increased inter-utility co- operation on DCC issues.	Low



12 of 15

**ENGINEERING & MODIFICATIONS** 

Page:

BUSINESS CASE SUMMARY

## 7/ POST IMPLEMENTATION REVIEW PLAN

Type of PIR:	Targeted Final AFS	Targeted PIR Approval	PIR Responsibility
	Date:	Date:	(Sponsor Title)
Simplified	Dec 2012	Jun 2013	Director, ESD

#### Comments:

	Measurable Parameter	Current Baseline	Targeted Result	How will it be measured?	Who will measure it? (person / group)
1.	Replacement DCC availability	Pickering B Life extension or declining performance of existing DCCs	Qualified DCC replacement available at end of COG Program (June 20, 2008)	Replacement DCCs obtainable at known cost and schedule	Pickering B Performance Engineering Manager
2.	Staff qualifications at risk	Currently, 23 qualifications within the Computers and Control Design (CCD) Department are at risk	Availability of DCC training courses reduces qualifications at risk to ≤ 5	Use of methodology defined by Human Resources	CCD Manager
3.	Pickering A Operator Interface (PACE) obsolescence	PA DCC System Health Report at risk of turning yellow	PA DCC System Health white or better as result of replacement of the obsolete PACE interface	Conformant with System Performance Monitoring standards	DCC system engineers
4.	Quality	Project Charter N- PCH-64000-0001	All project 62553 deliverables are completed and of acceptable quality	AFS completion for all project segments	Accountable project segment managers
5.	Reliability and Maintainability	DCC System Health Reports at all stations	System Health is white or better	Conformant with System Performance Monitoring standards	DCC system engineers





13 of 15

Page:

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

### Project Name 10 - 62553

## Full Release Business Case Summary N-BCS-66400-10001-R000

Attachment "A"

#### **Project Cost Summary**

\$000's Choose One	LTD Prior Years 2005	2006	2007	2008	2009	2010	Future	Total	LTD This Mti Feb 2006
Project Management (OPG)		40	40	40	40	50	140	350	
Engineering & Drafting (OPG)	16	212	350	610	655	490	430	2,763	4
Material									
Installation – PWU, BTU	1			-Children					-
Contract – Project Mgmt	·		122 3723	法院的会社会	C. Britshiphel	and the second	States in	55.2.21	
Contract - Design	L.								
Contract - Installation						and southers	以開始時间	San Shi	
Contract - Other			- automation and						
			NILSIS PIPE			NAN BARA	Proposition of the		8
	R		10.3217	Statistics and	NIM SHE		And a second second second second second second second second second second second second second second second s		
nterest (Capital Project Only)									
Sub Total (excl Contingency)									and the second
General Contingency			385 Y						aceson 020
Specific Contingency					-		Carles and		-
Grand Total	572	1,600	2,400	2,400	2,400	2,400	2,720	14,492	N/A
2006-2010 Business Plan	825	2,209	3,000	2,000	2,000	2,000	2,380	14,414	N/A
/ariance to Business Plan excl Contingency}		1					_,		

Removal Costs included in above	0
Definition Costs included in above	572
Estimate Name, Quality, etc	Budget Estimate +30% to -15%
Design Complete:	Zero to Minimal

Reviewed By:

July ZE, ZOOG Date: Li Carro

1. Veilleux oject Manager

Approved By:		
Stor 11	2h 27.200	Č,
R.J. Hohendorf	Date	

R.J. Hohendorf (/ P Eng & Mods Manager (Strat IV)

# ONTARIO GENERATION

OPG Confidential

Page:

14 of 15

ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

Attachment B			_	Cost De	etail				
	prior	<u>2006</u>	2007	<u>2008</u>	<u>2009</u>	<u>2010</u>	BP tot	<u>future</u>	total
COG Joint Project Eng JP Eng S/W Std Material	16 0	30 20	30 20	120 30	200 40	100 30	496 140		496 140
Contract -Other Contract - Design JP Total	572	756	405	410	650	290	3083	300	3383
PACE Proj. Mgmt. (PM) Eng Material Install		20 80	20 200	20 380	20 350	30 300	110 1310	100 300	210 1610
Contract - Design PACE Total	0	100	720	1000	1060	1100	3980	1100	5080
B cables & canners & PA Breakjack Panels PM Eng Material		22	20				0 42	50	0 92
Install Contract-Design PBC Total	0	32	175	25	55	230	517	200	717
PA Test Facility PM Eng		_	20	20	5		0 0 45		0 0 45
Mat PATF Total	0	0	20	85	5	0	110	0	110
PB Spares Eng Mat		20					20		20
PBS Total	0	220	200	0	0	200	620	0	620
PA Spares Eng \ Mat		20					20		20
PAS Total	0	202	200	200	0	0	602	0	602
DCC Training PM Eng		20 20	20 60	20 60	20 60	20 60	100 260	40 80	140 340

#### Courternal entres and

ONTARIOPO ER GENERATION	
----------------------------	--

1 C

	Page:
OPG Confidential	15 of 15

#### ENGINEERING & MODIFICATIONS BUSINESS CASE SUMMARY

DCCT Total		50	200 280	200	150 230	100	700	300 A20	1000
	prior	2006	2007	2008	2009	<u>2010</u>	BP tot	future	total
TOTAL								<u> </u>	
PM	0	40	40	40	40	50	210	140	350
Eng	16	212	350	610	655	490	2333	430	2763
Material									
Install	<u>e</u> -						Carl mann		dist.r
					and states and states				
Contract - Design						1218 C 1 1 1 1			
Contract - Design Contract - Other				General St	enge under Große under	and a state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the			
Contract - Other			- (			1999 - 1999 - 1999 - 1999 1999 - 1997 - 1997 - 1997 1999 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 19	Griffens - Logis St C S S S.	al esta de la composición de la composición de la composición de la composición de la composición de la composi Composición de la composición de la comp	-
-			- p-6 (198						

